Display Pressure Transmitters

KT-302H Series

INSTRUCTION MANUAL

TCD210241AF

Autonics

Thank you for choosing our Autonics product.
Read and understand the instruction manual and manual thoroughly before using the product.
For your safety, read and follow the below safety considerations before using.
For your safety, read and follow the considerations written in the instruction manual, other manuals and Autonics website.
Keep this instruction manual in a place where you can find easily.

Visit Autonics website (www.autonics.com or QR code) for the latest information. Manuals, CAD files, certifications, software, etc. are available. The dimensions, specifications, certifications, etc. are subject to change without notice for product improvement. Certain models may be discontinued without notice.

Safety Considerations

- Observe all 'Safety Considerations' for safe and proper operation to avoid hazards.
- ⚠ symbol indicates caution due to special circumstances in which hazards may occur.

⚠ Warning Failure to follow instructions may result in serious injury or death.

01. Fail-safe device must be installed when using the unit with machinery that may cause serious injury or substantial economic loss.(e.g. nuclear power control, medical equipment, ships, vehicles, railways, aircraft, combustion apparatus, safety equipment, crime/disaster prevention devices, etc.)
Failure to follow this instruction may result in personal injury, economic loss or fire.
02. Do not use or store the unit in the place where flammable/explosive/corrosive gas, high humidity, direct sunlight, radiant heat, vibration, impact or salinity may be present.
Failure to follow this instruction may result in explosion or fire.
03. The explosion proof standard of this unit is Ex d IIC T6, protection structure of this unit is IP67 and the range of max. surface temperature is below 85℃.
04. Do not disassemble or modify the unit.
Failure to follow this instruction may result in fire or electric shock.

⚠ Caution Failure to follow instructions may result in injury or product damage.

01. Do not apply beyond rated pressure.
Failure to follow this instruction may result in product damage.
02. Use the unit within the rated specifications.
Failure to follow this instruction may result in fire or product damage.
03. Keep the product away from metal chip, dust, and wire residue which flow into the unit.
Failure to follow this instruction may result in fire or product damage.
04. Check 'Connections' before wiring.
Failure to follow this instruction may result in explosion or fire.
05. This product is designed to detect the pressure of noncorrosive medium. Do not use for corrosive medium.
Failure to follow this instruction may result in product damage.
06. Use a dry cloth to clean the unit, and do not use water or organic solvent.
Failure to follow this instruction may result in fire or electric shock.

Cautions during Use

- Follow instructions in 'Cautions during Use'. Otherwise, it may cause unexpected accidents.
- Power supply should be insulated and limited voltage / current or Class 2, SELV power supply device.
- The connection of this unit should be separated from the power line and high voltage line in order to prevent inductive noise.
- Switch or circuit breaker should be installed nearby users for convenient control.
- Use verified explosion-proof cable gland or sealing fitting (explosion proof standard: over Ex d IIC T6, IP rating: over IP67 protection structure).
- Use dedicated external terminal for earth. For connecting earth, use a spring washer and earth cable which is over 4mm^2.
- LCD performance may vary depending on the usage environment. Check the environmental conditions, and do not install the device in places where direct sunlight or high temperatures may be present.
- This unit may be used in the following environments.
  - Indoor / Outdoor (in the environment condition rated in 'Specifications')
  - Altitude max. 2,000m
  - Pollution degree 2
  - Installation category II
- **This explosion-proof unit is certified and the same specifications which is reported to Korea Gas Safety Corporation.**

Ordering Information

This is only for reference, the actual product does not support all combinations.
For selecting the specified model, follow the Autonics website .

KT-302H ❶ - ❷ ❸ ❹ ❺

❶ Pressure type
S: Gauge, sealed gauge [01]
A: Absolute

❷ Rated pressure range

Gauge		Absolute
01	0 to 35 kPa	0 to 35 kPa
02	0 to 0.1 MPa	0 to 0.1 MPa
03	0 to 0.2 MPa	0 to 0.2 MPa
04	0 to 0.7 MPa	0 to 0.7 MPa
05	0 to 2 MPa	0 to 2 MPa
06	0 to 3.5 MPa	0 to 3.5 MPa
07	0 to 7 MPa	-
08	0 to 21 MPa	
09	0 to 35 MPa	
Sealed gauge		
14	-0.1 to 0 MPa	
15	-0.1 to 0.2 MPa	
16	-0.1 to 0.7 MPa	
17	-0.1 to 2 MPa	
18	-0.1 to 3.5 MPa	
Z	User pressure range	

❸ Install bracket
0: Without bracket
1: With bracket

❹ Pressure port
0: G3/8 (PF, standard)
1: Others

❺ User pressure range [02]
Customized pressure range

01) The unit is sealed structure. Measurements are taken based on the standard atmospheric pressure at the time of sealing.
Standard atmospheric pressure = 101.3 kPa (1.013 bar)
02) The pressure range is set to customized pressure range. (select "Z" at ② Rated pressure range)

Product Components

- Product
- Instruction manual

Specifications


Series	KT-302H
Applicable medium	Gas, liquid, oil (except corrosive environment of SUS316)
Power supply	9 - 45 VDC⎓
Output	DC 4 - 20 mA (2-wire, low limit: 3.8 mA, high limit: 22.8 mA)
Accuracy [01]	± 0.2 % of F.S. (at 25 °C)
Sampling period	200 ms
Display type	PV display part: 7 segment 5 digit, parameter display part: 16 segment 8 digit, bar LED: 52
Display range	-9999 to 99999
Setting method	Front key, HART-protocol
Certification	CE UKCA EAC
Unit weight (packaged)	≈ 1.4 kg (≈ 1.7 kg)

Ambient temperature	-20 to 70 °C, storage: -40 to 85 °C (rated at no freezing or condensation)
Ambient humidity	0 to 85 %RH, storage: 0 to 85 %RH (rated at no freezing or condensation)
Max. pressure	300 % of max. rated pressure
Protection structure	IP67 (IEC standard)
Material	Body: aluminum (AlDc.8S), cover O - Ring: Buna N, diaphragm: SUS316, connection: SUS316
Explosion class [02]	Ex d IIC T6


01) F.S. is rated pressure range.
02) This explosion class is acquired and managed by Konics co., ltd.

Dimensions


- Unit: mm, For the detailed drawings, follow the Autonics website.




■ With bracket



Connections




Opening the Cover



- To open the cover, unscrew the M3×6L headless bolt using a 1.5 hexagon wrench and rotate the cover.

Unit Descriptions



1. Display part
Displays PV (present value) and the unit message.
2. [M] key
Enters the setting mode and saves the setting value.
3. [▲] key
Changes the setting value of data.
4. [◀] key
Changes setting position of data.

Parameter Setting

- Some parameters are activated/deactivated depending on the model or setting of other parameters.
- [M]: Enters parameter setting mode, saves setting value or moves to the next parameter.
  [◀]: Moves digit, [▲]: Changes setting value
- Never press the [M] key and reapply the power at the same time, or the product is reset and does not operate.


Parameter			Setting range	Unit
1	Display contents	dISM	mA, %, PV	-
2	Decimal point	dOTN	0 to 3	-
3	Pressure unit	UNI	MPa, kPa, Pa, mmHg, mbar, bar, %, m, cm, kg, Torr, FtH$_2$O, inHg, atm, g/cm^2, inH$_2$O, kg/cm^2, mH$_2$O, mmH$_2$O, psi	-
4	Deviation correction	OFS	-9999 to 99999	3. Pressure unit
5	Input value low limit	L	-9999 to 99999	3. Pressure unit
6	Input value high limit	H	-9999 to 99999	3. Pressure unit
7	Density setting	dENSITY	00.000 to 19.999	-
8	Output type	OUT	LINE: linear, SQRT: square root	-

Functions

■ Deviation correction


The error of the current pressure value on display is corrected by removing deviations from the open pressure port.

- Setting an arbitrary value during operation may deviate from the accuracy.



■ Measurement range

Sets the output range between maximum and minimum input within the rated pressure range.
The measurement range can be set within the rated pressure range with the 5. Input value low limit and 6. Input value high limit parameters.



18, Bansong-ro 513Beon-gil, Haeundae-gu, Busan, Republic of Korea, 48002
www.autonics.com | +82-2-2048-1577 | sales@autonics.com

Autonics