



Number	17GR0205/01	Replaces	17GR0205/00
Issue date	08-03-2024	Contract number	E0001
Due date	08-03-2034	Module	B (Type testing)
Report number	120408	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063AU1408		

EU TYPE EXAMINATION CERTIFICATE (GAR)

Kiwa hereby declares that the **gas filter**, model(s):

GFK...

Manufacturer

**Elster GmbH (Honeywell)
Strotheweg 1
49504 Lotte - Büren
Germany**

meet(s) the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 13611:2019

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Ron Scheepers
Managing director

Kiwa Nederland B.V.
Wilmsdorf 50
P.O. Box 137
7300 AC APELDOORN
The Netherlands

<https://www.kiwaenergy.com>





Number	17GR0205/01	Replaces	17GR0205/00
Issue date	08-03-2024	Contract number	E0001
Due date	08-03-2034	Module	B (Type testing)
Report number	120408	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063AU1408	Page	1 of 1

APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

Manufacturer:

Elster GmbH (Honeywell)

List of all available types:

Gas filter approved on relevant clauses of EN 13611.

Type Number Survey:

GFK Gas Filter

15 Connection size 15
20 Connection size 20
25 Connection size 25
32 Connection size 32
40 Connection size 40
50 Connection size 50
65 Connection size 65
80 Connection size 80
100 Connection size 100
125 Connection size 125
150 Connection size 150
200 Connection size 200
250 Connection size 250

R Rp thread (connection size 15, 20, 25, 32, 40, 50, 65)
F DIN flanged (connection size 40, 50, 65, 80, 100, 125, 150, 200, 250)
N NPT thread (connection size 15, 20, 25, 32, 40, 50, 65)
A ANSI flanged (connection size 40, 50, 65, 80, 100)

T T product

10 pe max. = 1 bar
40 pe max. = 4 bar
60 pe max. = 6 bar

-3 Plug screw at the inlet and outlet
-6 Measuring adapter at the inlet and outlet

Special conditions:

None