



Number	18GR0580/01	Replaces	18GR0580/00
Issue date	19-09-2025	Contract number	E 0001
Due date	19-09-2035	Module	B (Type testing)
Report number	124310	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063BT1310		

EU TYPE EXAMINATION CERTIFICATE (GAR)

Kiwa hereby declares that the **automatic burner control systems**, model(s):

IFD 2xx

Manufacturer

Elster GmbH (Honeywell)
Strotheweg 1
49504 Lotte - Büren
Germany

meet(s) the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 298:2022

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Ron Scheepers
Managing director

Kiwa Nederland B.V.
Wilmsdorf 50
P.O. Box 137
7300 AC APELDOORN
The Netherlands

<https://www.kiwaenergy.com>





Number	18GR0580/01	Replaces	18GR0580/00
Issue date	19-09-2025	Contract number	E 0001
Due date	19-09-2035	Module	B (Type testing)
Report number	124310	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063BT1310	Page	1 of 1

APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

Manufacturer: Elster GmbH (Honeywell)

Types: IFD 244-x /1 Q (I)
IFD 244-x /2 Q (I)
IFD 244-x /1 W (I) (Z)
IFD 244-x /2 W (I)

IFD 258-x /1 Q (I)
IFD 258-x /2 Q (I)
IFD 258-x /1 W (I)
IFD 258-x /2 W (I)

IFD 258-x /1 Y (I)
IFD 258-x /2 P (I)

x= 3, 5 or 10 s.
Optional (I) integrated Ignition.
Optional (Z) customized version.

Scope:

Application:	Appliances burning gaseous and permanent operation (Ionisation) Appliances burning gaseous and non-permanent operation (UV detector)
Flame detection:	Ionisation, external UV detector UVS
Applied technology:	Complex electronics
Ambient temperature:	-20 °C to +60 °C
Electrical supply:	(P)100 - (R)115 - (Q)120 - (Y)200 - (W)230 Vac 50/60Hz
Protection:	With enclosure and IP 54
Installation environment	Pollution degree 1, 2 or 3
Gas valve output:	U rated.max. 1.0 A

See the installation and operating instructions for all specifications and possible options available for the above listed type(s).

Approved safety relevant functions:

Automatic burner control system:	EN 298	Class C
Reset function:	EN 298	Class B

Remarks/special conditions:

None.