



Number:	UKCA/0558/21/308	Replaces:	18GR0580/00
Issue Date:	06-12-2021	Contract Number:	PS7133
Due Date:	06-12-2031	Module:	B (Type Testing)
Report Number:	124310	Scope:	Gas Appliances
PIN:	0063BT1310	Page	1 of 2

UKCA TYPE EXAMINATION CERTIFICATE

Kiwa Ltd. hereby declares that the model type(s)

IFD 2xx

Manufactured by Elster GmbH (Honeywell)
Lotte - Büren, Germany

Meet(s) the essential requirements as described in the:

Gas Appliances Regulation (Regulation (EU) 2016/426 as brought into GB law and amended), and the Gas Appliances (Enforcement) and Miscellaneous Amendment Regulations 2018 No 389, and amendments to UK SI 2019/696 Product Safety and Metrology, and subsequent amendments, The Product Safety, Metrology and Mutual Recognition Agreement (Amendment) (EU Exit) Regulations 2019 No 1246, and subsequent amendments. This certificate is not valid in Northern Ireland – and is applicable to England, Scotland and Wales only.

Reference standards: BS EN 298:2012, BS EN 14459:2007

Signed on behalf of Kiwa Ltd.
(UK Approved Body Number 0558)

Mark Crowther
Technical Director
Kiwa Ltd.

390/1709/01

Kiwa Gastec
Kiwa House
Malvern View Business Park
Stella Way
Bishops Cleeve
Cheltenham
GL52 7DQ
United Kingdom
T +44 (0)1242 677877
F +44 (0)1242 676506
www.kiwa.co.uk



0217



Number:	UKCA/0558/21/308	Replaces:	18GR0580/00
Issue Date:	06-12-2021	Contract Number:	PS7133
Due Date:	06-12-2031	Module:	B (Type Testing)
Report Number:	124310	Scope:	Gas Appliances
PIN:	0063BT1310	Page	2 of 2

APPENDIX TO UKCA TYPE EXAMINATION CERTIFICATE

Manufacturer: Elster GmbH (Honeywell)

Types: IFD 244-x /1 Q (I)
IFD 244-x /2 Q (I)
IFD 244-x /1 W (I) (Z)
IFD 244-x /2 W (I)

IFD 258-x /1 Q (I)
IFD 258-x /2 Q (I)
IFD 258-x /1 W (I)
IFD 258-x /2 W (I)

IFD 258-x /1 Y (I)
IFD 258-x /2 P (I)

x= 3, 5 or 10 s.
Optional (I) integrated Ignition.
Optional (Z) customized version.

Scope:

Application:	Appliances burning gaseous and permanent operation (Ionisation) Appliances burning gaseous and non-permanent operation (UV detector)
Flame detection:	Ionisation, external UV detector UVS
Applied technology:	Complex electronics
Ambient temperature:	-20 °C to +60 °C
Electrical supply:	(P)100 - (R)115 - (Q)120 - (Y)200 - (W)230 Vac 50/60Hz
Protection:	With enclosure and IP 54
Installation environment	Pollution degree 1, 2 or 3
Gas valve output:	Rated.max. 1.0 A

See the installation and operating instructions for all specifications and possible options available for the above listed type(s).

Approved safety relevant functions:

Automatic burner control system:	EN 298	Class C
Reset function:	EN 14459, Annex J	Class B

Remarks/special conditions:

None.