

EU type examination certificate

EU-Baumusterprüfbescheinigung

CE-0085AS0202

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Elster GmbH Strotheweg 1, D-49504 Lotte (Büren)
Distributor <i>Vertreiber</i>	Elster GmbH Strotheweg 1, D-49504 Lotte (Büren)
Product Category <i>Produktart</i>	gas fittings: Safety shut-off device for natural gas and all-gas (4303)
Product Description <i>Produktbezeichnung</i>	Slam shut device for upper and lower shut off pressure with external sensing connection
Model <i>Modell</i>	JSAV . . .
Countries of Destination <i>Bestimmungsländer</i>	AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MT, NL, NO, PL, PT, RO, SE, SI, SK
Test Reports <i>Prüfberichte</i>	supplement test: 19-00275-095 from 20.01.2020 (EBI)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 14382 (01.11.2019)

Date of Expiry / File No. 18.04.2028 / 20-0152-GEA
Ablaufdatum / AZ

20.07.2020 Kö A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
...25R40/...	nominal diameter: DN 25 ambient temperature range: -20...+60 °C max. allowable pressure PS: 4 bar	
...40R40/...; ...40F40/...	nominal diameter: DN 40 ambient temperature range: -20...+60 °C max. allowable pressure PS: 4 bar	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
JSAV .../1	slam shut device for upper shut off pressure, functional class B
JSAV .../2	slam shut device for upper and lower shut off pressure, functional class A
JSAV ...R...	connection: internal thread Rp1 or Rp 1/1/2, ISO 7-1
JSAV ...F...	connection: flange in the dimension PN16

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

trip pressure range: upper: 40 - 500 mbar; lower: 8 - 150 mbar
accuracy group: AG10
temperature class: class 2
meter/trip mechanism: USSA
optional: breathing valve