



AGA CERTIFIED PRODUCT



Certificate Holder: **ELSTER GMBH**
ABN/ACN No. (if applicable): N/A
Manufacturer: **Elster GmbH**
Agent (if applicable): N/A
Type of Component: **Gas Leakage Detection System**
Model No. & Description: **Kromschroder**
(Refer www.aga.asn.au for more details)

Honeywell Tightness Controls TC, Valve Proving System

Electrical supply data & control circuit 230V AC, 50/60 Hz

TC1...05W/W..., TC2...05W/W... & TC3...05W/W...

Electrical supply data 230V AC, 50/60 Hz control circuit 24V DC

TC1...05W/K..., TC2...05W/K... & TC3...05W/K...

Electrical supply data & control circuit 120V AC 50/60 Hz

TC1...05Q/Q..., TC2...05Q/Q... & TC3...05Q/Q...

Electrical supply data 120V AC 50/60 Hz, control circuit 24V DC

TC1...05Q/K..., TC2...05Q/K... & TC3...05Q/K...

Electrical supply data & control circuit 24V DC

TC1...05K/K..., TC2...05K/K... & TC3...05K/K...

Temperature Range: -20°C - 60°C

Working pressure 50 kPa

Relevant Standard(s): **AS 4630 – 2005 (Inc Amdt 1)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



Client Manager

Certificate Authorised

Certificate first issued: **21 February 2019**

Certificate No: **8618**

This copy valid from: **17 April 2020**

Refer specification issue: **02**

QF714/11

This Certificate issued by The Australian Gas Association ABN 98 004 206 044