



AGA CERTIFIED PRODUCT

Certificate Holder: **ELSTER GMBH**

ABN/ACN No. (if applicable): N/A

Manufacturer: **KROMSCHRODER AG**

Agent (if applicable): N/A

Type of Component: **SOLENOID VALVE - CLASS 1**

Model No. & Description:
(Refer www.aga.asn.au for more details)

**KROMSCHRODER
VGP SERIES MODEL**

VGP10	MWP 20kPa	3
VGP15	MWP 20kPa	3
VGP20	MWP 15kPa	3
VGP25	MWP 15kPa	3

(Temperature range: -20°C to 60°C)

Models Suffix:

R	Rp Internal thread
01	Pmax = 15kPa
02	Pmax = 20kPa
Q	Mains voltage 120V AC, 50/60 Hz
W	Mains voltage 230V AC, 50/60 Hz
5	Connection via rectifier adapter without standard socket
6	Connection via rectifier adapter and standard socket
7	Connection via socket with integrated rectifier circuit

Relevant Standard(s): **AS 4629-2005
(Incorporating Amendment No. 1)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- This Certificate remains the property of the AGA; and
- The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



Client Manager

Certificate Authorised

Certificate first issued: **24 July 1997**

Certificate No: **5567**

This copy valid from: **17 April 2020**

Refer specification issue: **04**