

**DCP250  
Controller Programmer  
User's Manual**

**57-77-25-18  
Revision 2  
November 2015**

# Copyrights, Notices and Trademarks

---

© Copyright 2015 by Honeywell, Inc.

Revision 2, November 2015

While the information in this document is presented in good faith and believed to be accurate, Honeywell disclaims any implied warranties of merchantability and fitness for a particular purpose and makes no express warranties except as may be stated in the written agreement with and for its customers. In no event is Honeywell liable to anyone for any indirect, special, or consequential damages. The information and specifications in this document are subject to change without notice.


Honeywell, TDC 3000, SFC, SmartLine, PlantScape, Experion PKS, and TotalPlant are registered trademarks of Honeywell International Inc. Other brand or product names are trademarks of their respective owners. While the information in this document is presented in good faith and believed to be accurate, Honeywell disclaims any implied warranties of merchantability and fitness for a particular purpose and makes no express warranties except as may be stated in the written agreement with and for its customers. In no event is Honeywell liable to anyone for any indirect, special, or consequential damages. The information and specifications in this document are subject to change without notice.

Honeywell, TDC 3000, SFC, SmartLine, PlantScape, Experion PKS, and TotalPlant are registered trademarks of Honeywell International Inc. Other brand or product names are trademarks of their respective owners.

Honeywell Process Solutions  
1250 W Sam Houston Pkwy S  
Houston, TX 77042



**Warning:** The international hazard symbol is inscribed adjacent to the rear connection terminals. It is important to read this manual before installing or commissioning the unit.



**Warning:** This symbol means the equipment is protected throughout by double insulation.



**Warning:** Products covered by this manual are suitable for Indoor use, Installation Category II, Pollution category 2 environments.



**Note:** It is strongly recommended that applications incorporate a high or low limit protective device, which will shut down the equipment at a pre-set process condition in order to prevent possible damage to property or products.

## Support and Contact Information

For Europe, Asia Pacific, North and South America contact details, refer to the back page of this manual or the appropriate Honeywell Solution Support web site:

Honeywell Corporate [www.honeywellprocess.com](http://www.honeywellprocess.com)

Honeywell Process Solutions <https://www.honeywellprocess.com/en-US/explore/products/instrumentation/panel-mounted-controllers-and-programmers>

Training Classes <http://www.automationcollege.com>

---

## Telephone and Email Contacts

| Area                     | Organization                | Phone Number                                                               |
|--------------------------|-----------------------------|----------------------------------------------------------------------------|
| United States and Canada | Honeywell Inc.              | 1-800-343-0228 Customer Service<br>1-800-423-9883 Global Technical Support |
| Global Email Support     | Honeywell Process Solutions | <a href="mailto:ask-ssc@honeywell.com">ask-ssc@honeywell.com</a>           |

# Table of Contents

|          |                                                      |           |
|----------|------------------------------------------------------|-----------|
| <b>1</b> | <b>Introduction.....</b>                             | <b>1</b>  |
| <b>2</b> | <b>Installation .....</b>                            | <b>2</b>  |
| 2.1      | Unpacking .....                                      | 2         |
| 2.2      | Installation .....                                   | 2         |
| 2.3      | Panel-Mounting .....                                 | 2         |
| 2.4      | Cleaning .....                                       | 3         |
| <b>3</b> | <b>Field Upgrade Options .....</b>                   | <b>4</b>  |
| 3.1      | Plug-Modules and Upgradeable Functions.....          | 4         |
| 3.1.1    | Board Positions .....                                | 5         |
| 3.2      | Preparing to Install or Remove Plug-in Modules ..... | 5         |
| 3.2.1    | Main Board Connectors.....                           | 6         |
| 3.3      | Removing/Replacing Option Modules .....              | 7         |
| 3.4      | Replacing the Instrument in its Housing .....        | 7         |
| 3.5      | Auto Detection of Plug-in Modules .....              | 7         |
| 3.6      | Data Recorder Board .....                            | 8         |
| 3.7      | Profiler Enabling.....                               | 8         |
| <b>4</b> | <b>Electrical Installation.....</b>                  | <b>9</b>  |
| 4.1      | Avoiding EMC Problems .....                          | 9         |
| 4.1.1    | Cable Isolation & Protection .....                   | 9         |
| 4.1.2    | Noise Suppression at Source .....                    | 10        |
| 4.2      | Sensor Placement (Thermocouple or RTD) .....         | 11        |
| 4.3      | Thermocouple Wire Identification .....               | 11        |
| 4.4      | Pre-wiring – Cautions, Warnings & Information.....   | 12        |
| 4.5      | Connections and Wiring.....                          | 13        |
| 4.5.1    | Central Terminal Connections .....                   | 13        |
| 4.5.2    | Outer Terminal Connections .....                     | 14        |
| 4.5.3    | Power Connections .....                              | 14        |
| 4.5.4    | Universal Input 1 Connections .....                  | 16        |
| 4.5.5    | Universal / Auxiliary Input 2 Connections.....       | 17        |
| 4.5.6    | Base Option 1.....                                   | 19        |
| 4.5.7    | Base Option 2.....                                   | 19        |
| 4.5.8    | Plug-in Module Slot 1 Connections .....              | 20        |
| 4.5.9    | Plug-in module slot 2 Connections .....              | 21        |
| 4.5.10   | Plug-in Slot 3 Connections .....                     | 23        |
| 4.5.11   | Plug-in Slot A Connections.....                      | 25        |
| 4.5.12   | Option C Connections .....                           | 27        |
| <b>5</b> | <b>Powering Up.....</b>                              | <b>29</b> |
| 5.1      | Powering Up Procedure.....                           | 29        |
| 5.2      | Front Panel Overview .....                           | 29        |

|          |                                                            |           |
|----------|------------------------------------------------------------|-----------|
| 5.3      | Display .....                                              | 29        |
| 5.4      | LED Functions.....                                         | 29        |
| 5.5      | Keypad Functions & Navigation.....                         | 30        |
| <b>6</b> | <b>Messages &amp; Error Indications .....</b>              | <b>31</b> |
| 6.1      | Plug-in Module Problems.....                               | 31        |
| 6.2      | Sensor Break Detection .....                               | 31        |
| 6.3      | Un-Calibrated Input Detection.....                         | 31        |
| 6.4      | PV Over-range or Under-range Indication .....              | 31        |
| 6.5      | Auxiliary Input Over-range or Under-range Indication ..... | 31        |
| 6.6      | Cascade-Open.....                                          | 32        |
| 6.7      | Profile Not Valid .....                                    | 32        |
| 6.8      | USB Data Transfer Failure message .....                    | 32        |
| 6.9      | Getting Help .....                                         | 32        |
| <b>7</b> | <b>Application Setup.....</b>                              | <b>33</b> |
| 7.1      | Pre-commissioning Considerations .....                     | 33        |
| <b>8</b> | <b>Operation and Configuration Menus.....</b>              | <b>36</b> |
| 8.1      | Operation Mode .....                                       | 36        |
| 8.1.1    | Navigating and Adjusting Values in Operator Mode.....      | 36        |
| 8.1.2    | Operation Mode Screen Sequence .....                       | 37        |
| 8.2      | Main Menu .....                                            | 41        |
| 8.2.1    | Entry into the Main Menu.....                              | 41        |
| 8.2.2    | Unlock Codes .....                                         | 42        |
| 8.3      | Setup Wizard.....                                          | 42        |
| 8.3.1    | Manual entry to the Setup Wizard .....                     | 43        |
| 8.4      | Supervisor Mode.....                                       | 43        |
| 8.4.1    | Entry into Supervisor Mode .....                           | 43        |
| 8.5      | Configuration Menu.....                                    | 45        |
| 8.5.1    | Entry into the Configuration Menu .....                    | 45        |
| 8.6      | The USB Menu.....                                          | 63        |
| 8.6.1    | Entry into the USB Menu .....                              | 63        |
| 8.7      | Recorder Control Menu.....                                 | 65        |
| 8.7.1    | Entry into the Recorder Control Menu .....                 | 65        |
| 8.8      | Profiler Setup Menu .....                                  | 66        |
| 8.8.1    | Entry into the Profiler Setup Menu.....                    | 66        |
| 8.9      | Profiler Control Menu .....                                | 70        |
| 8.10     | Service & Product Information Mode.....                    | 71        |
| 8.10.1   | Entry into Service & Product Information Mode .....        | 71        |
| 8.11     | Automatic Tuning Menu .....                                | 71        |
| 8.11.1   | Entry into the Automatic Tuning Menu .....                 | 72        |
| 8.12     | Lost Lock Codes.....                                       | 73        |
| <b>9</b> | <b>Input Calibration &amp; Multi-point Scaling.....</b>    | <b>74</b> |

|           |                                                             |           |
|-----------|-------------------------------------------------------------|-----------|
| 9.1       | User Calibration .....                                      | 74        |
| 9.1.1     | Calibration Reminder .....                                  | 74        |
| 9.1.2     | Single Point Calibration .....                              | 74        |
| 9.1.3     | Two Point Calibration .....                                 | 75        |
| 9.1.4     | Multi-point Scaling .....                                   | 75        |
| 9.2       | Base Calibration Adjustment .....                           | 76        |
| 9.2.1     | Required Equipment .....                                    | 76        |
| 9.2.2     | Performing a Calibration Check .....                        | 76        |
| 9.2.3     | Recalibration Procedure .....                               | 77        |
| <b>10</b> | <b>Digital Inputs .....</b>                                 | <b>78</b> |
| 10.1      | Digital Signal Type .....                                   | 78        |
| 10.1.1    | Inverting Digital Inputs .....                              | 78        |
| 10.2      | Soft Digital Inputs .....                                   | 79        |
| 10.3      | Digital Input Functions .....                               | 79        |
| <b>11</b> | <b>Cascade Control .....</b>                                | <b>81</b> |
| 11.1      | Example Cascade Application .....                           | 81        |
| 11.2      | Normal Cascade Operation .....                              | 82        |
| 11.3      | Cascade-Open .....                                          | 82        |
| 11.4      | Manual Mode .....                                           | 82        |
| 11.5      | Cascade Tuning .....                                        | 82        |
| 11.5.1    | To automatically pre-tune a cascade: .....                  | 82        |
| 11.5.2    | To manually tune a cascade: .....                           | 83        |
| <b>12</b> | <b>Ratio Control .....</b>                                  | <b>84</b> |
| 12.1      | Stoichiometric Combustion .....                             | 84        |
| <b>13</b> | <b>Redundant Input .....</b>                                | <b>86</b> |
| <b>14</b> | <b>Valve Motor Drive / 3-Point Stepping Control .....</b>   | <b>87</b> |
| 14.1      | Special Wiring Considerations for Valve Motor Control ..... | 87        |
| 14.2      | Position Feedback .....                                     | 88        |
| 14.2.1    | Valve Limiting .....                                        | 88        |
| <b>15</b> | <b>Setpoint Sources .....</b>                               | <b>89</b> |
| 15.1      | Loop 1 Setpoint Sources .....                               | 89        |
| 15.1.1    | Loop 1 Profile Setpoint .....                               | 89        |
| 15.2      | Loop 2 Setpoint Sources .....                               | 89        |
| 15.2.1    | Loop 2 Profile Setpoint .....                               | 89        |
| <b>16</b> | <b>Profiler .....</b>                                       | <b>90</b> |
| 16.1      | Introduction .....                                          | 90        |
| 16.2      | Profiler Enabling .....                                     | 90        |
| 16.3      | Profile Components .....                                    | 90        |
| 16.3.1    | Profile Header & Segment Information .....                  | 90        |
| 16.3.2    | Profile Starting & Standard Segments .....                  | 91        |
| 16.3.3    | Two Loop Profiles .....                                     | 91        |

|           |                                                                  |            |
|-----------|------------------------------------------------------------------|------------|
| 16.3.4    | Loop-back Segments.....                                          | 92         |
| 16.4      | Profile Running / Holding vs. Hold Segments .....                | 93         |
| 16.5      | The Auto-Hold Feature .....                                      | 93         |
| 16.5.1    | Auto Hold Examples .....                                         | 94         |
| 16.6      | Profile Cycles & Repeat Sequences .....                          | 95         |
| 16.7      | Power/Signal Lost Recovery Actions .....                         | 96         |
| 16.8      | Profile End Actions .....                                        | 97         |
| 16.9      | Profile Abort Actions .....                                      | 98         |
| <b>17</b> | <b>USB Interface.....</b>                                        | <b>99</b>  |
| 17.1      | Using the USB Port .....                                         | 99         |
| 17.1.1    | USB Memory Stick Folders & Files .....                           | 99         |
| <b>18</b> | <b>Data Recorder.....</b>                                        | <b>100</b> |
| 18.1      | Recordable Values .....                                          | 100        |
| 18.1.1    | Recorder Control and Status .....                                | 100        |
| 18.1.2    | Uploading Data .....                                             | 101        |
| 18.2      | Additional Features & Benefits from the Recorder .....           | 101        |
| <b>19</b> | <b>Controller Tuning .....</b>                                   | <b>102</b> |
| 19.1      | PID Sets & Gain Scheduling .....                                 | 102        |
| 19.2      | Automatic Tuning.....                                            | 103        |
| 19.3      | Manually Tuning .....                                            | 105        |
| 19.3.1    | Tuning Control Loops - PID with Primary Output only.....         | 105        |
| 19.3.2    | Tuning Control Loops - PID with Primary & Secondary Outputs..... | 105        |
| 19.3.3    | Valve, Damper & Speed Controller Tuning .....                    | 107        |
| 19.3.4    | Fine Tuning.....                                                 | 109        |
| <b>20</b> | <b>Serial Communications .....</b>                               | <b>112</b> |
| 20.1      | Supported Protocols .....                                        | 112        |
| 20.1.1    | RS485 Configuration .....                                        | 112        |
| 20.1.2    | Ethernet Configuration.....                                      | 112        |
| 20.2      | Supported Modbus Functions .....                                 | 114        |
| 20.2.1    | Function Descriptions .....                                      | 114        |
| 20.2.2    | Exception Responses .....                                        | 115        |
| 20.3      | Modbus Parameters .....                                          | 116        |
| 20.3.1    | Data Formats .....                                               | 116        |
| 20.4      | Parameter Register Address Listings.....                         | 116        |
| 20.4.1    | Calibration Reminder Parameters .....                            | 117        |
| 20.4.2    | Universal Process Input 1 Parameters .....                       | 117        |
| 20.4.3    | Universal Process Input 2 Parameters .....                       | 121        |
| 20.4.4    | Digital Input Setup Parameters.....                              | 125        |
| 20.4.5    | Plug-in Module Slot A Parameters .....                           | 138        |
| 20.4.6    | Plug-in Module Slot 1 Parameters.....                            | 139        |
| 20.4.7    | Plug-in Module Slot 2 Parameters.....                            | 142        |

|         |                                            |     |
|---------|--------------------------------------------|-----|
| 20.4.8  | Plug-in Module Slot 3 Parameters.....      | 145 |
| 20.4.9  | Output 4 Parameters .....                  | 147 |
| 20.4.10 | Output 5 Parameters .....                  | 149 |
| 20.4.11 | Linear Output 6 Parameters .....           | 150 |
| 20.4.12 | Linear Output 7 Parameters .....           | 151 |
| 20.4.13 | Loop 1 Setpoint Parameters.....            | 152 |
| 20.4.14 | Loop 2 Setpoint Parameters.....            | 153 |
| 20.4.15 | Aux A Input Parameters .....               | 154 |
| 20.4.16 | Loop 1 Control Parameters .....            | 154 |
| 20.4.17 | Loop 2 Control Parameters .....            | 160 |
| 20.4.18 | Alarm Parameters.....                      | 166 |
| 20.4.19 | Recorder & Clock Parameters.....           | 174 |
| 20.4.20 | Display & Security .....                   | 179 |
| 20.4.21 | Instrument Data Parameters .....           | 186 |
| 20.4.22 | Profiler Control & Status Parameters ..... | 188 |
| 20.4.23 | Profile Setup via Modbus .....             | 190 |

## **21 Glossary .....207**

|       |                                   |     |
|-------|-----------------------------------|-----|
| 21.1  | Active Setpoint .....             | 207 |
| 21.2  | Actual Setpoint .....             | 207 |
| 21.3  | Alarm Activation Inhibit.....     | 207 |
| 21.4  | Alarm Configuration.....          | 207 |
| 21.5  | Alarm Duration Inhibit.....       | 207 |
| 21.6  | Alarm Operation .....             | 209 |
| 21.7  | Alarm Types .....                 | 210 |
| 21.8  | Alternate Setpoint.....           | 210 |
| 21.9  | Auto Pre-Tune .....               | 210 |
| 21.10 | Automatic Reset.....              | 210 |
| 21.11 | Auxiliary Input .....             | 210 |
| 21.12 | Auxiliary Input Lower Limit.....  | 210 |
| 21.13 | Auxiliary Input Offset.....       | 210 |
| 21.14 | Auxiliary Input Type .....        | 210 |
| 21.15 | Auxiliary Input Upper Limit.....  | 211 |
| 21.16 | Band Alarm Value .....            | 211 |
| 21.17 | Bar Graphs.....                   | 211 |
| 21.18 | Bias .....                        | 211 |
| 21.19 | Bumpless Transfer.....            | 211 |
| 21.20 | Calibration .....                 | 211 |
| 21.21 | Cascade Control .....             | 211 |
| 21.22 | Clock Configuration.....          | 212 |
| 21.23 | Communications Write Enable ..... | 212 |
| 21.24 | Configuration Menu.....           | 212 |
| 21.25 | Contactors.....                   | 212 |

|       |                                  |     |
|-------|----------------------------------|-----|
| 21.26 | Continuous Control .....         | 212 |
| 21.27 | Control Configuration .....      | 212 |
| 21.28 | Control Deviation.....           | 212 |
| 21.29 | Control Action.....              | 212 |
| 21.30 | Control Enable/Disable .....     | 212 |
| 21.31 | Control Power Alarm .....        | 213 |
| 21.32 | Control Type.....                | 213 |
| 21.33 | Controller.....                  | 214 |
| 21.34 | Controller Mode.....             | 214 |
| 21.35 | Correcting Variable .....        | 214 |
| 21.36 | CPU.....                         | 214 |
| 21.37 | Custom Display Mode .....        | 214 |
| 21.38 | Cycle Time .....                 | 214 |
| 21.39 | Data Recorder .....              | 214 |
| 21.40 | Deadband.....                    | 214 |
| 21.41 | Derivative Action .....          | 214 |
| 21.42 | Deviation Alarm .....            | 215 |
| 21.43 | Digital Input .....              | 215 |
| 21.44 | Direct Acting Control .....      | 215 |
| 21.45 | Display Configuration .....      | 215 |
| 21.46 | Display Languages.....           | 216 |
| 21.47 | Display Resolution .....         | 216 |
| 21.48 | Effective Setpoint .....         | 216 |
| 21.49 | Engineering Units.....           | 216 |
| 21.50 | Ethernet.....                    | 216 |
| 21.51 | Gain Scheduling.....             | 216 |
| 21.52 | Indicator .....                  | 216 |
| 21.53 | Input Configuration.....         | 216 |
| 21.54 | Input Filter Time Constant.....  | 216 |
| 21.55 | Input Range.....                 | 217 |
| 21.56 | Input Span .....                 | 217 |
| 21.57 | Integral Action .....            | 217 |
| 21.58 | Invert Digital Input .....       | 217 |
| 21.59 | Latching Output.....             | 217 |
| 21.60 | LED .....                        | 217 |
| 21.61 | Linear Input .....               | 217 |
| 21.62 | Linear Output .....              | 218 |
| 21.63 | Limit Controller .....           | 218 |
| 21.64 | Local Setpoints.....             | 218 |
| 21.65 | Lock Codes .....                 | 218 |
| 21.66 | Logical Output Combinations..... | 219 |
| 21.67 | Loop Alarm.....                  | 219 |

|        |                                  |     |
|--------|----------------------------------|-----|
| 21.68  | LSD .....                        | 219 |
| 21.69  | mADC.....                        | 220 |
| 21.70  | Main Menu .....                  | 220 |
| 21.71  | Main Setpoint .....              | 220 |
| 21.72  | Manual Loop Alarm Time.....      | 220 |
| 21.73  | Manual Mode .....                | 220 |
| 21.74  | Manual Reset.....                | 220 |
| 21.75  | Master & Slave Controllers ..... | 221 |
| 21.76  | Modbus RTU .....                 | 221 |
| 21.77  | Modbus TCP .....                 | 221 |
| 21.78  | Minimum Motor On Time .....      | 221 |
| 21.79  | Modulating Valve .....           | 222 |
| 21.80  | Motor Travel Time.....           | 222 |
| 21.81  | Multi-Point Scaling .....        | 222 |
| 21.82  | mVDC.....                        | 222 |
| 21.83  | On-Off Control.....              | 222 |
| 21.84  | On-Off Differential .....        | 223 |
| 21.85  | On-Off Hysteresis .....          | 223 |
| 21.86  | Operation Mode .....             | 223 |
| 21.87  | Output Configuration.....        | 223 |
| 21.88  | Overlap/Deadband.....            | 223 |
| 21.89  | PC Software .....                | 224 |
| 21.90  | PD Control .....                 | 225 |
| 21.91  | PI Control .....                 | 225 |
| 21.92  | PID Control .....                | 225 |
| 21.93  | PID Gain Sets .....              | 225 |
| 21.94  | PLC .....                        | 225 |
| 21.95  | Pre-Tune .....                   | 225 |
| 21.96  | Power Output Limits.....         | 226 |
| 21.97  | Primary Proportional Band.....   | 226 |
| 21.98  | Process High Alarm .....         | 226 |
| 21.99  | Process Inputs .....             | 226 |
| 21.100 | Process Low Alarm n Value.....   | 226 |
| 21.101 | Process Variable (PV).....       | 226 |
| 21.102 | Process Variable Offset .....    | 226 |
| 21.103 | Profile Control Menu .....       | 227 |
| 21.104 | Profile Events .....             | 227 |
| 21.105 | Profile Header .....             | 227 |
| 21.106 | Profile Segments.....            | 227 |
| 21.107 | Profile Setup Menu .....         | 227 |
| 21.108 | Profiler.....                    | 227 |
| 21.109 | Profiler Mode.....               | 227 |

|        |                                          |     |
|--------|------------------------------------------|-----|
| 21.110 | Proportional Control .....               | 228 |
| 21.111 | Rate.....                                | 228 |
| 21.112 | Rate of Change Alarm .....               | 228 |
| 21.113 | Ratio Control .....                      | 228 |
| 21.114 | Recorder Configuration .....             | 228 |
| 21.115 | Recorder Option.....                     | 228 |
| 21.116 | Recorder Menu .....                      | 228 |
| 21.117 | Relay .....                              | 228 |
| 21.118 | Remote Setpoint (RSP) .....              | 229 |
| 21.119 | Retransmit Output .....                  | 229 |
| 21.120 | Retransmit Output Scale Maximum .....    | 229 |
| 21.121 | Retransmit Output Scale Minimum .....    | 229 |
| 21.122 | Reset To Defaults .....                  | 229 |
| 21.123 | Reverse Acting Control .....             | 229 |
| 21.124 | RS485 .....                              | 229 |
| 21.125 | RTD.....                                 | 230 |
| 21.126 | Scaled Input Upper Limit.....            | 230 |
| 21.127 | Scaled Input Lower Limit.....            | 230 |
| 21.128 | Secondary Proportional Band .....        | 230 |
| 21.129 | Self-Tune.....                           | 231 |
| 21.130 | Sensor Break Pre-Set Power.....          | 231 |
| 21.131 | Serial Communications Configuration..... | 231 |
| 21.132 | Serial Communications Option .....       | 231 |
| 21.133 | Set Valve Closed Position.....           | 231 |
| 21.134 | Set Valve Opened Position .....          | 231 |
| 21.135 | Setpoint .....                           | 232 |
| 21.136 | Setpoint Upper Limit.....                | 232 |
| 21.137 | Setpoint Lower Limit.....                | 232 |
| 21.138 | Setpoint Ramp Rate .....                 | 232 |
| 21.139 | Setpoint Selection .....                 | 232 |
| 21.140 | Setup Wizard.....                        | 232 |
| 21.141 | Solid State Relay (SSR).....             | 232 |
| 21.142 | Solenoid Valve .....                     | 233 |
| 21.143 | Supervisor Mode .....                    | 233 |
| 21.144 | Thermocouple .....                       | 233 |
| 21.145 | Three Point Stepping Control.....        | 233 |
| 21.146 | Time Proportioning Control .....         | 233 |
| 21.147 | Trend Displays .....                     | 234 |
| 21.148 | Tuning .....                             | 234 |
| 21.149 | Tuning Menu .....                        | 234 |
| 21.150 | Triac .....                              | 234 |
| 21.151 | USB Menu.....                            | 234 |

|           |                                                        |            |
|-----------|--------------------------------------------------------|------------|
| 21.152    | Valve Motor Drive Control (VMD)                        | 235        |
| 21.153    | Valve Position or Flow Indication                      | 235        |
| 21.154    | Valve Open & Closed Limits                             | 235        |
| <b>22</b> | <b>PC Software</b>                                     | <b>236</b> |
| 22.1      | Using the PC Software                                  | 236        |
| 22.2      | Instrument Simulation                                  | 237        |
| 22.3      | Configuring the Connection                             | 237        |
| 22.3.1    | Connection from PC to Bottom Configuration Socket      | 238        |
| 22.3.2    | Connection from PC to Rear RS485 Communications Option | 238        |
| 22.3.3    | Connection from PC/Network to Ethernet Port            | 239        |
| 22.3.4    | Changing the IP Address                                | 239        |
| 22.3.5    | USB Memory Stick Folders & Files                       | 240        |
| 22.4      | Instrument Configuration                               | 240        |
| 22.4.1    | Main Parameter Adjustment                              | 240        |
| 22.4.2    | Extending Functionality via Software                   | 241        |
| 22.5      | Profile Creation and Editing                           | 243        |
| 22.6      | Data Recorder Trend Upload & Analysis                  | 244        |
| <b>23</b> | <b>Specifications</b>                                  | <b>246</b> |
| 23.2      | Universal Process Inputs                               | 246        |
| 23.2.1    | General Input 1 and 2 Specifications                   | 246        |
| 23.2.2    | Thermocouple Input                                     | 246        |
| 23.2.3    | Resistance Temperature Detector (RTD) Input            | 247        |
| 23.2.4    | DC Linear Input                                        | 247        |
| 23.2.5    | Input Functions                                        | 248        |
| 23.3      | Auxiliary Input                                        | 248        |
| 23.4      | Digital Inputs                                         | 249        |
| 23.5      | Output Specifications                                  | 250        |
| 23.6      | Communications                                         | 252        |
| 23.7      | Control Loop(s)                                        | 253        |
| 23.8      | Alarms                                                 | 254        |
| 23.9      | Profiler Option                                        | 254        |
| 23.10     | Data Recorder Option                                   | 255        |
| 23.11     | Display                                                | 255        |
| 23.12     | Operating Conditions                                   | 255        |
| 23.13     | Conformance Norms                                      | 255        |
| 23.14     | Dimensions                                             | 255        |
| <b>24</b> | <b>Model Selection Guide</b>                           | <b>256</b> |



# 1 Introduction

This product is a 1/4 DIN size (96 x 96mm front) microprocessor based graphical controller programmer, featuring a 160 x 80 pixel, monochrome LCD with dual color (red/green) backlight. It operates from 100-240V at 50/60 Hz or 24V-48V AC/DC, depending on the model purchased. It can measure and control up to two process variables from a variety of sources such as temperature, pressure, flow and level. Primary and secondary control outputs are possible for each loop.

Optional features include a second process input, USB interface, remote setpoint inputs RS485 or Ethernet communications, profile control and data recording. Control options include cascade, ratio and 3-point stepping valve control. Automatic tuning or 5 stage gain-scheduling are also available.

The USB Interface option allows uploading or downloading instrument configuration settings to/from a USB memory stick, for easy configuration of multiple instruments or transfer to/from the PC configuration software. If the data recorder or profiler options are fitted, recordings and profile information can be transferred via the memory stick.

The data recorder option allows the user to make recordings of the processes over time. Recordings can be transferred to a memory stick using the USB interface or downloaded via one of the communications options.

The Profiler option allows the user to predefine up to 255 segments, shared amongst up to 64 Setpoint Profiles. These control the setpoint levels for the control loop(s) over time, increasing, decreasing or holding their values as required. When combined with the real-time clock (part of the Data Recorder option) the profiling capabilities are expanded to allow automatic program start at a defined time and day.

Inputs are user configurable for thermocouple and RTD probes, as well as linear process signal types such as mVDC, VDC or mADC. Two-point calibration or multipoint scaling can compensate for errors or non-linear signals. Output options include single or dual relays, single or dual SSR drivers, triacs or linear mA/V DC. These can be used for process control, alarms/events or retransmission of the process variable or setpoint to external devices. Transmitter power supply options can provide an unregulated 24V DC (22mA) auxiliary output voltage, or a 0 to 10VDC stabilised excitation for external signal transmitters.

Up to 7 alarms can be defined as process high or low, deviation (active above or below controller setpoint), band (active both above and below setpoint), rate of input change, control loop, PID power or signal break types. Alarm status can be indicated by lighting an LED, changing the display backlight color or viewing the active alarm status screen. These alarms can be linked to any suitable output.

Configuration for basic applications is possible using the easy Setup Wizard run automatically at first power-up or manually later. Access to the full range of parameters is via a simple menu driven front panel interface, or the PC based configuration software.

## 2 Installation

### 2.1 Unpacking

1. Remove the product from its packing. Retain the packing for future use, in case it is necessary to transport the instrument to a different site or to return it to the supplier for servicing.
2. The instrument is supplied with a panel gasket and push-fit mounting clamp. A multi-page concise manual is supplied with the instrument, in one or more languages. Examine the delivered items for damage or defects. If any are found, contact your supplier immediately.

### 2.2 Installation



**CAUTION:** Installation should be only performed by technically competent personnel. It is the responsibility of the installing engineer to ensure that the configuration is safe. Local Regulations regarding electrical installation & safety must be observed (e.g. US National Electrical Code (NEC) or Canadian Electrical Code).




Figure 1. Main dimensions

### 2.3 Panel-Mounting

The controller should be mounted in a properly earthed metal cabinet. The mounting panel must be rigid and may be up to 6.0mm (0.25 inches) thick. The cut-out size is:

**92mm x 92mm (+0.5mm / -0.0mm).**

Instruments may be mounted side-by-side in a multiple installation, but instrument to panel moisture and dust sealing will be compromised. Allow a 20mm gap above, below and behind the instrument for ventilation. The cut-out width (for  $n$  instruments) is:

$$(96n - 4) \text{ mm or } (3.78n - 0.16) \text{ inches}$$


If panel sealing must be maintained, mount each instrument into an individual cut-out with 10mm or more clearance between the edges of the holes.



**Note:** The mounting clamp tongues may engage the ratchets either on the sides or the top/bottom faces of the Instrument housing. When installing several Instruments side-by-side in one cut-out, use the ratchets on the top/bottom faces.



**CAUTION:** Ensure the inside of the panel remains within the instrument operating temperature and that there is adequate airflow to prevent overheating.



**Note:** For an effective IP66 seal against dust and moisture, ensure gasket is well compressed against the panel, with the 4 tongues located in the same ratchet slot.

Figure 2. Panel-Mounting the instrument



**CAUTION:** Do not remove the panel gasket, as this may result in inadequate clamping and sealing of the instrument to the panel.

Once the instrument is installed in its mounting panel, it may be subsequently removed from its housing if necessary, as described in the Fitting and Removing Plug-in Modules section.

## 2.4 Cleaning

Clean the front panel by washing with warm soapy water and dry immediately. If the USB option is fitted, close the USB port cover before cleaning.

## 3 Field Upgrade Options

### 3.1 Plug-Modules and Upgradeable Functions

Plug-Modules can be either pre-installed at the time of manufacture, or retrofitted in the field to expand the capabilities of the controller. Contact your supplier to purchase these items. Part numbers and circuit board identification numbers for the plug-in modules and accessories are shown below.

| Upgrade Kits/PC Software                         | Reference    |
|--------------------------------------------------|--------------|
| Relay Module (Slot 1)                            | 51453391-517 |
| Relay Module (Slot 2 & 3)                        | 51453391-518 |
| 10Vdc SSR Driver Module (Slot 1)                 | 51453391-502 |
| 10Vdc SSR Driver Module (Slot 2 & 3)             | 51453391-507 |
| Dual SSR Driver Module (Slot 2 & 3)              | 51453391-519 |
| TRIAC Module (Slot 1)                            | 51453391-503 |
| TRIAC Module (Slot 2 & 3)                        | 51453391-508 |
| Linear (mA, Vdc) Module (Slot 1)                 | 51453391-504 |
| Dual Relay Module (Slot 2 & 3)                   | 51453391-510 |
| Dual SSR Output Module (Slot 2 & 3)              | 51453391-519 |
| 24V Transmitter Power Supply Module (slot 2 & 3) | 51453391-511 |
| RS485 Communication (Slot A)                     | 51453391-512 |
| Ethernet Communication (Slot A)                  | 51453391-521 |
| Digital Input Module (Slot A)                    | 51453391-513 |
| Basic Aux Input Module (RSP/Position) (Slot A)   | 51453391-515 |
| Program Configuration/Profile Editing Software   | 51453391-522 |



**CAUTION:** Plastic pegs prevent fitting of older non-reinforced single relay modules (board identification numbers 637/01 and 638/01). Fitting the older relay modules reduces the isolation rating to Basic 240V isolation and is therefore not recommended.

Remove this peg when fitting Dual Relay Modules.



Note: All dual relay modules have reinforced isolation.

### 3.1.1 Board Positions




Figure 3. Rear view (uncased) & board positions

### 3.2 Preparing to Install or Remove Plug-in Modules



**CAUTION:** Before removing the instrument from its housing, ensure that all power has been removed from the rear terminals. Modules / boards should be replaced by a technically competent technician.

1. Grip the edges of the front panel (there is a finger grip on each edge) and pull it forwards approximately 10mm, until the Front Panel Removal Latch prevents further movement. The purpose of the latch is to prevent removal of the instrument without the use of a tool.
2. The Front Panel Removal Latch must be pushed down to allow removal of the instrument. Using a tool (e.g. screwdriver or pen tip), press down it down through the front central ventilation hole. This will release the instrument from the case.
3. The internal boards can now be accessed. Take note of the orientation of the instrument and boards for subsequent replacement into the housing. The positions of the boards, their mountings and the Front Panel Removal Latch are shown above.

### 3.2.1 Main Board Connectors




**Figure 4. Main board connectors**

This product is designed to allow the user to reconfigure some hardware options in the field by changing the plug-in modules in slots 1, 2, 3, & A located on the power supply and 1<sup>st</sup> universal input boards. The main boards (display/CPU, power supply, inputs 1 & 2 and digital input/USB) are factory fitted, but may be removed while reconfiguring the plug-in modules. Take care when re-fitting these boards. Observe the power supply board transformer color, and case labelling to check the supply voltage, otherwise irreparable damage may occur.



**CAUTION:** Replacement of boards must be carried out by a technically competent technician. If the Power Supply board does not match the labelling, users may apply incorrect voltage resulting in irreparable damage.

### 3.3 Removing/Replacing Option Modules

1. To remove or replace Plug-in Modules 1, 2, 3 or A it is necessary to detach the power supply and input boards from the front panel by lifting first the upper and then lower mounting struts.
2. Remove or fit the modules to the connectors on the power supply and input boards. The location of the connectors is shown below. Plastic pegs prevent fitting of older non-reinforced single relay modules – *Remove the peg to fit dual relay modules*
3. Assemble the Power Supply and Input boards together. Tongues on each option module locate into slots cut into the main boards, opposite each of the connectors. Hold the Power and Input boards together and relocate them back on their mounting struts.
4. Push the boards forward to ensure correct connection to the front Display/CPU board and re-check the installation of the Option C and/or 2<sup>nd</sup> Input / Base Option 2 boards if present.



**CAUTION:** Check for correct orientation of the modules and that all pins are located correctly.

### 3.4 Replacing the Instrument in its Housing



**CAUTION:** Before replacing the instrument in its housing, ensure that all power has been removed from the rear terminals.

With the required option modules correctly located into their respective positions the instrument can be replaced into its housing as follows:

1. Hold the Power Supply and Input boards together.
2. Align the boards with the guides in the housing.
3. Slowly and firmly, push the instrument into position in its case.



**CAUTION:** Ensure that the instrument is correctly orientated. A mechanical stop will operate if an attempt is made to insert the instrument in the wrong orientation, this stop **MUST NOT** be over-ridden.

### 3.5 Auto Detection of Plug-in Modules

The instrument automatically detects which plug-in modules have been fitted into each slot.

The menus and screens change to reflect the options compatible with the hardware. The modules fitted can be viewed in the product information menu, as detailed in the Product & Service Information Mode section of this manual.

## 3.6 Data Recorder Board

If installed, the Data Recorder memory and Real Time Clock (RTC) components are located on a plug-in daughter board attached to the front Display/CPU board.



**CAUTION:** Servicing of the Data Recorder/RTC circuit and replacement of the lithium battery should only be carried out by a technically competent technician.

## 3.7 Profiler Enabling

If you purchased a controller with the Profiler option installed, these features will be enabled during manufacture.

Controllers supplied without the Profiler option installed can be upgraded in the field by purchasing a licence code number from your supplier. A unique code must be purchased to enable profiling on each controller that requires it.

### 3.7.1.1 Entering the Profiler Enable Code

Hold down the ◀ and ▼ keys during the power-up “splash screen”.

Using the ▼ or ▲ keys, enter the 16-character licence code in the displayed screen. Press ► to move on to the next character. Press ◀ to move back to the previous character.

Press ► after entering the final character.

To confirm if profiling is installed in your instrument, check the Controller Feature Information in Product & Service Information Mode.

## 4 Electrical Installation



**CAUTION:** Installation should be only performed by technically competent personnel. It is the responsibility of the installing engineer to ensure that the configuration is safe. Local Regulations regarding electrical installation & safety must be observed (e.g. US National Electrical Code (NEC) or Canadian Electrical Code).

### 4.1 Avoiding EMC Problems

This controller has passed EMC compliance tests to EN61326-1:2013. There should be no difficulty achieving this level of compliance in use, but it should be borne in mind that the wiring of the installation can significantly reduce the efficiency of instrumentation immunity due to the ease with which high frequency RF can enter via unprotected cables.

The following general recommendations can reduce the possibility of EMC problems.

1. If the instrument is being installed in existing equipment, wiring in the area should be checked to ensure that good wiring practices have been followed.
2. The controller should be mounted in a properly earthed metal cabinet. All round metal shielding is important, so the cabinet door may require a conductive sealing strip.
3. It is good practice to ensure that the AC neutral is at or near ground (earth) potential. A proper neutral will help ensure maximum performance from the instrument.
4. Consider using a separate isolation transformer to feed only the instrumentation. A transformer can protect instruments from noise found on the AC power supply.

#### 4.1.1 Cable Isolation & Protection

Four voltage levels of input and output wiring may be used with the unit:

1. Analog inputs or outputs (for example thermocouple, RTD, VDC, mVDC or mADC)
2. Relays & Triac outputs
3. Digital Inputs & SSR Driver outputs
4. AC power



**CAUTION:** The only wires that should run together are those of the same category.

If any wires need to run parallel with any from another category, maintain a minimum space of 150mm between them. If wires **MUST** cross each other, ensure they do so at 90 degrees to minimise interference.

Keep signal cables as short as possible. If an earthed thermocouple is used or if the sensor has a screened cable, it should be earthed at one point only, preferably at the sensor location or cabinet entry point, by means of a metal gland. Ideally all analog and digital signals should be shielded like this, but for unscreened cables, large diameter ferrite sleeves at the cabinet entry point are an effective method of reducing RF interference. Looping cables through the ferrite sleeves a number of times improves the efficiency of the filtering. For mains input cables the fitting a suitable mains filter can provide good results.

### 4.1.2 Noise Suppression at Source

If possible, eliminate mechanical contact relays and replace with solid-state relays.

Noise-generating devices such as Ignition transformers, arc welders, motor drives, relays and solenoids should be mounted in a separate enclosure. If this is not possible, separate them from the instrumentation, by the largest distance possible.

Many manufacturers of relays, contactors etc supply 'surge suppressors' to reduce noise at its source. For those devices that do not have surge suppressors supplied, Resistance-Capacitance (RC) networks and/or Metal Oxide Varistors (MOV) may be added.

**Inductive coils:-** MOVs are recommended for transient suppression in inductive coils. Connect as close as possible, in parallel to the coil. Additional protection may be provided by adding an RC network across the MOV.




**Figure 5. Transient suppression with inductive coils**

**Contacts:-** Arcing may occur across contacts when they open and close. This results in electrical noise as well as damage to the contacts. Connecting a properly sized RC network can eliminate this arc.

For circuits up to 3 amps, a combination of a 47 ohm resistor and 0.1 microfarad capacitor (1000 volts) is recommended. For circuits from 3 to 5 amps, connect two of these in parallel.




**Figure 6. Contact noise suppression**

## 4.2 Sensor Placement (Thermocouple or RTD)

If a temperature probe is to be subjected to corrosive or abrasive conditions, it must be protected by an appropriate thermowell.

Probes must be positioned to reflect the true process temperature:

1. In a liquid media - the most agitated area
2. In air - the best circulated area



**CAUTION:** The placement of probes into pipe work some distance from the heating vessel leads to transport delay, which results in poor control.

For a two wire RTD, a wire link should be used in place of the third wire (see the wiring section for details). Two wire RTDs should only be used with lead lengths less than 3 metres. Use of three wire RTDs is strongly recommended to reduce errors do to lead resistance.

## 4.3 Thermocouple Wire Identification

The different thermocouple types are identified by their wires color, and where possible, the outer insulation as well. There are several standards in use throughout the world, but most regions now use the International IEC584-3 standard.

The table below shows the wire and sheath colors used for most common thermocouple types. The format used in this table is:

|        |        |
|--------|--------|
| + Wire | Sheath |
| - Wire |        |

| THERMOCOUPLE WIRE COLOR CHART |    |                        |        |                  |        |                |        |                   |        |                  |       |
|-------------------------------|----|------------------------|--------|------------------|--------|----------------|--------|-------------------|--------|------------------|-------|
| Type                          |    | International IEC584-3 |        | USA ANSI MC 96.1 |        | British BS1843 |        | French NFC 42-324 |        | German DIN 43710 |       |
| J                             | +  | Black                  | Black  | White            | Black  | Yellow         | Black  | Yellow            | Black  | Red              | Blue  |
|                               | -  | White                  | Black  | Red              | Black  | Blue           | Black  | Black             | Black  | Blue             | Blue  |
| T                             | +  | Brown                  | Brown  | Blue             | Blue   | White          | Blue   | Yellow            | Blue   | Red              | Brown |
|                               | -  | White                  | Brown  | Red              | Blue   | Blue           | Blue   | Blue              | Blue   | Brown            | Brown |
| K                             | +  | Green                  | Green  | Yellow           | Yellow | Brown          | Red    | Yellow            | Yellow | Red              | Green |
|                               | -* | White                  | Green  | Red              | Yellow | Blue           | Red    | Purple            | Yellow | Green            | Green |
| N                             | +  | Pink                   | Pink   | Orange           | Orange | Orange         | Orange |                   |        |                  |       |
|                               | -  | White                  | Pink   | Red              | Orange | Blue           | Orange |                   |        |                  |       |
| B                             | +  | Grey                   | Grey   | Grey             | Grey   |                |        |                   |        | Red              | Grey  |
|                               | -  | White                  | Grey   | Red              | Grey   |                |        |                   |        | Grey             | Grey  |
| R & S                         | +  | Orange                 | Orange | Black            | Green  | White          | Green  | Yellow            | Green  | Red              | White |
|                               | -  | White                  | Orange | Red              | Green  | Blue           | Green  | Green             | Green  | White            | White |
| C (W5)                        | +  |                        |        | White            | White  |                |        |                   |        |                  |       |
|                               | -  |                        |        | Red              | White  |                |        |                   |        |                  |       |



**Note:** \* = Wire is magnetic – a magnet can be used to assist with correctly identifying the type and polarity of the conductors


## 4.4 Pre-wiring – Cautions, Warnings & Information



**CAUTION:** Installation should be only performed by technically competent personnel. It is the responsibility of the installing engineer to ensure that the configuration is safe. Local Regulations regarding electrical installation & safety must be observed (e.g. US National Electrical Code (NEC) or Canadian Electrical Code).



**CAUTION:** This equipment is designed for installation in an enclosure that provides adequate protection against electric shock. The isolation switch should be located in close proximity to the unit, in easy reach of the operator and appropriately marked.



**WARNING:** This symbol means the equipment is protected throughout by double insulation. All external circuits connected must provide double insulation. Failure to comply with the installation instructions may impact the protection provided by the unit.

### **WARNING:**

**TO AVOID ELECTRICAL SHOCK, AC POWER WIRING MUST NOT BE CONNECTED TO THE SOURCE DISTRIBUTION PANEL UNTIL ALL WIRING PROCEDURES ARE COMPLETED. CHECK THE INFORMATION LABEL ON THE CASE TO DETERMINE THE CORRECT VOLTAGE BEFORE CONNECTING TO A LIVE SUPPLY.**

## 4.5 Connections and Wiring

### 4.5.1 Central Terminal Connections



**Note:** The wiring diagram below shows all possible combinations to the main connections (numbered 1 to 24) in the centre of the case rear. The actual connections required depends upon the features and modules fitted.




Figure 7. Central Terminals 1 to 24

#### WARNING:

**CHECK THE INFORMATION LABEL ON THE CASE TO DETERMINE THE CORRECT VOLTAGE BEFORE CONNECTING TO A LIVE SUPPLY.**

## 4.5.2 Outer Terminal Connections



**Note:** The wiring diagram below shows the Central Terminals (numbered 25 to 42) at the sides of the case rear. Connections for the 2<sup>nd</sup> Input, Base Option 2 and Digital Input C are shown. The actual connections required depends upon the features and modules fitted.




Figure 8. Outer Terminals 25 to 42

## 4.5.3 Power Connections

### WARNING:

CHECK THE INFORMATION LABEL ON THE CASE TO DETERMINE THE CORRECT VOLTAGE BEFORE CONNECTING TO A LIVE SUPPLY.



**CAUTION:** This equipment is designed for installation in an enclosure that provides adequate protection against electric shock. An isolation switch should be located in close proximity to the unit, in easy reach of the operator and appropriately marked.

#### 4.5.3.1 Power Connections - Mains Powered Instruments

Mains powered instruments operate from a 100 to 240V ( $\pm 10\%$ ) 50/60Hz supply. Power consumption is 20VA. Connect the line and neutral as illustrated via a UL listed fuse type: 250V AC 1Amp anti-surge and a two-pole IEC60947-1 & IEC60947-3 compliant isolation switch / circuit breaker located within easy reach of the operator and appropriately marked.

If relays switch mains voltage this should be separate from the instruments mains supply.




Figure 9. Mains Power Connections

#### 4.5.3.2 Power Connections - 24/48V AC/DC Powered Instruments

24/48V AD/DC powered instruments will operate from a 20 to 48V AC or 22 to 55V DC supply. AC power consumption is 15VA max, DC power consumption is 12 watts max. Connection should be via a UL listed fuse type: 65v dc 350mAmp anti-surge and a two-pole IEC60947-1 & IEC60947-3 compliant isolation switch / circuit breaker located within easy reach of the operator and appropriately marked.




Figure 10. 24/48V AC/DC Power Connections

## 4.5.4 Universal Input 1 Connections

Universal Input 1 is present on all models. This input is normally used for the measured variable signal from a process to be controlled. It can be connected to thermocouples; resistance temperature detectors; analog mA; mV or V DC signals. The input settings are in the Input 1 Configuration sub-menu. Connections for the various types are shown below. Ensure that the signal is correctly connected, paying particular attention to the polarity.

### 4.5.4.1 Universal Input 1 Connections - Thermocouple (T/C)

Supported thermocouple types & ranges are listed in the input specifications section on page 246. Only use the correct thermocouple wire or compensating cable from the sensor to the instrument terminals avoiding joints in the cable if possible. Where joints are made, special thermocouple connectors must be used. Failure to use the correct wire type and connectors will lead to inaccurate readings. Ensure correct polarity of the wires by cross-referencing the colors with the thermocouple reference table above.




Figure 11. Input 1 - Thermocouple Connections

### 4.5.4.2 Universal Input 1 Connections – PT100 / NI120 (RTD) input

The inputs supports two types of RTD. PT100 (platinum sensor, 100 $\Omega$  at 0°C). For three wire RTDs, connect the resistive leg and the common legs of the RTD as illustrated. For a two wire RTD a wire link should be fitted across terminals 2 & 3 (in place of the third wire). Two wire RTDs should only be used when the leads are less than 3 metres long. Avoid cable joints.




Figure 12. Input 1 - RTD Connections

Four wire RTDs can be used, provided that the fourth wire is left unconnected. This wire should be cut short or tied back so that it cannot contact any of the terminals on the rear of the instrument.

#### 4.5.4.3 Universal Input 1 Connections - Linear Volt, mV or mA input

The input supports the following linear/analog signals: 0 to 50mV; 10 to 50mV; 0 to 5V; 1 to 5V; 0 to 10V; 2 to 10V; 0 to 20mV; 4 to 20mA from any suitable source. Voltage & millivolt signals are connected to terminals 2 & 3, milliamp signals are connected to 1 & 3. Carefully observe the position & polarity of the connections.




Figure 13. Input 1 - DC Volt, mV & mA Connections

#### 4.5.5 Universal / Auxiliary Input 2 Connections

An Auxiliary Input 2 option is fitted to some models. This can connect to a potentiometer; analog mA; mV or V DC signal for a remote setpoint input signal, or for flow/valve position feedback information.

Alternatively, a second Universal Input 2 option may be fitted. In addition to the remote setpoint input signal or feedback information possible with the auxiliary input, the 2<sup>nd</sup> Universal Input can be used as a second process control loop for two control loops, or used in conjunction with input one in more complex single control loops. Universal Input 2 can be connected to thermocouples; resistance temperature detectors; potentiometers; analog mA; mV or V DC signals.

The settings are in the Input 2 Configuration sub-menu. Connections for the various types are shown below. Ensure that the signal is correctly connected, paying particular attention to the polarity.

##### 4.5.5.1 Universal Input 2 Connections - Thermocouple (T/C)

The optional 2<sup>nd</sup> universal input, supports various thermocouple types. Supported types & ranges are listed in the input specifications section on page 246.

Only use the correct thermocouple wire or compensating cable from the sensor to the instrument terminals avoiding joints in the cable if possible. Where joints are made, special thermocouple connectors must be used. Failure to use the correct wire type and connectors will lead to inaccurate readings. Ensure correct polarity of the wires by cross-referencing the colors with a thermocouple reference table.




Figure 14. Input 2 - Thermocouple Connections

#### 4.5.5.2 Universal Input 2 Connections – PT100 / NI120 (RTD) input

The optional 2<sup>nd</sup> universal input, supports two types of RTD. PT100 (platinum sensor, 100Ω at 0°C). For three wire RTDs, connect the resistive leg and the common legs of the RTD as illustrated. For a two wire RTD a wire link should be fitted across terminals 35 & 36 (in place of the third wire). Two wire RTDs should only be used when the leads are less than 3 metres long. If possible, avoid cable joints.




Figure 15. Input 2 - RTD Connections

Four wire RTDs can be used, provided that the fourth wire is left unconnected. This wire should be cut short or tied back so that it cannot contact any of the terminals on the rear of the instrument.

#### 4.5.5.3 Universal / Auxiliary Input 2 Connections - Linear Volt, mV or mA input

The optional auxiliary or 2<sup>nd</sup> universal input supports the following linear/analog signals: 0 to 50mV; 10 to 50mV; 0 to 5V; 1 to 5V; 0 to 10V; 2 to 10V; 0 to 20mV; 4 to 20mA from any suitable source. Voltage & millivolt signals are connected to terminals 2 & 3, milliamp signals are connected to 1 & 3. Carefully observe the polarity of the connections.




Figure 16. Input 2 - DC Volt, mV & mA Connections

#### 4.5.5.4 Universal / Auxiliary Input 2 Connections – Potentiometer

The optional auxiliary or 2<sup>nd</sup> universal input, the terminals detailed below can be used to connect a feedback potentiometer. Minimum potentiometer resistance is  $\geq 100\Omega$ .




Figure 17. Input 2 - Potentiometer Connections

## 4.5.6 Base Option 1

Base Option 1 provides one or two factory fitted outputs. A relay designated as Output 4 is fitted on all models, and an optional linear mA/V DC designated as Output 6. Base options cannot be added after manufacture. The functions of outputs 4 & 6 are set in the Output Configuration sub-menu. Connect as illustrated below.

### 4.5.6.1 Base Option 1 Relay Output 4

Present on all instruments, Output 4 is a SPST relay, rated at 2 amps at 240 VAC resistive. If it is used to switch mains voltages, the supply should be separate from the instrument supply and should be correctly switched and fused.




Figure 18. Relay Output 4 Connections

### 4.5.6.2 Base Option 1 Linear Output 6

Part of base option 1, Output 6 is an optional linear mV/V DC analog output. The type & range are selectable from 0 to 5, 0 to 10, 2 to 10V & 0 to 20 or 4 to 20mA.




Figure 19. Linear Output 6 Connections

## 4.5.7 Base Option 2

Base Option 2 provides one or two factory fitted outputs. An optional relay designated as Output 5, and an optional linear mA/V DC designated as Output 7. Base options cannot be added after manufacture. The functions of outputs 5 & 7 are set in the Output Configuration sub-menu. Connect as illustrated below.

### 4.5.7.1 Base Option 2 Relay Output 5

Part of base option 2, Output 5 is a SPST relay, rated at 2 amps at 240 VAC resistive. If it is used to switch mains voltages, the supply should be separate from the instrument supply and should be correctly switched and fused.




Figure 20. Relay Output 5 Connections

#### 4.5.7.2 Base Option 2 Linear Output 7

Part of base option 2, Output 7 is an optional linear mV/V DC analog output. The type & range are selectable from 0 to 5, 0 to 10, 2 to 10V & 0 to 20 or 4 to 20mA.




Figure 21. Linear Output 7 Connections

#### 4.5.8 Plug-in Module Slot 1 Connections

A selection of plug-in modules are available for Module Slot 1. They can be fitted during manufacture, or purchased and fitted later by the user. Modules in slot 1 are designated Output 1. They are not interchangeable with those in slot 2 or 3. Their function is set in the Output Configuration sub-menu. Connect as illustrated below.

##### 4.5.8.1 Plug-in Module Slot 1 – Single Relay Output Module

If fitted with a single relay output module, connect as shown. The relay contacts are SPDT and rated at 2 amps resistive, 240 VAC. If it is used to switch mains voltages, the supply should be separate from the instrument supply and should be correctly switched and fused.




Figure 22. Plug-in Module Slot 1 – Single Relay Module

##### 4.5.8.2 Plug-in Module Slot 1 – Single SSR Driver Output Module

If fitted with a single SSR Driver output module, connect as shown. The 10V DC pulse signal (load resistance  $\geq 500$  ohms) is isolated from all inputs/outputs except other SSR drivers.




Figure 23. Plug-in Module Slot 1 – Single SSR Driver Module

#### 4.5.8.3 Plug-in Module Slot 1 - Triac Output Module

If fitted with a triac output module, connect as shown. This output is rated at 0.01 to 1 amp @ 280V AC 50/60Hz. Isolated from all other inputs and outputs. A snubber should be fitted across inductive loads to ensure reliable switch off of the Triac.




Figure 24. Plug-in Module Slot 1 - Triac Module

#### 4.5.8.4 Plug-in Module Slot 1 - Linear Voltage or mADC Output module

If fitted with a DC linear output module, connect as shown. Output type & range are selectable from 0 to 5, 0 to 10, 2 to 10V & 0 to 20 or 4 to 20mA. Isolated from all other inputs and outputs.




Figure 25. Plug-in Module Slot 1 - Linear Voltage & mADC Module

### 4.5.9 Plug-in module slot 2 Connections

A selection of plug-in modules are available for Module Slot 2. They are interchangeable with slot 3, but not slot 1. They can be fitted during manufacture, or purchased and fitted later by the user. Modules in slot 2 are designated Output 2, and for dual modules Output 2A and 2B. Their functions are set in the Output Configuration sub-menu. Connect as illustrated below.

#### 4.5.9.1 Plug-in Module Slot 2 – Single Relay Output Module

If fitted with a single relay output module, connect as shown. The relay contacts are SPDT and rated at 2 amps resistive, 240 VAC. If it is used to switch mains voltages, the supply should be separate from the instrument supply and should be correctly switched and fused.




Figure 26. Plug-in Module Slot 2 – Single Relay Module

#### 4.5.9.2 Plug-in Module Slot 2 - Dual Relay Output Module

If fitted with a dual relay output module, connect as shown. This module has two independent SPST relays for outputs 2A and 2B, with a shared common terminal. The contacts are rated at 2 amp resistive 240 VAC. If used to switch mains voltages, the supply should be separate from the instruments mains supply and the contacts should be correctly switched and fused.




Figure 27. Plug-in Module Slot 2 - Dual Relay Module

#### 4.5.9.3 Plug-in Module Slot 2 – Single SSR Driver Output Module

If fitted with a single SSR Driver output module, connect as shown. The 10V DC pulse signal (load resistance  $\geq 500$  ohms) is isolated from all inputs/outputs except other SSR drivers.




Figure 28. Plug-in Module Slot 2 – Single SSR Driver Module

#### 4.5.9.4 Plug-in Module Slot 2 – Dual SSR Driver Output Module

If fitted with a dual SSR Driver output module, the two solid-state relay driver outputs are designated as Output 2A and 2B. The outputs are 10V DC pulse signals, (load resistance  $\geq 500$  ohms). They are isolated from all inputs/output except other SSR driver outputs. Connect as shown making note of the shared positive common terminal.




Figure 29. Plug-in Module Slot 2 – Dual SSR Driver Module

#### 4.5.9.5 Plug-in Module Slot 2 - Triac Output Module

If fitted with a Triac output module, connect as shown. This output is rated at 0.01 to 1 amp @ 280V AC 50/60Hz. Isolated from all other inputs and outputs. A snubber should be fitted across inductive loads to ensure reliable switch off of the Triac.




Figure 30. Plug-in Module Slot 2 - Triac Module

#### 4.5.9.6 Plug-in Module Slot 2 - Transmitter Power Supply Module

If fitted with a transmitter power supply module (TxPSU), connect as shown. The output is a 24V nominal (unregulated, 19 to 28V DC), supply at 22mA max. Only one TxPSU is supported, do not fit in slot 2 if one is already fitted in slot 3.




Figure 31. Plug-in Module Slot 2 - Transmitter Power Supply Module

### 4.5.10 Plug-in Slot 3 Connections

A selection of plug-in modules are available for Module Slot 3. They are interchangeable with slot 2, but not slot 1. They can be fitted during manufacture, or purchased and fitted later by the user. Modules in slot 3 are designated Output 3, and for dual modules Output 3A and 3B. Their functions are set in the Output Configuration sub-menu. Connect as illustrated below.

#### 4.5.10.1 Plug-in Module Slot 3 – Single Relay Output Module

If fitted with a single relay output module, connect as shown. The relay contacts are SPDT and rated at 2 amps resistive, 240 VAC. If it is used to switch mains voltages, the supply should be separate from the instrument supply and should be correctly switched and fused.




Figure 32. Plug-in Module Slot 3 – Single Relay Module

#### 4.5.10.2 Plug-in Module Slot 3 - Dual Relay Output Module

If fitted with a dual relay output module, connect as shown. This module has two independent SPST relays for outputs 3A and 3B, with a shared common terminal. The contacts are rated at 2 amp resistive 240 VAC. If used to switch mains voltages, the supply should be separate from the instruments mains supply and the contacts should be correctly switched and fused.




Figure 33. Plug-in Module Slot 3 - Dual Relay Module

#### 4.5.10.3 Plug-in Module Slot 3 – Single SSR Driver Output Module

If fitted with a single SSR Driver output module, connect as shown. The 10V DC pulse signal (load resistance  $\geq 500$  ohms) is isolated from all inputs/outputs except other SSR drivers.




Figure 34. Plug-in Module Slot 3 – Single SSR Driver Module

#### 4.5.10.4 Plug-in Module Slot 3 – Dual SSR Driver Output Module

If fitted with a dual SSR Driver output module, the two solid-state relay driver outputs are designated as Output 3A and 3B. The outputs are 10V DC pulse signals, (load resistance  $\geq 500$  ohms). They are isolated from all inputs/output except other SSR driver outputs. Connect as shown making note of the shared positive common terminal.




Figure 35. Plug-in Module Slot 3 – Dual SSR Driver Module

#### 4.5.10.5 Plug-in Module Slot 3 - Triac Output Module

If fitted with a Triac output module, connect as shown. This output is rated at 0.01 to 1 amp @ 280V AC 50/60Hz. Isolated from all other inputs and outputs. A snubber should be fitted across inductive loads to ensure reliable switch off of the Triac.




Figure 36. Plug-in Module Slot 3 - Triac Module

#### 4.5.10.6 Plug-in Module Slot 3 - Transmitter Power Supply Module

If fitted with a transmitter power supply module (TxPSU), connect as shown. The output is a 24V nominal (unregulated, 19 to 28V DC), supply at 22mA max. Only one TxPSU is supported, do not fit in slot 3 if one is already fitted in slot 2.




Figure 37. Plug-in Module Slot 3 - Transmitter Power Supply Module

### 4.5.11 Plug-in Slot A Connections

A selection of plug-in modules are available for Module Slot A. They can be fitted during manufacture, or purchased and fitted later by the user. Depending on their functions, they are setup Input or Communications configuration sub-menus. Connect as illustrated below.

#### 4.5.11.1 Plug-in Module Slot A – Basic Auxiliary Input Module

If fitted with a basic auxiliary mA/V DC analog input module, connect as shown. Isolated from all inputs/outputs. Consider using the 2<sup>nd</sup> auxiliary input (if available) instead, as this has additional features and leaves plug-in module slot A free for other modules.




Figure 38. Plug-in Module Slot A – Basic Auxiliary Input Module

#### 4.5.11.2 Plug-in Module Slot A - Ethernet Communications Module

If fitted with the Ethernet communication module, the communications protocol available is Modbus TCP. Isolated from all inputs/outputs. If necessary, cut out the removable panel to access the RJ45 connector through the top of the case. No rear connections are required.

#### 4.5.11.3 Plug-in Module Slot A - RS485 Serial Communications Module

If fitted with the RS485 serial communication module, the protocol used is Modbus RTU. Isolated from all inputs/outputs. Carefully observe the polarity of the A (Rx/Tx +ve) and B (Rx/Tx -ve) connections.




Figure 39. Plug-in Module Slot A – RS485 Serial Communications Module



**CAUTION:** External computing devices connected to the communications port should comply with the standard, UL 60950.

#### 4.5.11.4 Plug-in Module Slot A – Single Digital Input Module

If a digital input module is fitted, it provides a fully isolated input that is held high via a pull-up resistor. The input can be connected to either to voltage free contacts (e.g. from a switch), or a TTL compatible signal. Logic High = Open contacts ( $>5000\Omega$ ) or 2 to 24VDC signal. Logic Low = Closed contacts ( $<50\Omega$ ) or -0.6 to +0.8VDC signal.. Connect as shown.




Figure 40. Plug-in Module Slot A – Digital Input A Module

## 4.5.12 Option C Connections

Option C offers a factory fitted multiple digital input option. The board also accommodates the USB port if that option is fitted. The USB port does not have connections on the rear terminal, it is accessed via the front panel.

### 4.5.12.1 Option C Connections – Multiple Digital Input Module

If the Multiple Digital Input option is fitted, the connections are as illustrated. The 8 opto-isolated inputs each have a positive input terminal and share a common negative terminal.

The inputs are held high with internal pull-up resistors, so may be connected to either voltage free contacts (e.g. from a switch), or TTL compatible signals:

Logic High = Open contacts ( $>5000\Omega$ ) or 2 to 24VDC signal.

Logic Low = Closed contacts ( $<50\Omega$ ) or -0.6 to +0.8VDC signal.




Figure 41. Option C - Multiple Digital Inputs C1 to C8

#### 4.5.12.2 Special Wiring Considerations for Valve Motor Control

Valve Motor Drive (VMD) controllers require two identical outputs to be assigned to position the valve. One to open and one to close the valve. These outputs can be two single relays, two triacs, two SSR drivers or one dual relay, but it is recommended to use two single relays (SPDT change-over contacts), and to interlock the relay wiring as shown. This prevents both motor windings from being driven at the same time, even under fault conditions.

Switching actuators directly connected to the valve motor must only be used up to half of their rated voltage (see **CAUTION** below). The internal relay and triac outputs are rated at 240VAC, so the maximum motor voltage when using them in this way is therefore 120V unless interposing relays are used. Interposing relays or other devices used to control the valve must themselves be rated for twice the motor supply voltage.




Figure 42. Interlocking of Valve Motor Drive Relays



**CAUTION:** The windings of a valve motor effectively form an autotransformer. This has a voltage doubling effect when power is applied to either the Open or Close terminal, causing twice the supplied voltage at the other terminal. For this reason, switching devices directly connected to the valve motor must only be used up to half of their rated voltage. The maximum motor voltage when using the internal relays/triacs is therefore 120V unless interposing relays are used. Interposing relays or other devices used to control the valve must themselves be rated for twice the motor supply voltage.

## 5 Powering Up



**CAUTION:** Ensure safe wiring practices have been followed. When powering up for the first time, disconnect the output connections. The instrument must be powered from a supply according to the wiring label on the side of the unit. The supply will be either 100 to 240V AC, or 24/48V AC/DC powered. Check carefully the supply voltage and connections before applying power

### 5.1 Powering Up Procedure

At power up, a self-test procedure is automatically started, during which a splash screen is displayed and the LED indicators are lit. At the first power up from new, a Setup Wizard runs to assist configuration of basic applications (*refer to the Setup Wizard section on page 42*). At all other times, the instrument returns to the normal operation mode once the self-test procedure is complete.

### 5.2 Front Panel Overview

The illustration below shows an instrument fitted with the optional USB socket located to the right of the four keypad buttons. Clean the front panel by washing with warm soapy water and dry immediately. If the USB option is fitted, close the port cover before cleaning.



Figure 43. A Typical Front Panel

### 5.3 Display


The instrument has a 160 x 80 pixel monochrome graphical display with dual color (red/green) backlight. The main display typically shows the process variables, setpoints, power / deviation bar graphs or graphical trends during normal operation. There are recorder and profile status screen. The top line of the display has labels for the 4 LED indicators. If desired, the backlight color can be changed to indicate the presence of an active alarm or latched output. *Refer to the Display Configuration section - page 62*

### 5.4 LED Functions

There are four red LEDs that by default indicate the status of the primary & secondary outputs, automatic tuning and alarm status. The top line of the graphical display has four labels for LED indicators. The function of these LEDs and their display labels can be changed using the PC configuration software. The information in this manual assumes standard functions for these LEDs.

## 5.5 Keypad Functions & Navigation

Each instrument has four keypad switches, which are used to navigate through the user menus and adjust the parameter values. In configuration screens, a context sensitive scrolling help text is displayed that guides the user about the function of the keys.

| Keypad Button Functions                                                             |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
|-------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Button                                                                              | Function                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |
|    | Moves backwards to the previous parameter or screen in the current mode. Holding this key down for more than 1 second skips immediately to the previous screen accepting <b>ALL</b> values as shown.<br><b>CAUTION:</b> If editing a parameter, ensure that the current (highlighted) parameter value is correct before pressing the key as this action will update and store the value displayed.                                                                                     |
|    | In menus and configuration choice screens, this key moves to the next item on the list.<br>Editable values can be decreased by pressing this key. Holding the key down speeds up the change.<br>In Trend views this key moves the Cursor Line back through the stored data points                                                                                                                                                                                                      |
|   | In menus and configuration choice screens, this key moves to the previous item on the list.<br>Editable values can be increased by pressing this key. Holding the key down speeds up the change.<br>In Trend views this key moves the Cursor Line forward through the stored data points                                                                                                                                                                                               |
|  | Moves forwards to the next parameter or screen in the current mode. Holding this key down for more than 1 second skips immediately to the next screen accepting <b>ALL</b> values as shown.<br><b>CAUTION:</b> If editing a parameter, ensure that the current (highlighted) parameter value is correct before pressing the key as this action will update and store the value displayed.                                                                                              |
|  | Pressing the ▲ key while holding down the ► key causes the instrument to move up one menu level. From Operation Mode and in most menus, this will result in entry to the Main Menu.<br>From sub-menus, it is necessary to carry out this sequence more than once to reach the main menu.<br><b>CAUTION:</b> If editing a parameter, ensure that the current (highlighted) parameter value is correct before pressing the key as this action will update and store the value displayed. |

## 6 Messages & Error Indications

### 6.1 Plug-in Module Problems

If an invalid or unknown module is detected in one of the plug-in module slots during the power-up self-test, the message “**Fault Found, Press ►, for details**” is shown. This is followed by “**Replace faulty module in Module Slot *n*, Press ►,**” (where *n* is the faulty slot location). The Service Contact information is displayed next showing details of who to contact if a fault persists

Replace the module in slot “*n*”. If this does not solve the problem, return the instrument for investigation.



**CAUTION:** Do not continue using the product until the error is resolved.

### 6.2 Sensor Break Detection

Whenever a problem is detected with a process variable or auxiliary input connection, the displayed value for that input is replaced with the word “**OPEN**”; except in Ratio control where an open input 1 or 2 is shown as “**x1-Open**” or “**x2-Open**”. See Redundant Input (page 86) to protect critical processes from sensor faults.

This may be the result of a failed sensor, a broken connection or an input circuit fault.

In this condition, the control outputs go to the pre-set power value (see *Control Configuration – page 49*).



**CAUTION:** Correct the signal/wiring problem to continue normal operation.

### 6.3 Un-Calibrated Input Detection

The instrument is fully calibrated during manufacture. If a fault occurs and calibration data is lost, the process input displays are replaced with the word “**ERROR**” and error is shown instead of “Calibrated” for effected inputs in Service & Product Information mode.

In this condition, the control outputs go to the pre-set power value (see *Control Configuration – page 49*).



**CAUTION:** Perform a full base calibration of the input before continuing normal operation (see page 76). If the problem persists, return the instrument for servicing.

### 6.4 PV Over-range or Under-range Indication

If a measured process input value is more than 5% above than the Scaled Input Upper Limit, its value is replaced by the word “**HIGH**” to indicate that it is out of range.

If a measured process input value is more than 5% below than the Scaled Input Lower Limit, its value is replaced by the word “**LOW**” to indicate that it is out of range.

### 6.5 Auxiliary Input Over-range or Under-range Indication

If the auxiliary Remote Setpoint input is more than 5% above than the Auxiliary Input Upper Limit, its value is replaced by the word “**HIGH**” to indicate that it is out of range.

If the auxiliary Remote Setpoint input is more than 5% below than the Auxiliary Input Lower Limit, its value is replaced by the word “**LOW**” to indicate that it is out of range.

## 6.6 Cascade-Open

“**Cascade Open**” is shown on the main screen if the internal link has been severed between cascaded master and slave control loops. This mode should only be used for diagnostics and slave tuning. Close the cascade for proper operation. Refer to the Cascade Control section (page 81) for more information.

## 6.7 Profile Not Valid

If the user attempts to run a profile that would take the setpoint beyond the current setpoint limits, the profile will not run and the message “**Profile Not Valid**” is displayed at the bottom of the profile status screen.

## 6.8 USB Data Transfer Failure message

If the instrument cannot successfully write to the USB memory stick, the message “**Data Transfer Failure**” will be displayed. Check that there is adequate disk space on the memory stick, then retry.

If the instrument cannot successfully read data from the USB memory stick, the message “**Data Transfer Failure**” will also appear. Check that this operation would not cause the maximum number of profiles and/or segments to be exceeded then retry.

## 6.9 Getting Help

### 6.9.1.1 First Level Support

If the errors persist or other problems are encountered, refer your supplier for first level support. This includes help with configuration, tuning, servicing and replacement modules.

### 6.9.1.2 Second Level Support

If your supplier is unable to assist or cannot be contacted, check the Service & Product Information screen on the main menu for details of who to contact.

### 6.9.1.3 Third Level Support

If further assistance is required, contact the nearest company from those listed on the back page of this manual.

### 6.9.1.4 Servicing

If you need to return your instrument for servicing, contact your supplier or check the Service & Product Information screen on the main menu for instructions for its return.

## 7 Application Setup

Before beginning configuration, consider how the controller will be used in your application. For instance, how many control loops are needed, is cascade or ratio control required, will the unit control a valve motor, do you need setpoint profiling etc. Consideration should also be given to the output types, alarms and tuning method.

This section is intended to help with this process, guiding you through the major configuration settings. Additional information can be found in the relevant sections of this manual, including the glossary, configuration menus, and dedicated sections for major features. These are listed in the table of contents.

### 7.1 Pre-commissioning Considerations

An easy Setup Wizard is available for basic applications (*see page 42*) where the most commonly required parameters are present for adjustment in turn. The wizard has a sub-set of the full configuration menu options. For more complex applications where the wizard is not sufficient, consideration must be given to the following fundamental questions:

If fitted, how will the 2nd input be used?

- One loop only (if the 2nd input not fitted or not used in this application)
- Two independent control loops (*see page 49*).
- Valve feedback for loop 1 (*see page 88*).
- A “redundant” backup for the 1st input (*see page 86*).
- Cascaded with the first control loop (*see page 81*).
- A reference input for ratio control (*see page 84*).

How will the instrument physically control the process?

- Primary only or primary & secondary control outputs (*see page 213*).
- Direct valve motor drive outputs (*see page 87*).

The table below shows the main input and control configuration settings for these application types (*see page 45 for the configuration menus*).

| Process Type*<br>(only if 2nd<br>input fitted)                                | Loop 1 / Master                                                |                                                                                                    | Loop 2 / Slave                              |                                           |
|-------------------------------------------------------------------------------|----------------------------------------------------------------|----------------------------------------------------------------------------------------------------|---------------------------------------------|-------------------------------------------|
|                                                                               | Control<br>Configuration:<br>Control Select                    | Control<br>Configuration:<br>Control Type                                                          | Control<br>Configuration:<br>Control Select | Control<br>Configuration:<br>Control Type |
| <b>One Loop*</b><br>Input 2<br>Configuration  <br>Input 2 Usage<br>= Not Used | Standard PID<br>Control Select<br>= Control Standard           | Primary Only<br>Control Type<br>= Single<br>-----<br>Primary / Secondary<br>Control Type<br>= Dual |                                             |                                           |
|                                                                               | Valve Motor Drive<br>Control Select<br>= VMD (TPSC)<br>Control |                                                                                                    |                                             |                                           |

| Process Type*<br>(only if 2nd<br>input fitted)                                                                                                         | Loop 1 / Master                                                       |                                                      | Loop 2 / Slave                                                        |                                                      |
|--------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------|------------------------------------------------------|-----------------------------------------------------------------------|------------------------------------------------------|
|                                                                                                                                                        | Control<br>Configuration:<br>Control Select                           | Control<br>Configuration:<br>Control Type            | Control<br>Configuration:<br>Control Select                           | Control<br>Configuration:<br>Control Type            |
| <b>Two Loops*</b><br>Input 2<br>Configuration  <br>Input 2 Usage<br>= Standard                                                                         | <u>Standard PID</u><br>Control Select<br>= Control Standard           | <u>Primary Only</u><br>Control Type<br>= Single      | <u>Standard PID</u><br>Control Select<br>= Control Standard           | <u>Primary Only</u><br>Control Type<br>= Single      |
|                                                                                                                                                        |                                                                       | <u>Primary / Secondary</u><br>Control Type<br>= Dual |                                                                       | <u>Primary / Secondary</u><br>Control Type<br>= Dual |
|                                                                                                                                                        | <u>Valve Motor Drive</u><br>Control Select<br>= VMD (TPSC)<br>Control |                                                      | <u>Valve Motor Drive</u><br>Control Select<br>= VMD (TPSC)<br>Control |                                                      |
| <b>+Feedback*</b><br>Input 2<br>Configuration  <br>Input 2 Usage<br>= Feedback                                                                         | <u>Valve Motor Drive</u><br>Control Select<br>= VMD (TPSC)<br>Control |                                                      |                                                                       |                                                      |
| <b>Redundant*</b><br>Input 2<br>Configuration  <br>Input 2 Usage<br>= Redundant<br>Input                                                               | <u>Standard PID</u><br>Control Select<br>= Control Standard           | <u>Primary Only</u><br>Control Type<br>= Single      |                                                                       |                                                      |
|                                                                                                                                                        |                                                                       | <u>Primary / Secondary</u><br>Control Type<br>= Dual |                                                                       |                                                      |
|                                                                                                                                                        | <u>Valve Motor Drive</u><br>Control Select<br>= VMD (TPSC)<br>Control |                                                      |                                                                       |                                                      |
| <b>Cascade*</b><br>Input 2<br>Configuration  <br>Input 2 Usage<br>= Standard<br>AND<br>Loop 1 / Master<br>Configuration  <br>Control Mode<br>= Cascade |                                                                       |                                                      | <u>Standard PID</u><br>Control Select<br>= Control Standard           | <u>Primary Only</u><br>Control Type<br>= Single      |
|                                                                                                                                                        |                                                                       |                                                      |                                                                       | <u>Primary / Secondary</u><br>Control Type<br>= Dual |
|                                                                                                                                                        |                                                                       |                                                      | <u>Valve Motor Drive</u><br>Control Select<br>= VMD (TPSC)<br>Control |                                                      |
| <b>Ratio*</b><br>Input 2<br>Configuration  <br>Input 2 Usage<br>= Standard<br>AND<br>Loop 1 / Master<br>Configuration  <br>Control Mode<br>= Ratio     | <u>Standard PID</u><br>Control Select<br>= Control Standard           |                                                      |                                                                       |                                                      |
|                                                                                                                                                        | <u>Valve Motor Drive</u><br>Control Select<br>= VMD (TPSC)<br>Control |                                                      |                                                                       |                                                      |

Which outputs will be used for control, and are alarms or event outputs needed?

- Output configuration (see page 56).
- Alarms & Profile Events (see page

- Alarm Types 210 & 227).

What are the sources for the setpoints?

- Local setpoint(s) only, or a remote setpoint input (see page 218 & 229).
- Profile Control (see page 90).

Is Input re-configuration required?

- Analog input calibration & scaling (see page 74).
- Digital input functions (see page 78).

Which other features are to be used?

- Data Recorder (see page 100).
- Serial Communications (see page 112).
- USB Interface (see page 99).

Once you have an understanding of your application and how the controller will be used, continue on to the configuration and use section below.



**CAUTION:** Configuration & commissioning must be completed before proceeding to Operation Mode. It is the responsibility of the installing engineer to ensure that the configuration is safe.

## 8 Operation and Configuration Menus

This section contains information on all of the controller's modes and the configuration menus.

### 8.1 Operation Mode

This is the mode used during normal operation of the instrument. It can be accessed from the Main Menu, and is the usual mode entered at power-up. The available displays are dependent upon the features/options fitted and the way in which it has been configured.

The Base screen is the usual screen displayed during operation. It provides "at a glance" information about the process. The Profile Status screen shows similar information when using profiles.

Subsequent screens allow the display and selection/adjustment\* of the setpoints. From display configuration, a selection of other parameter screens can be made available for operator selection/adjustment\*. These include: profile control; cascade open/close; auto/manual control; setpoint ramp rate; setpoint source; control enable; clear latched outputs; data recording & status trend views. Optional operator mode screens are marked ■ in the screen lists.

Some screens will persist until the user navigates away, others will 'time-out' back to the base screen.

\* If required, all Operation Mode parameters can be made read only (see Display Configuration on page 62). Otherwise parameters such as setpoints can be adjusted within their configured limits.

#### **WARNING:**

**DURING NORMAL USE, THE USER MUST NOT REMOVE THE CONTROLLER FROM ITS HOUSING OR HAVE UNRESTRICTED ACCESS TO THE REAR TERMINALS, AS THIS WOULD PROVIDE POTENTIAL CONTACT WITH HAZARDOUS LIVE PARTS.**



**CAUTION:** Set all Configuration parameters as required before starting normal operations. It is the responsibility of the installing engineer to ensure that the configuration is safe for the intended application.

#### 8.1.1 Navigating and Adjusting Values in Operator Mode

Press ► to move forward or ◀ to move backwards through the available screens.

When a displayed value can be adjusted, use ▼ or ▲ to change its value.

The next/previous screen follows the last parameter. If no further changes are needed, hold down ► or ◀ for >1sec to skip straight to the next/previous screen accepting ALL values shown.

In Trend Views, pressing ▼ or ▲ moves the cursor line back and forward through the last 240 data points.

## 8.1.2 Operation Mode Screen Sequence

All possible screens are listed below. The sequence shown depends on the configuration and status. E.g. settings for “Loop 2” only apply if 2nd input is fitted and configured for 2-loop control.

■ Some screens are only shown if set to do so in Display Configuration.


After 2 minutes without key activity, the most screens revert to the Base Operating Screen. Screens marked ⌚ do not revert automatically. They remain displayed until the user navigates away.

### ⌚ Calibration Check Due Warning

If a Calibration Reminder is set and the due date has passed this will be shown at every power up, and repeated once per day. Press ➤ to acknowledge and continue using the instrument temporarily without recalibration. Change the due date or disable the reminder to cancel the warning.

This feature is only possible if the recorder is fitted. It is enabled in Input Configuration.

### ⌚ Single Control Loop: Normal Operation



#### 1-LOOP OPERATION

Default LED indicator functions are PRI, SEC, TUNE & ALARM - the functions and their labels can be altered only with the PC configuration software.

In valve motor drive mode, the power bar-graph is replaced by valve **Open / Stop / Close** unless the 2<sup>nd</sup> input is used for position feedback, where it shows **0 to 100%** valve position.

In manual mode the effective setpoint is replaced by the **%Manual Power** and the label “MAN”.

In manual mode with valve motor drive the setpoint is replaced by valve **Open / Stop / Close**.

If control is disabled the effective setpoint value is replaced by “OFF”.

### ⌚ Two Control Loops: Normal Operation



#### 2-LOOP OPERATION

Default LED indicator functions are PRI 1, PRI 2, TUNE & ALARM - the functions and their labels can be altered only with the PC configuration software.


In valve motor drive mode, the power bar-graph is replaced by valve **Open / Stop / Close**.

In manual mode the effective setpoints are replaced by the **%Manual Power** and the label “MAN”.


In manual mode with valve motor drive the setpoint is replaced by valve **Open / Stop / Close**.

If control is disabled the effective setpoint value of that loop is replaced by “OFF”.

|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |  |  |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|--|
| <div><div><div><div><div><div></div><div></div><div></div><div></div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div><div></div></div></div></div></div> |  |  |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|--|

| Two Control Loops: Profiler Status                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p><b>LED Indicators</b></p> <p><b>Profile Status Indicators*:</b></p> <p>▶ Run,    Held, ■ Stopped</p> <p><b>Loop Descriptions*</b></p> <p><i>* = in loop 1 &amp; 2 screen area</i></p>                                                                                                                                                                                                                                                                                                                                                                                           |  <p><b>LED Function Labels Engineering Units*</b></p> <p><b>Process Variable Values &amp; Setpoints*</b></p> <p><b>Profile Name &amp; Progress Segment No. Type &amp; Progress (or Delayed Start Time)</b></p> <p><b>2-LOOP PROFILE STATUS</b></p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
| <p>Default LED indicator functions are as shown in the initial base screen.</p> <p>In manual mode the effective setpoints are replaced by the %<b>Manual Power</b> and the label “<b>MAN</b>”.</p> <p>In manual mode with valve motor drive the setpoints are replaced by valve <b>Open / Stop / Close</b>.</p> <p> <b>Note:</b> If power is lost when a profile is running and recovery is set to continue, the bar-graph re-starts from the beginning but the overall time remains correct.</p> |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| <b>Event Status</b>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                | Lists all configured profile events with their current status (Active or Inactive) – <i>Shown only when the instrument is in profiler mode.</i>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
| <b>Cascade Mode</b>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                | Allows the user to open the cascade, breaking the master-slave link for commissioning & tuning.<br><b>CAUTION: Return to Cascade-CLOSE when finished!</b><br>■ <i>only shown if set to do so in Display Configuration.</i>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |
| <b>Auto/Manual Control Selection – Loop 1 (or Cascade Slave)</b>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   | <p>Switches loop 1 (or the cascade slave loop) between automatic and manual control modes. Switching between these modes uses “Bumpless Transfer”.</p> <p>■ <i>only shown if set to do so in Display Configuration.</i></p> <p>When using standard PID control, Manual mode replaces the Setpoint display with a -100 to 100% power output level value, labelled “<b>Man</b>”.</p> <p>The ▼ or ▲ keys are used to adjust the manual power value.</p> <p>When using VMD control, Manual mode replaces the Setpoint display with the valve movement status (<b>Opening, Closing or Stopped</b>), labelled “<b>Man</b>”.</p> <p>The ▼ key opens the valve and the ▲ key closes the valve.</p> <p>If Manual control is selected when in Cascade mode, the slave loops % power value shown. This is the power output fed directly to the control actuator (e.g. power to the heater elements).</p> <p><b>CAUTION: Manual mode overrides the automatic control loop. It also ignores any output power limits, valve open/close limits and the control enable/disable setting. The operator is responsible for maintaining the process within safe limits.</b></p> <p> <b>Note:</b> In Manual mode a running profile will hold until automatic control is reselected.</p> |
| <b>Setpoint Value Display &amp; Adjustment – Loop 1</b>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            | View and adjust the main and alternate setpoints for loop 1 (or the master loop in cascade mode). The setpoints can be set to any value within the setpoint limits set in Control Configuration. View and adjust local (internal) setpoints for the loop. The currently selected setpoint is marked as “active”. <i>If the alternate setpoint is remote it cannot be adjusted from the keypad.</i>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |
| <b>Setpoint Ramp Rate – Loop 1</b>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 | <p>The setpoint ramp rate adjustment for loop 1. Adjustable between 0.1 and 9999.0 display units per hour. When set to “OFF”, setpoint changes will step immediately to the new value - ■ <i>only shown if set to do so in Display.</i></p> <p> <b>Note:</b> If the setpoint ramp feature is used, it disables pre-tune completely, and if self-tune is used, it will only calculate new terms after the ramp has completed and the setpoint is constant.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |
| <b>Select Active Setpoint – Loop 1</b>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             | Select if the main or alternate setpoint is to be the “active” setpoint for loop 1 (or the master loop in cascade mode). ■ <i>only shown if set to do so in Display.</i>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |

|                                                         |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |
|---------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Control Enable – Loop 1</b>                          | <p>Enables or disables loop 1 control outputs. When disabled, the primary and secondary control outputs of loop 1 are set to zero 0% (unless manual mode has been selected) and the setpoint value is replaced by “OFF”.</p> <p>■ only shown if set to do so in Display.</p> <p><b>CAUTION:</b> The instrument cannot control the process when disabled.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |
| <b>Auto/Manual Control Selection – Loop 2</b>           | <p>Switches loop 2 between automatic and manual control modes. Switching between these modes uses “Bumpless Transfer”.</p> <p>■ only shown if set to do so in Display Configuration.</p> <p>When using standard PID control, Manual mode replaces the Setpoint display with a -100 to 100% power output level value, labelled “Man”.</p> <p>The ▼ or ▲ keys are used to adjust the manual power value.</p> <p>When using VMD control, Manual mode replaces the Setpoint display with the valve movement status (<b>Opening, Closing or Stopped</b>), labelled “Man”.</p> <p>The ▼ key opens the valve and the ▲ key closes the valve.</p> <p><b>CAUTION:</b> Manual mode overrides the automatic control loop. It also ignores any output power limits, valve open/close limits and the control enable/disable setting. The operator is responsible for maintaining the process within safe limits.</p> <p> <b>Note:</b> In manual mode a running profile will hold if it is controlling the setpoint of loop 2, until automatic control is reselected.</p> |
| <b>Setpoint Value Display &amp; Adjustment – Loop 2</b> | <p>View and adjust the main and alternate setpoints for loop 2. The setpoints can be set to any value within the setpoint limits set in Control Configuration. View and adjust local (internal) setpoints for the loop. The currently selected setpoint is marked as “active”.</p> <p><i>If the alternate setpoint is remote it cannot be adjusted from the keypad.</i></p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
| <b>Setpoint Ramp Rate – Loop 2</b>                      | <p>The setpoint ramp rate adjustment for loop 2. Adjustable between 0.1 and 9999.0 display units per hour. When set to “OFF”, setpoint changes will step immediately to the new value - ■ only shown if set to do so in Display.</p> <p> <b>Note:</b> If the setpoint ramp feature is used, it disables pre-tune completely, and if self-tune is used, it will only calculate new terms after the ramp has completed and the setpoint is constant.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |
| <b>Select Active Setpoint – Loop 2</b>                  | <p>Select if the main or alternate setpoint is to be the “active” setpoint for loop 2 (or the master loop in cascade mode). ■ only shown if set to do so in Display.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
| <b>Control Enable – Loop 2</b>                          | <p>Enables or disables loop 2 control outputs. When disabled, the primary and secondary control outputs of loop 2 are set to zero 0% (unless manual mode has been selected) and the setpoint value is replaced by “OFF”.</p> <p>■ only shown if set to do so in Display Configuration.</p> <p><b>CAUTION:</b> The instrument cannot control the process when disabled.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |
| <b>Alarm Status</b>                                     | <p>Lists the status of the alarms. Shown if any of the 7 alarms is active.</p> <p><i>The titles “Alarm n” can be replaced with the PC configuration software to a user defined 8 character name for each alarm.</i></p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |
| <b>Clear Latched Outputs</b>                            | <p>Hold down ▼ or ▲ for <u>3 seconds</u> to clear the selected latched output – An output will only reset if the condition that caused it to latch on is no-longer present.</p> <p>■ only shown if set to do so in Display Configuration.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |
| <b>Recorder Memory Full Warning</b>                     | <p>Indicates that the Data Recorder memory is full and that recording has either stopped or is overwriting older data if in FIFO recording mode.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         |
| <b>Manual Recording Trigger</b>                         | <p>Set the manual recording trigger on or off.</p> <p>■ only shown if set to do so in Display Configuration.</p> <p> <b>Note:</b> Setting the manual trigger to off may not stop the recording. Data recording will still take place if another recording trigger is active.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          |

|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Recorder Status Information</b>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         | <p>Shows the recording status (“Stopped” or “Recording”); icons for any active recording triggers; the recording mode (FIFO or Record Until Memory Is Used); the approximate recording time remaining* and a memory usage bar-graph. In FIFO mode, the time remaining is replaced with “FIFO” when full.</p> <p><i>*If the status of alarms is recorded, extra samples are taken when the alarms change state reducing the available recording time. Take this into account when determining if there is sufficient memory available.</i></p> <div style="text-align: center;"> <b>Icons for Active Recorder Triggers</b> </div> <div style="display: flex; justify-content: space-around; align-items: center;"> <div style="text-align: center;"> <br/> <b>Manual<br/>Record ON</b> </div> <div style="text-align: center;"> <br/> <b>Digital Input<br/>Record ON</b> </div> <div style="text-align: center;"> <br/> <b>Profile<br/>Record ON</b> </div> <div style="text-align: center;"> <br/> <b>Alarm<br/>Record ON</b> </div> </div> |
| <div style="text-align: center;">  <b>Trend Views: One per Control Loop</b> </div> <div style="display: flex; justify-content: space-between;"> <div style="width: 30%;"> <p><b>Active Alarm(s)</b></p> <p><b>Process Variable Trend</b></p> <p><b>Setpoint Trend (dotted)</b></p> <p><b>Loop No, &amp; Time Markers<br/>(10 samples per marker)</b></p> </div> <div style="width: 40%; text-align: center;">  </div> <div style="width: 30%;"> <p><b>Trend Upper Scale Value<br/>Cursor Line</b></p> <p><b>PV Value At Cursor Line</b></p> <p><b>Trend Lower Scale Value</b></p> <p><b>Sample Interval (or time at<br/>cursor line)</b></p> </div> </div> <p style="text-align: center;"><b>TREND VIEW</b></p> <p>Trend views can be shown of each loop. They are auto-scaling graphs with alarm indication and other process information. The trend can be set to show the process variable only; the process variable &amp; setpoint (dotted line), or the minimum and maximum value of the process variable measured since the last sample. Any active alarm(s) are indicated above the graph.</p> <p>Graph types and data sample intervals (1 sec to 30 mins) are set in Display Configuration.</p> <p>Trend scale values adjust automatically to visible data (between 2 to 100% of the input span). 120 data points are visible. Pressing ▼ or ▲ moves the cursor line back through the graph to examine up to 240 data points. The process variable value of that data point is shown to the right of the cursor line and the sample rate value is replaced by the time represented by the cursor position.</p> <p><span style="color: blue;">■ only shown if set to do so in Display Configuration.</span></p> |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
| <div style="display: flex; align-items: center;"> <div style="width: 50px; text-align: center;">  </div> <div> <p><b>Note:</b> Trend data is not retained at power down or if the sample interval is changed.</p> </div> </div>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
| <b>- Custom Display Screens</b>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            | <p>You can copy up to 50 configuration menu parameters into normal operation mode using the PC software. These extended operator mode screens appear at the end of the normal sequence. If the parameter is normally displayed on screen with another parameter, both parameters will appear.</p> <div style="display: flex; align-items: center;"> <div style="width: 50px; text-align: center;">  </div> <div> <p><b>Note:</b> In this mode screens are <u>not pass-code protected</u>, they can be freely adjust. It is possible to make operation mode “read only”, including any custom screens from Display Configuration.</p> </div> </div>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |

## 8.2 Main Menu

This menu is used to access the various features and configuration settings. The available menus are dependent upon the features and options fitted and how it has been configured.

### 8.2.1 Entry into the Main Menu

Holding down ➤ and pressing ▲ from Operation Mode and most other screens will cause the unit to enter the Main Menu. Each time this key press sequence is made, the instrument moves to the next menu level above. Sub-menu levels will require this sequence to be pressed more than once in order to reach the Main Menu.

### 8.2.1.1 Navigating the Main Menu

Once in the Main Menu, press ▼ or ▲ to select the required option

Press ► to enter the chosen menu.

Scrolling “Help Text” is shown at the bottom of the screens to aid navigation.

### 8.2.2 Unlock Codes

To prevent unauthorised entry, most menus require a pass-code (1 to 9999) to gain entry. These menus are indicated by the symbol . The codes can be viewed and changed from the Lock Code Configuration sub-menu of Configuration Mode. The factory default unlock code is 10 for all modes but for security, these should be changed to new values. If the Configuration Mode lock code is lost, refer to Lost Lock Codes on page 73.

| MAIN MENU OPTIONS             |                                                                                                                                                                                                                                                                                                     |
|-------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Operation Mode                | The normal operation screens, displaying the process and setpoint values; selection/adjustment of the setpoints; auto/manual control; alarm/event status; trend views; data recorder and profile information.                                                                                       |
| Setup Wizard                  |  An easy, step-by-step parameter setup for simple applications.                                                                                                                                                    |
| Supervisor Mode               |  If configured from the PC software, a sub-set of up to 50 Configuration screens can be accessed.                                                                                                                  |
| Configuration Menu            |  Accesses the sub-menus for Inputs; Control Loops; Outputs; Alarms; Communications; Recorder; Clock; Display and Lock Codes. There is an option to Reset to Defaults wiping all user settings from the instrument. |
| Automatic Tuning              |  Selection of Pre-tune, Self-tune and Auto Pre-tune for the control loops.                                                                                                                                        |
| USB Menu                      |  Uploading/downloading instrument configuration, profile information and data recordings.                                                                                                                        |
| Recorder Control              |  Manually starting, stopping and deleting recordings.                                                                                                                                                            |
| Profile Setup                 |  Setting global parameters for all profiles; plus profile creation, editing and deletion.                                                                                                                        |
| Profile Control               |  Selection of profiles. Running, holding or aborting the selected profile.                                                                                                                                       |
| Service & Product Information | Contact information for service/support, followed by instrument information, including features and plug-in modules installed, serial number, firmware version etc.                                                                                                                                 |

## 8.3 Setup Wizard

An easy Setup Wizard runs automatically at first ever power-up. Follow the Wizard to setup parameters required for basic applications. The parameters covered by the Setup Wizard are marked with a **w** in the following sections covering the configuration mode sub-menus. Once completed, the Setup Wizard exits to Operation Mode.

The Wizard can be run again at any time from the Main Menu. An option to reset all parameters to default (*recommended*) is offered when manually running the wizard.



**CAUTION:** Resetting defaults all parameters, not just those covered by the quick setup wizard. For more complex applications the user may have to reconfigure other Configuration Menu settings before using the instrument.

Experts or users with more complex applications can select the parameters they wish to set-up directly from the Configuration Menus bypassing the Wizard.

### 8.3.1 Manual entry to the Setup Wizard

To select the Setup Wizard from the Main Menu.

Hold down ➤ and press ▲ to enter the Main Menu.

Press ▼ or ▲ to select Setup Wizard.



**Note:** With the exception of the first ever power-up, entry into this mode is security-protected by the Setup Wizard Lock Code. Refer to the Lock Code Configuration sub-menu.

Press ➤ to enter the Setup Wizard.

#### 8.3.1.1 Navigating in the Setup Wizard

Press ➤ to move forward, or ◀ to move backwards through the screens.

Press ▼ or ▲ to change the value as required.

Holding down ➤ or ◀ for more than 1 second skips immediately to the next/previous screen accepting **ALL** values as shown.

Hold down ➤ and press ▲ to return to the Main Menu

Scrolling “Help Text” is shown at the bottom of the screens to aid navigation.

| 🔒 SETUP WIZARD SCREENS                                 |   |                                                                                                             |
|--------------------------------------------------------|---|-------------------------------------------------------------------------------------------------------------|
| Setup Wizard Unlocking                                 | w | Enter correct code number to access Setup Wizard.<br><i>Factory Default value is 10.</i>                    |
| - key screens from Configuration Menu (those marked w) | w | Press ➤ to select each major configuration parameter in turn. Follow on-screen prompts to alter the values. |
| Setup Wizard Completed                                 | w | Confirms completion of the Setup Wizard. Exits to Operation Mode.                                           |

## 8.4 Supervisor Mode

This mode is only available if it has been configured from the PC software. Its purpose is to allow selected operators access to a lock-code protected sub-set of the configuration parameters, without providing them with the higher level configuration menu unlock code.

The PC software can copy up to 50 parameters from configuration menus for inclusion in the supervisor mode screen sequence. If the parameter is normally displayed on screen with another parameter, both parameters will appear. It is not possible to configure supervisor mode screens without using the software.

### 8.4.1 Entry into Supervisor Mode



**CAUTION:** Adjustments to these parameters should only be performed by personnel competent and authorised to do so.

Supervisor Mode is entered from the Main Menu

Hold down ➤ and press ▲ to enter the Main Menu.

Press ▼ or ▲ to select Supervisor Mode

Press ➤ to enter the Supervisor Mode.



**Note:** Entry into this mode is security-protected by the Supervisor Mode Lock Code. Refer to the Lock Code Configuration sub-menu.

#### 8.4.1.1 Navigating in Supervisor Mode

Press ➤ to move forward, or ◀ to move backwards through the screens.

Press ▼ or ▲ to change the value as required.

The next/previous screen follows the last parameter. If no further changes are required, hold down ➤ or ◀ >1sec to skip straight to next/previous screen accepting **ALL** values shown.

Hold down ➤ and press ▲ to return to the Main Menu

Scrolling “Help Text” is shown at the bottom of the screens to aid navigation.

| 🔒 SUPERVISOR MODE SCREENS     |                                                                                                                 |
|-------------------------------|-----------------------------------------------------------------------------------------------------------------|
| Supervisor Mode Unlocking     | If Supervisor Mode is configured, enter correct code number to continue.<br><i>Factory Default value is 10.</i> |
| - Supervisor Mode Screens ... | Press ➤ to select each selected parameter in turn. Follow on-screen prompts to alter the values.                |

## 8.5 Configuration Menu

This menu can be used as an alternative to the more limited Setup Wizard when the instrument is configured for the first time in more complex applications, or when further changes are required to the instruments settings. The configuration menu contains a number of sub-menus that allow access to all of the available parameters. The correct settings must be made before attempting to use the instrument in an application. Screens marked **w** are also shown in the Setup Wizard.

### 8.5.1 Entry into the Configuration Menu



**CAUTION:** Adjustments to these parameters should only be performed by personnel competent and authorised to do so.

Configuration is entered from the Main Menu

Hold down **➤** and press **▲** to enter the Main Menu.

Press **▼** or **▲** to select Configuration Menu



**Note:** Entry into this mode is security-protected by the Configuration Menu Lock Code. Refer to the Unlock Code section for more details.

Press **➤** to enter the Configuration Menu.

#### 8.5.1.1 Navigating the Configuration Menu

Configuration contains sub-menus to set-up the Inputs; Control; Outputs; Alarms; Communications; Recorder; Clock; Display and Lock Codes.

There is also an option to reset the instrument to its factory default settings.

The Input and Control sub-menus contain further sub-menus with configuration and calibration settings for each process input; control loops 1 & 2 and the digital inputs. Only parameters that are applicable to the hardware and options fitted will be displayed.

From the Configuration Menu, press **▼** or **▲** to select the required sub-menu.

Press **➤** to enter the sub-menu.

If required, press **▼** or **▲** to select the next level sub-menu, then press **➤** to enter.

Hold down **➤** and press **▲** to return to next higher menu level.

Scrolling “Help Text” is shown at the bottom of the screens to aid navigation.

| 🔒 CONFIGURATION MENU SCREENS: |                                                                                                                                                                    |
|-------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Configuration Mode Unlocking  | Enter correct code number to access Configuration Mode.<br><i>Factory Default value is 10.</i>                                                                     |
| Configuration Options         | Select the required Configuration Sub-Menu Option from: Inputs; Control; Outputs; Alarm; Communications; Recorder; Clock; Display; Lock Code or Reset To Defaults. |

## INPUT CONFIGURATION SUB-MENU SCREENS

**Input 1 Setup** - Sub-menu to setup Input 1. Press  +  to return to Input Menu

|                            |                                                                                   |                                                                                                                                                                                                                                                                                                            |
|----------------------------|-----------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Input Type                 | w                                                                                 | Select from various Thermocouple, RTD and Linear mA, mV or VDC inputs. - see <i>specifications section on page 246</i> , for available input types.                                                                                                                                                        |
|                            |  | <b>Note:</b> Recheck the units and decimal point settings if you change the input type.                                                                                                                                                                                                                    |
| Engineering Units          | w                                                                                 | Select display units from: °C; °F; °K; bar; %; %RH; pH; psi or none. <i>Temperature sensor inputs are limited to °C; °F</i>                                                                                                                                                                                |
| Decimal Point Position     | w                                                                                 | Sets the maximum display resolution to 0; 1; 2 or 3 decimal places. Numbers >99.999 never display more than 2 dec places, >999.99 never display more than 1 dec place and >99999 always display without a decimal place. <i>Temperature inputs are limited to 0 or 1 decimal place.</i>                    |
| Scaled Input Lower Limit   |                                                                                   | For temperature inputs, upper & lower limits set the usable span. The minimum span = 100 units, maximum span = range limits for the sensor type selected - see <i>specs on page 246</i> .                                                                                                                  |
| Scaled Input Upper Limit   |                                                                                   | For DC linear inputs, the limits define the values shown (-9999 to 9999.9) when input is at minimum and maximum values. Min span = 100 units.                                                                                                                                                              |
| Multi-Point Scaling Enable |                                                                                   | Enables or disables multi-point scaling. This allows up to 15 point input linearization for DC signals - <i>not possible with temperature sensor inputs</i>                                                                                                                                                |
| Scaling Point <i>n</i>     |                                                                                   | If multi-point scaling is enabled, up to 15 breakpoints* can scale input vs. displayed values between the scaled input limits. Each breakpoint has a % value for the input signal, and the value to display when the input is at that value. *A Scaling Point set to 100% input ends the scaling sequence. |
| Display Value <i>n</i>     |                                                                                   |                                                                                                                                                                                                                                                                                                            |
| CJC Enable/Disable         |                                                                                   | Enables/disables internal thermocouple Cold Junction Compensation. If disabled, external compensation will be required for thermocouples. The default value is Enabled.                                                                                                                                    |
| Input Filter Time          |                                                                                   | Removes unwanted signal noise. Adjustable from 0.1 to 100.0 seconds or OFF (default = 2s). Use the smallest value that gives acceptable results.<br><b>Caution:</b> Large values slow the response to changes in the process.                                                                              |

**Input 1 Calibration** - Sub-menu to calibrate Input 1. Press  +  to return to Input Menu

|                         |  |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
|-------------------------|--|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Calibration Type        |  | Select the calibration type from base; single or 2-point calibration. Select single to apply a calibration offset across the entire measured range. Use 2-point to enter calibration offsets at both low and high points of the usable range – refer to the <i>User Calibration details on page 74</i> .<br><b>Caution:</b> The default is Base Calibration. For single or 2-point calibration, the user must enter values to adjust the displayed value to match a known standard or accurate external reading. |
| Calibration Offset      |  | The single point calibration offset. Limited by the input span, +Ve values add to, –Ve values subtract from, the measured input across <u>entire</u> range.                                                                                                                                                                                                                                                                                                                                                      |
| Calibration Low Value   |  | The displayed value for the 1 <sup>st</sup> (low) adjustment of 2-point calibration. Choose a value close to the lowest level used in the application.                                                                                                                                                                                                                                                                                                                                                           |
| Calibration Low Offset  |  | The adjustment value for the 1 <sup>st</sup> (low) point when using 2-point calibration. +Ve values add to, –Ve values subtract from measured input at this point.                                                                                                                                                                                                                                                                                                                                               |
| Calibration High Value  |  | The displayed value for the 2 <sup>nd</sup> (high) adjustment of 2 point calibration. Choose a value close to the highest level used in the application.                                                                                                                                                                                                                                                                                                                                                         |
| Calibration High Offset |  | The adjustment value for the 2 <sup>nd</sup> (high) point when using 2-point calibration. +Ve values add to, –Ve values subtract from measured input at this point.                                                                                                                                                                                                                                                                                                                                              |

| Input 2 Setup - Sub-menu to setup Input 2. Press ▼ + ► to return to Input Menu |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
|--------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Input 2 Usage                                                                  | w Input 2 can be used as a standard process input for a second control loop (including its use as part of a cascade), a redundant input or a feedback signal input from a valve or flow meter. Redundant or Feedback disables the input as an independent control loop.                                                                                                                                                                                                                                                                                          |
| Input Type                                                                     | w If input 2 is selected as a standard process input, select from various Thermocouple, RTD and Linear mA, mV or VDC inputs. - see specifications section on page 246, for available input types.<br>If input 2 is selected as feedback possible types are limited to Linear mA, mV, VDC or Potentiometer.<br>Redundant inputs automatically assume the same input type as input 1.<br> <b>Note:</b> Recheck the units and decimal point settings if you change the input type. |
| Engineering Units                                                              | w Select display units from: °C; °F; °K; bar; %; %RH; pH; psi or none. Temperature sensor inputs are limited to °C; °F                                                                                                                                                                                                                                                                                                                                                                                                                                           |
| Decimal Point Position                                                         | w Sets the maximum display resolution to 0; 1; 2 or 3 decimal places. Numbers >99.999 never display more than 2 dec places, >999.99 never display more than 1 dec place and >99999 always display without a decimal place. Temperature inputs are limited to 0 or 1 decimal place.                                                                                                                                                                                                                                                                               |
| Scaled Input Lower Limit                                                       | For temperature inputs, upper & lower limits set the usable span. The minimum span = 100 units, maximum span = range limits for the sensor type selected - see specs on page 246.<br>For DC linear inputs, the limits define the values shown (-9999 to 9999.9) when input is at minimum and maximum values. Min span = 100 units.                                                                                                                                                                                                                               |
| Scaled Input Upper Limit                                                       |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
| Multi-Point Scaling Enable                                                     | Enables or disables multi-point scaling. This allows up to 15 point input linearization for DC signals - not possible with temperature sensor inputs                                                                                                                                                                                                                                                                                                                                                                                                             |
| Scaling Point <i>n</i>                                                         | If multi-point scaling is enabled, up to 15 breakpoints* can scale input vs. displayed values between the scaled input limits. Each breakpoint has a % value for the input signal, and the value to display when the input is at that value. *A Scaling Point set to 100% input ends the scaling sequence.                                                                                                                                                                                                                                                       |
| Display Value <i>n</i>                                                         |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
| CJC Enable/Disable                                                             | Enables/disables internal thermocouple Cold Junction Compensation. If disabled, external compensation will be required for thermocouples. The default value is Enabled.                                                                                                                                                                                                                                                                                                                                                                                          |
| Input Filter Time                                                              | Removes unwanted signal noise. Adjustable from 0.1 to 100.0 seconds or OFF (default = 2s). Use the smallest value that gives acceptable results.<br><b>Caution:</b> Large values slow the response to changes in the process.                                                                                                                                                                                                                                                                                                                                    |
| Set Valve Lower Position                                                       | If input 2 is selected as feedback indication, this stores the feedback value equal to the minimum valve travel. The procedure below moves the valve to the fully closed position to find the feedback value:<br>Press ▼ and ▲ simultaneously to begin feedback limit adjustment.<br>Press ▼ until the valve is closed to its limit of its travel.<br>Press ▼ and ▲ simultaneously to store the feedback level.                                                                                                                                                  |
| Set Valve Upper Position                                                       | If input 2 is selected as feedback indication, this stores the feedback value equal to the maximum valve travel. The procedure below moves the valve to the fully open position to find the feedback value:<br>Press ▼ and ▲ simultaneously to begin feedback limit adjustment.<br>Press ▲ until the valve is opened to its limit of its travel.<br>Press ▼ and ▲ simultaneously to store the feedback level.                                                                                                                                                    |

| Input 2 Calibration - Sub-menu to calibrate Input 2. Press ▼ + ► to return to Input Menu |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |
|------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Calibration Type                                                                         | <p>If input 2 is selected as a standard process input, the user can select the calibration type from base; single or 2-point calibration. Select single to apply a calibration offset across the entire measured range. Use 2-point to enter calibration offsets at both low and high points of the usable range – refer to the User Calibration details on page 74.</p> <p><b>Caution:</b> The default is Base Calibration. For single or 2-point calibration, the user must enter values to adjust the displayed value to match a known standard or accurate external reading.</p> |
| Calibration Offset                                                                       | The single point calibration offset. Limited by the input span, +Ve values add to, –Ve values subtract from measured input across the range.                                                                                                                                                                                                                                                                                                                                                                                                                                         |
| Calibration Low Value                                                                    | The displayed value for the 1 <sup>st</sup> (low) adjustment of 2-point calibration. Choose a value close to the lowest level used in the application.                                                                                                                                                                                                                                                                                                                                                                                                                               |
| Calibration Low Offset                                                                   | The adjustment value for the 1 <sup>st</sup> (low) point when using 2-point calibration. +Ve values add to, –Ve values subtract from measured input at this point.                                                                                                                                                                                                                                                                                                                                                                                                                   |
| Calibration High Value                                                                   | The displayed value for the 2 <sup>nd</sup> (high) adjustment of 2 point calibration. Choose a value close to the highest level used in the application.                                                                                                                                                                                                                                                                                                                                                                                                                             |
| Calibration High Offset                                                                  | The adjustment value for the 2 <sup>nd</sup> (high) point when using 2-point calibration. +Ve values add to, –Ve values subtract from measured input at this point.                                                                                                                                                                                                                                                                                                                                                                                                                  |

| Calibration Reminder - Calibration reminder Sub-menu. Press ▼ + ► to return to Input Menu |                                                                                                                                        |
|-------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|
| Calibration Reminder Enable/Disable                                                       | Enables/disables the Calibration Reminder shown at start-up (and daily thereafter), if the due date has passed - Recorder version only |
| Calibration Reminder Date                                                                 | Sets the due date for Calibration Reminder - Recorder version only                                                                     |

| Auxiliary Input A Setup - Sub-menu to setup auxiliary A input. Press ▼ + ► to return to Input Menu |                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |
|----------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Auxiliary Input A Type                                                                             | The analog input type/range to be applied to auxiliary input A. Select the type from 0-20 or 4-20mA; 0-5, 1-5, 0-10 or 2-10VDC.                                                                                                                                                                                                                                                                                                                                               |
| Aux A Input Lower Limit                                                                            | <p>These scale values relate to when auxiliary input A is at the range minimum &amp; maximum values. They are adjustable between <math>\pm 0.001</math> &amp; <math>\pm 10000</math>. When auxiliary input A provides a remote setpoint, the scaled input becomes the effective setpoint (although always constrained within setpoint limits).</p> <p><b>Caution:</b> Take care to scale correctly especially if being used as the remote setpoint source for both loops.</p> |
| Aux A Input Upper Limit                                                                            |                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |
| Auxiliary Input A Offset                                                                           | An offset applied to the scaled auxiliary input A value. Adjustable, from +/- 0.001 to 20000 units or OFF, with. +Ve values add, –Ve values subtracted. Useful in multi-zone setpoint slave applications. Default = OFF.                                                                                                                                                                                                                                                      |

| Digital Input Setup - Sub-menu to setup the Digital Inputs. Press ▼ + ► to return to Input Menu |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |        |          |          |          |          |          |          |
|-------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|----------|----------|----------|----------|----------|----------|
| Digital Input Status                                                                            | A diagnostic status (☐ = OFF, ☑ = ON, Ø = not available) for digital inputs A; C1 to C8 and “Soft “digital inputs S1 to S4. If used for profile selection, it also shows bit pattern type (binary or BCD) and selected profile number.                                                                                                                                                                                                                                                           |        |          |          |          |          |          |          |
| Tick Digital Inputs To Invert                                                                   | Select digitals input with ☑ to invert their operation (making them appear OFF when their actual state is ON). Inputs shown as Ø are not available.                                                                                                                                                                                                                                                                                                                                              |        |          |          |          |          |          |          |
| Profile Selection Type                                                                          | Select the bit pattern to be used for profile selection. Binary or BCD ( <i>Binary Coded Decimal</i> ). Select None if profile selection not is required.                                                                                                                                                                                                                                                                                                                                        |        |          |          |          |          |          |          |
| Choose Profile Selection                                                                        | For profiler versions, the Multi-Digital Input option can be used to select the profile to run with a standard binary bit pattern or binary coded decimal from BCD switches. C1 is the least significant bit (LSB) of the bit pattern. Profiles are numbered from 0 to 63.                                                                                                                                                                                                                       |        |          |          |          |          |          |          |
|                                                                                                 | Use the table to choose inputs C1 to Cn for the number of profiles to select:                                                                                                                                                                                                                                                                                                                                                                                                                    |        |          |          |          |          |          |          |
|                                                                                                 |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  | C1     | C1 to C2 | C1 to C3 | C1 to C4 | C1 to C5 | C1 to C6 | C1 to C7 |
|                                                                                                 | Binary                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           | 0 to 1 | 0 to 3   | 0 to 7   | 0 to 15  | 0 to 31  | 0 to 63  |          |
|                                                                                                 | BCD                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              | 0 to 1 | 0 to 3   | 0 to 7   | 0 to 9   | 0 to 19  | 0 to 39  | 0 to 63  |
|                                                                                                 | Any inputs chosen for profile selection are not available for other uses.<br>– refer to the <i>Digital Inputs</i> on page 78.                                                                                                                                                                                                                                                                                                                                                                    |        |          |          |          |          |          |          |
| Configure Digital Inputs                                                                        | Select any available digital input or soft digital input to be configured for use. The current status of each is shown as Assigned or Unused.                                                                                                                                                                                                                                                                                                                                                    |        |          |          |          |          |          |          |
| Soft Digital Input <i>n</i> Digital Input Logic                                                 | Set up a “Soft” digital input <i>n</i> that is the result of the Boolean AND selections of physical inputs, globally OR’d with the OR selections. Press ▲ or ▼ to select ☑ / deselect ☐ the options. Inputs shown as Ø are not available – refer to the <i>Digital Inputs</i> on page 78.                                                                                                                                                                                                        |        |          |          |          |          |          |          |
| Soft Digital Input <i>n</i> Alarm-Event                                                         | Further set up of “Soft” digital input <i>n</i> that adds the Boolean OR of Alarms & Events to the physical digital inputs already selected. Press ▲ or ▼ to select ☑ / deselect ☐ the options. Inputs shown as Ø are not available – refer to the <i>Digital Inputs</i> on page 78.                                                                                                                                                                                                             |        |          |          |          |          |          |          |
| Digital Input <i>n</i> Function                                                                 | Select the function to be operated from digital input <i>n</i> . – The possible functions are:<br>Loop 1 or 2 Setpoint Select; Loop 1 or 2 Auto/Manual Select; Loop 1 or 2 Control Select; Loop 1 or 2 Pre-Tune Select; Loop 1 or 2 Self-Tune Select<br>Clear All Latched Outputs; Output <i>n</i> Clear Latch; Output <i>n</i> Forcing On or Off; Profile Run/Hold; Profile Hold Segment Release; Profile Abort; Data Recorder Trigger or Key <i>n</i> Mimic (replicating pressing ◀ ▼ ▲ or ►). |        |          |          |          |          |          |          |

### CONTROL CONFIGURATION SUB-MENU SCREENS

| Control Loop 1 - Sub-menu to setup Control Loop 1. Press ▼ + ► to return to Input Menu        |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |
|-----------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| These settings apply to the master loop if the controller has been setup for cascade control. |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |
| Control Mode                                                                                  | <p>Select the fundamental application type, from: Standard; Cascade or Ratio. Refer to the <i>Application Setup</i> section on page 33.</p> <div>  <p><b>Notes:</b></p> <ol style="list-style-type: none"> <li>1. Choosing Cascade or Ratio disables the use of the 2nd input as a fully independent control loop.</li> <li>2. If you change the Control Mode while recording, the recorder will automatically stop, and the Items To Be Recorded are all turned off (nothing is selected for recording) so immediately recommencing recording will not record any items. To overcome this, the user must re-configure the Items To Be Recorded and restart the recording.</li> </ol> </div> |
| Cascade Mode                                                                                  | <p>Opens or closes the cascade link. Cascade-Open breaks the master-slave connection. This allows slave loop to be tuned &amp; adjusted independently.</p> <p><b>Caution: Return to Cascade when finished!</b></p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |

|                               |                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
|-------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Control Select                | Select from Control Standard or Control VMD (TPSC).<br>Use Control VMD to directly drive the windings of a motorised valve. This uses a 3-point stepping algorithm giving “open” and “close” outputs.<br>Use Standard for all other applications (including solenoid valves or modulating valves with positioning circuitry requiring mA or VDC signals).                                                                                        |
| Control Enable/Disable        | Used to temporarily disable the control outputs. Select control Enabled (normal) or Disabled – when disabled, control output(s) for this loop are turned off (unless manual mode has been selected), and the setpoint value is replaced by “OFF”.<br><b>Caution:</b> The instrument is not able to control the process when control is disabled and the Output Power Limits are ignored.                                                         |
| Auto/Manual Control Selection | Switches the control loop between Automatic and Manual Control. The operator monitors and alters power to correctly control the process (0 to 100% or -100 to +100% for dual control).<br><b>Caution:</b> Manual mode overrides the automatic control loop. It also ignores any output power limits, valve open/close limits and the control enable/disable setting. The operator is responsible for maintaining the process within safe limits. |
| Control Type                  | Select Single Control for primary control only (e.g. heating only <u>or</u> cooling only) or Dual for primary and secondary control outputs (e.g. heating <u>and</u> cooling) - <i>Dual is not possible with Ratio or VMD Control.</i>                                                                                                                                                                                                           |
| Primary Control Action        | Set the primary control output for Reverse or Direct Action.<br>Reverse action applies additional primary power as the process falls further below setpoint (e.g. heating applications).<br>Direct action applies additional primary power as the process rises higher above setpoint (e.g. cooling applications).<br>In dual control, secondary output action is opposite to primary action.                                                    |
| Control Status                | A “read-only” diagnostic status display of the current loop 1 process variable and effective setpoint values to assist with manual tuning.                                                                                                                                                                                                                                                                                                       |
| Power Output Levels           | A “read-only” diagnostic status display of the current loop 1 primary and secondary % output power levels to assist with manual tuning – <i>Not shown with VMD Control. Does not apply if control is disabled or in manual mode.</i>                                                                                                                                                                                                             |
| Gain Schedule PID Set in use  | A “read-only” diagnostic status display showing the PID set in use. The set used may vary based on the current setpoint or process variable value. – <i>Only shown if Gain Scheduling is in use.</i>                                                                                                                                                                                                                                             |
| PID Set Selection             | Choose to use one of five PID Sets; or choose Gain Schedule on SP or PV. – <i>This selects a fixed PID set to be “Active”; or automatically switch sets based changes in SP or PV values.</i>                                                                                                                                                                                                                                                    |
| Set <i>n</i> – Primary Pb     | The primary proportional band for PID Set <i>n</i> ( <i>n</i> = up to 5). Set as On-Off control, or a proportional band from 1 to 9999 display units – <i>Only the set(s) in use are shown.</i>                                                                                                                                                                                                                                                  |
| Set <i>n</i> – Secondary Pb   | The secondary proportional band for PID Set <i>n</i> ( <i>n</i> = up to 5) if dual control is used. Set as On-Off control, or a proportional band from 1 to 9999 display units – <i>Only the set(s) in use are shown.</i>                                                                                                                                                                                                                        |

|                           |                                                                                                                                                                                                                                                                                                                                                                                                                        |
|---------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Set $n$ – Integral        | The integral time value (Automatic Reset) for PID Set $n$ ( $n$ = up to 5). Adjustable from 1s to 99min 59s or OFF – <i>Only the set(s) in use shown.</i>                                                                                                                                                                                                                                                              |
| Set $n$ – Derivative      | The derivative time value (Rate) for PID Set $n$ ( $n$ = up to 5). Adjustable from 1s to 99 min 59s or OFF – <i>Only the set(s) in use are shown.</i>                                                                                                                                                                                                                                                                  |
| Set $n$ – Overlap         | The overlap (+ve) or deadband (-ve) between primary & secondary proportional bands for PID Set $n$ ( $n$ = up to 5). In display units - <i>limited to 20% of the combined primary &amp; secondary prop band width.</i>                                                                                                                                                                                                 |
| Set $n$ – On/Off Diff     | The on-off control hysteresis (deadband) for PID Set $n$ ( $n$ = up to 5). Adjustable from 1 to 300 display units, centred about the setpoint – <i>Only the set(s) in use are shown.</i>                                                                                                                                                                                                                               |
| Set $n$ - Breakpoint      | The SP or PV value where the PID Set $n$ ( $n$ = up to 5) if gain scheduling is used. Set 1 is used from Scaled Input Lower Limit to the Set 2 Breakpoint, then Set 2 used to the Set 3 Breakpoint etc. If a breakpoint is set to OFF subsequent PID sets are not used. The final PID set runs to the Scaled Input Upper Limit.                                                                                        |
| Manual Reset (Bias)       | The Manual Reset value to bias the control working point within the proportional band(s). Adjustable from 0 to 100% for single control or 100 to +100% for dual control. Typically set to 80% of typical power needed for setpoint, but lower values can help inhibit start-up overshoot.                                                                                                                              |
| Anti Wind-Up Limit        | Adjusts the value at which the “reset wind-up inhibit” is applied. Above this power level further integral action is suspended. Adjustable from 10 to 100% of PID power. Lower values inhibit overshoot.<br><b>Caution:</b> If set too low control deviation can occur (the process settles, but is offset above or below the setpoint). If this is observed, increase the value until the deviation error is removed. |
| Ratio SFAC                | The nominal ratio scaling factor used for Stoichiometric Ratio Control in burner fuel/air control applications. Adjustable from 0.010 to 99.999. – <i>refer to the Ratio Control section on page 84</i>                                                                                                                                                                                                                |
| Ratio NO                  | A constant between 0.0 & 9999.0, added to the x1 (input 1) value in Stoichiometric Ratio Control mode to allow for atomizing air when calculating the process value. The total air flow is therefore $x1 + NO$ .                                                                                                                                                                                                       |
| Primary Cycle Time        | The primary power cycle time. Adjustable from 0.5 to 512 seconds. Applied for time proportioned primary relay, SSR driver or triac control outputs – <i>Not used for VMD Control modes.</i>                                                                                                                                                                                                                            |
| Secondary Cycle Time      | The secondary power cycle time when dual control is used. Adjustable from 0.5 to 512 seconds. Applied for time proportioned primary relay, SSR driver or triac control outputs – <i>Not used for VMD Control modes.</i>                                                                                                                                                                                                |
| Primary Power Lower Limit | The minimum primary output power limit. The control algorithm will not allow the power output fall below this level. Adjustable from 0 to 90% but is always at least 10% below the primary power upper limit.<br><b>Caution:</b> The instrument will not be able to control the process correctly if the lower limit is above the level required to maintain setpoint.                                                 |
| Primary Power Upper Limit | The maximum primary output power limit. The control algorithm will not allow the power output rise above this level. Adjustable from 10 to 100% but is always at least 10% above the primary power lower limit.<br><b>Caution:</b> The instrument will not be able to control the process correctly if the upper limit is below the level required to maintain setpoint.                                               |

|                                   |                                                                                                                                                                                                                                                                                                                                                                               |
|-----------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Secondary Power Lower Limit       | The minimum secondary output power limit. The control algorithm will not allow the power output fall below this level. Adjustable from 0 to 90% but is always at least 10% below the secondary power upper limit.<br><b>Caution: The instrument will not be able to control the process correctly if the lower limit is above the level required to maintain setpoint.</b>    |
| Secondary Power Upper Limit       | The maximum secondary output power limit. The control algorithm will not allow the power output rise above this level. Adjustable from 10 to 100% but is always at least 10% above the secondary power lower limit.<br><b>Caution: The instrument will not be able to control the process correctly if the upper limit is below the level required to maintain setpoint.</b>  |
| Sensor Break Pre-set Power Output | Set the power level to be applied if the process input signal or an active remote setpoint input is lost. Adjustable from 0 to 100% for single control or -100 to +100% for dual control. The default value is OFF (0% power). <i>Does not apply if control is disabled or in manual mode.</i><br><b>Caution: Ensure the value set will maintain safe process conditions.</b> |
| Motor Travel Time                 | The motor travel time (valve movement time from fully open to fully closed in mm:ss). Adjustable from 5s to 5 mins - <i>In VMD Control Mode only.</i>                                                                                                                                                                                                                         |
| Minimum Motor On Time             | The minimum drive effort (in seconds) to begin moving the motorised valve in VMD Control Mode. Adjustable from 0.02 to $\frac{1}{10}$ of the Motor Travel Time.                                                                                                                                                                                                               |
| Valve Open Limit                  | The maximum position the controller will attempt to drive the valve to in VMD Control Mode. Adjustable from the valve close limit+1% to 100.0% (fully open) - <i>Only possible if the 2<sup>nd</sup> input is used for valve feedback.</i>                                                                                                                                    |
| Valve Close Limit                 | The minimum position the controller will attempt to drive the valve to in VMD Control Mode. Adjustable from 0.0% (fully closed) to the valve open limit-1% - <i>Only possible if the 2<sup>nd</sup> input is used for valve feedback.</i>                                                                                                                                     |
| Valve Sensor Break Action         | The direction to drive the valve if the process input signal or an active remote setpoint input is lost. The default action is to drive the valve closed.<br>– <i>Applies to VMD Control Mode only. Does not apply if control is disabled or in manual mode.</i><br><b>Caution: Set to safe values for the process!</b>                                                       |
| Setpoint Lower Limit              | The minimum allowable setpoint value. Adjustable within the scaled input limits, but cannot be above the setpoint upper limit. Applies to local, remote and profile setpoints.<br><b>Caution: Set to safe values for the process. Operators can adjust local setpoints to any value between the limits set.</b>                                                               |
| Setpoint Upper Limit              | The maximum allowable setpoint value. Adjustable within the scaled input limits, but cannot be below the setpoint lower limit. Applies to local, remote and profile setpoints.<br><b>Caution: Set to safe values for the process. Operators can adjust local setpoints to any value between the limits set.</b>                                                               |
| Setpoint Ramp Rate                | Setpoint Ramp Rate value, adjustable from 1 to 9999 display units per hour, or OFF. The ramp is applied at power-up ( <i>from current PV to SP</i> ) and whenever the setpoint value or source is changed. If set to OFF, the setpoint steps immediately to the new setpoint value.                                                                                           |
| Main Setpoint Source              | Select the source of the main setpoint. This can only be a “Local” setpoint set from the keypad, or Not used.                                                                                                                                                                                                                                                                 |
| Alternate Setpoint Source         | Select the source of the alternate setpoint. This can be a “Local” setpoint, not used, or an analog remote setpoint (RSP) signal applied to input 2 or auxiliary input A – <i>depending on available hardware.</i>                                                                                                                                                            |
| Main Setpoint Value               | Sets the current value of the main setpoint between the setpoint upper and lower limits.                                                                                                                                                                                                                                                                                      |
| Alternate Setpoint Value          | Sets the current value of the alternate setpoint between the setpoint upper and lower limits – <i>is read-only if alternate setpoint source is RSP.</i>                                                                                                                                                                                                                       |

|                           |                                                                                                                                                                                                                                                                                                         |
|---------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Select Active Setpoint    | Select if the main or alternate setpoint is to be the current “active” setpoint for this loop.                                                                                                                                                                                                          |
| Main Setpoint Offset      | An offset that can be added to the main setpoint (+ve values) or subtracted from it (-ve values) when the instrument is a comms slave in a multi-zone application. This changes the effective setpoint used for control.<br><b>Caution: It should be set to zero if an offset is not required.</b>      |
| Alternate Setpoint Offset | An offset that can be added to the alternate setpoint (+ve values) or subtracted from it (-ve values) when the instrument is a comms slave in a multi-zone application. This changes the effective setpoint used for control.<br><b>Caution: It should be set to zero if an offset is not required.</b> |

| Control Loop 2 - Sub-menu to setup Control Loop 1. Press  +  to return to Input Menu<br>These settings apply to the slave loop if the controller has been setup for cascade control. |                                                                                                                                                                                                                                                                                                                                                                                               |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Control Select                                                                                                                                                                                                                                                                                                                                          | Select from Control Standard or Control VMD (TPSC).<br>Use Control VMD to directly drive the windings of a motorised valve. This uses a 3-point stepping algorithm giving “open” and “close” outputs.<br>Use Standard for all other applications (including solenoid valves or modulating valves with positioning circuitry requiring mA or VDC signals).                                     |
| Control Enable/Disable                                                                                                                                                                                                                                                                                                                                  | Used to temporarily disable the control outputs. Select control Enabled (normal) or Disabled – when disabled, control output(s) for this loop are turned off (unless manual mode has been selected) and the setpoint value is replaced by “OFF”.<br><b>Caution: The instrument is not able to control the process when control is disabled and the Output Power Limits are ignored.</b>       |
| Auto/Manual Control Selection                                                                                                                                                                                                                                                                                                                           | Switches the control loop between Automatic and Manual Control.<br><b>Caution: Manual mode overrides the automatic control loop. It also ignores any output power limits, valve open/close limits and the control enable/disable setting. The operator is responsible for maintaining the process within safe limits.</b>                                                                     |
| Control Type                                                                                                                                                                                                                                                                                                                                            | Select Single Control for primary control only (e.g. heating only <u>or</u> cooling only) or Dual for primary and secondary control outputs (e.g. heating <u>and</u> cooling) - <i>Dual is not possible with Ratio or VMD Control.</i>                                                                                                                                                        |
| Primary Control Action                                                                                                                                                                                                                                                                                                                                  | Set the primary control output for Reverse or Direct Action.<br>Reverse action applies additional primary power as the process falls further below setpoint (e.g. heating applications).<br>Direct action applies additional primary power as the process rises higher above setpoint (e.g. cooling applications).<br>In dual control, secondary output action is opposite to primary action. |
| Control Status                                                                                                                                                                                                                                                                                                                                          | A “read-only” diagnostic status display of the current loop 2 process variable and effective setpoint values to assist with manual tuning.                                                                                                                                                                                                                                                    |
| Power Output Levels                                                                                                                                                                                                                                                                                                                                     | A “read-only” diagnostic status display of the current loop 2 primary and secondary % output power levels to assist with manual tuning – <i>Not shown with VMD Control. Does not apply if control is disabled or in manual mode.</i>                                                                                                                                                          |
| Gain Schedule PID Set in use                                                                                                                                                                                                                                                                                                                            | A “read-only” diagnostic status display showing the PID set in use. The set use may vary based on the current setpoint or process variable value. – <i>Only shown if Gain Scheduling is in use.</i>                                                                                                                                                                                           |
| PID Set Selection                                                                                                                                                                                                                                                                                                                                       | Choose to use one of five PID Sets; or choose Gain Schedule on SP or PV. – <i>This selects a fixed PID set to be “Active”; or automatically switch sets based changes in SP or PV values.</i>                                                                                                                                                                                                 |
| Set <i>n</i> – Primary Pb                                                                                                                                                                                                                                                                                                                               | The primary proportional band for PID Set <i>n</i> ( <i>n</i> = up to 5). Set as On-Off control, or a proportional band from 1 to 9999 display units – <i>Only the set(s) in use are shown.</i>                                                                                                                                                                                               |
| Set <i>n</i> – Secondary Pb                                                                                                                                                                                                                                                                                                                             | The secondary proportional band for PID Set <i>n</i> ( <i>n</i> = up to 5) if dual control is used. Set as On-Off control, or a proportional band from 1 to 9999 display units – <i>Only the set(s) in use are shown.</i>                                                                                                                                                                     |

|                             |                                                                                                                                                                                                                                                                                                                                                                                                                        |
|-----------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Set $n$ – Integral          | The integral time value (Automatic Reset) for PID Set $n$ ( $n$ = up to 5). Adjustable from 1s to 99min 59s or OFF – <i>Only the set(s) in use shown.</i>                                                                                                                                                                                                                                                              |
| Set $n$ – Derivative        | The derivative time value (Rate) for PID Set $n$ ( $n$ = up to 5). Adjustable from 1s to 99 min 59s or OFF – <i>Only the set(s) in use are shown.</i>                                                                                                                                                                                                                                                                  |
| Set $n$ – Overlap           | The overlap (+ve) or deadband (-ve) between primary & secondary proportional bands for PID Set $n$ ( $n$ = up to 5). In display units - <i>limited to 20% of the combined primary &amp; secondary prop band width.</i>                                                                                                                                                                                                 |
| Set $n$ – On/Off Diff       | The on-off control hysteresis (deadband) for PID Set $n$ ( $n$ = up to 5). Adjustable from 1 to 300 display units, centred about the setpoint – <i>Only the set(s) in use are shown.</i>                                                                                                                                                                                                                               |
| Set $n$ - Breakpoint        | The SP or PV value where the PID Set $n$ ( $n$ = up to 5) if gain scheduling is used. Set 1 is used from Scaled Input Lower Limit to the Set 2 Breakpoint, then Set 2 used to the Set 3 Breakpoint etc. If a breakpoint is set to OFF subsequent PID sets are not used. The final PID set runs to the Scaled Input Upper Limit.                                                                                        |
| Manual Reset (Bias)         | The Manual Reset value to bias the control working point within the proportional band(s). Adjustable from 0 to 100% for single control or 100 to +100% for dual control. Typically set to 80% of typical power needed for setpoint, but lower values can help inhibit start-up overshoot.                                                                                                                              |
| Anti Wind-Up Limit          | Adjusts the value at which the “reset wind-up inhibit” is applied. Above this power level further integral action is suspended. Adjustable from 10 to 100% of PID power. Lower values inhibit overshoot.<br><b>Caution:</b> If set too low control deviation can occur (the process settles, but is offset above or below the setpoint). If this is observed, increase the value until the deviation error is removed. |
| Primary Cycle Time          | The primary power cycle time. Adjustable from 0.5 to 512 seconds. Applied for time proportioned primary relay, SSR driver or triac control outputs – <i>Not used for VMD Control modes.</i>                                                                                                                                                                                                                            |
| Secondary Cycle Time        | The secondary power cycle time when dual control is used. Adjustable from 0.5 to 512 seconds. Applied for time proportioned primary relay, SSR driver or triac control outputs – <i>Not used for VMD Control modes.</i>                                                                                                                                                                                                |
| Primary Power Lower Limit   | The minimum primary output power limit. The control algorithm will not allow the power output fall below this level. Adjustable from 0 to 90% but is always at least 10% below the primary power upper limit.<br><b>Caution:</b> The instrument will not be able to control the process correctly if the lower limit is above the level required to maintain setpoint.                                                 |
| Primary Power Upper Limit   | The maximum primary output power limit. The control algorithm will not allow the power output rise above this level. Adjustable from 10 to 100% but is always at least 10% above the primary power lower limit.<br><b>Caution:</b> The instrument will not be able to control the process correctly if the upper limit is below the level required to maintain setpoint.                                               |
| Secondary Power Lower Limit | The minimum secondary output power limit. The control algorithm will not allow the power output fall below this level. Adjustable from 0 to 90% but is always at least 10% below the secondary power upper limit.<br><b>Caution:</b> The instrument will not be able to control the process correctly if the lower limit is above the level required to maintain setpoint.                                             |
| Secondary Power Upper Limit | The maximum secondary output power limit. The control algorithm will not allow the power output rise above this level. Adjustable from 10 to 100% but is always at least 10% above the secondary power lower limit.<br><b>Caution:</b> The instrument will not be able to control the process correctly if the upper limit is below the level required to maintain setpoint.                                           |

|                                   |                                                                                                                                                                                                                                                                                                                                                                               |
|-----------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Sensor Break Pre-set Power Output | Set the power level to be applied if the process input signal or an active remote setpoint input is lost. Adjustable from 0 to 100% for single control or -100 to +100% for dual control. The default value is OFF (0% power). <i>Does not apply if control is disabled or in manual mode.</i><br><b>Caution:</b> Ensure the value set will maintain safe process conditions. |
| Motor Travel Time                 | The motor travel time (valve movement time from fully open to fully closed in mm:ss). Adjustable from 5s to 5 mins - <i>In VMD Control Mode only.</i>                                                                                                                                                                                                                         |
| Minimum Motor On Time             | The minimum drive effort (in seconds) to begin moving the motorised valve in VMD Control Mode. Adjustable from 0.02 to $\frac{1}{10}$ of the Motor Travel Time.                                                                                                                                                                                                               |
| Slave SP Scale Min                | The effective cascade slave setpoint value equating to 0% power demand from the master controller - <i>Limited by the slave input scaling.</i><br><b>Caution:</b> Set to safe values for the process!                                                                                                                                                                         |
| Slave SP Scale Max                | The effective cascade slave setpoint value equating to 100% power demand from the master controller - <i>Limited by the slave input scaling.</i><br><b>Caution:</b> Set to safe values for the process!                                                                                                                                                                       |
| Valve Sensor Break Action         | The direction to drive the valve if the process input signal or an active remote setpoint input is lost. The default action is to drive the valve closed.<br>– <i>Applies to VMD Control Mode only. Does not apply if control is disabled or in manual mode.</i><br><b>Caution:</b> Set to safe values for the process!                                                       |
| Setpoint Lower Limit              | The minimum allowable setpoint value. Adjustable within the scaled input limits, but cannot be above the setpoint upper limit. Applies to local, remote and profile setpoints.<br><b>Caution:</b> Set to safe values for the process. Operators can adjust local setpoints to any value between the limits set.                                                               |
| Setpoint Upper Limit              | The maximum allowable setpoint value. Adjustable within the scaled input limits, but cannot be below the setpoint lower limit. Applies to local, remote and profile setpoints.<br><b>Caution:</b> Set to safe values for the process. Operators can adjust local setpoints to any value between the limits set.                                                               |
| Setpoint Ramp Rate                | Setpoint Ramp Rate value, adjustable from 1 to 9999 display units per hour, or OFF. The ramp is applied at power-up ( <i>from current PV to SP</i> ) and whenever the setpoint value or source is changed. If set to OFF, the setpoint steps immediately to the new setpoint value.                                                                                           |
| Main Setpoint Source              | Select the source of the main setpoint. This can only be a “Local” setpoint set from the keypad, or Not used.                                                                                                                                                                                                                                                                 |
| Alternate Setpoint Source         | Select the source of the alternate setpoint. This can be a “Local” setpoint, not used, or an analog remote setpoint signal applied to input 2 or auxiliary input A – <i>depending on available hardware.</i>                                                                                                                                                                  |
| Main Setpoint Value               | Sets the current value of the main setpoint between the setpoint upper and lower limits.                                                                                                                                                                                                                                                                                      |
| Alternate Setpoint Value          | Sets the current value of the alternate setpoint between the setpoint upper and lower limits.                                                                                                                                                                                                                                                                                 |
| Select Active Setpoint            | Select if the main or alternate setpoint is to be the “active” setpoint for this loop.                                                                                                                                                                                                                                                                                        |
| Main Setpoint Offset              | An offset that can be added to the main setpoint (+ve values) or subtracted from it (-ve values) when the instrument is a comms slave in a multi-zone application. This changes the effective setpoint used for control.<br><b>Caution:</b> It should be set to zero if an offset is not required.                                                                            |
| Alternate Setpoint Offset         | An offset that can be added to the alternate setpoint (+ve values) or subtracted from it (-ve values) when the instrument is a comms slave in a multi-zone application. This changes the effective setpoint used for control.<br><b>Caution:</b> It should be set to zero if an offset is not required.                                                                       |

## OUTPUTS CONFIGURATION SUB-MENU SCREENS

**Output *n* Configuration** - Up to 9 outputs listed. Any already used show as “Assigned” but can be changed. If “Digital” is shown, the output is driven directly via a digital input (see input configuration). Relevant screen sequences repeat for outputs fitted. Press  +  to return to Configuration Menu

|                                                  |   |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |
|--------------------------------------------------|---|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Linear Output <i>n</i> Type</b>               | w | Set the desired type for any linear outputs fitted. From: 0-5, 0-10, 1-5, 2-10V & 0-20, 4-20mA or 0-10VDC adjustable transmitter PSU.                                                                                                                                                                                                                                                                                                                                                                                                                                |
| <b>Adjustable 0-10V Transmitter PSU <i>n</i></b> | w | Sets the voltage required if linear output <i>n</i> type is 0-10VDC adjustable transmitter PSU.                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |
| <b>Output <i>n</i> Usage</b>                     | w | Sets the use for the output. From: Loop 1 or 2 Primary / Secondary Power; Logical OR or AND of Alarms & Profile Events (direct or reverse acting); Retransmission (of loop 1 or 2 effective setpoint, Input 1 or 2 process values). Choices offered are appropriate for the output type fitted (e.g. only linear outputs can retransmit).                                                                                                                                                                                                                            |
| <b>OP<i>n</i> OR Selection</b>                   | w | When an output usage is set for logical OR of alarms & profile events, this selects the alarms or events to be OR'd. Press  or  to select <input checked="" type="checkbox"/> or deselect <input type="checkbox"/> Alarms 1 to 7; Events 1 to 5; PR (Profile running); PE (Profile Ended). Direct outputs turn on, & reverse outputs turn off according to the selected logical OR combination.    |
| <b>OP<i>n</i> AND Selection</b>                  | w | When an output usage is set for logical AND of alarms & profile events, this selects the alarms or events to be AND'd. Press  or  to select <input checked="" type="checkbox"/> or deselect <input type="checkbox"/> Alarms 1 to 7; Events 1 to 5; PR (Profile running); PE (Profile Ended). Direct outputs turn on, & reverse outputs turn off according to the selected logical AND combination. |
| <b>Output <i>n</i> Latch Enable</b>              | w | If enabled, an output will remain latched ON even if the condition that caused it to be on is no-longer present, and remains latched even if the instrument is powered off-on. The output latch must be reset to turn it off.                                                                                                                                                                                                                                                                                                                                        |
|                                                  |   |  <b>Note:</b> An output cannot reset if the condition that caused it to turn on is still present.                                                                                                                                                                                                                                                                                                                                                                                 |
| <b>Output <i>n</i> Lower Retransmit Limit</b>    |   | The displayed value at which the retransmission output reaches its minimum level (e.g the display value when a 4 to 20mA retransmission output is at 4mA). Adjustable from -9999 to 9999.9. The output is at its minimum below this value. Above this value, it rises linearly in line with the displayed value to reach its maximum at the Upper Retransmit Limit display value.                                                                                                                                                                                    |
| <b>Output <i>n</i> Upper Retransmit Limit</b>    | w | The displayed value at which a retransmission output will be at its maximum level (e.g. the display value when a 4 to 20mA retransmission output is at 20mA). Adjustable from -9999 to 9999.9. The output is at its maximum above this display value. Below this value, it falls linearly in line with the displayed value to reach its minimum at the Lower Retransmit Limit display value.                                                                                                                                                                         |

## ALARM CONFIGURATION SUB-MENU SCREENS

**Alarm  $n$  Configuration** - 7 alarms listed with any already used shown as "Assigned". Relevant screen sequences repeat for each alarm ( $n = 1$  to 7). Press  +  to return to Configuration Menu

|                                               |          |                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
|-----------------------------------------------|----------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Alarm <math>n</math> Type</b>              | <b>w</b> | Sets the function of alarm $n$ from: Unused; Process High; Process Low; PV-SP Deviation; Band; Control Loop; Rate Of Signal Change per minute; Input Signal Break; % of Recorder Memory Used, Control Power High, Control Power Low.                                                                                                                                                                                                                  |
| <b>Alarm <math>n</math> Source</b>            | <b>w</b> | The signal source of Alarm $n$ from: Input 1, Input 2 & Auxiliary Input A; Control Loop 1; Control Loop 2; Loop 1 Primary or Secondary Power; Loop 2 Primary or Secondary Power – <i>auxiliary input A is only possible if fitted and the alarm type can only be input signal break.</i>                                                                                                                                                              |
| <b>Alarm <math>n</math> Value</b>             | <b>w</b> | The Alarm $n$ activation point – The value is limited by the scaled input limits for Process High; Process Low; PV-SP Deviation (+ve above, -ve below setpoint), Band (above or below setpoint) type alarms.<br>Rate of Signal Change is a rate of 0.0 to 99999 (rate in <i>units per minute</i> ).<br>Memory used, Control Power High, Control Power Low are 0.0 to 100.0% – <i>not required for Control Loop or Input Signal Break alarm types.</i> |
| <b>Alarm <math>n</math> Hysteresis</b>        |          | The deadband on the "safe" side of alarm $n$ , through which signal must pass before alarm deactivates - <i>not for Rate of Change, Control Loop, Input Break or Percentage of Memory used alarms.</i>                                                                                                                                                                                                                                                |
| <b>Alarm <math>n</math> Minimum Duration</b>  | <b>w</b> | The minimum time that alarm $n$ must be passed its threshold before activating (deactivation is not affected by this parameter). Adjustable from 0.0 to 9999.0 secs. – <i>not used for signal break, memory or loop alarms.</i><br><b>Caution:</b> If the duration is less than the time set, the alarm will not become active.                                                                                                                       |
| <b>Alarm <math>n</math> Inhibit</b>           | <b>w</b> | If the inhibit is enabled, it prevents the initial alarm activation if the alarm condition is true at power up. Activation only occurs once the alarm condition has passed and then reoccurred.                                                                                                                                                                                                                                                       |
| <b>Control <math>n</math> Loop Alarm Type</b> | <b>w</b> | Sets the loop alarm time source, from: Manual Loop Alarm Time (as set in the loop alarm $n$ time screen) or Automatic (twice the integral time constant setting). If configured, a Loop Alarm activates if no response is seen in loop $n$ after this time following the saturation of its power output. – <i>Only seen if an alarm is set for control loop type.</i>                                                                                 |
| <b>Control <math>n</math> Loop Alarm Time</b> | <b>w</b> | The time (max 99:59 mm:ss) for loop $n$ to begin responding after PID power output reaches saturation, if a manual loop alarm type is configured.                                                                                                                                                                                                                                                                                                     |

| COMMUNICATIONS CONFIGURATION SUB-MENU SCREENS |                                                                                                                                                                                                                              |
|-----------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>No Communications Warning</b>              | If Communications Configuration menu is entered without a communications module fitted.                                                                                                                                      |
| <b>Modbus Parity</b>                          | The setting for Modbus comms parity bit checking, from: Odd; Even or None. Set the same parity for all devices on the network – <i>Only seen if RS485 or Ethernet communications option is fitted.</i>                       |
| <b>Modbus Data Rate</b>                       | The setting for the Modbus comms data speed. From: 4800; 9600; 19200; 38400; 57600 or 115200 bps. Set the same speed for all devices on the network – <i>Only seen if RS485 or Ethernet communications option is fitted.</i> |
| <b>Master Mode, or Slave Address</b>          | Slave address (1 to 255), or multi-zone Setpoint Master Mode – <i>Only seen if RS485 or Ethernet communications option is fitted, but Master mode is not available over Ethernet.</i>                                        |
| <b>Target Register In Slave</b>               | Target memory register for the setpoint value in attached slave controllers. All slaves must have the same setpoint register address as set here - <i>Appears only if unit is in Master mode.</i>                            |
| <b>Master Mode Format</b>                     | The data format required by the attached setpoint slaves. From: Integer; integer with 1 decimal place or float - <i>Appears only if unit is in Master mode.</i>                                                              |
| <b>Serial Communications Write Enable</b>     | Enables/disables writing via RS485 or Ethernet communications. When disabled, parameters can be read, but attempts to change their values over comms are blocked.                                                            |

## DATA RECORDER CONFIGURATION SUB-MENU SCREENS:

|                               |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |
|-------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| No Recorder Warning           | If the Recorder Configuration menu is entered on an instrument without this option fitted.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |
| Recording In Progress Warning | A warning if recording when attempting to enter recorder configuration. - <i>Access to the configuration is denied unless the recording is paused.</i>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
| Pause (Override Trigger)      | Select No to continue recording or Yes to enter recorder configuration.<br> <b>Note:</b> Recording is paused until recorder configuration is completed. It restarts automatically on exit from this menu.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |
| Recorder Status Information   | <p>Current information about the data recorder feature, including if a recording is in progress (Recording or Stopped); the recording mode (FIFO or Record Until Memory Is Used); a % memory use bar-graph and the estimated available time remaining based on the data selected and memory left. <i>If the alarm status is recorded and is likely to change often, take this into account when determining if there is sufficient memory available.</i></p> <p>Icons are displayed for active recording triggers. If any trigger is active, the selected data will be recorded.</p> <div style="display: flex; justify-content: space-around; align-items: center;">     </div> <div style="display: flex; justify-content: space-around; align-items: center;"> <b>Manual Record</b> <b>Alarm Record</b> <b>Digital Input</b> <b>Profile Record</b> </div> <p>- see the Data Recorder in section on page 100</p> |
| Recorder Mode                 | <p>Choose Record Until Memory Used (stops recording when full) or Continuous FIFO (First In - First Out).</p> <p><b>Caution:</b> A FIFO recording will overwrite previous recordings in memory, starting with the oldest data first. Download the previous data before selecting this option.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          |
| Recording Sample Interval     | <p>Recording of the selected data will happen once every sample interval. From every: 1; 2; 5; 10; 15; 30 Seconds, or 1; 2; 5; 10; 15; 30 Minutes.</p> <p>- The recording interval does not affect Trend View sample rates.</p> <p> <b>Note:</b> Shorter intervals reduce the possible recording duration.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          |
| Recorder Auto Trigger         | Automatic recording triggers. From: None; On Alarm; During Profile and Alarm or Profile. Data is recorded if <u>any</u> trigger is active (including a digital input or manual recording start).                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
| Trigger On Alarms             | <p>Any combination of alarms 1 to 7 can be set to trigger a recording (TRG) or not (OFF). If any alarm set to TRG becomes active, the alarm recording trigger activates.</p> <p> <b>Note:</b> 10 samples at 1s intervals are stored and added to the recording prior to and after the data that is stored at the normal sample rate while the alarm is on.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          |
| Loop 1 Values To Record       | <p>Any combination of loop 1 values can be recorded from: Process Variable; Maximum or Minimum PV (since the previous sample was taken); Setpoint; Primary Power, Secondary Power. Set to Record (REC) or not (OFF).</p> <p> <b>Note:</b> Recording more parameters reduces the possible recording duration.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Loop 2 Values To Record       | <p>Any combination of loop 2 values can be recorded from: Process Variable; Maximum or Minimum PV (since the previous sample was taken); Setpoint; Primary Power, Secondary Power. Set to Record (REC) or not (OFF).</p> <p> <b>Note:</b> Recording more parameters reduces the possible recording duration.</p>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Other Values To Record        | If required, select to record the value of auxiliary input A.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              |

|                           |                                                                                                                                                                                                                                      |
|---------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Activities To Record      | Multiple process events can be recorded from: Alarm $n$ Status ( $n = 1$ to 7) or Unit turned Off/On.                                                                                                                                |
|                           |  <b>Note:</b> If an alarm changes state an extra sample is recorded using extra memory. The remaining recording time is reduced accordingly.        |
| Profiler Events To Record | The Profiler Event $n$ Status can be recorded ( $n = 1$ to 5).                                                                                                                                                                       |
|                           |  <b>Note:</b> If a profile event changes state an extra sample is recorded using extra memory. The remaining recording time is reduced accordingly. |

### CLOCK CONFIGURATION SUB-MENU SCREENS

|             |   |                                                                                                                                                             |
|-------------|---|-------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Date Format | w | The format used for all displayed dates: <i>dd/mm/yyyy</i> (Day / Month / Year) or <i>mm/dd/yyyy</i> (Month / Day / Year). – <i>Recorder versions only.</i> |
| Set Date    | w | Set the internal clock Date – Entered in the format defined by Date Format screen. – <i>Recorder versions only.</i>                                         |
| Set Time    | w | Set the internal clock Time. - In <i>hh:mm:ss</i> (Hours : Minutes : Seconds) format. – <i>Recorder versions only.</i>                                      |



**Note:** Clock settings cannot be changed when the data recorder is active.

| DISPLAY CONFIGURATION SUB-MENU SCREENS |                                                                                                                                                                                                                                                                                                                             |
|----------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Language                               | Select English or the alternate local language. The alternate language is selected at time of order, but can be changed later using the PC software.                                                                                                                                                                        |
| Enable Custom Display Mode             | Enables/disables the Custom Operation Mode, if configured. The screens seen in this mode are configured using the PC configuration software.                                                                                                                                                                                |
| Read Only Operation Mode?              | Allows Operation Mode to be Read/Write or Read-Only where screens can be seen but the values cannot be changed.                                                                                                                                                                                                             |
| Display Color                          | From: Red only; Green only; Red to Green on Alarm or Green to Red on Alarm; Red to Green if Output Latched or Green to Red if Output Latched.                                                                                                                                                                               |
| Invert Display                         | Standard or Inverted display image.                                                                                                                                                                                                                                                                                         |
| Display Contrast                       | Screen contrast (10 and 100) to improve clarity. 100 = maximum contrast.                                                                                                                                                                                                                                                    |
| Loop 1 Trend Sample Interval           | The Interval between the displayed values on the loop 1 trend graph. From: Every 1; 2; 5; 10; 15; 30 Seconds, or 1; 2; 5; 10; 15; 30 Minutes.<br>- <i>Independent from the loop 2 trend graph and data recorder sample rates.</i>                                                                                           |
| Loop 1 Trend View Mode                 | The data to display on the loop 1 trend graph. From: Process Value only, PV (solid) & SP (dotted) at sample time, or the Max & Min PV between samples (candle-stick graph). <i>Alarm active indication is always shown at the top of graph.</i>                                                                             |
| Loop 2 Trend Sample Interval           | The Interval between the displayed values on the loop 2 trend graph. From: Every 1; 2; 5; 10; 15; 30 Seconds, or 1; 2; 5; 10; 15; 30 Minutes.<br>- <i>Independent from the loop 1 trend graph and data recorder sample rates.</i>                                                                                           |
| Loop 2 Trend View Mode                 | The data to display on the loop 1 trend graph. From: Process Value only, PV (solid) & SP (dotted) at sample time, or the Max & Min PV between samples (candle-stick graph). <i>Alarm active indication is always shown at the top of graph.</i>                                                                             |
| Operator Visibility                    | Extra parameters can be made visible/adjustable in Operation Mode from: Profile Control; Recorder Start/Stop; Recorder Status; Loop 1 & 2 Setpoint Select; Loop 1 & 2 Auto/Manual Select; Loop 1 & 2 Control Select; Loop 1 & 2 Trend View; Loop 1 & 2 Setpoint Ramp Rate.<br><a href="#">See ▢ in Operator Mode lists.</a> |

| LOCK CODE CONFIGURATION SUB-MENU SCREEN |                                                                                                                                                                                                                                                       |
|-----------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Lock Code Configuration                 | Set Lock Codes (passwords) for the following configuration and control menus: Setup Wizard; Configuration Mode; Tuning Menu; Supervisor Mode; USB Menu; Recorder Menu, Profiler Setup and Profiler Menu. Independently adjustable from 1-9999 or OFF. |
|                                         |  <b>Note:</b> The factory default value is 10 for all lock codes. For security, users are recommended to change these codes.                                         |

| RESET TO DEFAULTS SUB-MENU SCREEN |                                                                                                                                             |
|-----------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------|
| Reset To Defaults                 | The user can set all parameters back to their factory default values before preparing the instrument for installation in a new application. |
|                                   | <b>Caution:</b> The user must reconfigure all of the required settings before using the instrument.                                         |

## 8.6 The USB Menu

A notification is shown if a USB memory stick is inserted or removed from the USB port. The USB Menu will automatically be offered after insertion. The USB menu can also be accessed from the Main Menu.

### 8.6.1 Entry into the USB Menu



**CAUTION:** Do not remove the memory stick from the USB port whilst a Data Transfer to or from the USB stick is in progress. Data loss or corruption may result.

The USB Menu is entered from the Main Menu

Hold down ➤ and press ▲ to enter the Main Menu.

Press ▼ or ▲ to select the USB Menu



**Note:** Entry into this mode is security-protected by the USB Menu Lock Code. Refer to the Lock Code Configuration sub-menu.

Press ➤ to enter the USB Menu.

#### 8.6.1.1 Navigating in the USB Menu

Press ➤ to move forward, or ◀ to move backwards through the screens.

Press ▼ or ▲ to change the value as required.

The next/previous screen follows the last parameter. If no further changes are required, hold down ➤ or ◀ >1sec to skip straight to next/previous screen accepting ALL values shown.

Hold down ➤ and press ▲ to return to the Main Menu

Scrolling “Help Text” is shown at the bottom of the screens to aid navigation.



**Note:** During Data Transfer, normal operation carries on in the background, but operator access to other screens is not possible. The transfer of a full memory can take up to 20 minutes. Only begin a transfer when you are certain that access (e.g. setpoint changes) will not be required.

| 🔒 USB MENU SCREENS       |                                       |                                                                                                                                                                                                                                                                |
|--------------------------|---------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| USB Mode Unlocking       |                                       | Enter correct code number to access the USB Menu.<br><i>Factory Default value is 10.</i>                                                                                                                                                                       |
| Read/Write To USB Device |                                       | Select the required action from: Read Configuration File; Write Configuration File; Write Recorder Log File. Read Profile Files; Write Profile Files.                                                                                                          |
|                          |                                       |  <b>Note:</b> "Writing" is downloading from the Instrument to the USB stick. "Reading" is uploading from the USB stick to the Instrument.                                     |
| Write                    | Select Profile To Write               | If writing a profile to the USB memory stick, choose a profile to write from the list provided.                                                                                                                                                                |
|                          | Enter A File Name                     | Enter an 8-character file name if writing configurations or profiles. A file extension is automatically added to the end of file name (bct for configurations or pfl for profiles).<br><b>Caution:</b> Existing files with the same name will be over-written. |
|                          | Enter A Folder Name                   | Recorder logs can contain multiple files. The user enters an 8-character folder name for these logs. See the Data Recorder section on page 100.                                                                                                                |
|                          |                                       |  <b>Note:</b> To prevent existing recordings being over-written, an error message is shown if the folder name entered already exists.                                        |
|                          | Writing Profile, Configuration or Log | An animated screen is shown the files are being written.<br><b>Caution:</b> Do not disconnect USB device until completed! Data loss or corruption may result.                                                                                                  |
|                          | Transfer Successful                   | Confirmation that the data transfer to the USB stick completed correctly. Press ➤ to continue                                                                                                                                                                  |
| Read                     | Transfer Failure                      | For write failures, check for adequate disk space on the USB stick.                                                                                                                                                                                            |
|                          | Select File                           | Select the Configuration or Profile file to transfer from the USB stick.<br><b>Caution:</b> Configuration reads overwrite <u>all</u> of the instruments existing settings with new values.                                                                     |
|                          | Reading Profile or Configuration File | An animated screen is shown while files are being read.<br><b>Caution:</b> Do not remove the memory stick whilst this operation is in progress. Data corruption may result.                                                                                    |
|                          | Transfer Successful                   | Confirmation that the data transfer from the USB stick completed correctly. Press ➤ to continue.                                                                                                                                                               |
|                          | Transfer Failure                      | For read failures, check the maximum number of profiles and/or segments is not being exceeded.                                                                                                                                                                 |

## 8.7 Recorder Control Menu

This menu allows the user to manually start a recording or to delete previous recordings. Refer to the Recorder Configuration sub-menu in Configuration Mode for information about how to setup the data to be recorded and the recording interval and the Data Recorder Option section on page 100 for general information about the recorder feature.

### 8.7.1 Entry into the Recorder Control Menu

The Recorder Control Menu is entered from the Main Menu

Hold down ➤ and press ▲ to enter the Main Menu.

Press ▼ or ▲ to select the Recorder Control Menu



**Note:** Entry into this mode is security-protected by the recorder control menu lock code. Refer to the Lock Code Configuration sub-menu.

Press ➤ to enter the Recorder Control Menu.

#### 8.7.1.1 Navigating the Recorder Control Menu

Press ➤ to move forward, or ◀ to move backwards through parameters & screens.

Holding down ➤ or ◀ for more than 1 second skips immediately to the next/previous screen accepting **ALL** values as shown.

Press ▼ or ▲ to select or change the value as required.

The next/previous screen follows the last parameter. If no further changes are required, hold down ➤ or ◀ >1sec to skip straight to next/previous screen accepting **ALL** values shown.

Hold down ➤ and press ▲ to return to the Main Menu

Scrolling “Help Text” is shown at the bottom of the screens to aid navigation.

| 🔒 RECORDER MENU SCREENS       |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |
|-------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Recorder Mode Unlocking       | Enter correct code number to access the Data Recorder Menu.<br><i>Factory Default value is 10.</i>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |
| Recording In Progress Warning | Shown if a recording is in progress when the recorder control menu is entered.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |
| Start/Stop Data Recording     | Turn on or off the manual recording trigger.<br> <b>Note:</b> Recording continues if another record trigger is active (e.g. on alarm/profile or via a digital input). Access is restricted to this screen only until recording stops (remove all active triggers).                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |
| Recorder Status Information   | <p>Current information about the data recorder feature, including if a recording is in progress (Recording or Stopped); the recording mode (FIFO or Record Until Memory Is Used); a % memory use bar-graph and the estimated available time remaining based on the data selected and memory left. <i>If the alarm status is recorded and is likely to change often, take this into account when determining if there is sufficient memory available.</i> Icons are displayed for active recording triggers. If any are active, the selected data will be recorded.</p> <div style="display: flex; justify-content: space-around; align-items: center;">     </div> <p style="text-align: center;"> <b>Manual Record    Alarm Record    Digital Input    Profile Record</b> </p> <p>- see the Data Recorder in section on page 100</p> |
| Clear Recordings              | Clears the recorder memory. Download any recorded data before use.<br><b>Caution:</b> This permanently deletes <u>All</u> recorded data.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |

## 8.8 Profiler Setup Menu

Screens marked ⌚ will not time-out automatically. They must be completed for a valid profile to be created. Refer to the Profiler section on page 90 for more details about the profiler.

### 8.8.1 Entry into the Profiler Setup Menu

The Profiler Setup Menu is entered from the Main Menu

Hold down ➤ and press ▲ to enter the Main Menu.

Press ▼ or ▲ to select the Profiler Setup Menu



**Note:** Entry into this mode is security-protected by the profiler setup menu lock code. Refer to the Lock Code Configuration sub-menu.

Press ➤ to enter the Profiler Setup Menu.

#### 8.8.1.1 Navigating the Profiler Setup Menu

Press ➤ to move forward, or ◀ to move backwards through the screens.

Press ▼ or ▲ to select or change the value as required.

Holding down ➤ or ◀ for more than 1 second skips immediately to the next/previous screen accepting **ALL** values as shown.

Hold down ➤ and press ▲ to return to the Main Menu

Scrolling “Help Text” is shown at the bottom of the screens to aid navigation.

## 🔔 PROFILER SETUP MENU SCREENS

|                                      |                                  |                                                                                                                                                                                                                                                                          |
|--------------------------------------|----------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Profiler Setup Menu Unlocking</b> |                                  | Enter correct code number to access Profiler Setup Menu.<br><i>Factory Default value is 10.</i>                                                                                                                                                                          |
| <b>Profile Setup Options</b>         |                                  | Select the required profile setup sub-menu option from: General Configuration; Create a Profile; Edit a Profile Header; Edit a Profile Segment; Insert a Segment; Delete a Segment; Delete a Profile or Delete ALL Profiles.                                             |
| <b>General Profile Configuration</b> |                                  | Sub-menu with global settings affecting all profiles.<br><i>Press ▼ + ➡ to return to Profile Setup Menu</i>                                                                                                                                                              |
| <b>General</b>                       | <b>Enable Edit While Running</b> | Enables or disables the ability to edit profiles whilst a profile is running.<br><b>Caution:</b> Edits made to the <u>current or next segment of the running profile will take effect until after the profile is restarted.</u>                                          |
|                                      | <b>Timer Start Function</b>      | Enable or disable automatic starting of profiles. When enabled, delayed starts are possible, or if the selected profile has a day & time trigger it waits until the time set before starting.                                                                            |
|                                      |                                  |  <b>Note:</b> If the Timer Start Function is disabled, profiles can only be manually started, and with <u>immediate effect</u> even if they have a delay or day & time trigger defined. |

| Timer Start Function | Delay set              | Start Date/Time set           |
|----------------------|------------------------|-------------------------------|
| Enabled              | Delayed by delay value | Delayed until Start Date/Time |
| Disabled             | Starts immediately     | Starts immediately            |

|                               |                                                                                     |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |
|-------------------------------|-------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Create A Profile</b>       |                                                                                     | ⌚ Sub-menu to create a new profile. A header is created first, followed by the segments – see <i>below</i> .<br><b>Caution:</b> It is not possible to exit from this sub-menu until profile creation is fully complete. Do not turn off the power during profile creation or editing. When the profile creation/editing is complete the instrument returns automatically to the profile setup main menu.<br> <b>Note:</b> A warning is displayed if the maximum number of 64 profiles or 255 segments is exceeded.      |
| <b>Profile Header Details</b> | <b>Profile Header:</b> <i>Settings that apply to the chosen profile as a whole.</i> |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |
|                               | <b>Enter Profile Name</b>                                                           | ⌚ Give each profile a unique descriptive name of up to 16 characters. The name is shown in the profile status screen and in profile selection lists.                                                                                                                                                                                                                                                                                                                                                                                                                                                       |
|                               | <b>Number of Loops (linked to profile)</b>                                          | ⌚ Select if a profile controls the setpoint of first loop only, or both control loops, or Cascade. This parameter is not the same as the Control Mode in the Control configuration menu and sets a profile 'type'.<br><br>1, 2 or Cascade can be selected. This screen is "read only" when editing a profile. The number cannot be changed once the profile has been created.<br> <b>Note:</b> the segment type and time settings are common to both loops. Some segment types are not available with 2-loop profiling. |
|                               | <b>Profile Starting Point</b>                                                       | ⌚ The setpoint value used at the beginning of the first segment. From: Current Setpoint or Current Process Variable. The setpoint starts from the measured PV(s) or effective setpoint(s) of the process as it begins running.                                                                                                                                                                                                                                                                                                                                                                             |
|                               | <b>Profile Start Trigger</b>                                                        | ⌚ From: None (profile start is not delayed); After Delay or Day and Time.<br><i>- Day and Time possible on the recorder version only.</i><br> <b>Note:</b> If the Timer Start Function has been disabled, profiles can only be manually started, and with <u>immediate effect</u> even if they have a delay or day & time trigger defined.                                                                                                                                                                              |
|                               | <b>Profile Start Time</b>                                                           | ⌚ If Day and Time is the Profile Start Trigger, this is the time (hh:mm:ss) when the profile will begin if it is selected to run.                                                                                                                                                                                                                                                                                                                                                                                                                                                                          |

|                         |                                                                                    |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
|-------------------------|------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Profile Segment Details | Profile Start Day(s)                                                               | 🕒 If Day and Time is the Profile Start Trigger, this is the Day(s) when the profile should run. From: Mon; Tue; Wed; Thu; Fri; Sat; Sun; Mon-Fri; Mon-Sat; Sat-Sun or All.                                                                                                                                                                                                                                                                                                       |
|                         | Profile Start Delay Time                                                           | 🕒 If After Delay is the Profile Start Trigger, this is the delay time of up to 99:59 (hh:mm) before a profile begins after a start request has been given.                                                                                                                                                                                                                                                                                                                       |
|                         | Profile Recovery Method                                                            | 🕒 The power-on action if profile was running at power-down (e.g. after a power cut), or following correction of a signal break. From: Control outputs off; Restart profile from the beginning; Maintain last profile setpoint; Use controller setpoint; Continue profile from where it was when power failed.                                                                                                                                                                    |
|                         | Profile Recovery Time                                                              | 🕒 The Recovery Method is ignored (the profile continues from where power failed), if power off for less than this time. Max 99:59 (hh:mm). - <i>Recorder version only.</i>                                                                                                                                                                                                                                                                                                       |
|                         | Profile Abort Action                                                               | 🕒 The action taken after profile has been forced to stop early. From: Control outputs off; Maintain last profile setpoint or Use controller setpoint.                                                                                                                                                                                                                                                                                                                            |
|                         | Profile Cycles                                                                     | 🕒 The number of times the program should run each time it is started. From 1 to 9999 or Infinite.                                                                                                                                                                                                                                                                                                                                                                                |
|                         | <b>Profile Segments:</b> <i>Settings that apply to individual profile segments</i> |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
|                         | Segment Number                                                                     | 🕒 Shows the number of the profile segment being created. The maximum number of profiles across all profiles is 255.                                                                                                                                                                                                                                                                                                                                                              |
|                         | Segment Type                                                                       | 🕒 Set the segment type from: Ramp Time (time to reach target SP); Ramp Rate (rate of change towards target SP – <i>Single loop profiles only</i> ); Step (jump to target SP); Dwell (keep current SP); Hold (hold profile until released); Loop (back to previous segment); Join (to another profile); End or Repeat Sequence Then End (repeat a sequence of joined profiles).                                                                                                   |
|                         |                                                                                    |  <b>Note:</b> Segment Ramp Rate is not available if the profile controls two loops. A Join, End or Repeat Sequence Then End is the last segment in the profile. Repeat Sequence Then End is always the last profile in a sequence.                                                                                                                                                            |
|                         | Loop 1 Target Setpoint (Master when Cascade control)                               | 🕒 The setpoint value to be reached control loop 1 by the end of this segment, if the type is Ramp Time, Ramp Rate or Step.                                                                                                                                                                                                                                                                                                                                                       |
|                         | Loop 2 Target Setpoint                                                             | 🕒 If the profile is controlling 2 loops, this is the setpoint value to be reached control loop 2 by the end of the segment, if the type is Ramp Time or Step.                                                                                                                                                                                                                                                                                                                    |
|                         | Segment Ramp Time                                                                  | The time (hh:mm:ss) to reach the segment target setpoint if the segment type is Ramp Time.                                                                                                                                                                                                                                                                                                                                                                                       |
|                         | Segment Ramp Rate                                                                  | 🕒 The rate of change towards the Segment Target Setpoint if segment type is Ramp Rate. The rate can be from 0.001 to 9999.9 display units per hour.                                                                                                                                                                                                                                                                                                                              |
|                         | Segment Dwell Time                                                                 | 🕒 The time (hh:mm:ss) to maintain the current setpoint if the segment type is Dwell.                                                                                                                                                                                                                                                                                                                                                                                             |
|                         | Number of Loops                                                                    | 🕒 If the segment type is Loop, enter the number of times to repeat the loop back, before continuing forward to the next segment.                                                                                                                                                                                                                                                                                                                                                 |
|                         | Slave Maximum Setpoint                                                             | <p>🕒 Present for Ramp or Step segments. The setpoint value for the Maximum Temperature allowed for the Slave Temperature. This is directly related to the output power from the Master loop.</p> <p>The Slave Maximum Setpoint is adjustable within the Scaled Input Lower and Upper Limit, and is limited by the Slave SP Scale Min &amp; Slave SP Scale Max while a cascade profile is running. The Slave Maximum Setpoint effectively limits the Master PID output power.</p> |
|                         | Back to Segment Number                                                             | <p>🕒 If the segment type is Loop, enter the segment to loop back to.</p> <p> <b>Note:</b> Two Loop-backs cannot be set to cross each other.</p>                                                                                                                                                                                                                                               |

|                        |                             |                                                                                     |                                                                                                                                                                                                                          |
|------------------------|-----------------------------|-------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|                        | Loop 1 Auto-Hold Type       | ⌚                                                                                   | The auto-hold type for this segment to ensure loop 1 tracks the setpoint. From: None (no auto-hold); Above Setpoint (hold if too high only); Below Setpoint (hold if too low only) or Band (hold if too high or low).    |
|                        | Loop 1 Auto-Hold Band Value | ⌚                                                                                   | The distance loop 1 can be from setpoint. Beyond this the profile is held for the selected Auto-Hold Type.                                                                                                               |
|                        |                             |    | <b>Note:</b> For Two-Loop Profiles, either loop can cause the profile to hold. The profile continues only when both loops are within their Auto-Hold Bands.                                                              |
|                        | Loop 2 Auto-Hold Type       | ⌚                                                                                   | The auto-hold type for this segment to ensure loop 2 tracks the setpoint. From: None (no auto-hold); Above Setpoint (hold if too high only); Below Setpoint (hold if too low only) or Band (hold if too high or low).    |
|                        | Loop 2 Auto-Hold Band Value | ⌚                                                                                   | The distance loop 2 can be from setpoint. Beyond this the profile is held for the selected Auto-Hold Type.                                                                                                               |
|                        |                             |    | <b>Note:</b> For Two-Loop Profiles, either loop can cause the profile to hold. The profile continues only when both loops are within their Auto-Hold Bands. Loop 2 Auto-Hold has no effect when Cascade control is used. |
|                        | Segment Hold Release Type   | ⌚                                                                                   | A hold segment can either be released by an Operator/Digital input or be set to wait until a specified Time of Day - <i>Recorder version only</i> .                                                                      |
|                        | Hold Release Time           | ⌚                                                                                   | The time of day (hh:mm:ss) when a Hold Segment will release if the Release Type is Time Of Day. The profile is held by the hold segment and only released at the next occurrence of the time of day set.                 |
|                        | Times To Repeat Sequence    | ⌚                                                                                   | The number of times the entire sequence of profiles should run. – if the last segment is Repeat Sequence Then End.                                                                                                       |
|                        | Segment End Type            | ⌚                                                                                   | The action taken after the profile ends normally. From: Control Outputs Off; Maintain Last Profile Setpoint or Use Controller Setpoint.                                                                                  |
|                        | Select Profile To Join      | ⌚                                                                                   | Choose a profile to join to from the list provided – if the final segment type is Join. The selected profile will start immediately the current profile ends.                                                            |
|                        | Event <i>n</i>              | ⌚                                                                                   | Select the events to be active during this segment. <i>n</i> = 1 to 5.<br><b>Note:</b> For end segments, the events selected to be active stay on until the instrument exits from profiler mode or a new profile runs.   |
|                        |                             |  | <b>Note:</b> For end segments, the events selected to be active stay on until the instrument exits from profiler mode or a new profile runs.                                                                             |
| Edit A Profile Header  |                             | ⌚                                                                                   | Choose the profile to be edited from the list of names provided, then alter any values as required – <i>The profile header details are as shown in “Create A Profile” above.</i>                                         |
| Edit A Profile Segment |                             | ⌚                                                                                   | Choose the profile, then the segment to be edited from the lists provided. Alter any values as required – <i>The profile segment details are as shown in “Create A Profile” above.</i>                                   |
|                        |                             |  | <b>Note:</b> The last segment type can only be set to Join, End or Repeat Sequence Then End. Use Insert or Delete to change the end position.                                                                            |
| Insert A Segment       |                             | ⌚                                                                                   | Choose the profile, then the new segment’s position from the lists provided – Enter the new segment values as required – <i>The profile segment details are as shown in “Create A Profile” above.</i>                    |
|                        |                             |  | <b>Note:</b> The new segment type cannot be set to Join, End or Repeat Sequence Then End. Use Delete to change the end position.                                                                                         |
| Delete A Segment       |                             | ⌚                                                                                   | Choose the profile, then the segment to be deleted from the lists provided. End, Join or Repeat segments cannot be deleted.                                                                                              |
| Delete A Profile       |                             | ⌚                                                                                   | Choose the profile to be deleted from the list of names is provided. The user is prompted confirm the deletion.                                                                                                          |
| Delete All Profiles    |                             | ⌚                                                                                   | If selected, the user is prompted to confirm that the profiles should be deleted.<br><b>Caution:</b> This deletes <u>all</u> profiles from memory!                                                                       |

## 8.9 Profiler Control Menu

| 🔒 PROFILER CONTROL MENU SCREENS |                                                                                   |                                                                                                                                                                                                                                                                                     |
|---------------------------------|-----------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Profiler Control Menu Unlocking |                                                                                   | Enter correct code number to access Profiler Control Menu.<br><i>Factory Default value is 10.</i>                                                                                                                                                                                   |
| Profile Control                 |                                                                                   | If a profile is running, from: Do Nothing; Abort Profile (end immediately); or Jump to Next Profile Segment; Hold Profile or Release Hold.<br>If profile not running, from: Do Nothing; Run Profile; End Profile Control (return to normal controller operation) or Select Profile. |
| Select Profile                  |                                                                                   | Selects a profile. If Run Profile was chosen in the previous screen, the profile starts (after a delay if one is enabled). Otherwise the profile is selected, but waits for a run instruction (e.g. via digital input or timer).                                                    |
|                                 |  | <b>Note:</b> Selection is “read only” if profile selection is via a digital input. Otherwise choose from the list of profile names provided.                                                                                                                                        |



### Profile Notes

- a. The profile type needs to match the control type, i.e. single, dual or cascade.

A Cascade profile cannot be run on an instrument set to single or dual loop control. Nor is it possible to run a single loop or dual loop type profile on a controller that is set to Cascade control.

- b. The Slave Maximum Setpoint parameter is not used when the profiles are not running.
- c. Only the Loop 1 Auto-Hold (Master) works when used for Cascade, the Loop 2 Auto-Hold has no effect.
- d. The Slave Maximum Setpoint is only visible when set to Cascade control and Loop 2 Target Setpoint is then hidden.
- e. Slave Maximum Setpoint is hidden when Cascade control is not use, Loop 2 Target Setpoint is then hidden.
- f. The PreTune can be engaged whilst the profile is running, except in a Ramp or Step segment.

## 8.10 Service & Product Information Mode

This is read only information about the instrument, its modules and enabled features. It has contact information to tell the user where they can obtain service, sales or technical support for the product. Normally this is the manufacturer or suppliers' details. Using the PC software, the user can enter their own contact information. There are 7 lines of text - each up to 25 characters in length.

### 8.10.1 Entry into Service & Product Information Mode

The Service & Product Information Mode is entered from the Main Menu

Hold down ► and press ▲ to enter the Main Menu.

Press ▼ or ▲ to select the Service & Product Information Mode

Press ► to enter the Service & Product Information Mode.

#### 8.10.1.1 Navigating Product Information Mode

Press ► to move forward or ◀ to move backwards through the displayed information.

Hold down ► and press ▲ to return to the Main Menu

Scrolling "Help Text" is shown at the bottom of the screens to aid navigation.

| SERVICE & PRODUCT INFORMATION SCREENS: |                                                                                                                                                                                                                 |
|----------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Plug-in Module Information             | Lists the type plug-in modules types in Slots 1, 2, 3 or A – see <i>page 4</i> for a full list of field upgradeable plug-in options.                                                                            |
| Base Options                           | Lists factory fitted base options, from: 2nd Universal/Aux input; Output 4 & 5 Relay; Output 6 & 7 Linear mA/V DC.                                                                                              |
| Optional Features                      | Lists which other optional features are fitted/enabled, from: Profiler; USB Port; Data Recorder and 8 Digital Inputs.                                                                                           |
| Firmware Information                   | The type and version of firmware installed in the instrument.                                                                                                                                                   |
| Product Revision Level                 | Software and Hardware update status.                                                                                                                                                                            |
| Serial Number                          | The instrument serial number.                                                                                                                                                                                   |
| Date of Manufacture                    | The instrument Date of Manufacture (date format is dd/mm/yyyy).                                                                                                                                                 |
| Input 1 Calibration Status             | The base calibration status for each signal type on input 1.<br><b>Caution:</b> Re-calibrate input 1 for mVDC, VDC, mADC, RTD or Thermocouple CJC if they do not say "Calibrated" – see <i>page 76</i>          |
| Input 2 Calibration Status             | The base calibration status for each signal type on optional input 2.<br><b>Caution:</b> Re-calibrate input 2 for mVDC, VDC, mADC, RTD or Thermocouple CJC if they do not say "Calibrated" – see <i>page 76</i> |
| Calibration Check Due Date             | The date re-calibration is due. – only shown if the Calibration Reminder is enabled in the Input Configuration menu.                                                                                            |
| For Service Contact                    | Contact information for service, sales or technical support.                                                                                                                                                    |

## 8.11 Automatic Tuning Menu

The automatic tune menu is used to engage pre-tune and/or self-tune to assist setting up proportional bands and the integral and derivative time values used by the control loops.

Pre-tune can be used to set PID parameters approximately. Self-tune may then be used to optimise the tuning if required. See the Tuning section on page 102 for more information.

Pre-tune can be set to run automatically after every power-up by enabling Auto Pre-Tune.

### 8.11.1 Entry into the Automatic Tuning Menu

The Automatic Tuning Menu is entered from the Main Menu

Hold down ► and press ▲ to enter the Main Menu.

Press ▼ or ▲ to select the Automatic Tuning Menu.

Press ► to enter the Automatic Tuning Menu.

#### 8.11.1.1 Navigating the Automatic Tuning Menu

Press ► to move forward or ◀ to move backwards through the selections.

Press ▼ or ▲ to change values or engage and disengage the tuning as required.

Hold down ► and press ▲ to return to the Main Menu

Scrolling “Help Text” is shown at the bottom of the screens to aid navigation.

| 🔧 AUTOMATIC TUNING MENU SCREENS |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
|---------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Automatic Tuning Mode Unlocking | Enter correct code number to access the Automatic Tuning Menu.<br><i>Factory Default value is 10.</i>                                                                                                                                                                                                                                                                                                                                                                                                                                            |
| Control loop 1 or 2             | Select which control loop you want to tune – <i>if unit has 2 control loops.</i>                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |
| Cascade Mode                    | To pre-tune a cascade slave, select open-cascade.<br> <b>Note:</b> When slave tuning is completed, repeat choosing open-cascade to tune the master.                                                                                                                                                                                                                                                                                                            |
| Pre-Tune Method                 | From: Pre-Tune Standard or Pre-Tune at Value. Standard Pre-Tune tests the process response half-way from the activation point to the setpoint. Pre-Tune at Valve allows the user to specify where the test occurs.                                                                                                                                                                                                                                                                                                                               |
| Pre-Tune Value                  | Sets the value at which the process is tested for Pre-Tune at Valve.<br><b>Caution: Consider possible over-shoot!</b>                                                                                                                                                                                                                                                                                                                                                                                                                            |
| Pre-Tune Save Location          | Store the pre-tune result to one of 5 PID sets. The new PID terms can be stored to any set, <u>without changing</u> the “active set” from control configuration.                                                                                                                                                                                                                                                                                                                                                                                 |
| Run Pre-Tune on Setpoint Now?   |  Turns pre-tune on/off for the <u>chosen</u> PID Set. If configured, the <b>TUNE</b> LED indicator flashes whilst pre-tune is operating - <i>*see below.</i><br> <b>Note:</b> Pre-tune is disabled in on-off control mode; if the PV is less than 5% of span from setpoint; during Profiles; if the setpoint is ramping or if the selected control loop has been disabled. |
| Pre-Tune Status                 | Shows the current pre-tune status: Running or Stopped. If an attempt to run pre-tune failed, the reason is shown.                                                                                                                                                                                                                                                                                                                                                                                                                                |
| Engage Self-Tune                | Turns self-tune on/off for the <u>active</u> PID Set. If configured, the <b>TUNE</b> LED indicator is continuously on whilst self-tune is operating - <i>*see below.</i><br> <b>Note:</b> Self-Tune disabled if control is On-Off or disabled. If engaged during setpoint ramping, profile ramps or pre-tuning it is suspended until the ramp or pre-tune is completed.                                                                                       |
| Self-Tune Status                | Shows current self-tune status: Running or Stopped. If an attempt to run self-tune failed, the reason is shown.                                                                                                                                                                                                                                                                                                                                                                                                                                  |
| Auto Pre-Tune At Power Up       | Enables/disables automatic pre-tune. When enabled, this attempts to tune the <u>active</u> PID set at every power-up (see Run Pre-Tune Now above).<br> <b>Note:</b> Auto Pre-tune applies standard pre-tune engagement rules at power-up. It is disabled in on-off control mode; if the PV is less than 5% of span from setpoint; during Profiles; if the setpoint is ramping or if the selected control loop has been disabled.                              |

\* **TUNE** indication is the default function of LED 3 but the user may have altered the LED functions or the labels using the PC Configuration Software. If LED 3 is used as a **TUNE** indicator, it flashes while pre-tune is operating, and is continuously on whilst self-tune is operating. If both pre-tune and self-tune are engaged the **TUNE** indicator will flash until pre-tune is finished, and is then continuously on.



**Note:** Pre-tune will flash the LED instead of turning it on, but flashing will be obscured if the LED had been configured to be used in conjunction with other functions and one of these is on.

## 8.12 Lost Lock Codes

All menu lock codes can be viewed or changed from configuration mode – *see page 63*. In the event that the configuration mode lock code is forgotten, the instrument can be forced into Lock Code Configuration from power-up, where the codes can be checked or set to new values.

### 8.12.1.1 Forcing Lock Code Configuration

Power down the instrument.

Re-apply the power and hold down ► and ▲ for more than 5 seconds as the start-up splash screen appears. The Lock Code Configuration menu is displayed.

Press ► to move forward or ◀ to move backwards through the screen elements.

Make note of the codes or press ▼ or ▲ to change their values if required.

Hold down ► and press ▲ to return to the Main Menu

Scrolling “Help Text” is shown at the bottom of the screens to aid navigation.

## 9 Input Calibration & Multi-point Scaling

### 9.1 User Calibration

The process inputs can be adjusted to remove sensor errors or to match the characteristics of the attached process. For each loop, independent use of base (unadjusted), single point offset or two point calibration strategies are possible, as is the use of multi-point scaling for the displayed values of linear inputs. These parameters are in the Input 1 & 2 calibration sub-menus of Input Configuration Sub-Menu Screens - *page 46*.



**CAUTION:** Incorrect use of Calibration & Scaling can make the displayed value very different from the actual process variable. There is no front panel indication of when these parameters are in use.



**Note:** These methods do not alter the internal instrument calibration. Simply choose Base Calibration to restore normal measured values.

Re-calibration of the internal base values is possible, but should only be attempted by qualified personnel as it overwrites the factory calibration – see Base Calibration Adjustment below if you think this may be required.


#### 9.1.1 Calibration Reminder

If the Data Recorder feature is fitted, a calibration reminder can be set for a future date. From this date a daily reminder is shown (*and shown at every start-up*), until a new date has been set. This is useful in applications that require a regular check of the measured accuracy – see *Input Configuration Sub-Menu Screens on page 46*.

#### 9.1.2 Single Point Calibration

This is a 'zero offset' applied to the process variable across the entire span. Positive values are added to the reading, negative values are subtracted. It can be used if the error is constant across the range, or the user is only interested in a single critical value.

To use, select Single Point Calibration from the input calibration menu, and simply enter a value equal, but opposite to the observed error to correct the reading.



This example shows a positive offset value. For example:

If the process displays 27.8 when it should read 30, The error is -2.2 so an applied offset of +2.2 would change the displayed value to 30.

The same offset is applied to all values, so at 100.0 the new displayed value would be 102.2.

**Figure 44. Single Point Calibration**

### 9.1.3 Two Point Calibration

This method is used where an error is not constant across the range.

Separate offsets are applied at two points in the range to eliminate both “zero” and “span” errors. To use:

1. Measure and record the error at a low point in the process.
2. Measure and record the error at a high point in the process.
3. Go to the first two point input calibration screen.
  - a. Enter the desired low point value as the Calibration Low PV value.
  - b. Enter an equal, but opposite value to the observed error as the Calibration Low Offset to correct the error at the low point.
4. Go to the second two point input calibration screen.
  - a. Enter the desired high point as the Calibration High PV value.
  - b. Enter an equal, but opposite value to the observed error as the Calibration High Offset to correct the error at the high point.




Figure 45. Two Point Calibration



**CAUTION:** Choose values as near as possible to the bottom and top of your usable span to achieve maximum calibration accuracy. The effect of any error can grow at values beyond the chosen calibration points.

### 9.1.4 Multi-point Scaling

If an input is connected to a linear input signal (mA, mV or VDC), multi-point scaling can be enabled. This allows the linearization of a non-linear signal. – see *Input Configuration Sub-Menu Screens on page 46*.

The Scale Input Upper & Lower Limits define the values shown when the input is at its minimum and maximum values. Up to 15 breakpoints can scale the input vs. displayed value between these limits. It is advisable to concentrate the break points in the area of the range with the most non-linearity, or an area of particular importance to the application.




**Figure 46. Multi-point Scaling**

## 9.2 Base Calibration Adjustment

Calibration of each input type is carried out during manufacture. This can be verified in the Service and Product Info screens.

Re-calibration of the internal base values is possible, but should only be attempted by qualified personnel as it overwrites the factory calibration.

For most applications, base re-calibration is not required during the lifetime of the instrument.

### WARNING:

**BASE CALIBRATION SHOULD ONLY BE PERFORMED IF ERRORS HAVE BEEN ENCOUNTERED. REFER TO CALIBRATION CHECK BELOW.**



**CAUTION:** Any calibration adjustment must only be performed by personnel who are technically competent and authorised to do so. The equipment used must be in a known good state of calibration.

### 9.2.1 Required Equipment

To verify the accuracy of the instrument or to carry out recalibration, a suitable calibration signal source is required for each input type as listed below. Accuracy must be better than  $\pm 0.05\%$  of reading:

1. DC linear inputs: 0 to 50mV, 0 to 10VDC and 0 to 20mADC.
2. Thermocouple inputs - complete with 0°C reference facility, appropriate thermocouple functions and compensating lead wire.
3. RTD inputs: decade resistance box with connections for three-wire input.

### 9.2.2 Performing a Calibration Check

1. Setup input 1 for the input signal type to be checked.
2. Power up the instrument and correctly connect the signal source.  
Leave powered up for at least five minutes for RTD and DC linear inputs, and at least 30 minutes for thermocouple inputs.
3. After the appropriate delay for stabilisation, check the calibration at a number of cardinal points by applying the appropriate input signal.  
The observed readings should be within the tolerances stated in the specifications (*see page 246*).
4. Test the other signal types as above if required.
5. Repeat the process for input 2 if fitted.

### 9.2.3 Recalibration Procedure

For each process input, recalibration is carried out in six phases as shown in the table below; each phase corresponds to a basic input type.



**Note:** The 50mV calibration phase **MUST** always be calibrated before calibration of the thermocouple input.

| INPUT CALIBRATION PHASES |                          |                     |                   |       |                   |       |
|--------------------------|--------------------------|---------------------|-------------------|-------|-------------------|-------|
| Type                     | Signal<br>(<0.05% error) | Cable Type          | Input 1 Terminals |       | Input 2 Terminals |       |
|                          |                          |                     | +                 | -     | +                 | -     |
| <b>Milli-volt</b>        | 50 mVDC                  | Copper Wire         | 2                 | 3     | 6                 | 7     |
| <b>Voltage</b>           | 10 VDC                   | Copper Wire         | 2                 | 3     | 6                 | 7     |
| <b>Milliamps (pt 1)</b>  | 0 mADC                   | Copper Wire         | 3                 | 1     | 7                 | 5     |
| <b>Milliamps (pt 2)</b>  | 20 mADC                  | Copper Wire         | 3                 | 1     | 7                 | 5     |
| <b>RTD</b>               | 200 ohm                  | Copper 3-Wires      | 1                 | 2 & 3 | 5                 | 6 & 7 |
| <b>Thermocouple</b>      | 0°C K type source        | K Thermocouple Wire | 2                 | 3     | 6                 | 7     |

1. For optimum accuracy, leave the instrument power-up for >30 minutes to warm up before beginning the calibration, and then toggle the power off/on to restart the instrument.
2. During the power-up “splash screen”, press ▼ and ► together until the Input 1 Calibration Status screen is displayed.
3. Correctly connect the 1<sup>st</sup> phase signal (50mV), then press ► to select the first phase
4. Press ▼ + ▲ to initiate the calibration.
5. During calibration the message “50mV DC Input Calibrating” will display for a few seconds. This should be followed by the “Calibration Successful” confirmation.
6. If the input is misconnected or an incorrect signal is applied, the calibration will be aborted and the values will not be altered. The display will show “Failed: Signal Too Small!” or “Failed: Signal Too Large!”. Correct the problem and repeat that phase before continuing.
7. Press ► to select the next calibration phase.
8. Repeat this process for each input type until all the phases are calibrated. For each phase, ensure that the correct input is applied, using the appropriate connections.
9. If the instrument has 2 process inputs, when the first input sequence completes, the Input 2 Calibration Status screen is displayed. Repeat the procedure from 3 above for this input.
10. Once calibration is complete, recorder versions will ask for a Calibration Reminder Date. If required, this can be changed to the date of your next calibration check. Ensure that Calibration Reminders are enabled in Input Configuration to receive a reminder.
11. Press ► + ▲ to exit to the main menu.



**Note:** The Calibration Mode automatically exits if there is no button activity for two minutes.

# 10 Digital Inputs

Digital inputs are driven to one of two states (active or inactive) by an applied voltage signal or a contact opening/closing.

A total of 9 physical digital inputs are possible on this instrument. A multiple digital input can be installed at time of purchase, and a single plug-in module can be fitted in option slot A.

## 10.1 Digital Signal Type


The digital inputs can be connected to volt-free contacts, or to a voltage signal (compatible with TTL). They can often be used in parallel with equivalent menu selections, where either can change function status.

Some inputs are level sensitive, while others are edge sensitive requiring a High to Low or Low to High transition to change functions status. Pre-Tune is always off at power-up (except if auto pre-tune is enabled), but other edge sensitive functions retain their power off status at power on. *See the tables below for details.*

Open contacts (>5000Ω) or 2 to 24VDC signal = Logic High (*logic low if inverted*).  
Closed contacts (<50 Ω) or -0.6 to +0.8VDC signal = Logic Low (*logic high if inverted*).



**CAUTION:** The response time is ≥0.25 seconds. Signals applied for less than this time may not register and the function might not change state.



Digital Input Setup  
Status A 81828384  
C1 C2 C3 C4 C5 C6 C7 C8  
Profile Dis Mode : BCD  
Profile Dis Value : 6

A diagnostic screen assists commissioning and fault finding by showing the current signal state for all digital inputs.

Slot A, C1 to C8 & Soft digital input status (☑ = Active, ∅ = Unavailable)


Profile select bit format (BCD or Binary)

Profile selected (example shown: C1-C3 = 011 = 6)

### 10.1.1 Inverting Digital Inputs

Digital inputs can be inverted to reverse their action making an “on” input behave as off. Step thorough each input using the ➤ key. Press ▲ to invert ☑ the highlighted input and ▼ to un-invert ☐. Hold ➤ down to skip to next screen accepting the values shown.


Highlighted Input



Digital Input Setup  
Tick Inputs to Invert  
A 1 2 3 4 5 6 7 8  
☐ ☐ ☑ ☑ ☐ ☐ ☐ ☐

## 10.2 Soft Digital Inputs

In addition to the physical digital inputs, four “soft” digital inputs are available. They are used to select functions in the same way as the physical inputs.



The four soft digital inputs can be configured by combining physical inputs, alarms & events using Boolean logic. Input AND selections are then globally OR'd with the input OR selections, the alarms & the events. By using the invert inputs function, NAND & NOR equivalents can be created.

## 10.3 Digital Input Functions

Some or all of inputs C1 to C7 can be used for profile selection. If used in this way they cannot be used for any other functions.

Soft inputs and any physical digital inputs not allocated for profile selection can be used to change the instrument status.

Each input can only perform a single function.

The possible functions are listed below.



### 10.3.1.1 Single Functions

Digital inputs can often work in parallel with equivalent menus, where either can change function status.

In the table below, ■ = Level Sensitive: Where a High or low signal sets the function status.

▮ = Edge Sensitive: High-Low or Low-High transition changes the function status.

Pre-Tune is always off at power on (except if auto pre-tune is in use), and profile recovery is as configured, but others functions retain their power off status when the power returns.

| Function                  | Logic High* | Logic Low*   | Sensitivity / Functions' Power On State |
|---------------------------|-------------|--------------|-----------------------------------------|
| Loop 1 Control Select     | Enabled     | Disabled     | ▮ / Retained                            |
| Loop 2 Control Select     | Enabled     | Disabled     | ▮ / Retained                            |
| Loop 1 Auto/Manual Select | Automatic   | Manual       | ▮ / Retained                            |
| Loop 2 Auto/Manual Select | Automatic   | Manual       | ▮ / Retained                            |
| Loop 1 Setpoint Select    | Main SP     | Alternate SP | ▮ / Retained                            |
| Loop 2 Setpoint Select    | Main SP     | Alternate SP | ▮ / Retained                            |
| Loop 1 Pre-Tune Select    | Stop        | Run          | ▮ / OFF                                 |
| Loop 2 Pre-Tune Select    | Stop        | Run          | ▮ / OFF                                 |
| Loop 1 Self-Tune Select   | Stop        | Run          | ▮ / Retained                            |
| Loop 2 Self-Tune Select   | Stop        | Run          | ▮ / Retained                            |

|                                  |            |             |                      |
|----------------------------------|------------|-------------|----------------------|
| Profile Run/Hold                 | Hold       | Run         | ⌈ ⌋ / As configured  |
| Profile Hold Segment Release     | No Action  | Release     | ⌈ ⌋ / Retained       |
| Profile Abort                    | No Action  | Abort       | ■ / As Digital Input |
| Data Recorder Trigger            | Not Active | Active      | ■ / As Digital Input |
| Output <i>n</i> Forcing          | Off/Open   | On/Closed   | ■ / As Digital Input |
| Clear All Latched Outputs        | No Action  | Reset       | ■ / As Digital Input |
| Output <i>n</i> Clear Latch      | No Action  | Reset       | ■ / As Digital Input |
| Key <i>n</i> Mimic (for ◀ ▶ ▲ ▼) | No Action  | Key Pressed | ■ / As Digital Input |

### 10.3.1.2 Profile Selection via digital inputs

For instruments with the profiler option, the multi-digital input option can be used to select the profile to run using either a standard binary bit pattern, or binary coded decimal from BCD switches. Profile selection inputs are all level sensitive (■), with a high/open signal equating to a binary 1 (assuming non-inverted), and a low/closed signal equating to a binary 0 (assuming non-inverted).

Profiles are numbered 0 to 63. Select inputs C1 to C<sub>n</sub> for the required number of profiles, from the table:

|                                                                                                                                                                                                                                                                                                                                                       | C1                            | C1 to C2                    | C1 to C3                  | C1 to C4                    | C1 to C5                 | C1 to C6               | C1 to C7             |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------|-----------------------------|---------------------------|-----------------------------|--------------------------|------------------------|----------------------|
| Binary                                                                                                                                                                                                                                                                                                                                                | 0 to 1                        | 0 to 3                      | 0 to 7                    | 0 to 15                     | 0 to 31                  | 0 to 63                |                      |
| BCD                                                                                                                                                                                                                                                                                                                                                   | 0 to 1                        | 0 to 3                      | 0 to 7                    | 0 to 9                      | 0 to 19                  | 0 to 39                | 0 to 63              |
| Using Binary To Select Profile Numbers                                                                                                                                                                                                                                                                                                                |                               |                             |                           |                             |                          |                        |                      |
| Selection of profiles is via a simple binary bit pattern. C1 is the least significant bit (LSB).                                                                                                                                                                                                                                                      |                               |                             |                           |                             |                          |                        |                      |
|                                                                                                                                                                                                                                                                                                                                                       | C6 to C1                      | C5 to C1                    | C4 to C1                  | C3 to C1                    | C2 to C1                 | C1                     |                      |
|                                                                                                                                                                                                                                                                                                                                                       | 000000 to 111111<br>(0 to 63) | 00000 to 11111<br>(0 to 31) | 0000 to 1111<br>(0 to 15) | 000 to 111<br>(0 to 7)      | 00 to 11<br>(0 to 3)     | 0 to 1<br>(0 to 1)     |                      |
| Using BCD To Select Profile Numbers                                                                                                                                                                                                                                                                                                                   |                               |                             |                           |                             |                          |                        |                      |
| A single BCD switch can be used to select profiles 0 to 9 using C1 to C4, with a bit pattern identical to standard binary. For larger numbers, a double BCD switch arrangement is needed. A separate binary pattern is applied to C5 to C7 for the “tens” digit (10 = 001, 20 = 010, 30 = 011 etc). Any number combination higher than 63 is invalid. |                               |                             |                           |                             |                          |                        |                      |
|                                                                                                                                                                                                                                                                                                                                                       | Multiples of ten (0x to 6x)   |                             |                           | Multiples of one (x0 to x9) |                          |                        |                      |
|                                                                                                                                                                                                                                                                                                                                                       | C7 to C1                      | C6 to C1                    | C5 to C1                  | C4 to C1                    | C3 to C1                 | C2 to C1               | C1                   |
|                                                                                                                                                                                                                                                                                                                                                       | 000 to 110<br>(0x to 6x)      | 00 to 11<br>(0x to 3x)      | 0 to 1<br>(0x to 1x)      | 0000 to 1001<br>(x0 to x9)  | 000 to 111<br>(x0 to x7) | 00 to 11<br>(x0 to x3) | 0 to 1<br>(x0 to x1) |

# 11 Cascade Control

Applications with long time lags (e.g. with two or more capacities such as heated jackets) can be difficult to control with a single control loop. The solution is to split the process into two or more cascaded loops consisting of a Master and Slave(s) acting on a common actuator. Ideally, the slave loop's natural response time should be at least 5 times faster than the master.

The master controller measures the process temperature and compares it to the desired product setpoint. Its correcting variable (0 to 100% PID output) becomes the slave's effective setpoint (scaled to suit the process). This setpoint is compared to the slave's process input, and the controlling actuator is adjusted accordingly.



**Note:** Cascade control is only available on models fitted with the 2nd control loop. The master loop uses input 1; and the slave loop uses input 2.

## 11.1 Example Cascade Application

In this example the controlling actuator is a heater, indirectly heating the product via an oil jacket. The maximum input to the slave represents 300°C, thus restricting the jacket temperature. At start-up the master compares the product temperature (ambient) to its setpoint (250°C) and gives 100%. This sets the maximum slave setpoint (300°C), which is compared to the oil temperature (ambient) and the slave requests maximum heater output.




**Figure 47. Cascade example**

As the oil temperature rises towards the slave setpoint, its output falls. Gradually, the product temperature will also begin rising, at a rate dependant on the transfer rate/lag between the oil jacket and the product. Eventually this causes the master's PID output to decrease, reducing the slave setpoint. The oil temperature is reduced towards the new slave setpoint. This continues until the system becomes balanced. The result is quicker, smoother control with the ability to cope with changes in the load. Overshoot is minimised and the jacket temperature is kept within acceptable tolerances.

## 11.2 Normal Cascade Operation

During operation, the master and slave are coupled together and. "**Cascade**" is displayed. The master process value and setpoint are most relevant to the user. The master setpoint is directly adjustable. The process value of the slave controller is displayed for information only.

## 11.3 Cascade-Open

The cascade can be disconnected via menu selection, switching from normal operation to direct control of the slave. "**Cascade-Open**" is displayed. Opening the cascade is "Bumpless". The current cascade value is used as the initial slave setpoint (displayed as "**SlaveSP**"). The process is then controlled and adjusted solely by the slave controller using this setpoint. Switching back to Cascade is also bumpless.



**CAUTION:** The master process value is not under control when the cascade is open, but will be affected by the slave process. The operator is responsible for maintaining safe conditions.

## 11.4 Manual Mode

The controller can be put into manual mode (via digital inputs or menu selection), switching from normal operation to direct control of the slave loop's correcting variable. Manual power is adjusted from 0% or -100 to 100%. "**MAN**" is displayed.



**CAUTION:** Manual mode disables the cascade loop. It also ignores any output power limits, valve open/close limits and the control enable/disable setting. The operator is responsible for maintaining the process within safe limits.

## 11.5 Cascade Tuning

The user can tune the slave and master loops manually, or use the pre-tune feature (see Controller Tuning on page 102).

In either case the slave control loop must first be optimised on its own, followed by the master loop in combination with the previously tuned slave.

### 11.5.1 To automatically pre-tune a cascade:

1. Go to the Automatic Tuning menu
2. Select "Cascade-Open" from the pre-tune menu to tune the PID set(s) on the slave.
3. After the slave has successfully tuned, pre-tune the master/slave combination by selecting "Cascade-Closed" from the pre-tune menu.



**Note:** The cascade remains open until you pre-tune the master or manually select Cascade-Closed.

### **11.5.2 To manually tune a cascade:**

1. Select Cascade-Open from the Cascade Control menu, breaking the link between the master and slave loops.
2. Set the slave controller setpoint manually to the appropriate value for your application.
3. Tune the slave for relatively fast control ('proportional only' is often sufficient).
4. Select Cascade-Closed from the Cascade Control menu to link the master and slave loops, then tune the master/slave combination.

## 12 Ratio Control

A ratio control loop is used where the quantity of one of the material is to be controlled in proportion to the measured quantity of a second material. The controller mixes the materials at the desired ratio by adjusting the flow of input 1. The flow of input 2 may be controlled separately, but is not controlled by the ratio control loop itself.

The process value used by the controller is therefore determined by the ratio of the two inputs rather than a single measured variable.



**Note:** Ratio control is available on models with the 2<sup>nd</sup> Auxiliary Input, or two loop models. The feature and information displayed is optimised for control of burner fuel/air, but can be used in other flow ratio applications.

### 12.1 Stoichiometric Combustion

Below is an example of stoichiometric combustion ratio control. For optimum combustion the fuel-air ratio is set so that there are no flammable residues in the waste gas.




**Figure 48. Ratio Control Example**

It is normal in this application to display the process value and setpoint as relative values rather than the physical ratio or absolute values. A scaling factor is set such that the displayed value will be 1.00 at the correct stoichiometric ratio for the application.

Inputs 1 and 2 are configured and scaled to match the attached flow meters.

In this example a 4 to 20mA signal at x1 represents 0 to 1000m<sup>3</sup>/h of airflow controlled by a valve. The second 4 to 20mA signal at x2 represents 0 to 100m<sup>3</sup>/h of fuel oil. The fuel flow is not affected by this control loop. Atomizing air is fed in with the fuel oil at a constant rate 'NO'. This must be considered when calculating the correct fuel/air mix. Total airflow is x1 + NO.

The stoichiometric factor, *SFac* is entered to match the desired ratio. E.g for 10 parts total airflow to one part fuel, *SFac* would be 10.

The setpoint (entered as a relative value such as 1.00) is multiplied by *SFac* when calculating the control deviation. E.g. with a setpoint of 1.00 and *SFac* of 10 the controller attempts to make the physical ratio 10. With a setpoint of 1.03 it would attempt to make the ratio 10.3 for 3% excess air.


The instantaneous (controlled) process value is calculated from the physical ratio, divided by *SFac*. Like the setpoint, this is displayed as relative value.

E.g. if *SFac* is 10, with 59.5m<sup>3</sup>/h airflow measured at *x1*, 0.5m<sup>3</sup>/h atomising air applied at *NO* and 6m<sup>3</sup>/h fuel is measured at *x2*, the instantaneous process value would be:

$$\frac{x1+NO}{x2*SFac} = \frac{59.5+0.5}{6*10} = 1.00$$

If fuel flow remained at 6m<sup>3</sup>/h and the setpoint was adjusted to 1.05 (5% excess air), the controller would increase the *x1* air flow to 62.5m<sup>3</sup>/h.

$$\frac{x1+NO}{x2*SFac} = \frac{62.5+0.5}{6*10} = 1.05$$



Typical Ration display with Setpoint at 1.05

## 13 Redundant Input

If the 2<sup>nd</sup> universal input is fitted, the second input can be configured as a redundant input for the main process input. This increases process security by protecting against the possible loss of valuable product resulting from sensor failure.

A second sensor is connected to input 2 so that if the main sensor fails, the instrument automatically switches to this backup or “redundant” sensor.

In this condition, if input 1 has a signal break alarm configured it will activate, but any other process input or control status alarms seamlessly switch to the 2<sup>nd</sup> input. The 2<sup>nd</sup> input continues to be used until the signal to input 1 is restored.



**Note:** The user may not even be aware of a sensor fault, so it is strongly recommended that signal break alarms are configured for both inputs to provide a notification if problems occur.

The redundant sensor must be of the same type, and be correctly located in the application ready to take over if needed. If the redundant input option is selected, the 2<sup>nd</sup> input cannot be used for other functions.



**Note:** If both signals are lost at the same time, the PV value display is replaced with “**OPEN**” and the normal sensor break actions occur.

## 14 Valve Motor Drive / 3-Point Stepping Control

When directly controlling the motor of a modulating valve or damper, set the Control Mode to VMD in configuration mode to enable the 3-point stepping Valve Motor Drive control algorithm.

The term “3-point stepping” is used because there are 3 output states, open valve, close valve or stopped (no action). Switched outputs move the valve further open, or further closed when a control deviation error is detected. If the error is reduced to zero, no further output is required until the load conditions change.


VMD mode doesn't allow on-off control (the minimum proportional band equates to 0.5% of the scaled input span) and usually requires PI control, where the derivative parameter is set to OFF.



**Note:** Some modulating valves have positioning circuitry to adjust the valve position. These require a DC linear mA or voltage output and use the standard control algorithm (Set Control Mode to Standard).

### 14.1 Special Wiring Considerations for Valve Motor Control

Valve motor drive mode must have two identical outputs assigned to position the valve. One to open and one to close the valve. These outputs can be two single relays, two triacs, two SSR drivers or one dual relay, but it is recommended to use two single relays (SPDT change-over contacts), and to interlock the wiring as shown. This prevents both motor windings from being driven at the same time, even under fault conditions.



**CAUTION:** The windings of a valve motor effectively form an autotransformer. This causes a voltage doubling effect when power is applied to either the Open or Close terminal, causing twice the supplied voltage at the other terminal.

Switching actuators directly connected to the valve motor must only be used up to half of their rated voltage. The internal relay and triac outputs in this instrument are rated at 240VAC. Therefore, the maximum motor voltage when using them is therefore 120V unless interposing relays are used. Interposing relays or other devices used to control the valve must themselves be rated for twice the motor supply voltage.

## 14.2 Position Feedback

In VMD mode this instrument uses a boundless (open-loop) 3-point stepping algorithm. It does not require any kind of position feedback in order to correctly control the process and can therefore avoid problems associated with faulty feedback signals.

However, where valve feedback is available it can still be displayed in a bar-graph as a percentage open (0 to 100%). Position feedback is usually provided by means of a potentiometer mechanically linked to the valve. The output of a related flow meter can also be used to indicate the relative valve position. Flow meters typically have linear 0-20/4-20mA or 0-5/0-10V signals. To display the position/flow signal the 2nd input must be configured for this purpose.

The input is adjusted and scaled to show 0 to 100% representing valve fully closed to fully open, or a flow rate equating to fully closed to fully open. The valve position scaling parameters are set in the Input Configuration sub menus – *see page 46*.

### 14.2.1 Valve Limiting

When valve position/flow indication is in use, the signal can be used by the controller to limit the valve movement. Upper and/or lower limits can be set beyond which it will not attempt to drive the valve. The valve open and close limits are set in the Control Configuration sub menu – *see page 49*.



**CAUTION:** These limits must be used with care. They are effectively control power limits. Do not set values that prevent proper control of the process!

## 15 Setpoint Sources

The setpoint is the target value at which the instrument attempts to maintain the process variable. Each loop can have a Main “local” setpoint set from the keypad and an Alternate setpoint.

### 15.1 Loop 1 Setpoint Sources

Loop 1 can have a Main “local” setpoint set from the keypad and an Alternate setpoint.

The alternate setpoint source can be either another local Setpoint or a remote setpoint (RSP), set by a mA or V DC signal applied to the 2nd input or to auxiliary input A. The control loop can only use one setpoint source at a time for each loop. This is called the “Active Setpoint”. If the profiler option is fitted this provides the setpoint when the profiler is in use, replacing both main and alternate setpoints.

Main/alternate setpoint selection can be made via a digital input; from the Control Configuration menu or if enabled in the Display Configuration sub-menu, an operator screen can be used to select the setpoint. The chosen setpoint selection method can be used to permanently select one of the setpoints, or allow switching between them.

*Refer to the Control Configuration Sub-Menu Screens on page 49 for setpoint settings.*

#### 15.1.1 Loop 1 Profile Setpoint

When in profile control mode, the selected profile always provides the active setpoint source for loop 1 (see page 90). Once profile control mode is exited, the selected main or alternate setpoint for loop 1 becomes active again.

### 15.2 Loop 2 Setpoint Sources

Loop 2 can have a Main “local” setpoint set from the keypad and an Alternate setpoint.

The alternate setpoint source can be either another local Setpoint or a remote setpoint (RSP), set by a mA or V DC signal applied to auxiliary input A. The control loop can only use one setpoint source at a time for each loop. This is called the “Active Setpoint”. If the profiler option is fitted this provides the setpoint, replacing both main and alternate setpoints, when 2-loop profiling is in use.

Main/alternate setpoint selection can be made via a digital input; from the Control Configuration menu or if enabled in the Display Configuration sub-menu, an operator screen can be used to select the setpoint. The chosen setpoint selection method can be used to permanently select one of the setpoints, or allow switching between them.

*Refer to the Control Configuration Sub-Menu Screens on page 49 for setpoint settings.*

#### 15.2.1 Loop 2 Profile Setpoint

If the selected profile was configured to control the setpoint of both loops, it will provide the active setpoint source (see page 90). Once profile control mode is exited, the selected main or alternate setpoint for loop 2 becomes active again.

# 16 Profiler

This section covers the Profiler (*or setpoint programmer*) option. To confirm if profiling is enabled on your controller, refer to the Service & Product Info menu (see page 71).

## 16.1 Introduction

The Profiler feature allows the user to store up to 255 profile segments, shared between a maximum of 64 Profiles. Each profile controls the value of the setpoint over time; increasing, decreasing or holding their values as required. The profile can control both setpoints if the 2<sup>nd</sup> control loop is fitted.

Profiler options and screens are added to the Main Menu and Operation Mode – *See pages 67, 70 & 36.*

## 16.2 Profiler Enabling

Controllers supplied without the Profiler option installed can be upgraded by purchasing a licence code number. Refer to the Field Upgrade information on page 4.

To obtain the correct code you must tell your supplier the instrument serial number – this can be found in the Service & Product Info menu (see page 71).

To enter the licence code, hold down the ◀ + ▼ keys during the power-up splash screen. Enter the 16-character licence code in the displayed screen and press ▶.

## 16.3 Profile Components

General profile configuration settings apply to all profiles. They enable or disable “profile editing while running”, and automatic starting of the selected profile if it has been configured with a delay or day & time start trigger.

If delay or day & time start triggers are disabled, profiles can only be manually started, and this is with immediate effect even if they have a delay or day & time trigger defined.

If delay or day & time start triggers are enabled, delayed starts are possible, and if the selected profile has a day & time trigger it will wait until the time set and before starting.



**Note:** Even if profile editing is enabled, changes to the current and next segment or a running profile will not take effect until the profile is next run. Changes to other segments will take effect immediately.

### 16.3.1 Profile Header & Segment Information

Each profile has its own header information plus 1 or more segments. The header information is unique for each profile, it contains the profile’s name; if it controls just one or both loops; how it should start & stop; the abort & power-loss recovery actions; and how many times it should be repeated.



**Note:** Profile Header information is only stored to memory as the Segment creation sequence begins. No profile is created if you exit before this point. Segment information is stored as each segment is created, but the profile remains invalid until an end or join segment is defined.

Segments can be ramps, dwells, steps or special segments such as holds, ends, joins or loop-backs.

If the instrument also has the data recorder option, its real time clock (RTC) expands the profiling capabilities by adding Day & Time profile start options, releasing of hold segments at a specific time of day and changing the power fail recovery option to one based on the length of time the power has been off. These features are explained below and in the Profiler Setup and Profile Control menus (*See pages 67 & 70*).

### 16.3.2 Profile Starting & Standard Segments

The example profile below explains the standard segment types required to make a simple profile or profile sequence. A **Start Trigger** is the instruction to begin the selected profile. This can be from the profile control menu, a digital input signal, via a serial communications command or if enabled in the display configuration, the profile can be controlled from an operator screen.

Following a Start Trigger, profiles can start immediately, after a delay, or using the Day & Time start timer (*Day & Time start available on with the Recorder option only*). Following the start trigger, the remaining delay time or the start day & time are shown in the profile status bar-graph until the profile begins running.



**Note:** Profiles outside current setpoint limits will not run, A “profile not valid” error shows if you attempt to run a profile under these circumstances.




**Figure 49. Profile Starting and Standard Segment Types**

Ramps and Step Segments have target setpoint that they will reach as they finish.

If a segment is a **Ramp-Time** type, the slope needed to reach the target setpoint in the defined time will change depending on the starting setpoint value.

For a **Ramp-Rate** segment, the slope is defined by the segments Ramp Rate, so the time to reach the target setpoint will change instead. This is of particular significance for the first segment, since the starting value of the process may not be known in advance.



**Note:** When using the instrument as a two loop profiler Ramp-Rate type segments are not available. Calculate the time from the starting value to the target setpoint and use Ramp-Time instead.

A **Dwell** (often called a “soak”) holds the previous setpoint value for the specified dwell time.

**Step** segments jump straight to the new target setpoint value.

An **End** segment ends the profile or profile sequence.

If the last segment is a **Join**, the “join target” profile will begin running.



**Note:** If the join target has been deleted the profile sequence will abort and the last profiles abort action will apply.

### 16.3.3 Two Loop Profiles


If the instrument is configured to control two control loops, the setpoint of both loops can be maintained when profiling. Both setpoints are synchronised to a common segment time-base, but have independent target setpoints for each of the segments.



**Note:** When using the instrument as a two loop profiler Ramp-Rate type segments are not available. Calculate the time from the starting value to the target setpoint and use Ramp-Time instead.

The example below shows how two loop profiling works in practice.

Auto-Hold settings and target setpoints are independent for each loop, but the segment types and time settings are the same.



Seg. ① & ② shows a ramp and a dwell with the shared time base

The ramp direction can be different (Seg. ③), and although one loop cannot ramp while the other dwells, a "dwell" is achieved by a ramp with its final setpoint value at the same value as the previous segment (Seg. ④). Similarly, if only one loop is to Step to a new value, make the other "step" to its existing setpoint value. If you later change the previous setpoint, you may have to change both segments.

The Loop-back feature takes both loops back to the same defined earlier segment.



**Note:** Auto-Hold settings are independent for each loop. Either loop can cause the profile to auto-hold, holding both loops at the current setpoint value. The profile continues only when both loops are back within their hold bands.

### 16.3.4 Loop-back Segments

A **Loop-back** segment goes back to a specified segment in the current profile. This action is repeated for the required number of times (1 to 9999) before the profile continues onwards. More than one Loop Segment can be used in a profile, but they cannot cross.




Figure 50. Loop-back Segments

## 16.4 Profile Running / Holding vs. Hold Segments




Figure 51. Run/Hold & Hold Segments

A **Hold** condition during a segment maintains the current profile setpoint value(s). Once the hold condition is stopped the Ramp or Dwell continues. The user can request that the profile holds, or it can be instigated automatically.



**Note:** A running segment will hold if the operator or a digital input instructs it to. It can also hold due to “auto-hold”, if one of the profile control loops is disabled, if a cascade is set to “open” or if manual control is selected.

A **Hold Segment** is a pre-planned hold programmed into the profile. It maintains the value of the previous segment and the profile does not continue until a **Continue Trigger** occurs. This can be via a key-press, serial communications, a digital input signal or after waiting until a pre-set time of day (*time of day is available with the recorder option only*).

## 16.5 The Auto-Hold Feature

There are independent auto-hold settings for each segment of each loop controlled by the profile. When utilised, auto-hold ensures that the profile and the actual processes remain synchronised. If the process does not closely match the setpoints (within the defined **Hold Bands**), the profile will be held until it returns within bounds. When Auto-Hold becomes active, the profile status is shown as “Held”.



**Note:** The segment time is increased by the time that the process is out of bounds, extending the total profile run time.

Auto-hold can be configured to hold the profile if the process goes beyond the hold band **Above The Setpoint** only, **Below The Setpoint** only or it can be set to **Band** (either side of the setpoint).



**Note:** For two-loop profiles, either loop can cause the profile to hold. The entire profile (i.e. both loops) will be held if either process is outside of its auto-hold band. It continues only when both loops are back within their auto-hold bands.

## 16.5.1 Auto Hold Examples

### 16.5.1.1 Auto Hold on Dwells




**Figure 52. Auto-Hold on a Dwell Segment**

During a Dwell, the dwell time is increased by the time that the process is outside of the hold band in the selected direction(s). This ensures the process was at the desired level for the required amount of time.

### 16.5.1.2 Auto Hold on Ramps




**Figure 53. Auto-Hold On A Ramp Segment**

During a Ramp segment, the ramp is held at the current setpoint value while the process is outside of the hold band in the selected direction(s). The time taken to complete the ramp is increased by the time taken by the Auto-Hold.

## 16.6 Profile Cycles & Repeat Sequences

A profile can be configured to run itself from 1 to 9999 times or continuously using the Profile Cycles setting. A profile ending with **Repeat Then End** will run the entire sequence of profiles again from 1 to 9999 times before ending.





Figure 54. Profile Cycles & Repeats

## 16.7 Power/Signal Lost Recovery Actions

If the power is cut or the input signal is lost while a profile is running, the instrument will use the defined **Profile Recovery Method** once the signal / power returns. The profile recovery method is set in the profile header.

The possible profile recovery options are explained below.



### Possible Recovery Methods:

- A End the profile and maintain the setpoint value(s) from the time the power failed.
- B End the profile and use Controller Setpoint value(s).
- C End the profile with the Control outputs off - *setpoint value replaced by "OFF"*.
- D Restart the profile again from the beginning.
- E Continue profile from the point it had reached when the power failed

See note  
below

**Figure 55. End, Abort and Recovery Actions**



**Note:** Recorder versions always use option E (Continue profile) if the "off time" is less than the Profile Recovery Time setting. If the "off time" is longer, the defined Profile Recovery Method is used.




**Note:** With option E, after the power returns profile bar graph resets and shows the remaining/elapsed time for the profile only since re-starting.

## 16.8 Profile End Actions

Once a running profile ends, that profiles' **Segment End Type** defines the action taken by the instrument. If a sequence of profiles are joined together, the End Segment Type of the last profile in the sequence will be carried out when it completes. The end segment type is set in the final profile segment data.

The possible profile end actions are explained below.



### Possible Profile End Actions:

- See note below
- A** At profile end, maintain the Final Setpoint value(s) of the last segment.
  - B** At profile end, exit Profiler Mode and use the Controller Setpoint value(s).
  - C** At profile end, remain in Profiler Mode with the Control outputs off.

**Figure 56. Profile End Action**




**Note:** When using two loop profiles, the end-action applies to both loops, but each ends with its own individual setpoint in line with the method chosen.

## 16.9 Profile Abort Actions

If a running profile is forced to end early, the **Profile Abort Action** defines action taken by the instrument. The profile abort action is set in the profile header.

If a profile sequence is forced to end early, the profile abort action of the current segment will be used.

The possible abort options are explained below.



### Possible Profile Abort Actions:

- See note below
- A Abort the profile and maintain the value of the setpoint at the time of the abort.
  - B Abort the profile and exit Profiler Mode using the Controller Setpoint value.
  - C Abort the profile and remain in Profiler Mode with the Control outputs off.

**Figure 57. Profile Abort Action**



**Note:** When using two loop profiles, the abort-action applies to both loops, but each ends with its own individual setpoint in line with the method chosen.

# 17USB Interface

The features in this section are available on models fitted with the optional USB Interface.

## 17.1Using the USB Port


The USB Interface can be used to upload or download instrument settings to or from a USB memory stick (FAT32 formatted). Easy configuration of multiple instruments is achieved by copying from one instrument to another, or by transferring data from the PC configuration software. If the Data Recorder or Profiler options are fitted, recordings and profile information can also be transferred via USB memory stick. *Refer also to the USB menu on page 63.*

### 17.1.1 USB Memory Stick Folders & Files

When a USB stick is inserted, the instrument looks for, and if necessary creates the **DEVICE**, **CONFIG**, **PROFILE** and **RECORDER** folders. Files must be located in these folders in order to be used by the instrument. When preparing to upload files from your PC, ensure that you save them to the correct folder on the memory stick.



**CAUTION:** If the file name already exists, data will be overwritten.



**Note:** To speed up the disk operation, keep the number of files in these folders to a minimum.

The first recorder log file is named 001-0001.csv. A new file is created with the first 3 digits incremented (e.g. **002**-0001.csv; **003**-0001.csv etc) each time the data being recorded is changed. The last 4 digits increment (e.g. 001-0002.csv; 001-0003.csv etc) if the file size reaches 65535 lines, if a recording is stopped then re-started or if there is a period of >10s without an alarm when recording from an alarm trigger.



**CAUTION:** Do not remove the memory stick during data transfer. Data corruption may result.



**CAUTION:** During data transfer, normal operations carry on in the background, but operator access is denied. Transfer of full memory can take up to 20 minutes. Only begin a transfer when access to the instrument (e.g. setpoint changes) will not be required.

# 18Data Recorder

The optional Data Recorder allows the recording of process conditions to memory over time. It operates independently from the Trend Views. The recorder includes 1Mb of flash memory to store data when powered down and a real time clock (RTC) with a battery backup.



**CAUTION:** Servicing of the Data Recorder/RTC circuit and replacement of the internal lithium battery should be carried out by only a trained technician.

## 18.1Recordable Values

A selection of values can be recorded for each control loop, from: Process Variable; Maximum or Minimum Process Values (since the previous sample); Setpoints; Primary Power, Secondary Power or Auxiliary Input values. Additionally the status of Alarms and Profiler Events can be recorded, as can when the unit is turned On/Off. *See the Recorder Configuration sub-menu on page 59.*

Sampling rates between 1 second and 30 minutes are possible, with the data either recorded until all memory is used, or with a continuous “First In/First Out” buffer overwriting the oldest data when full.

The recording capacity is dependent on sample rate and number of values recorded. For example: Two analog values will record for 21 days at 30s intervals. More values or faster sample rates reduce the duration proportionally.



**Note:** If recorded, each alarm/event change forces an extra sample to be recorded, reducing the remaining recording time available. If these are likely to change often, take this into account when determining if there is sufficient memory available.

### 18.1.1 Recorder Control and Status

Options for starting/stopping recordings include **Manually** (from the recorder menu or a screen added to operation mode); a **Digital Input**; during a **Running Profile**; or **Record on Alarm**. *See the Recorder Configuration sub-menu on page 59.*

The recorder control menu (page 66) allows the manual trigger to be started or stopped, as well as deleting recorded data from memory.

A status screen is shown with current information about the recorder, including if a recording is in progress (Recording or Stopped); the recording mode (FIFO or Record Until Memory Is Used); a % memory use bar-graph and the estimated available time remaining based on the data selected and memory used.

These icons are displayed for each active recording trigger.



**Manual Record**



**Alarm Record**



**Digital Input**



**Profile Record**

Recorder status and manual record trigger control can optionally be added to

Operation Mode. This is enabled or disabled in the Display Configuration sub-menu on page 62.



**Note:** The recorder control screens allow the manual trigger to be started or stopped, but recording will continue as long as any trigger that has been configured is active.

## 18.1.2 Uploading Data

Recordings can be transferred to a memory stick using the USB Port (*See page 99*). They can also be uploaded directly to the PC software via the configuration port or RS485/Ethernet communications if fitted.

|    | A                             | B        | C      | D           | E           | F           | G       |
|----|-------------------------------|----------|--------|-------------|-------------|-------------|---------|
| 1  | SerialNumber=00724406-003-010 |          |        |             |             |             |         |
| 2  | FileDate=06.08.2013 09:41:09  |          |        |             |             |             |         |
| 3  | Date(en)                      | Time     | PV1    | Alarm 1 St: | Alarm 2 St: | Alarm 3 St: | Alarm 4 |
| 4  | 01/08/2013                    | 18:33:40 | 199.76 | 0           | 0           | 0           |         |
| 5  | 01/08/2013                    | 18:33:52 | 199.8  | 0           | 0           | 0           |         |
| 6  | 01/08/2013                    | 18:34:14 | 199.84 | 0           | 0           | 0           |         |
| 7  | 01/08/2013                    | 18:34:24 | 199.88 | 0           | 0           | 0           |         |
| 8  | 01/08/2013                    | 18:34:34 | 199.92 | 0           | 0           | 0           |         |
| 9  | 01/08/2013                    | 18:34:44 | 199.96 | 0           | 0           | 0           |         |
| 10 | 01/08/2013                    | 18:34:54 | 200    | 0           | 0           | 0           |         |
| 11 | 01/08/2013                    | 18:35:04 | 200.04 | 0           | 1           | 0           |         |
| 12 | 01/08/2013                    | 18:35:14 | 200.08 | 0           | 1           | 0           |         |
| 13 | 01/08/2013                    | 18:35:24 | 200.12 | 0           | 1           | 0           |         |
| 14 | 01/08/2013                    | 18:35:34 | 200.16 | 0           | 1           | 0           |         |
| 15 | 01/08/2013                    | 18:35:44 | 200.2  | 0           | 1           | 0           |         |
| 16 | 01/08/2013                    | 18:35:54 | 200.24 | 0           | 1           | 0           |         |
| 17 | 01/08/2013                    | 18:35:58 | 200.28 | 0           | 1           | 0           |         |
| 18 | 01/08/2013                    | 18:36:08 | 200.32 | 0           | 1           | 0           |         |
| 19 | 01/08/2013                    | 18:36:18 | 200.36 | 0           | 1           | 0           |         |
| 20 | 01/08/2013                    | 18:36:28 | 200.4  | 0           | 1           | 0           |         |
| 21 | 01/08/2013                    | 18:36:38 | 200.44 | 0           | 1           | 0           |         |

The data is stored in Comma Separated format (.csv) which can be opened and analysed with the optional PC software or opened directly into a spreadsheet. Many third party software programs can also import data in the .csv format.

The file contains a header identifying the source instruments serial number, the date of the file upload and descriptions of the data columns.

The data columns seen depends on the data selected to record, but will always include the date and time of each sample. The date format follows the instrument date format selection. Date(en) is dd/mm/yyyy, and Date (us) is mm/dd/yyyy.



**Note:** Analysis with the PC software is limited to 8 analog channels, so only the first 8 will be displayed. The number of recorded alarms & events is not limited.

## 18.2 Additional Features & Benefits from the Recorder

The real time clock (RTC) included with the data recorder also expands the profiling capabilities (*see Profiler on page 90*) and allows a “calibration due” reminder to be shown at a specified date (*see the Input Configuration sub-menu on page 46*).



**Note:** If you change the Control Mode while recording, the recorder will automatically stop, and the Items To Be Recorded are all turned off (i.e. nothing is selected for recording) so immediately recommencing recording will not record any items. To overcome this, the user must re-configure the Items To Be Recorded and restart the recording.

# 19 Controller Tuning


## 19.1 PID Sets & Gain Scheduling

Up to 5 sets of PID tuning terms can be entered for each control loop, allowing the instrument to be pre-set for differing conditions. Each set has individual values for the following parameters: Primary Proportional Band; Secondary Proportional Band; On-Off Differential; Integral Time; Derivative time; Overlap/Deadband. The parameter values can be entered in the control configuration sub menu (*page 49*), but also see Automatic Tuning below for automatic tuning of the PID sets.

The PID sets might be configured for different applications, or to allow for differing process or load conditions that might occur in a single application. In this case one set at a time would be selected as the “Active PID” set for that loop.

Alternatively, if the process conditions change significantly during use (e.g. if it is partially exothermic as the temperature rises) Gain Scheduling can be employed.

Gain scheduling ‘bumplessly’ switches PID sets automatically at successively higher setpoint or process values, giving optimal control across a wide range of process conditions. This is explained in the diagram below.



Gain Scheduling breakpoints can be selected to switch PID sets with a change in the current setpoint value, or the current process value.



**Note:** ON/OFF control is possible with the individual PID sets but cannot be used with gain scheduling. On/off control is replaced with the default proportional band if gain scheduling is turned on.

If the a change to the scale lower or upper limits forces any of the breakpoints out of bounds, all breakpoints will be turned off and the instruments uses the default PID set 1.

## 19.2 Automatic Tuning

To automatically optimise the controllers tuning terms for the process, you can use Pre-Tune, Self-Tune or Auto Pre-Tune independently for each control loop.



**Note:** Automatic tuning will not engage if either proportional band is set to On/Off control. Also, pre-tune (including an auto pre-tune attempt) will not engage if the setpoint is ramping, if a profile is running, or if the Process Variable is <5% of span from setpoint.

### 19.2.1.1 Pre-Tune

Pre-tune performs a single disturbance of the normal start-up pattern so that a good approximation of the ideal PID values can be made prior reaching setpoint. It automatically stops running when the test is complete. The user chooses which PID set the new tuning terms will be applied to, but this selection does not change the selected “active PID set”. This allows tuning of any PID set for future use before return to control with the current PID set.

In VMD mode, derivative is not applied by pre-tune, and the controller is optimised for PI control. In standard control mode, PI & D are all calculated, which may not suit all processes.

There are two pre-tune modes with different process test points. The first is “Standard Pre-Tune” which tests the process response half-way from the activation point (the process value when pre-tune began running) to the current setpoint. The second type is “Pre-Tune at Value” which allows the user to specify the exact point at which the process test will occur.



**CAUTION:** Consider possible process over-shoot when selecting the value to tune at. If there is a risk of damage to the product or equipment select a safe value.

During pre-tune, the controller outputs full primary power until the process reaches the specified test point. Power is then removed (full secondary power applied for dual control), causing an oscillation which the pre-tune algorithm uses to calculate the proportional band(s), integral and derivative time. The pre-tune process is shown below.




Figure 58. Pre-Tune Operation

Pre-tune is selected from the automatic tuning menu. It will not engage if either primary or secondary outputs on a controller are set for On-Off control, during setpoint/profile ramping or if the process variable is less than 5% of the input span from the setpoint.



**Note:** To pre-tune a cascade, first select “Cascade-Open” to tune the PID set(s) on the slave. After the slave has successfully tuned, remember to pre-tune the master/slave combination (this time select “Cascade-Closed”). The cascade remains open until you do this.

### 19.2.1.2 Auto Pre-Tune

As a single-shot operation, pre-tune will automatically disengage once complete, but can be configured to run at every power up using the auto pre-tune function. If auto pre-tune is selected, a Standard Pre-tune will attempt to run at every power up, applying new tuning terms to the current Active PID set. Auto pre-tune will not be able to test the process if at the time the controller is powered up, either primary or secondary outputs are set for On-Off control, during setpoint/profile ramping or if the process variable is less than 5% of the input span from the setpoint. Auto pre-tune is not possible with cascade control mode.

### 19.2.1.3 Self-Tune

If engaged, self-tune uses a pattern recognition algorithm to continuously monitor and adjust for control deviation. It optimises the tuning by applying new PID terms to the current Active PID set while the controller is operating. In VMD control mode, derivative is not applied by self-tune, and the controller is optimised for PI control.




**Figure 59. Self-Tune Operation**

The diagram shows a typical application involving a process start up, setpoint change and load disturbance. In each case, self-tune observes one complete oscillation before calculating new terms. Successive deviations cause the values to be recalculated converging towards optimal control. When the controller is switched off, these terms are stored and used as starting values at switch on. The stored values may not always be ideal, if for instance the controller is new or the application has changed. In this case the user can use pre-tune to establish new initial values for self-tune to fine-tune.

Use of continuous self-tuning is not always appropriate. For example frequent artificial load disturbances, such as where an oven door is often left open for extended periods, might lead to calculation errors. In standard control mode, PI & D are all calculated, which may not suit all processes. Self-Tune cannot be engaged if the instrument is set for on-off control or with cascade control mode.

## 19.3 Manually Tuning

### 19.3.1 Tuning Control Loops - PID with Primary Output only

This technique balances the need to reach setpoint quickly, with the desire to limit setpoint overshoot at start-up or during process changes. It determines values for the primary proportional band and the integral and derivative time constants that allow the controller to give acceptable results in most applications that use a single control device.



**CAUTION:** This technique is suitable only for processes that are not harmed by large fluctuations in the process variable.

1. Check that the scaled input limits and the setpoint limits are set to safe and appropriate levels for your process. Adjust if required.
2. Set the setpoint to the normal operating value for the process (or to a lower value if an overshoot beyond this value might cause damage).
3. Select On-Off control (i.e. set the primary proportional band to zero).
4. Switch on the process. The process variable will rise above and then oscillate about the setpoint. Record the peak-to-peak variation (**P**) of the first cycle (i.e. the difference between the highest value of the first overshoot and the lowest value of the first undershoot), and the time period of the oscillation (**T**) in minutes. See the diagram below.
5. Calculate the PID control parameters (primary proportional band, integral time and derivative time) using the formulas shown.
6. Repeat steps 1-5 for the second control loop if required




Figure 60. Manually Tuning - PID with Primary Output

### 19.3.2 Tuning Control Loops - PID with Primary & Secondary Outputs

This tuning technique balances the need to reach setpoint quickly, with the desire to limit setpoint overshoot at start-up and during process changes. It determines values for the primary & secondary proportional bands, and the integral and derivative time constants that allow the controller to give acceptable results in most applications using dual control (e.g. Heat & Cool).



**CAUTION:** These techniques are suitable only for processes that are not harmed by large fluctuations in the process variable.

### 19.3.2.1 Method 1 – For Simple Processes


Use this method if the process is simple/easily controlled and the relative power available from the primary and secondary actuators is approximately symmetrical (e.g. if the maximum heating and cooling power is equal)

1. Tune the controller using only the Primary Control output as described in steps 1 to 5 of Manually Tuning - PID with Primary Output, above.
2. Set the Secondary Proportional Band to the same value as the Primary Proportional Band and monitor the operation of the controller in dual control mode.
3. If there is a tendency to oscillate as the control passes into the Secondary Proportional Band, increase its value. If the process appears to be over-damped (slow to respond) in the region of the secondary proportional band, decrease its value.
4. When the PID tuning values have been determined, if there is a disturbance to the process variable as control passes from one proportional band to the other, set the **Overlap/Deadband** parameter to a positive value to introduce some overlap. Adjust this value by trial and error until satisfactory results are obtained.

### 19.3.2.2 Method 2 – For Asymmetrical Processes

Use this method if the relative power available from the primary and secondary actuators is not symmetrical (e.g. if the maximum cooling power is less than the maximum heating power)

1. Check that the scaled input limits and the setpoint limits of the loop in question are set to safe and appropriate levels for your process. Adjust if required.
2. Set the setpoint to the normal operating value for the process (or to a lower value if overshoots beyond this value might cause damage).
3. Select **On-Off** control by setting the primary proportional band to zero (the secondary proportional band will automatically be set on-off control when you do this).
4. Switch on the process. The **process variable** will oscillate about the setpoint. Record the peak-to-peak variation (**V**) of the oscillation (i.e. the difference between the on-going overshoot and undershoot), the time period of the oscillation (**T**) in minutes and the maximum rate of rise (**dP**) and fall (**dS**) as the oscillation continues.



**V** = On-going Peak-to-Peak variation

**T** = Time period of oscillation (minutes)

**dS** = Maximum rate of rise

**dP** = Maximum rate of fall

**R** = Ratio  $\frac{dS}{dP}$

**Primary proportional band** =  $Pb.P = \frac{V}{R}$

**Secondary proportional band** =  $R \times Pb.P$

**Integral Time** = T minutes      **Derivative Time** =  $\frac{T}{6}$

5. Calculate and enter the PID control parameters (primary proportional band, integral time and derivative time) using the formulas shown, and observe the process.
6. If symmetrical oscillation occurs, increase the proportional bands together, maintaining the same ratio. If the asymmetrical oscillation occurs, adjust the ratio between the bands until it becomes symmetrical, then increase the bands together, maintaining the new ratio.
7. When the PID tuning values have been determined, if there is a disturbance to the process variable as control passes from one proportional band to the other, set the **Overlap/Deadband** parameter to a small positive value to introduce some overlap. Adjust this value by trial and error to find the minimum value that gives satisfactory results.

### 19.3.3 Valve, Damper & Speed Controller Tuning

This tuning method is used when controlling devices such as dampers, modulating valves or motor speed controllers. It applies equally to modulating valves with their own valve positioning circuitry, or in VMD mode where the instrument directly controls the valve motor— see *Valve Motor Drive / 3-Point Stepping Control* on page 14. It determines values for the primary proportional band, and integral time constant. The derivative time is normally set to **OFF**. This type of PI Control minimises valve/motor wear whilst giving optimal process control.


In VMD modem the Motor Travel Time and Minimum On Time must be correctly set to match the valve specifications before attempting to tune the controller.



**CAUTION:** This technique is suitable only for processes that are not harmed by large fluctuations in the process variable.

1. Set the setpoint to the normal operating process value (or to a lower value if overshoot beyond this value is likely to cause damage).
2. Set the Primary Proportional Band a value approximately equal to 0.5% of the input span for the loop to be tuned. (*Span is the difference between the scaled input limits*).
3. Set the Integral & Derivative time constants both to OFF.
4. Switch on the process. The process variable should oscillate about the setpoint.

5. Follow the instructions in the diagram below. At each stage, allow sufficient settling time before moving on to the next stage. **P.Pb** is the Primary Proportional Band, **Int.T** is the Integral Time Constant.



*This method can also be used to tune PID loops. Set Derivative to approx.  $T_a / 4$*

**Figure 61. Manually Tuning – PI Control**

### 19.3.4 Fine Tuning

Small adjustments can be made to correct minor control problems. These examples assume reverse acting control (e.g. heating). Adjust accordingly for direct action. If they do not help solve the problem, re-tune the controller as detailed on the preceding sections.



**Note:** When fine tuning the settings, only adjust one parameter at a time, and allow enough time for the process to settle into its new state each time you change a value.

#### 19.3.4.1 Cycle Times


A separate cycle time adjustment parameter is provided for the Primary and Secondary control when using time-proportioning control outputs.

If the process oscillates at the same frequency as the cycle time, it indicates it may be too long for the process. Decrease the cycle time and re-check the period of oscillation, if it has changed to match the new cycle time this confirms that the time is too long.


If the control actuators will accept it, continue reducing the cycle time until the process stabilises, or no further improvement is seen.

Recommended times. Relays  $\geq 10$  seconds. SSR Driver 1 second.

##### Proportional Cycle Times



**Ideal:** Stable Process



**Too Long:** Oscillation period = cycle time.




**Note:** Adjusting the cycle time affects the controllers operation; a shorter cycle time gives more accurate control, but mechanical control actuators such as relays will have a reduced life span.


#### 19.3.4.2 Proportional Bands

Increase the width of the proportional bands if the process overshoots or oscillates excessively. Decrease the width of the proportional band if the process responds slowly or fails to reach setpoint.

##### Proportional Bands



**Too Narrow:** Process Oscillates




**Too Wide:** Slow warm up and response

#### 19.3.4.3 Integral Time Constant


To find the optimum integral time, decrease its value until the process becomes unstable, then increase it a little at a time, until stability has is restored. Induce a load disturbance or make a setpoint change to verify that the

process stabilises. If not increase the value some more and re-test. If the response is too slow, decrease the integral time, but avoid instability.

### Integral Time



**Too Short:** Overshoots and oscillates




**Too Long:** Slow warm up and response

#### 19.3.4.4 Derivative Time Constant


Initially set the derivative to between  $1/4^{\text{th}}$  and  $1/10^{\text{th}}$  of the Integral time value.

Increase the derivative time if the process overshoots/undershoots. Increase it a little at a time, but if the process becomes unstable, decrease it until the oscillation stops. Induce a load disturbance or make a setpoint change to verify that the process stabilises. If not decrease the value some more and re-test.

### Derivative Time



**Too Long:** Oscillates and over corrects when process disturbed



**Too Short:** Slow warm up and disturbance response under-corrects



**Note:** When controlling a modulating valve, it is usually recommended that derivative is set to OFF to avoid excessive valve activity. Derivative can cause process instability in these processes.


#### 19.3.4.5 Anti Wind-up

If after fully optimising the tuning, there is an overshoot of the setpoint at start-up or in response to large setpoint changes, the reset wind-up inhibit point can be reduced to suspend integral action until the process is closer to setpoint. If set too low control deviation can occur (the process settles, but is offset above or below the setpoint). If this is observed, increase the value until the deviation error is removed.

### Anti Wind-up



**Too Small:** Overshoots setpoint before settling



**Too Short:** Slow to setpoint or offset above/below setpoint

#### 19.3.4.6 Manual Reset


For proportional only control, after making all other adjustments, if a positive control deviation error exists (process is offset above the setpoint) reduce the manual reset until the error is eliminated. If there is a negative error (process is offset below the setpoint) increase manual reset until the error is eliminated.

For PID or PI control, typically set manual reset to approximately 80% of power needed to maintain setpoint, but lower values can be used to inhibit start-up overshoot if required.

##### Manual Reset



**Too High:** Overshoots setpoint at start-up



**Too Low:** Slow to setpoint

## 20 Serial Communications

### 20.1 Supported Protocols

Communication with a Modbus RTU or Modbus TCP master device is possible if the appropriate communications module is fitted in option slot A. An RS485 Module is required for Modbus RTU. An Ethernet Module is required for Modbus TCP.

The instrument can also act as “setpoint master” over RS485 for multi-zone applications. In this mode the unit continuously sends its setpoint value using Modbus broadcast messages. Master mode is not available with Ethernet module.

To protect the EEPROM from excessive write operations, the 6 most recent parameter write requests are held in standard RAM. All data is written to EEPROM at power-down or if another parameter is changed. Avoid continuously changing more than 6 parameters.

All models also have a configuration socket for bench setup via the PC configuration software prior to installation. An RS232 to TTL lead (*available from your supplier*) is required in order to use this socket. A front mounted USB port is available on some models; this can also be used to configure the instrument or to transfer recorder or profile files via a USB memory stick.

#### 20.1.1 RS485 Configuration

The RS485 address, bit rate and character format are configured via the front panel from the Comms Configuration sub-menu or by using the PC Configurator software.

|                   |                                               |
|-------------------|-----------------------------------------------|
| Data rate:        | 4800, 9600, 19200, 38400, 57600 or 115200 bps |
| Parity:           | None (default), Even, Odd                     |
| Character format: | Always 8 bits per character.                  |
| Device Address:   | <i>See below.</i>                             |

##### 20.1.1.1 RS485 Device Addressing

The instrument must be assigned a unique device address in the range 1 to 255. This address is used to recognise Modbus queries intended for this instrument. With the exception of globally addressed broadcast messages, the instrument ignores Modbus queries that do not match the address that has been assigned to it.

The instrument will accept broadcast messages (global queries) using device address 0 no matter what device address is assigned to it. No response messages are returned for globally addressed queries.

#### 20.1.2 Ethernet Configuration

For Modbus TCP communications (Modbus over Ethernet), the Ethernet IP address can either be assigned by a Dynamic Host Configuration Protocol (DHCP), BootP or AutoIP server on the network, or manually assigned using the IP address allocation software tool.

Refer to the PC Software section of this manual on page 236 for more information about setting the IP address. The supported data rates 10/100BASE-T (10 or 100 Mbps) are automatically detected.

## Link Layer

A query (data request or command) is transmitted from the Modbus Master to the Modbus Slave. The slave instrument assembles the reply to the master. This instrument is normally a slave device. It can only act as a master when being use as setpoint master controller to broadcast its setpoint to other controllers in a multi-zone application.




Figure 62. Modbus Link Layer

A message for either a QUERY or RESPONSE is made up of an inter-message gap followed by a sequence of data characters. The inter-message gap is at least 3.5 data character times - the transmitter must not start transmission until 3 character times have elapsed since reception of the last character in a message, and must release the transmission line within 3 character times of the last character in a message.



**Note:** Three character times is approximately 0.25ms at 115200 bps, 0.51ms at 57600 bps, 0.75ms at 38400 bps, 1.5ms at 19200 bps, 3ms at 9600 bps and 6ms at 4800bps.

Data is encoded for each character as binary data, transmitted LSB first.

For a QUERY the address field contains the address of the slave destination. The slave address is given together with the Function and Data fields by the Application layer. The CRC is generated from the address, function and data characters.

For a RESPONSE the address field contains the address of the responding slave. The Function and Data fields are generated by the slave application. The CRC is generated from the address, function and data characters.

The standard MODBUS RTU CRC-16 calculation employing the polynomial  $2^{16}+2^{15}+2^2+1$  is used.

|                   |                        |                         |                             |                           |
|-------------------|------------------------|-------------------------|-----------------------------|---------------------------|
| Inter-message gap | Address<br>1 character | Function<br>1 character | Data<br><i>n</i> characters | CRC Check<br>2 characters |
|-------------------|------------------------|-------------------------|-----------------------------|---------------------------|

## 20.2 Supported Modbus Functions

The following Modbus function types are supported by this instrument:

| Function Code | Modbus Meaning                | Description                                                                                                                       |
|---------------|-------------------------------|-----------------------------------------------------------------------------------------------------------------------------------|
| 03 / 04       | Read Holding/Input registers  | Read current binary value of specified number of parameters at given address. Up to 64 parameters can be accessed with one query. |
| 06            | Write Single Register         | Writes two bytes to a specified word address.                                                                                     |
| 08            | Diagnostics                   | Used for loopback test only.                                                                                                      |
| 16 (0x10 hex) | Write Multiple Registers      | Writes up to 253 bytes of data to the specified address range.                                                                    |
| 23 (0x17 hex) | Read/Write Multiple Registers | Reads and Writes 253 bytes of data to the specified address ranges.                                                               |

### 20.2.1 Function Descriptions

The following is interpreted from the Modbus protocol description obtainable from [www.modbus.org](http://www.modbus.org). Refer to that document if clarification is required. In the function descriptions below, the preceding device address value is assumed, as is the correctly formed two-byte CRC value at the end of the QUERY and RESPONSE frames.

#### 20.2.1.1 Function 03 / 04 - Read Holding/Input Registers

Reads current binary value of data at the specified word addresses.

##### QUERY: Function 03 / 04 - Read Holding/Input Registers

| Func Code | Address of 1 <sup>st</sup> Word |    | Number of Words |    |
|-----------|---------------------------------|----|-----------------|----|
| 03/04     | LO                              | LO | HI              | LO |

##### RESPONSE: Function 03 / 04 - Read Holding/Input Registers

| Func Code | Byte Count | 1 <sup>st</sup> Word |    | etc | Last Word |    |
|-----------|------------|----------------------|----|-----|-----------|----|
| 03/04     | xx         | HI                   | LO | →   | HI        | LO |



**Note:** In the response the "Number of Bytes" indicates the number of data bytes read from the instrument. E.g. if 5 words are read, the count will be 10 (0xA hex). The maximum number of words that can be read is 64. If a parameter does not exist at one of the addresses read, a value of 0000h is returned for that word.

#### 20.2.1.2 Function 06 - Write Single Register

Writes two bytes to a specified word address.

##### QUERY: Function 06 - Write Single Register

| Func Code | Address of Word |    | Value to write |    |
|-----------|-----------------|----|----------------|----|
| 06        | HI              | LO | HI             | LO |

##### RESPONSE: Function 06 - Write Single Register

| Func Code | Address of Word |    | Value Written |    |
|-----------|-----------------|----|---------------|----|
| 06        | HI              | LO | HI            | LO |



**Note:** The Response normally returns the same data as the query.

### 20.2.1.3 Function 08 - Loopback Diagnostic Test

| QUERY: Function 08 - Loopback Diagnostic Test |                 |    |       |    |  |
|-----------------------------------------------|-----------------|----|-------|----|--|
| Func Code                                     | Diagnostic Code |    | Value |    |  |
| 08                                            | 00              | 00 | HI    | LO |  |

| RESPONSE: Function 08 - Loopback Diagnostic Test |              |    |       |    |  |
|--------------------------------------------------|--------------|----|-------|----|--|
| Func Code                                        | Sub-function |    | Value |    |  |
| 08                                               | 00           | 00 | HI    | LO |  |



**Note:** The Response normally returns the same data as the loopback query. Other diagnostic codes are not supported.

### 20.2.1.4 Function 16 - Write Multiple Registers (0x10 Hex)

Writes consecutive word (two-byte) values starting at the specified address.

| QUERY: Function 16 - Write Multiple Registers (0x10 Hex) |                               |    |                 |    |            |          |    |     |           |    |  |
|----------------------------------------------------------|-------------------------------|----|-----------------|----|------------|----------|----|-----|-----------|----|--|
| Func Code                                                | 1 <sup>st</sup> Write Address |    | Number of Words |    | Byte Count | 1st Word |    | etc | Last Word |    |  |
| 10                                                       | HI                            | LO | HI              | LO | xx         | HI       | LO | →   | HI        | LO |  |

| RESPONSE: Function 16 - Write Multiple Registers (0x10 Hex) |                  |    |                 |    |  |  |  |  |  |  |  |
|-------------------------------------------------------------|------------------|----|-----------------|----|--|--|--|--|--|--|--|
| Func Code                                                   | 1st Word Address |    | Number of Words |    |  |  |  |  |  |  |  |
| 10                                                          | HI               | LO | HI              | LO |  |  |  |  |  |  |  |



**Note:** The maximum number of data bytes that can be written in one message is 253 bytes.

### 20.2.1.5 Function 23 Hex - Read / Write Multiple Registers (0x17 hex)

Reads and writes the requested number of consecutive words (two-bytes) starting at the specified addresses.

| QUERY: Function 23 Hex - Read / Write Multiple Registers (0x17 hex) |                              |    |                 |    |                               |    |                       |    |            |                 |     |           |    |    |
|---------------------------------------------------------------------|------------------------------|----|-----------------|----|-------------------------------|----|-----------------------|----|------------|-----------------|-----|-----------|----|----|
| Func Code                                                           | 1 <sup>st</sup> Read Address |    | Number of Words |    | 1 <sup>st</sup> Write Address |    | Number of Write Words |    | Byte Count | Values to Write |     |           |    |    |
|                                                                     |                              |    |                 |    |                               |    |                       |    |            | 1st Word        | etc | Last Word |    |    |
| 17                                                                  | HI                           | LO | HI              | LO | HI                            | LO | HI                    | LO | xx         | HI              | LO  | →         | HI | LO |

| RESPONSE: Function 23 Hex - Read / Write Multiple Registers (0x17 hex) |            |           |    |     |           |    |  |  |  |
|------------------------------------------------------------------------|------------|-----------|----|-----|-----------|----|--|--|--|
| Func Code                                                              | Byte Count | Read Data |    |     |           |    |  |  |  |
|                                                                        |            | 1st Word  |    | etc | Last Word |    |  |  |  |
| 17                                                                     | xx         | HI        | LO | →   | HI        | LO |  |  |  |



**Note:** The maximum number of data bytes that can be read and written in one message is 253 bytes.

## 20.2.2 Exception Responses

If a QUERY is sent without a communication error, but the instrument cannot interpret it, an Exception RESPONSE is returned. The exception response consists of a modified version of the original function code and an exception code that explains what was wrong with the message. Possible exception responses and their reasons are:

| Function Code                                                                                                                         | Exception Code | Modbus Meaning       | Description                                                                                                                                                                                                     |
|---------------------------------------------------------------------------------------------------------------------------------------|----------------|----------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| The original function code with its most significant bit (MSB) set. <i>This offsets it by 0x80, so for example 0x06 becomes 0x86.</i> | 00             | Unused               | None.                                                                                                                                                                                                           |
|                                                                                                                                       | 01             | Illegal function     | Function number is out of range.                                                                                                                                                                                |
|                                                                                                                                       | 02             | Illegal Data Address | <b>Write functions:</b> Parameter number is out of range or not supported. <i>(for write functions only).</i><br><b>Read Functions:</b> Start parameter does not exist or the end parameter greater than 65536. |
|                                                                                                                                       | 03             | Illegal Data Value   | Attempt to write invalid data / required action not executed.                                                                                                                                                   |



**Note:** In the case of multiple exception codes for a single query, the Exception code returned is the one corresponding to the first parameter in error.

## 20.3 Modbus Parameters

The register addresses for the Modbus parameters are detailed in the tables below.  
The Access column indicates if a parameter is read only (RO) or if it can also be written to (R/W).  
Communications writes will not be implemented if the Writing Via Serial Comms parameter in the Communications Configuration sub-menu is set to Disabled.



**Note:** Read only parameters will return an exception if an attempt is made to write values to them.  
Some parameters that do not apply for a particular configuration will still accept read / writes (e.g. attempting to scale a linear output which has not been fitted).

### 20.3.1 Data Formats

Data can be accessed in three formats: **Integer Only** (decimal places are not included), **Integer with 1 Decimal Place** (only the first decimal place value is included) or an IEEE / Motorola (big endian) **Floating Point Number**. Where possible use floating point numbers especially if the values have more than one decimal place.

## 20.4 Parameter Register Address Listings

| Calculating Parameter Register Addresses               |                |                    |                                     |                                             |
|--------------------------------------------------------|----------------|--------------------|-------------------------------------|---------------------------------------------|
| Register Address Calculation                           |                | Integer Only       | Integer+1                           | Floating Point                              |
|                                                        | (hex)<br>(dec) | Address<br>Address | Address + 0x4000<br>Address + 16384 | Address x 2 + 0x8000<br>Address x 2 + 32768 |
| Address Example:<br>(For Loop 1 Process Variable)      | (hex)          | 0x0407             | 0x4407                              | 0x880E                                      |
|                                                        | (dec)          | 1031               | 17415                               | 34830                                       |
| Data Value Returned:<br>If actual Value = 23.9 decimal | (hex)          | 0x00, 0x17         | 0x00, 0xEF                          | 0x41, 0xBF, 0x33, 0x33                      |
|                                                        | (dec)          | 23                 | 239                                 | 23.9 as floating decimal                    |

The register address offset calculations are shown above.

For your convenience, the parameter tables on the following pages show each parameter's Modbus register address as a decimal and hexadecimal number for all three formats.

The tables also show if the parameter has read-only (**RO**) or read-write (**RW**) access.

Analog parameter values and their limits are expressed as decimals.

Bit parameters list the bit positions and their meaning (bit 0 = LSB). Only bits that have a function are listed, unused bits are omitted.

## 20.4.1 Calibration Reminder Parameters

| Parameter Name & Register Address                                                                                                                                                                                                                                                                                                                                                                                              |         |        |       |        |                                                                                                                                                                                                                                                                                                                                                            |                             |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------|--------|-------|--------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|
|                                                                                                                                                                                                                                                                                                                                                                                                                                | Integer | Int +1 | Float | Access | Values                                                                                                                                                                                                                                                                                                                                                     | & Descriptions              |
| Calibration Reminder Enable                                                                                                                                                                                                                                                                                                                                                                                                    |         |        |       |        | Value                                                                                                                                                                                                                                                                                                                                                      | Calibration Reminder Status |
| Dec                                                                                                                                                                                                                                                                                                                                                                                                                            | 1048    | 17432  | 34864 | RW     | 0                                                                                                                                                                                                                                                                                                                                                          | Disabled                    |
| Hex                                                                                                                                                                                                                                                                                                                                                                                                                            | 0418    | 4418   | 8830  |        | 1                                                                                                                                                                                                                                                                                                                                                          | Enabled                     |
| Calibration Reminder Date                                                                                                                                                                                                                                                                                                                                                                                                      |         |        |       |        | Value                                                                                                                                                                                                                                                                                                                                                      | Calibration Status          |
| Dec                                                                                                                                                                                                                                                                                                                                                                                                                            | n/a     | n/a    | 34866 | RW     | This can be entered only as a floating point number. When converted to binary the least significant 19 bits represents the date in this format:<br><br>www DDDDD MMMM YYYYYYY<br>YYYYYYY = YEAR<br>MMMM = MONTH<br>DDDDD = DAY OF MONTH (1-31 but must be valid)<br>www = Day of the week The day of week portion is calculated from the date (Read Only). |                             |
| Hex                                                                                                                                                                                                                                                                                                                                                                                                                            | n/a     | n/a    | 8832  |        |                                                                                                                                                                                                                                                                                                                                                            |                             |
| <p>Example with date set to 31/07/2012</p> <p>Day (31) = 11111</p> <p>Month (7) = 0111</p> <p>Year (12) = 0001100</p> <p>Bits 17 and higher are ignored when writing so 11111 0111 0001100 (64396 decimal) is just one of many possible numbers to write as 31/07/2012, and when reading the date back, the number returned is 10 11111 0111 0001100 (195468 decimal) because bits 17-19 are 010 (to represent “Tuesday”).</p> |         |        |       |        |                                                                                                                                                                                                                                                                                                                                                            |                             |

## 20.4.2 Universal Process Input 1 Parameters

| Parameter Name & Register Address |         |        |       |        |        |                            |
|-----------------------------------|---------|--------|-------|--------|--------|----------------------------|
|                                   | Integer | Int +1 | Float | Access | Values | & Descriptions             |
| Universal Process Input 1 Type    |         |        |       |        | Value  | Process Input Type         |
| Dec                               | 1024    | 17408  | 34816 | RW     | 0      | B Type Thermocouple        |
| Hex                               | 0400    | 4400   | 8800  |        | 2      | C Type Thermocouple        |
|                                   |         |        |       |        | 4      | D Type Thermocouple        |
|                                   |         |        |       |        | 6      | E Type Thermocouple        |
|                                   |         |        |       |        | 8      | J Type Thermocouple        |
|                                   |         |        |       |        | 10     | K Type Thermocouple        |
|                                   |         |        |       |        | 12     | L Type Thermocouple        |
|                                   |         |        |       |        | 14     | N Type Thermocouple        |
|                                   |         |        |       |        | 16     | R Type Thermocouple        |
|                                   |         |        |       |        | 18     | S Type Thermocouple        |
|                                   |         |        |       |        | 20     | T Type Thermocouple        |
|                                   |         |        |       |        | 22     | PtRh 20%: 40% Thermocouple |
|                                   |         |        |       |        | 24     | PT100 RTD                  |
|                                   |         |        |       |        | 26     | NI120 RTD                  |
|                                   |         |        |       |        | 28     | 0 to 20mA DC               |
|                                   |         |        |       |        | 29     | 4 to 20mA DC               |
|                                   |         |        |       |        | 30     | 0 to 50mV DC               |

|                                        |      |       |       |    |                                                                                                       |                                             |
|----------------------------------------|------|-------|-------|----|-------------------------------------------------------------------------------------------------------|---------------------------------------------|
|                                        |      |       |       |    | 31                                                                                                    | 10 to 50mV DC                               |
|                                        |      |       |       |    | 32                                                                                                    | 0 to 5V DC                                  |
|                                        |      |       |       |    | 33                                                                                                    | 1 to 5V DC                                  |
|                                        |      |       |       |    | 34                                                                                                    | 0 to 10V DC                                 |
|                                        |      |       |       |    | 35                                                                                                    | 2 to 10V DC                                 |
|                                        |      |       |       |    | 36                                                                                                    | Potentiometer                               |
| Input 1 Engineering Units              |      |       |       |    | Value                                                                                                 | Engineering Units For Display               |
| Dec                                    | 1025 | 17409 | 34818 | RW | 0                                                                                                     | = None                                      |
| Hex                                    | 0401 | 4401  | 8802  |    | 1                                                                                                     | = °C (Default for Europe)                   |
|                                        |      |       |       |    | 2                                                                                                     | = °F (Default for USA)                      |
|                                        |      |       |       |    | 3                                                                                                     | = °K                                        |
|                                        |      |       |       |    | 4                                                                                                     | = Bar                                       |
|                                        |      |       |       |    | 5                                                                                                     | = pH                                        |
|                                        |      |       |       |    | 6                                                                                                     | = %                                         |
|                                        |      |       |       |    | 7                                                                                                     | = %RH                                       |
|                                        |      |       |       |    | 8                                                                                                     | = PSI                                       |
| Input 1 Maximum Display Decimal Places |      |       |       |    | Value                                                                                                 | Maximum Number Of Decimal Places In Display |
| Dec                                    | 1026 | 17410 | 34820 | RW | 0                                                                                                     | None (e.g. 1234)                            |
| Hex                                    | 0402 | 4402  | 8804  |    | 1                                                                                                     | One (e.g. 123.4)                            |
|                                        |      |       |       |    | 2                                                                                                     | Two (e.g. 12.34)                            |
|                                        |      |       |       |    | 3                                                                                                     | Three (e.g. 1.234)                          |
| Input 1 Scaled Input Lower Limit       |      |       |       |    | Scaling Value Low Limit                                                                               |                                             |
| Dec                                    | 1027 | 17411 | 34822 | RW | Valid between input 1 range maximum and minimum (see <i>Specifications</i> section for input details) |                                             |
| Hex                                    | 0403 | 4403  | 8806  |    |                                                                                                       |                                             |
| Input 1 Scaled Input Upper Limit       |      |       |       |    | Scaling Value High Limit                                                                              |                                             |
| Dec                                    | 1028 | 17412 | 34824 | RW | Valid between input 1 range maximum and minimum (see <i>Specifications</i> section for input details) |                                             |
| Hex                                    | 0404 | 4404  | 8808  |    |                                                                                                       |                                             |
| Input 1 Process Variable Offset        |      |       |       |    | Single Point Calibration PV Offset                                                                    |                                             |
| Dec                                    | 1029 | 17413 | 34826 | RW | Used for Single Point Calibration of input 1<br>Valid between the scaled input lower & upper limits   |                                             |
| Hex                                    | 0405 | 4405  | 880A  |    |                                                                                                       |                                             |
| Input 1 Filter Time Constant           |      |       |       |    | Input 1 Process Input Filter Time                                                                     |                                             |
| Dec                                    | 1030 | 17414 | 34828 | RW | Valid between 0.0 and 512.0                                                                           |                                             |
| Hex                                    | 0406 | 4406  | 880C  |    |                                                                                                       |                                             |
| Input 1 Process Variable               |      |       |       |    | Process Input 1 Value                                                                                 |                                             |
| Dec                                    | 1031 | 17415 | 34830 | RO | The current input 1 process value                                                                     |                                             |
| Hex                                    | 0407 | 4407  | 880E  |    |                                                                                                       |                                             |
| Input 1 Signal /Sensor Break Flag      |      |       |       |    | Value                                                                                                 | Process Input Break Status                  |
| Dec                                    | 1032 | 17416 | 34832 | RO | 0                                                                                                     | Inactive                                    |
| Hex                                    | 0408 | 4408  | 8810  |    | 1                                                                                                     | Active ( <i>break detected</i> )            |
| Input 1 Signal Under Range Flag        |      |       |       |    | Value                                                                                                 | Process Input Under Range Status            |
| Dec                                    | 1033 | 17417 | 34834 | RO | 0                                                                                                     | Inactive                                    |
| Hex                                    | 0409 | 4409  | 8812  |    | 1                                                                                                     | Active ( <i>under-range detected</i> )      |
| Input Signal Over Range Flag           |      |       |       |    | Value                                                                                                 | Process Input Over Range Status             |
| Dec                                    | 1034 | 17418 | 34836 | RO | 0                                                                                                     | Inactive                                    |
| Hex                                    | 040A | 440A  | 8814  |    | 1                                                                                                     | Active ( <i>over-range detected</i> )       |
| Input 1 Cold Junction Compensation     |      |       |       |    | Value                                                                                                 | CJC Status                                  |
| Dec                                    | 1035 | 17419 | 34838 | RW | 0                                                                                                     | Disabled                                    |
| Hex                                    | 040B | 440B  | 8816  |    | 1                                                                                                     | Enabled ( <i>default</i> )                  |

| Input 1 Multi-point Scaling Enable |      |       |       |    | Value                                                                        | Multi-point Scaling Status                                |
|------------------------------------|------|-------|-------|----|------------------------------------------------------------------------------|-----------------------------------------------------------|
| Dec                                | 1053 | 17437 | 34874 | RW | 0                                                                            | Disabled                                                  |
| Hex                                | 041D | 441D  | 883A  |    | 1                                                                            | Enabled ( <i>valid only if the input type is linear</i> ) |
| Input 1 Scale Point 1              |      |       |       |    | Multi-Point Scaling Point 1                                                  |                                                           |
| Dec                                | 1054 | 17438 | 34876 | RW | Percentage of the scaled input where multi-point scaling value 1 is applied. |                                                           |
| Hex                                | 041E | 441E  | 883C  |    | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.              |                                                           |
| Input 1 Display Point 1            |      |       |       |    | Multi-Point Scaling Display Value For Point 1                                |                                                           |
| Dec                                | 1055 | 17439 | 34878 | RW | Value to display at multi-point scaling point 1                              |                                                           |
| Hex                                | 041F | 441F  | 883E  |    | Valid between the scaled input lower & upper limits                          |                                                           |
| Input 1 Scale Point 2              |      |       |       |    | Multi-Point Scaling Point 2                                                  |                                                           |
| Dec                                | 1056 | 17440 | 34880 | RW | Percentage of the scaled input where multi-point scaling value 2 is applied. |                                                           |
| Hex                                | 0420 | 4420  | 8840  |    | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.              |                                                           |
| Input 1 Display Point 2            |      |       |       |    | Multi-Point Scaling Display Value For Point 2                                |                                                           |
| Dec                                | 1057 | 17441 | 34882 | RW | Value to display at multi-point scaling point 2                              |                                                           |
| Hex                                | 0421 | 4421  | 8842  |    | Valid between the scaled input lower & upper limits                          |                                                           |
| Input 1 Scale Point 3              |      |       |       |    | Multi-Point Scaling Point 3                                                  |                                                           |
| Dec                                | 1058 | 17442 | 34884 | RW | Percentage of the scaled input where multi-point scaling value 3 is applied. |                                                           |
| Hex                                | 0422 | 4422  | 8844  |    | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.              |                                                           |
| Input 1 Display Point 3            |      |       |       |    | Multi-Point Scaling Display Value For Point 3                                |                                                           |
| Dec                                | 1059 | 17443 | 34886 | RW | Value to display at multi-point scaling point 3                              |                                                           |
| Hex                                | 0423 | 4423  | 8846  |    | Valid between the scaled input lower & upper limits                          |                                                           |
| Input 1 Scale Point 4              |      |       |       |    | Multi-Point Scaling Point 4                                                  |                                                           |
| Dec                                | 1060 | 17444 | 34888 | RW | Percentage of the scaled input where multi-point scaling value 4 is applied. |                                                           |
| Hex                                | 0424 | 4424  | 8848  |    | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.              |                                                           |
| Input 1 Display Point 4            |      |       |       |    | Multi-Point Scaling Display Value For Point 4                                |                                                           |
| Dec                                | 1061 | 17445 | 34890 | RW | Value to display at multi-point scaling point 4                              |                                                           |
| Hex                                | 0425 | 4425  | 884A  |    | Valid between the scaled input lower & upper limits                          |                                                           |
| Input 1 Scale Point 5              |      |       |       |    | Multi-Point Scaling Point 5                                                  |                                                           |
| Dec                                | 1062 | 17446 | 34892 | RW | Percentage of the scaled input where multi-point scaling value 5 is applied. |                                                           |
| Hex                                | 0426 | 4426  | 884C  |    | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.              |                                                           |
| Input 1 Display Point 5            |      |       |       |    | Multi-Point Scaling Display Value For Point 5                                |                                                           |
| Dec                                | 1063 | 17447 | 34894 | RW | Value to display at multi-point scaling point 5                              |                                                           |
| Hex                                | 0427 | 4427  | 884E  |    | Valid between the scaled input lower & upper limits                          |                                                           |
| Input 1 Scale Point 6              |      |       |       |    | Multi-Point Scaling Point 6                                                  |                                                           |
| Dec                                | 1064 | 17448 | 34896 | RW | Percentage of the scaled input where multi-point scaling value 6 is applied. |                                                           |
| Hex                                | 0428 | 4428  | 8850  |    | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.              |                                                           |
| Input 1 Display Point 6            |      |       |       |    | Multi-Point Scaling Display Value For Point 6                                |                                                           |
| Dec                                | 1065 | 17449 | 34898 | RW | Value to display at multi-point scaling point 6                              |                                                           |
| Hex                                | 0429 | 4429  | 8852  |    | Valid between the scaled input lower & upper limits                          |                                                           |
| Input 1 Scale Point 7              |      |       |       |    | Multi-Point Scaling Point 7                                                  |                                                           |
| Dec                                | 1066 | 17450 | 34900 | RW | Percentage of the scaled input where multi-point scaling value 7 is applied. |                                                           |
| Hex                                | 042A | 442A  | 8854  |    | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.              |                                                           |
| Input 1 Display Point 7            |      |       |       |    | Multi-Point Scaling Display Value For Point 7                                |                                                           |
| Dec                                | 1067 | 17451 | 34902 | RW | Value to display at multi-point scaling point 7                              |                                                           |
| Hex                                | 042B | 442B  | 8856  |    | Valid between the scaled input lower & upper limits                          |                                                           |

|                                 |      |       |       |           |                                                                               |
|---------------------------------|------|-------|-------|-----------|-------------------------------------------------------------------------------|
| <b>Input 1 Scale Point 8</b>    |      |       |       | <b>RW</b> | <b>Multi-Point Scaling Point 8</b>                                            |
| Dec                             | 1068 | 17452 | 34904 |           | Percentage of the scaled input where multi-point scaling value 8 is applied.  |
| Hex                             | 042C | 442C  | 8858  |           | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.               |
| <b>Input 1 Display Point 8</b>  |      |       |       | <b>RW</b> | <b>Multi-Point Scaling Display Value For Point 8</b>                          |
| Dec                             | 1069 | 17453 | 34906 |           | Value to display at multi-point scaling point 8                               |
| Hex                             | 042D | 442D  | 885A  |           | Valid between the scaled input lower & upper limits                           |
| <b>Input 1 Scale Point 9</b>    |      |       |       | <b>RW</b> | <b>Multi-Point Scaling Point 9</b>                                            |
| Dec                             | 1070 | 17454 | 34908 |           | Percentage of the scaled input where multi-point scaling value 9 is applied.  |
| Hex                             | 042E | 442E  | 885C  |           | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.               |
| <b>Input 1 Display Point 9</b>  |      |       |       | <b>RW</b> | <b>Multi-Point Scaling Display Value For Point 9</b>                          |
| Dec                             | 1071 | 17455 | 34910 |           | Value to display at multi-point scaling point 9                               |
| Hex                             | 042F | 442F  | 885E  |           | Valid between the scaled input lower & upper limits                           |
| <b>Input 1 Scale Point 10</b>   |      |       |       | <b>RW</b> | <b>Multi-Point Scaling Point 10</b>                                           |
| Dec                             | 1072 | 17456 | 34912 |           | Percentage of the scaled input where multi-point scaling value 10 is applied. |
| Hex                             | 0430 | 4430  | 8860  |           | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.               |
| <b>Input 1 Display Point 10</b> |      |       |       | <b>RW</b> | <b>Multi-Point Scaling Display Value For Point 10</b>                         |
| Dec                             | 1073 | 17457 | 34914 |           | Value to display at multi-point scaling point 10                              |
| Hex                             | 0431 | 4431  | 8862  |           | Valid between the scaled input lower & upper limits                           |
| <b>Input 1 Scale Point 11</b>   |      |       |       | <b>RW</b> | <b>Multi-Point Scaling Point 11</b>                                           |
| Dec                             | 1074 | 17458 | 34916 |           | Percentage of the scaled input where multi-point scaling value 11 is applied. |
| Hex                             | 0432 | 4432  | 8864  |           | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.               |
| <b>Input 1 Display Point 11</b> |      |       |       | <b>RW</b> | <b>Multi-Point Scaling Display Value For Point 11</b>                         |
| Dec                             | 1075 | 17459 | 34918 |           | Value to display at multi-point scaling point 11                              |
| Hex                             | 0433 | 4433  | 8866  |           | Valid between the scaled input lower & upper limits                           |
| <b>Input 1 Scale Point 12</b>   |      |       |       | <b>RW</b> | <b>Multi-Point Scaling Point 12</b>                                           |
| Dec                             | 1076 | 17460 | 34920 |           | Percentage of the scaled input where multi-point scaling value 12 is applied. |
| Hex                             | 0434 | 4434  | 8868  |           | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.               |
| <b>Input 1 Display Point 12</b> |      |       |       | <b>RW</b> | <b>Multi-Point Scaling Display Value For Point 12</b>                         |
| Dec                             | 1077 | 17461 | 34922 |           | Value to display at multi-point scaling point 12                              |
| Hex                             | 0435 | 4435  | 886A  |           | Valid between the scaled input lower & upper limits                           |
| <b>Input 1 Scale Point 13</b>   |      |       |       | <b>RW</b> | <b>Multi-Point Scaling Point 13</b>                                           |
| Dec                             | 1078 | 17462 | 34924 |           | Percentage of the scaled input where multi-point scaling value 13 is applied. |
| Hex                             | 0436 | 4436  | 886C  |           | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.               |
| <b>Input 1 Display Point 13</b> |      |       |       | <b>RW</b> | <b>Multi-Point Scaling Display Value For Point 13</b>                         |
| Dec                             | 1079 | 17463 | 34926 |           | Value to display at multi-point scaling point 13                              |
| Hex                             | 0437 | 4437  | 886E  |           | Valid between the scaled input lower & upper limits                           |
| <b>Input 1 Scale Point 14</b>   |      |       |       | <b>RW</b> | <b>Multi-Point Scaling Point 14</b>                                           |
| Dec                             | 1080 | 17464 | 34928 |           | Percentage of the scaled input where multi-point scaling value 14 is applied. |
| Hex                             | 0438 | 4438  | 8870  |           | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.               |
| <b>Input 1 Display Point 14</b> |      |       |       | <b>RW</b> | <b>Multi-Point Scaling Display Value For Point 14</b>                         |
| Dec                             | 1081 | 17465 | 34930 |           | Value to display at multi-point scaling point 14                              |
| Hex                             | 0439 | 4439  | 8872  |           | Valid between the scaled input lower & upper limits                           |

| Input 1 Scale Point 15              |      |       |       | Multi-Point Scaling Point 15                   |                                                                                                                                                  |
|-------------------------------------|------|-------|-------|------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------|
| Dec                                 | 1082 | 17466 | 34932 | RW                                             | Percentage of the scaled input where multi-point scaling value 15 is applied.<br>0.1 to 100.0% *set to 100% ends scaling sequence at that point. |
| Hex                                 | 043A | 443A  | 8874  |                                                |                                                                                                                                                  |
| Input 1 Display Point 15            |      |       |       | Multi-Point Scaling Display Value For Point 15 |                                                                                                                                                  |
| Dec                                 | 1083 | 17467 | 34934 | RW                                             | Value to display at multi-point scaling point 15<br>Valid between the scaled input lower & upper limits                                          |
| Hex                                 | 043B | 443B  | 8876  |                                                |                                                                                                                                                  |
| User Calibration Type               |      |       |       | Value                                          | Calibration Type                                                                                                                                 |
| Dec                                 | 1085 | 17469 | 34938 | RW                                             | 0    None (input 1 base calibration used)                                                                                                        |
| Hex                                 | 043D | 443D  | 887A  |                                                | 1    Single Point Calibration                                                                                                                    |
|                                     |      |       |       |                                                | 2    Two Point Calibration                                                                                                                       |
| User Calibration Point - Low Value  |      |       |       | Two Point Calibration Low Point                |                                                                                                                                                  |
| Dec                                 | 1086 | 17470 | 34940 | RW                                             | The input value at which the Low Offset will be applied<br>Valid between input 1 scaled input lower & upper limits                               |
| Hex                                 | 043E | 443E  | 887C  |                                                |                                                                                                                                                  |
| User Calibration Low Offset         |      |       |       | Two Point Calibration Low Offset Value         |                                                                                                                                                  |
| Dec                                 | 1087 | 17471 | 34942 | RW                                             | The Low Offset value applied to the reading at the Low Calibration Point<br>0.0 to 100.0%                                                        |
| Hex                                 | 043F | 443F  | 887E  |                                                |                                                                                                                                                  |
| User Calibration Point - High Value |      |       |       | Two Point Calibration High Point               |                                                                                                                                                  |
| Dec                                 | 1088 | 17472 | 34944 | RW                                             | The input value at which the High Offset will be applied<br>Valid between input 1 scaled input lower & upper limits                              |
| Hex                                 | 0440 | 4440  | 8880  |                                                |                                                                                                                                                  |
| User Calibration High Offset        |      |       |       | Two Point Calibration High Offset Value        |                                                                                                                                                  |
| Dec                                 | 1089 | 17473 | 34946 | RW                                             | The High Offset value applied to the reading at the High Calibration Point<br>0.0 to 100.0%                                                      |
| Hex                                 | 0441 | 4441  | 8882  |                                                |                                                                                                                                                  |

### 20.4.3 Universal Process Input 2 Parameters

| Parameter Name & Register Address |         |        |       |        |        |                                                                    |
|-----------------------------------|---------|--------|-------|--------|--------|--------------------------------------------------------------------|
|                                   | Integer | Int +1 | Float | Access | Values | & Descriptions                                                     |
| Universal Input 2 Usage           |         |        |       |        | Value  | Process Input Type                                                 |
| Dec                               | 1166    | 17550  | 35100 | RW     | 0      | Standard                                                           |
| Hex                               | 048E    | 448E   | 891C  |        | 1      | Feedback signal for Input 1                                        |
|                                   |         |        |       |        | 2      | Redundant Sensor ( <i>backup for Input 1 Thermocouple or RTD</i> ) |
|                                   |         |        |       |        | 3      | Not Used ( <i>or Indication only</i> )                             |
| Universal Process Input 2 Type    |         |        |       |        | Value  | Process Input Type                                                 |
| Dec                               | 1100    | 17484  | 34968 | RW     | 0      | B Type Thermocouple                                                |
| Hex                               | 044C    | 444C   | 8898  |        | 2      | C Type Thermocouple                                                |
|                                   |         |        |       |        | 4      | D Type Thermocouple                                                |
|                                   |         |        |       |        | 6      | E Type Thermocouple                                                |
|                                   |         |        |       |        | 8      | J Type Thermocouple                                                |
|                                   |         |        |       |        | 10     | K Type Thermocouple                                                |
|                                   |         |        |       |        | 12     | L Type Thermocouple                                                |
|                                   |         |        |       |        | 14     | N Type Thermocouple                                                |
|                                   |         |        |       |        | 16     | R Type Thermocouple                                                |
|                                   |         |        |       |        | 18     | S Type Thermocouple                                                |
|                                   |         |        |       |        | 20     | T Type Thermocouple                                                |
|                                   |         |        |       |        | 22     | PtRh 20%: 40% Thermocouple                                         |
|                                   |         |        |       |        | 24     | PT100 RTD                                                          |

|                                        |      |       |       |    |                                                                                                     |                                             |
|----------------------------------------|------|-------|-------|----|-----------------------------------------------------------------------------------------------------|---------------------------------------------|
|                                        |      |       |       |    | 26                                                                                                  | NI120 RTD                                   |
|                                        |      |       |       |    | 28                                                                                                  | 0 to 20mA DC                                |
|                                        |      |       |       |    | 29                                                                                                  | 4 to 20mA DC                                |
|                                        |      |       |       |    | 30                                                                                                  | 0 to 50mV DC                                |
|                                        |      |       |       |    | 31                                                                                                  | 10 to 50mV DC                               |
|                                        |      |       |       |    | 32                                                                                                  | 0 to 5V DC                                  |
|                                        |      |       |       |    | 33                                                                                                  | 1 to 5V DC                                  |
|                                        |      |       |       |    | 34                                                                                                  | 0 to 10V DC                                 |
|                                        |      |       |       |    | 35                                                                                                  | 2 to 10V DC                                 |
|                                        |      |       |       |    | 36                                                                                                  | Potentiometer                               |
| Input 2 Engineering Units              |      |       |       |    | Value                                                                                               | Engineering Units For Display               |
| Dec                                    | 1101 | 17485 | 34970 | RW | 0                                                                                                   | = None                                      |
| Hex                                    | 044D | 444D  | 889A  |    | 1                                                                                                   | = °C (Default for Europe)                   |
|                                        |      |       |       |    | 2                                                                                                   | = °F (Default for USA)                      |
|                                        |      |       |       |    | 3                                                                                                   | = °K                                        |
|                                        |      |       |       |    | 4                                                                                                   | = Bar                                       |
|                                        |      |       |       |    | 5                                                                                                   | = pH                                        |
|                                        |      |       |       |    | 6                                                                                                   | = %                                         |
|                                        |      |       |       |    | 7                                                                                                   | = %RH                                       |
|                                        |      |       |       |    | 8                                                                                                   | = PSI                                       |
| Input 2 Maximum Display Decimal Places |      |       |       |    | Value                                                                                               | Maximum Number Of Decimal Places In Display |
| Dec                                    | 1102 | 17486 | 34972 | RW | 0                                                                                                   | None (e.g. 1234)                            |
| Hex                                    | 044E | 444E  | 889C  |    | 1                                                                                                   | One (e.g. 123.4)                            |
|                                        |      |       |       |    | 2                                                                                                   | Two (e.g. 12.34)                            |
|                                        |      |       |       |    | 3                                                                                                   | Three (e.g. 1.234)                          |
| Input 2 Scaled Input Lower Limit       |      |       |       |    | Scaling Value Low Limit                                                                             |                                             |
| Dec                                    | 1103 | 17487 | 34974 | RW | Valid between input 2 range maximum and minimum (see Specifications section for input details)      |                                             |
| Hex                                    | 044F | 444F  | 889E  |    |                                                                                                     |                                             |
| Input 2 Scaled Input Upper Limit       |      |       |       |    | Scaling Value High Limit                                                                            |                                             |
| Dec                                    | 1104 | 17488 | 34976 | RW | Valid between input 2 range maximum and minimum (see Specifications section for input details)      |                                             |
| Hex                                    | 0450 | 4450  | 88A0  |    |                                                                                                     |                                             |
| Input 2 Process Variable Offset        |      |       |       |    | Single Point Calibration PV Offset                                                                  |                                             |
| Dec                                    | 1105 | 17489 | 34978 | RW | Used for Single Point Calibration of input 2<br>Valid between the scaled input lower & upper limits |                                             |
| Hex                                    | 0451 | 4451  | 88A2  |    |                                                                                                     |                                             |
| Input 2 Filter Time Constant           |      |       |       |    | Input 2 Process Input Filter Time                                                                   |                                             |
| Dec                                    | 1106 | 17490 | 34980 | RW | Valid between 0.0 and 512.0                                                                         |                                             |
| Hex                                    | 0452 | 4452  | 88A4  |    |                                                                                                     |                                             |
| Input 2 Process Variable               |      |       |       |    | Process Input 2 Value                                                                               |                                             |
| Dec                                    | 1107 | 17491 | 34982 | RO | The current input 2 process value                                                                   |                                             |
| Hex                                    | 0453 | 4453  | 88A6  |    |                                                                                                     |                                             |
| Input 2 Signal /Sensor Break Flag      |      |       |       |    | Value                                                                                               | Process Input Break Status                  |
| Dec                                    | 1108 | 17492 | 34984 | RO | 0                                                                                                   | Inactive                                    |
| Hex                                    | 0454 | 4454  | 88A8  |    | 1                                                                                                   | Active (break detected)                     |
| Input 2 Signal Under Range Flag        |      |       |       |    | Value                                                                                               | Process Input Under Range Status            |
| Dec                                    | 1109 | 17493 | 34986 | RO | 0                                                                                                   | Inactive                                    |
| Hex                                    | 0455 | 4455  | 88AA  |    | 1                                                                                                   | Active (under-range detected)               |

|                                           |      |       |       |                                                      |                                                                              |
|-------------------------------------------|------|-------|-------|------------------------------------------------------|------------------------------------------------------------------------------|
| <b>Input 2 Signal Over Range Flag</b>     |      |       |       | <b>Value</b>                                         | <b>Process Input Over Range Status</b>                                       |
| Dec                                       | 1110 | 17494 | 34988 | RO                                                   | 0 Inactive                                                                   |
| Hex                                       | 0456 | 4456  | 88AC  |                                                      | 1 Active ( <i>over-range detected</i> )                                      |
| <b>Input 2 Cold Junction Compensation</b> |      |       |       | <b>Value</b>                                         | <b>CJC Status</b>                                                            |
| Dec                                       | 1111 | 17495 | 34990 | RW                                                   | 0 Disabled                                                                   |
| Hex                                       | 0457 | 4457  | 88AE  |                                                      | 1 Enabled ( <i>default</i> )                                                 |
| <b>Input 2 Multi-point Scaling Enable</b> |      |       |       | <b>Value</b>                                         | <b>Multi-point Scaling Status</b>                                            |
| Dec                                       | 1129 | 17513 | 35026 | RW                                                   | 0 Disabled                                                                   |
| Hex                                       | 0469 | 4469  | 88D2  |                                                      | 1 Enabled ( <i>only if the input type is linear</i> )                        |
| <b>Input 2 Scale Point 1</b>              |      |       |       | <b>Multi-Point Scaling Point 1</b>                   |                                                                              |
| Dec                                       | 1130 | 17514 | 35028 | RW                                                   | Percentage of the scaled input where multi-point scaling value 1 is applied. |
| Hex                                       | 046A | 446A  | 88D4  |                                                      | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.              |
| <b>Input 2 Display Point 1</b>            |      |       |       | <b>Multi-Point Scaling Display Value For Point 1</b> |                                                                              |
| Dec                                       | 1131 | 17515 | 35030 | RW                                                   | Value to display at multi-point scaling point 1                              |
| Hex                                       | 046B | 446B  | 88D6  |                                                      | Valid between the scaled input lower & upper limits                          |
| <b>Input 2 Scale Point 2</b>              |      |       |       | <b>Multi-Point Scaling Point 2</b>                   |                                                                              |
| Dec                                       | 1132 | 17516 | 35032 | RW                                                   | Percentage of the scaled input where multi-point scaling value 2 is applied. |
| Hex                                       | 046C | 446C  | 88D8  |                                                      | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.              |
| <b>Input 2 Display Point 2</b>            |      |       |       | <b>Multi-Point Scaling Display Value For Point 2</b> |                                                                              |
| Dec                                       | 1133 | 17517 | 35034 | RW                                                   | Value to display at multi-point scaling point 2                              |
| Hex                                       | 046D | 446D  | 88DA  |                                                      | Valid between the scaled input lower & upper limits                          |
| <b>Input 2 Scale Point 3</b>              |      |       |       | <b>Multi-Point Scaling Point 3</b>                   |                                                                              |
| Dec                                       | 1134 | 17518 | 35036 | RW                                                   | Percentage of the scaled input where multi-point scaling value 3 is applied. |
| Hex                                       | 046E | 446E  | 88DC  |                                                      | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.              |
| <b>Input 2 Display Point 3</b>            |      |       |       | <b>Multi-Point Scaling Display Value For Point 3</b> |                                                                              |
| Dec                                       | 1135 | 17519 | 35038 | RW                                                   | Value to display at multi-point scaling point 3                              |
| Hex                                       | 046F | 446F  | 88DE  |                                                      | Valid between the scaled input lower & upper limits                          |
| <b>Input 2 Scale Point 4</b>              |      |       |       | <b>Multi-Point Scaling Point 4</b>                   |                                                                              |
| Dec                                       | 1136 | 17520 | 35040 | RW                                                   | Percentage of the scaled input where multi-point scaling value 4 is applied. |
| Hex                                       | 0470 | 4470  | 88E0  |                                                      | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.              |
| <b>Input 2 Display Point 4</b>            |      |       |       | <b>Multi-Point Scaling Display Value For Point 4</b> |                                                                              |
| Dec                                       | 1137 | 17521 | 35042 | RW                                                   | Value to display at multi-point scaling point 4                              |
| Hex                                       | 0471 | 4471  | 88E2  |                                                      | Valid between the scaled input lower & upper limits                          |
| <b>Input 2 Scale Point 5</b>              |      |       |       | <b>Multi-Point Scaling Point 5</b>                   |                                                                              |
| Dec                                       | 1138 | 17522 | 35044 | RW                                                   | Percentage of the scaled input where multi-point scaling value 5 is applied. |
| Hex                                       | 0472 | 4472  | 88E4  |                                                      | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.              |
| <b>Input 2 Display Point 5</b>            |      |       |       | <b>Multi-Point Scaling Display Value For Point 5</b> |                                                                              |
| Dec                                       | 1139 | 17523 | 35046 | RW                                                   | Value to display at multi-point scaling point 5                              |
| Hex                                       | 0473 | 4473  | 88E6  |                                                      | Valid between the scaled input lower & upper limits                          |
| <b>Input 2 Scale Point 6</b>              |      |       |       | <b>Multi-Point Scaling Point 6</b>                   |                                                                              |
| Dec                                       | 1140 | 17524 | 35048 | RW                                                   | Percentage of the scaled input where multi-point scaling value 6 is applied. |
| Hex                                       | 0474 | 4474  | 88E8  |                                                      | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.              |
| <b>Input 2 Display Point 6</b>            |      |       |       | <b>Multi-Point Scaling Display Value For Point 6</b> |                                                                              |
| Dec                                       | 1141 | 17525 | 35050 | RW                                                   | Value to display at multi-point scaling point 6                              |
| Hex                                       | 0475 | 4475  | 88EA  |                                                      | Valid between the scaled input lower & upper limits                          |

|                          |      |       |       |                                                |                                                                                                                                                  |
|--------------------------|------|-------|-------|------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------|
| Input 2 Scale Point 7    |      |       |       | Multi-Point Scaling Point 7                    |                                                                                                                                                  |
| Dec                      | 1142 | 17526 | 35052 | RW                                             | Percentage of the scaled input where multi-point scaling value 7 is applied.<br>0.1 to 100.0% *set to 100% ends scaling sequence at that point.  |
| Hex                      | 0476 | 4476  | 88EC  |                                                |                                                                                                                                                  |
| Input 2 Display Point 7  |      |       |       | Multi-Point Scaling Display Value For Point 7  |                                                                                                                                                  |
| Dec                      | 1143 | 17527 | 35054 | RW                                             | Value to display at multi-point scaling point 7<br>Valid between the scaled input lower & upper limits                                           |
| Hex                      | 0477 | 4477  | 88EE  |                                                |                                                                                                                                                  |
| Input 2 Scale Point 8    |      |       |       | Multi-Point Scaling Point 8                    |                                                                                                                                                  |
| Dec                      | 1144 | 17528 | 35056 | RW                                             | Percentage of the scaled input where multi-point scaling value 8 is applied.<br>0.1 to 100.0% *set to 100% ends scaling sequence at that point.  |
| Hex                      | 0478 | 4478  | 88F0  |                                                |                                                                                                                                                  |
| Input 2 Display Point 8  |      |       |       | Multi-Point Scaling Display Value For Point 8  |                                                                                                                                                  |
| Dec                      | 1145 | 17529 | 35058 | RW                                             | Value to display at multi-point scaling point 8<br>Valid between the scaled input lower & upper limits                                           |
| Hex                      | 0479 | 4479  | 88F2  |                                                |                                                                                                                                                  |
| Input 2 Scale Point 9    |      |       |       | Multi-Point Scaling Point 9                    |                                                                                                                                                  |
| Dec                      | 1146 | 17530 | 35060 | RW                                             | Percentage of the scaled input where multi-point scaling value 9 is applied.<br>0.1 to 100.0% *set to 100% ends scaling sequence at that point.  |
| Hex                      | 047A | 447A  | 88F4  |                                                |                                                                                                                                                  |
| Input 2 Display Point 9  |      |       |       | Multi-Point Scaling Display Value For Point 9  |                                                                                                                                                  |
| Dec                      | 1147 | 17531 | 35062 | RW                                             | Value to display at multi-point scaling point 9<br>Valid between the scaled input lower & upper limits                                           |
| Hex                      | 047B | 447B  | 88F6  |                                                |                                                                                                                                                  |
| Input 2 Scale Point 10   |      |       |       | Multi-Point Scaling Point 10                   |                                                                                                                                                  |
| Dec                      | 1148 | 17532 | 35064 | RW                                             | Percentage of the scaled input where multi-point scaling value 10 is applied.<br>0.1 to 100.0% *set to 100% ends scaling sequence at that point. |
| Hex                      | 047C | 447C  | 88F8  |                                                |                                                                                                                                                  |
| Input 2 Display Point 10 |      |       |       | Multi-Point Scaling Display Value For Point 10 |                                                                                                                                                  |
| Dec                      | 1149 | 17533 | 35066 | RW                                             | Value to display at multi-point scaling point 10<br>Valid between the scaled input lower & upper limits                                          |
| Hex                      | 047D | 447D  | 88FA  |                                                |                                                                                                                                                  |
| Input 2 Scale Point 11   |      |       |       | Multi-Point Scaling Point 11                   |                                                                                                                                                  |
| Dec                      | 1150 | 17534 | 35068 | RW                                             | Percentage of the scaled input where multi-point scaling value 11 is applied.<br>0.1 to 100.0% *set to 100% ends scaling sequence at that point. |
| Hex                      | 047E | 447E  | 88FC  |                                                |                                                                                                                                                  |
| Input 2 Display Point 11 |      |       |       | Multi-Point Scaling Display Value For Point 11 |                                                                                                                                                  |
| Dec                      | 1151 | 17535 | 35070 | RW                                             | Value to display at multi-point scaling point 11<br>Valid between the scaled input lower & upper limits                                          |
| Hex                      | 047F | 447F  | 88FE  |                                                |                                                                                                                                                  |
| Input 2 Scale Point 12   |      |       |       | Multi-Point Scaling Point 12                   |                                                                                                                                                  |
| Dec                      | 1152 | 17536 | 35072 | RW                                             | Percentage of the scaled input where multi-point scaling value 12 is applied.<br>0.1 to 100.0% *set to 100% ends scaling sequence at that point. |
| Hex                      | 0480 | 4480  | 8900  |                                                |                                                                                                                                                  |
| Input 2 Display Point 12 |      |       |       | Multi-Point Scaling Display Value For Point 12 |                                                                                                                                                  |
| Dec                      | 1153 | 17537 | 35074 | RW                                             | Value to display at multi-point scaling point 12<br>Valid between the scaled input lower & upper limits                                          |
| Hex                      | 0481 | 4481  | 8902  |                                                |                                                                                                                                                  |
| Input 2 Scale Point 13   |      |       |       | Multi-Point Scaling Point 13                   |                                                                                                                                                  |
| Dec                      | 1154 | 17538 | 35076 | RW                                             | Percentage of the scaled input where multi-point scaling value 13 is applied.<br>0.1 to 100.0% *set to 100% ends scaling sequence at that point. |
| Hex                      | 0482 | 4482  | 8904  |                                                |                                                                                                                                                  |
| Input 2 Display Point 13 |      |       |       | Multi-Point Scaling Display Value For Point 13 |                                                                                                                                                  |
| Dec                      | 1155 | 17539 | 35078 | RW                                             | Value to display at multi-point scaling point 13<br>Valid between the scaled input lower & upper limits                                          |
| Hex                      | 0483 | 4483  | 8906  |                                                |                                                                                                                                                  |
| Input 2 Scale Point 14   |      |       |       | Multi-Point Scaling Point 14                   |                                                                                                                                                  |
| Dec                      | 1156 | 17540 | 35080 | RW                                             | Percentage of the scaled input where multi-point scaling value 14 is applied.<br>0.1 to 100.0% *set to 100% ends scaling sequence at that point. |
| Hex                      | 0484 | 4484  | 8908  |                                                |                                                                                                                                                  |

| Input 2 Display Point 14            |      |       |       | Multi-Point Scaling Display Value For Point 14 |                                                                               |                                      |
|-------------------------------------|------|-------|-------|------------------------------------------------|-------------------------------------------------------------------------------|--------------------------------------|
| Dec                                 | 1157 | 17541 | 35082 | RW                                             | Value to display at multi-point scaling point 14                              |                                      |
| Hex                                 | 0485 | 4485  | 890A  |                                                | Valid between the scaled input lower & upper limits                           |                                      |
| Input 2 Scale Point 15              |      |       |       | Multi-Point Scaling Point 15                   |                                                                               |                                      |
| Dec                                 | 1158 | 17542 | 35084 | RW                                             | Percentage of the scaled input where multi-point scaling value 15 is applied. |                                      |
| Hex                                 | 0486 | 4486  | 890C  |                                                | 0.1 to 100.0% *set to 100% ends scaling sequence at that point.               |                                      |
| Input 2 Display Point 15            |      |       |       | Multi-Point Scaling Display Value For Point 15 |                                                                               |                                      |
| Dec                                 | 1159 | 17543 | 35086 | RW                                             | Value to display at multi-point scaling point 15                              |                                      |
| Hex                                 | 0487 | 4487  | 890E  |                                                | Valid between the scaled input lower & upper limits                           |                                      |
| User Calibration Type               |      |       |       | Value                                          | Calibration Type                                                              |                                      |
| Dec                                 | 1161 | 17545 | 35090 | RW                                             | 0                                                                             | None (input 2 base calibration used) |
| Hex                                 | 0489 | 4489  | 8912  |                                                | 1                                                                             | Single Point Calibration             |
|                                     |      |       | 2     |                                                | Two Point Calibration                                                         |                                      |
| User Calibration Point - Low Value  |      |       |       | Two Point Calibration Low Point                |                                                                               |                                      |
| Dec                                 | 1162 | 17546 | 35092 | RW                                             | The input value at which the Low Offset will be applied                       |                                      |
| Hex                                 | 048A | 448A  | 8914  |                                                | Valid between input 2 scaled input lower & upper limits                       |                                      |
| User Calibration Low Offset         |      |       |       | Two Point Calibration Low Offset Value         |                                                                               |                                      |
| Dec                                 | 1163 | 17547 | 35094 | RW                                             | The Low Offset value applied to the reading at the Low Calibration Point      |                                      |
| Hex                                 | 048B | 448B  | 8916  |                                                | 0.0 to 100.0%                                                                 |                                      |
| User Calibration Point - High Value |      |       |       | Two Point Calibration High Point               |                                                                               |                                      |
| Dec                                 | 1164 | 17548 | 35096 | RW                                             | The input value at which the High Offset will be applied                      |                                      |
| Hex                                 | 048C | 448C  | 8918  |                                                | Valid between input 2 scaled input lower & upper limits                       |                                      |
| User Calibration High Offset        |      |       |       | Two Point Calibration High Offset Value        |                                                                               |                                      |
| Dec                                 | 1165 | 17549 | 35098 | RW                                             | The High Offset value applied to the reading at the High Calibration Point    |                                      |
| Hex                                 | 048D | 448D  | 891A  |                                                | 0.0 to 100.0%                                                                 |                                      |

#### 20.4.4 Digital Input Setup Parameters

| Parameter Name & Register Address |         |        |       |        |        |                                                             |
|-----------------------------------|---------|--------|-------|--------|--------|-------------------------------------------------------------|
|                                   | Integer | Int +1 | Float | Access | Values | & Descriptions                                              |
| Invert Digital Inputs             |         |        |       |        | Bit    | If Bit = 1, Input <i>n</i> is Inverted (ON becomes OFF etc) |
| Dec                               | 10059   | 26443  | 52886 | RW     | 0      | Digital Input A                                             |
| Hex                               | 274B    | 674B   | CE96  |        | 1      | Digital Input C1                                            |
|                                   |         |        |       |        | 2      | Digital Input C2                                            |
|                                   |         |        |       |        | 3      | Digital Input C3                                            |
|                                   |         |        |       |        | 4      | Digital Input C4                                            |
|                                   |         |        |       |        | 5      | Digital Input C5                                            |
|                                   |         |        |       |        | 6      | Digital Input C6                                            |
|                                   |         |        |       |        | 7      | Digital Input C7                                            |
|                                   |         |        |       |        | 8      | Digital Input C8                                            |
| Profile Selection Type            |         |        |       |        | Value  | Profile Selection & Bit Pattern Format                      |
| Dec                               | 10029   | 26413  | 52826 | RW     | 0      | None                                                        |
| Hex                               | 272D    | 672D   | CE5A  |        | 1      | Binary                                                      |
|                                   |         |        |       |        | 2      | BCD                                                         |

| Digital input Profile Select |       |       |       |    | Value | Inputs Assigned Exclusively to Profile Selection |
|------------------------------|-------|-------|-------|----|-------|--------------------------------------------------|
| Dec                          | 10030 | 26414 | 52828 | RW | 0     | Digital Input C1                                 |
| Hex                          | 272E  | 672E  | CE5C  |    | 1     | Digital Input C1 to C2                           |
|                              |       |       |       |    | 2     | Digital Input C1 to C3                           |
|                              |       |       |       |    | 3     | Digital Input C1 to C4                           |
|                              |       |       |       |    | 4     | Digital Input C1 to C5                           |
|                              |       |       |       |    | 5     | Digital Input C1 to C6                           |
|                              |       |       |       |    | 6     | Digital Input C1 to C7                           |
|                              |       |       |       |    |       |                                                  |
| Digital Input A Usage        |       |       |       |    | Value | Usage for Digital Input A                        |
| Dec                          | 10020 | 26404 | 52808 | RW | 0     | Unused                                           |
| Hex                          | 2724  | 6724  | CE48  |    | 1     | Control 1 Enable Disable                         |
|                              |       |       |       |    | 2     | Control 2 Enable Disable                         |
|                              |       |       |       |    | 3     | Control 1 Auto/Manual                            |
|                              |       |       |       |    | 4     | Control 2 Auto/Manual                            |
|                              |       |       |       |    | 5     | Control 1 Setpoint Selection                     |
|                              |       |       |       |    | 6     | Control 2 Setpoint Selection                     |
|                              |       |       |       |    | 7     | Control 1 Pretune Enable/Disable                 |
|                              |       |       |       |    | 8     | Control 2 Pretune Enable/Disable                 |
|                              |       |       |       |    | 9     | Control 1 Selftune Enable/Disable                |
|                              |       |       |       |    | 10    | Control 2 Selftune Enable/Disable                |
|                              |       |       |       |    | 11    | Clear All Latched Outputs                        |
|                              |       |       |       |    | 12    | Recorder Digital Start/Stop Trigger              |
|                              |       |       |       |    | 13    | Profile Run/Hold                                 |
|                              |       |       |       |    | 14    | Profile Abort                                    |
|                              |       |       |       |    | 15    | Profile Hold Release                             |
|                              |       |       |       |    | 16    | Force Output 1 on/off                            |
|                              |       |       |       |    | 17    | Force Output 2 on/off                            |
|                              |       |       |       |    | 18    | Force Output 2B on/off                           |
|                              |       |       |       |    | 19    | Force Output 3 on/off                            |
|                              |       |       |       |    | 20    | Force Output 3B on/off                           |
|                              |       |       |       |    | 21    | Force Output 4 on/off                            |
|                              |       |       |       |    | 22    | Force Output 5 on/off                            |
|                              |       |       |       |    | 23    | Output 1 Clear Latch                             |
|                              |       |       |       |    | 24    | Output 2 Clear Latch                             |
|                              |       |       |       |    | 25    | Output 2B Clear Latch                            |
|                              |       |       |       |    | 26    | Output 3 Clear Latch                             |
|                              |       |       |       |    | 27    | Output 3B Clear Latch                            |
|                              |       |       |       |    | 28    | Output 4 Clear Latch                             |
|                              |       |       |       |    | 29    | Output 5 Clear Latch                             |
|                              |       |       |       |    | 30    | Up Key Press Mimic                               |
|                              |       |       |       |    | 31    | Down Key Press Mimic                             |
|                              |       |       |       |    | 32    | Back Key Press Mimic                             |
|                              |       |       |       |    | 33    | Right Key Press Mimic                            |
|                              |       |       |       |    |       |                                                  |
| Digital Input C1 Usage       |       |       |       |    | Value | Usage for Digital Input C1                       |
| Dec                          | 10021 | 26405 | 52810 | RW | 0     | Unused                                           |
| Hex                          | 2725  | 6725  | CE4A  |    | 1     | Control 1 Enable Disable                         |
|                              |       |       |       |    | 2     | Control 2 Enable Disable                         |
|                              |       |       |       |    | 3     | Control 1 Auto/Manual                            |
|                              |       |       |       |    | 4     | Control 2 Auto/Manual                            |

|                        |       |       |       |    |       |                                     |
|------------------------|-------|-------|-------|----|-------|-------------------------------------|
|                        |       |       |       |    | 5     | Control 1 Setpoint Selection        |
|                        |       |       |       |    | 6     | Control 2 Setpoint Selection        |
|                        |       |       |       |    | 7     | Control 1 Pretune Enable/Disable    |
|                        |       |       |       |    | 8     | Control 2 Pretune Enable/Disable    |
|                        |       |       |       |    | 9     | Control 1 Selftune Enable/Disable   |
|                        |       |       |       |    | 10    | Control 2 Selftune Enable/Disable   |
|                        |       |       |       |    | 11    | Clear All Latched Outputs           |
|                        |       |       |       |    | 12    | Recorder Start/Stop                 |
|                        |       |       |       |    | 13    | Profile Run/Hold                    |
|                        |       |       |       |    | 14    | Profile Abort                       |
|                        |       |       |       |    | 15    | Profile Hold Release                |
|                        |       |       |       |    | 16    | Force Output 1 on/off               |
|                        |       |       |       |    | 17    | Force Output 2 on/off               |
|                        |       |       |       |    | 18    | Force Output 2B on/off              |
|                        |       |       |       |    | 19    | Force Output 3 on/off               |
|                        |       |       |       |    | 20    | Force Output 3B on/off              |
|                        |       |       |       |    | 21    | Force Output 4 on/off               |
|                        |       |       |       |    | 22    | Force Output 5 on/off               |
|                        |       |       |       |    | 23    | Output 1 Clear Latch                |
|                        |       |       |       |    | 24    | Output 2 Clear Latch                |
|                        |       |       |       |    | 25    | Output 2B Clear Latch               |
|                        |       |       |       |    | 26    | Output 3 Clear Latch                |
|                        |       |       |       |    | 27    | Output 3B Clear Latch               |
|                        |       |       |       |    | 28    | Output 4 Clear Latch                |
|                        |       |       |       |    | 29    | Output 5 Clear Latch                |
|                        |       |       |       |    | 30    | Up Key Press Mimic                  |
|                        |       |       |       |    | 31    | Down Key Press Mimic                |
|                        |       |       |       |    | 32    | Back Key Press Mimic                |
|                        |       |       |       |    | 33    | Right Key Press Mimic               |
| Digital Input C2 Usage |       |       |       |    | Value | Usage for Digital Input C2          |
| Dec                    | 10022 | 26406 | 52812 | RW | 0     | Unused                              |
| Hex                    | 2726  | 6726  | CE4C  |    | 1     | Control 1 Enable Disable            |
|                        |       |       |       |    | 2     | Control 2 Enable Disable            |
|                        |       |       |       |    | 3     | Control 1 Auto/Manual               |
|                        |       |       |       |    | 4     | Control 2 Auto/Manual               |
|                        |       |       |       |    | 5     | Control 1 Setpoint Selection        |
|                        |       |       |       |    | 6     | Control 2 Setpoint Selection        |
|                        |       |       |       |    | 7     | Control 1 Pretune Enable/Disable    |
|                        |       |       |       |    | 8     | Control 2 Pretune Enable/Disable    |
|                        |       |       |       |    | 9     | Control 1 Selftune Enable/Disable   |
|                        |       |       |       |    | 10    | Control 2 Selftune Enable/Disable   |
|                        |       |       |       |    | 11    | Clear All Latched Outputs           |
|                        |       |       |       |    | 12    | Recorder Digital Start/Stop Trigger |
|                        |       |       |       |    | 13    | Profile Run/Hold                    |
|                        |       |       |       |    | 14    | Profile Abort                       |
|                        |       |       |       |    | 15    | Profile Hold Release                |
|                        |       |       |       |    | 16    | Force Output 1 on/off               |
|                        |       |       |       |    | 17    | Force Output 2 on/off               |
|                        |       |       |       |    | 18    | Force Output 2B on/off              |

|                        |       |       |       |    | 19    | Force Output 3 on/off               |
|------------------------|-------|-------|-------|----|-------|-------------------------------------|
|                        |       |       |       |    | 20    | Force Output 3B on/off              |
|                        |       |       |       |    | 21    | Force Output 4 on/off               |
|                        |       |       |       |    | 22    | Force Output 5 on/off               |
|                        |       |       |       |    | 23    | Output 1 Clear Latch                |
|                        |       |       |       |    | 24    | Output 2 Clear Latch                |
|                        |       |       |       |    | 25    | Output 2B Clear Latch               |
|                        |       |       |       |    | 26    | Output 3 Clear Latch                |
|                        |       |       |       |    | 27    | Output 3B Clear Latch               |
|                        |       |       |       |    | 28    | Output 4 Clear Latch                |
|                        |       |       |       |    | 29    | Output 5 Clear Latch                |
|                        |       |       |       |    | 30    | Up Key Press Mimic                  |
|                        |       |       |       |    | 31    | Down Key Press Mimic                |
|                        |       |       |       |    | 32    | Back Key Press Mimic                |
|                        |       |       |       |    | 33    | Right Key Press Mimic               |
| Digital Input C3 Usage |       |       |       |    | Value | Usage for Digital Input C3          |
| Dec                    | 10023 | 26407 | 52814 | RW | 0     | Unused                              |
| Hex                    | 2727  | 6727  | CE4E  |    | 1     | Control 1 Enable Disable            |
|                        |       |       |       |    | 2     | Control 2 Enable Disable            |
|                        |       |       |       |    | 3     | Control 1 Auto/Manual               |
|                        |       |       |       |    | 4     | Control 2 Auto/Manual               |
|                        |       |       |       |    | 5     | Control 1 Setpoint Selection        |
|                        |       |       |       |    | 6     | Control 2 Setpoint Selection        |
|                        |       |       |       |    | 7     | Control 1 Pretune Enable/Disable    |
|                        |       |       |       |    | 8     | Control 2 Pretune Enable/Disable    |
|                        |       |       |       |    | 9     | Control 1 Selftune Enable/Disable   |
|                        |       |       |       |    | 10    | Control 2 Selftune Enable/Disable   |
|                        |       |       |       |    | 11    | Clear All Latched Outputs           |
|                        |       |       |       |    | 12    | Recorder Digital Start/Stop Trigger |
|                        |       |       |       |    | 13    | Profile Run/Hold                    |
|                        |       |       |       |    | 14    | Profile Abort                       |
|                        |       |       |       |    | 15    | Profile Hold Release                |
|                        |       |       |       |    | 16    | Force Output 1 on/off               |
|                        |       |       |       |    | 17    | Force Output 2 on/off               |
|                        |       |       |       |    | 18    | Force Output 2B on/off              |
|                        |       |       |       |    | 19    | Force Output 3 on/off               |
|                        |       |       |       |    | 20    | Force Output 3B on/off              |
|                        |       |       |       |    | 21    | Force Output 4 on/off               |
|                        |       |       |       |    | 22    | Force Output 5 on/off               |
|                        |       |       |       |    | 23    | Output 1 Clear Latch                |
|                        |       |       |       |    | 24    | Output 2 Clear Latch                |
|                        |       |       |       |    | 25    | Output 2B Clear Latch               |
|                        |       |       |       |    | 26    | Output 3 Clear Latch                |
|                        |       |       |       |    | 27    | Output 3B Clear Latch               |
|                        |       |       |       |    | 28    | Output 4 Clear Latch                |
|                        |       |       |       |    | 29    | Output 5 Clear Latch                |
|                        |       |       |       |    | 30    | Up Key Press Mimic                  |
|                        |       |       |       |    | 31    | Down Key Press Mimic                |
|                        |       |       |       |    | 32    | Back Key Press Mimic                |
|                        |       |       |       |    | 33    | Right Key Press Mimic               |

| Digital Input C4 Usage |       |       |       |    | Value                               | Usage for Digital Input C4          |
|------------------------|-------|-------|-------|----|-------------------------------------|-------------------------------------|
| Dec                    | 10024 | 26408 | 52816 | RW | 0                                   | Unused                              |
| Hex                    | 2728  | 6728  | CE50  |    | 1                                   | Control 1 Enable Disable            |
|                        |       |       |       |    | 2                                   | Control 2 Enable Disable            |
|                        |       |       |       |    | 3                                   | Control 1 Auto/Manual               |
|                        |       |       |       |    | 4                                   | Control 2 Auto/Manual               |
|                        |       |       |       |    | 5                                   | Control 1 Setpoint Selection        |
|                        |       |       |       |    | 6                                   | Control 2 Setpoint Selection        |
|                        |       |       |       |    | 7                                   | Control 1 Pretune Enable/Disable    |
|                        |       |       |       |    | 8                                   | Control 2 Pretune Enable/Disable    |
|                        |       |       |       |    | 9                                   | Control 1 Selftune Enable/Disable   |
|                        |       |       |       |    | 10                                  | Control 2 Selftune Enable/Disable   |
|                        |       |       |       |    | 11                                  | Clear All Latched Outputs           |
|                        |       |       |       |    | 12                                  | Recorder Digital Start/Stop Trigger |
|                        |       |       |       |    | 13                                  | Profile Run/Hold                    |
|                        |       |       |       |    | 14                                  | Profile Abort                       |
|                        |       |       |       |    | 15                                  | Profile Hold Release                |
|                        |       |       |       |    | 16                                  | Force Output 1 on/off               |
|                        |       |       |       |    | 17                                  | Force Output 2 on/off               |
|                        |       |       |       |    | 18                                  | Force Output 2B on/off              |
|                        |       |       |       |    | 19                                  | Force Output 3 on/off               |
|                        |       |       |       |    | 20                                  | Force Output 3B on/off              |
|                        |       |       |       |    | 21                                  | Force Output 4 on/off               |
|                        |       |       |       |    | 22                                  | Force Output 5 on/off               |
|                        |       |       |       |    | 23                                  | Output 1 Clear Latch                |
|                        |       |       |       |    | 24                                  | Output 2 Clear Latch                |
|                        |       |       |       |    | 25                                  | Output 2B Clear Latch               |
|                        |       |       |       |    | 26                                  | Output 3 Clear Latch                |
|                        |       |       |       |    | 27                                  | Output 3B Clear Latch               |
|                        |       |       |       |    | 28                                  | Output 4 Clear Latch                |
|                        |       |       |       |    | 29                                  | Output 5 Clear Latch                |
|                        |       |       |       |    | 30                                  | Up Key Press Mimic                  |
|                        |       |       |       |    | 31                                  | Down Key Press Mimic                |
|                        |       |       |       |    | 32                                  | Back Key Press Mimic                |
|                        |       |       |       |    | 33                                  | Right Key Press Mimic               |
| Digital Input C5 Usage |       |       |       |    | Value                               | Usage for Digital Input C5          |
| Dec                    | 10025 | 26409 | 52818 | RW | 0                                   | Unused                              |
| Hex                    | 2729  | 6729  | CE52  |    | 1                                   | Control 1 Enable Disable            |
|                        |       |       |       |    | 2                                   | Control 2 Enable Disable            |
|                        |       |       |       |    | 3                                   | Control 1 Auto/Manual               |
|                        |       |       |       |    | 4                                   | Control 2 Auto/Manual               |
|                        |       |       |       |    | 5                                   | Control 1 Setpoint Selection        |
|                        |       |       |       |    | 6                                   | Control 2 Setpoint Selection        |
|                        |       |       |       |    | 7                                   | Control 1 Pretune Enable/Disable    |
|                        |       |       |       |    | 8                                   | Control 2 Pretune Enable/Disable    |
|                        |       |       |       |    | 9                                   | Control 1 Selftune Enable/Disable   |
|                        |       |       |       |    | 10                                  | Control 2 Selftune Enable/Disable   |
|                        |       |       |       |    | 11                                  | Clear All Latched Outputs           |
|                        |       |       |       | 12 | Recorder Digital Start/Stop Trigger |                                     |

|                        |       |       |       |    | 13    | Profile Run/Hold                    |
|------------------------|-------|-------|-------|----|-------|-------------------------------------|
|                        |       |       |       |    | 14    | Profile Abort                       |
|                        |       |       |       |    | 15    | Profile Hold Release                |
|                        |       |       |       |    | 16    | Force Output 1 on/off               |
|                        |       |       |       |    | 17    | Force Output 2 on/off               |
|                        |       |       |       |    | 18    | Force Output 2B on/off              |
|                        |       |       |       |    | 19    | Force Output 3 on/off               |
|                        |       |       |       |    | 20    | Force Output 3B on/off              |
|                        |       |       |       |    | 21    | Force Output 4 on/off               |
|                        |       |       |       |    | 22    | Force Output 5 on/off               |
|                        |       |       |       |    | 23    | Output 1 Clear Latch                |
|                        |       |       |       |    | 24    | Output 2 Clear Latch                |
|                        |       |       |       |    | 25    | Output 2B Clear Latch               |
|                        |       |       |       |    | 26    | Output 3 Clear Latch                |
|                        |       |       |       |    | 27    | Output 3B Clear Latch               |
|                        |       |       |       |    | 28    | Output 4 Clear Latch                |
|                        |       |       |       |    | 29    | Output 5 Clear Latch                |
|                        |       |       |       |    | 30    | Up Key Press Mimic                  |
|                        |       |       |       |    | 31    | Down Key Press Mimic                |
|                        |       |       |       |    | 32    | Back Key Press Mimic                |
|                        |       |       |       |    | 33    | Right Key Press Mimic               |
| Digital Input C6 Usage |       |       |       |    | Value | Usage for Digital Input C6          |
| Dec                    | 10026 | 26410 | 52820 | RW | 0     | Unused                              |
| Hex                    | 272A  | 672A  | CE54  |    | 1     | Control 1 Enable Disable            |
|                        |       |       |       |    | 2     | Control 2 Enable Disable            |
|                        |       |       |       |    | 3     | Control 1 Auto/Manual               |
|                        |       |       |       |    | 4     | Control 2 Auto/Manual               |
|                        |       |       |       |    | 5     | Control 1 Setpoint Selection        |
|                        |       |       |       |    | 6     | Control 2 Setpoint Selection        |
|                        |       |       |       |    | 7     | Control 1 Pretune Enable/Disable    |
|                        |       |       |       |    | 8     | Control 2 Pretune Enable/Disable    |
|                        |       |       |       |    | 9     | Control 1 Selftune Enable/Disable   |
|                        |       |       |       |    | 10    | Control 2 Selftune Enable/Disable   |
|                        |       |       |       |    | 11    | Clear All Latched Outputs           |
|                        |       |       |       |    | 12    | Recorder Digital Start/Stop Trigger |
|                        |       |       |       |    | 13    | Profile Run/Hold                    |
|                        |       |       |       |    | 14    | Profile Abort                       |
|                        |       |       |       |    | 15    | Profile Hold Release                |
|                        |       |       |       |    | 16    | Force Output 1 on/off               |
|                        |       |       |       |    | 17    | Force Output 2 on/off               |
|                        |       |       |       |    | 18    | Force Output 2B on/off              |
|                        |       |       |       |    | 19    | Force Output 3 on/off               |
|                        |       |       |       |    | 20    | Force Output 3B on/off              |
|                        |       |       |       |    | 21    | Force Output 4 on/off               |
|                        |       |       |       |    | 22    | Force Output 5 on/off               |
|                        |       |       |       |    | 23    | Output 1 Clear Latch                |
|                        |       |       |       |    | 24    | Output 2 Clear Latch                |
|                        |       |       |       |    | 25    | Output 2B Clear Latch               |
|                        |       |       |       |    | 26    | Output 3 Clear Latch                |

|                               |              |              |              |           |              |                                     |
|-------------------------------|--------------|--------------|--------------|-----------|--------------|-------------------------------------|
|                               |              |              |              |           | 27           | Output 3B Clear Latch               |
|                               |              |              |              |           | 28           | Output 4 Clear Latch                |
|                               |              |              |              |           | 29           | Output 5 Clear Latch                |
|                               |              |              |              |           | 30           | Up Key Press Mimic                  |
|                               |              |              |              |           | 31           | Down Key Press Mimic                |
|                               |              |              |              |           | 32           | Back Key Press Mimic                |
|                               |              |              |              |           | 33           | Right Key Press Mimic               |
| <b>Digital Input C7 Usage</b> |              |              |              |           | <b>Value</b> | <b>Usage for Digital Input C7</b>   |
| <b>Dec</b>                    | <b>10027</b> | <b>26411</b> | <b>52822</b> | <b>RW</b> | 0            | Unused                              |
| <b>Hex</b>                    | <b>272B</b>  | <b>672B</b>  | <b>CE56</b>  |           | 1            | Control 1 Enable Disable            |
|                               |              |              |              |           | 2            | Control 2 Enable Disable            |
|                               |              |              |              |           | 3            | Control 1 Auto/Manual               |
|                               |              |              |              |           | 4            | Control 2 Auto/Manual               |
|                               |              |              |              |           | 5            | Control 1 Setpoint Selection        |
|                               |              |              |              |           | 6            | Control 2 Setpoint Selection        |
|                               |              |              |              |           | 7            | Control 1 Pretune Enable/Disable    |
|                               |              |              |              |           | 8            | Control 2 Pretune Enable/Disable    |
|                               |              |              |              |           | 9            | Control 1 Selftune Enable/Disable   |
|                               |              |              |              |           | 10           | Control 2 Selftune Enable/Disable   |
|                               |              |              |              |           | 11           | Clear All Latched Outputs           |
|                               |              |              |              |           | 12           | Recorder Digital Start/Stop Trigger |
|                               |              |              |              |           | 13           | Profile Run/Hold                    |
|                               |              |              |              |           | 14           | Profile Abort                       |
|                               |              |              |              |           | 15           | Profile Hold Release                |
|                               |              |              |              |           | 16           | Force Output 1 on/off               |
|                               |              |              |              |           | 17           | Force Output 2 on/off               |
|                               |              |              |              |           | 18           | Force Output 2B on/off              |
|                               |              |              |              |           | 19           | Force Output 3 on/off               |
|                               |              |              |              |           | 20           | Force Output 3B on/off              |
|                               |              |              |              |           | 21           | Force Output 4 on/off               |
|                               |              |              |              |           | 22           | Force Output 5 on/off               |
|                               |              |              |              |           | 23           | Output 1 Clear Latch                |
|                               |              |              |              |           | 24           | Output 2 Clear Latch                |
|                               |              |              |              |           | 25           | Output 2B Clear Latch               |
|                               |              |              |              |           | 26           | Output 3 Clear Latch                |
|                               |              |              |              |           | 27           | Output 3B Clear Latch               |
|                               |              |              |              |           | 28           | Output 4 Clear Latch                |
|                               |              |              |              |           | 29           | Output 5 Clear Latch                |
|                               |              |              |              |           | 30           | Up Key Press Mimic                  |
|                               |              |              |              |           | 31           | Down Key Press Mimic                |
|                               |              |              |              |           | 32           | Back Key Press Mimic                |
|                               |              |              |              |           | 33           | Right Key Press Mimic               |
| <b>Digital Input C8 Usage</b> |              |              |              |           | <b>Value</b> | <b>Usage for Digital Input C8</b>   |
| <b>Dec</b>                    | <b>10028</b> | <b>26412</b> | <b>52824</b> | <b>RW</b> | 0            | Unused                              |
| <b>Hex</b>                    | <b>272C</b>  | <b>672C</b>  | <b>CE58</b>  |           | 1            | Control 1 Enable Disable            |
|                               |              |              |              |           | 2            | Control 2 Enable Disable            |
|                               |              |              |              |           | 3            | Control 1 Auto/Manual               |
|                               |              |              |              |           | 4            | Control 2 Auto/Manual               |
|                               |              |              |              |           | 5            | Control 1 Setpoint Selection        |

|                      |       |       |       |    | 6     | Control 2 Setpoint Selection        |
|----------------------|-------|-------|-------|----|-------|-------------------------------------|
|                      |       |       |       |    | 7     | Control 1 Pretune Enable/Disable    |
|                      |       |       |       |    | 8     | Control 2 Pretune Enable/Disable    |
|                      |       |       |       |    | 9     | Control 1 Selftune Enable/Disable   |
|                      |       |       |       |    | 10    | Control 2 Selftune Enable/Disable   |
|                      |       |       |       |    | 11    | Clear All Latched Outputs           |
|                      |       |       |       |    | 12    | Recorder Digital Start/Stop Trigger |
|                      |       |       |       |    | 13    | Profile Run/Hold                    |
|                      |       |       |       |    | 14    | Profile Abort                       |
|                      |       |       |       |    | 15    | Profile Hold Release                |
|                      |       |       |       |    | 16    | Force Output 1 on/off               |
|                      |       |       |       |    | 17    | Force Output 2 on/off               |
|                      |       |       |       |    | 18    | Force Output 2B on/off              |
|                      |       |       |       |    | 19    | Force Output 3 on/off               |
|                      |       |       |       |    | 20    | Force Output 3B on/off              |
|                      |       |       |       |    | 21    | Force Output 4 on/off               |
|                      |       |       |       |    | 22    | Force Output 5 on/off               |
|                      |       |       |       |    | 23    | Output 1 Clear Latch                |
|                      |       |       |       |    | 24    | Output 2 Clear Latch                |
|                      |       |       |       |    | 25    | Output 2B Clear Latch               |
|                      |       |       |       |    | 26    | Output 3 Clear Latch                |
|                      |       |       |       |    | 27    | Output 3B Clear Latch               |
|                      |       |       |       |    | 28    | Output 4 Clear Latch                |
|                      |       |       |       |    | 29    | Output 5 Clear Latch                |
|                      |       |       |       |    | 30    | Up Key Press Mimic                  |
|                      |       |       |       |    | 31    | Down Key Press Mimic                |
|                      |       |       |       |    | 32    | Back Key Press Mimic                |
|                      |       |       |       |    | 33    | Right Key Press Mimic               |
| Soft Digital 1 Usage |       |       |       |    | Value | Usage for "Soft" Digital Input S1   |
| Dec                  | 10036 | 26420 | 52840 | RW | 0     | Unused                              |
| Hex                  | 2734  | 6734  | CE68  |    | 1     | Control 1 Enable Disable            |
|                      |       |       |       |    | 2     | Control 2 Enable Disable            |
|                      |       |       |       |    | 3     | Control 1 Auto/Manual               |
|                      |       |       |       |    | 4     | Control 2 Auto/Manual               |
|                      |       |       |       |    | 5     | Control 1 Setpoint Selection        |
|                      |       |       |       |    | 6     | Control 2 Setpoint Selection        |
|                      |       |       |       |    | 7     | Control 1 Pretune Enable/Disable    |
|                      |       |       |       |    | 8     | Control 2 Pretune Enable/Disable    |
|                      |       |       |       |    | 9     | Control 1 Selftune Enable/Disable   |
|                      |       |       |       |    | 10    | Control 2 Selftune Enable/Disable   |
|                      |       |       |       |    | 11    | Clear All Latched Outputs           |
|                      |       |       |       |    | 12    | Recorder Digital Start/Stop Trigger |
|                      |       |       |       |    | 13    | Profile Run/Hold                    |
|                      |       |       |       |    | 14    | Profile Abort                       |
|                      |       |       |       |    | 15    | Profile Hold Release                |
|                      |       |       |       |    | 16    | Force Output 1 on/off               |
|                      |       |       |       |    | 17    | Force Output 2 on/off               |
|                      |       |       |       |    | 18    | Force Output 2B on/off              |
|                      |       |       |       |    | 19    | Force Output 3 on/off               |
|                      |       |       |       |    | 20    | Force Output 3B on/off              |

|                                   |       |       |       |    |     |                                                              |
|-----------------------------------|-------|-------|-------|----|-----|--------------------------------------------------------------|
|                                   |       |       |       |    | 21  | Force Output 4 on/off                                        |
|                                   |       |       |       |    | 22  | Force Output 5 on/off                                        |
|                                   |       |       |       |    | 23  | Output 1 Clear Latch                                         |
|                                   |       |       |       |    | 24  | Output 2 Clear Latch                                         |
|                                   |       |       |       |    | 25  | Output 2B Clear Latch                                        |
|                                   |       |       |       |    | 26  | Output 3 Clear Latch                                         |
|                                   |       |       |       |    | 27  | Output 3B Clear Latch                                        |
|                                   |       |       |       |    | 28  | Output 4 Clear Latch                                         |
|                                   |       |       |       |    | 29  | Output 5 Clear Latch                                         |
|                                   |       |       |       |    | 30  | Up Key Press Mimic                                           |
|                                   |       |       |       |    | 31  | Down Key Press Mimic                                         |
|                                   |       |       |       |    | 32  | Back Key Press Mimic                                         |
|                                   |       |       |       |    | 33  | Right Key Press Mimic                                        |
| Soft Digital 1 OR Digital Inputs  |       |       |       |    | Bit | If Bit value = 1 Input <i>n</i> Is Included in OR Selection  |
| Dec                               | 10040 | 26424 | 52848 | RW | 0   | Digital Input A                                              |
| Hex                               | 2738  | 6738  | CE70  |    | 1   | Digital Input C1                                             |
|                                   |       |       |       |    | 2   | Digital Input C2                                             |
|                                   |       |       |       |    | 3   | Digital Input C3                                             |
|                                   |       |       |       |    | 4   | Digital Input C4                                             |
|                                   |       |       |       |    | 5   | Digital Input C5                                             |
|                                   |       |       |       |    | 6   | Digital Input C6                                             |
|                                   |       |       |       |    | 7   | Digital Input C7                                             |
|                                   |       |       |       |    | 8   | Digital Input C8                                             |
| Soft Digital 1 AND Digital Inputs |       |       |       |    | Bit | If Bit value = 1 Input <i>n</i> Is Included in AND Selection |
| Dec                               | 10041 | 26425 | 52850 | RW | 0   | Digital Input A                                              |
| Hex                               | 2739  | 6739  | CE72  |    | 1   | Digital Input C1                                             |
|                                   |       |       |       |    | 2   | Digital Input C2                                             |
|                                   |       |       |       |    | 3   | Digital Input C3                                             |
|                                   |       |       |       |    | 4   | Digital Input C4                                             |
|                                   |       |       |       |    | 5   | Digital Input C5                                             |
|                                   |       |       |       |    | 6   | Digital Input C6                                             |
|                                   |       |       |       |    | 7   | Digital Input C7                                             |
|                                   |       |       |       |    | 8   | Digital Input C8                                             |
| Soft Digital 1 OR Alarms          |       |       |       |    | Bit | If Bit value = 1 Alarm <i>n</i> Is Included in OR Selection  |
| Dec                               | 10050 | 26434 | 52868 | RW | 0   | Alarm 1                                                      |
| Hex                               | 2742  | 6742  | CE84  |    | 1   | Alarm 2                                                      |
|                                   |       |       |       |    | 2   | Alarm 3                                                      |
|                                   |       |       |       |    | 3   | Alarm 4                                                      |
|                                   |       |       |       |    | 4   | Alarm 5                                                      |
|                                   |       |       |       |    | 5   | Alarm 6                                                      |
|                                   |       |       |       |    | 6   | Alarm 7                                                      |
| Soft Digital 1 OR Events          |       |       |       |    | Bit | If Bit value = 1 Event <i>n</i> Is Included in OR Selection  |
| Dec                               | 10051 | 26435 | 52870 | RW | 0   | Event 1                                                      |
| Hex                               | 2743  | 6743  | CE86  |    | 1   | Event 2                                                      |
|                                   |       |       |       |    | 2   | Event 3                                                      |
|                                   |       |       |       |    | 3   | Event 4                                                      |
|                                   |       |       |       |    | 4   | Event 5                                                      |
|                                   |       |       |       |    | 5   | Profile Running                                              |
|                                   |       |       |       |    | 6   | Profile End                                                  |

| Soft Digital 2 Usage             |       |       |       |    | Value | Usage for "Soft" Digital Input S2                           |
|----------------------------------|-------|-------|-------|----|-------|-------------------------------------------------------------|
| Dec                              | 10037 | 26421 | 52842 | RW | 0     | Unused                                                      |
| Hex                              | 2735  | 6735  | CE6A  |    | 1     | Control 1 Enable Disable                                    |
|                                  |       |       |       |    | 2     | Control 2 Enable Disable                                    |
|                                  |       |       |       |    | 3     | Control 1 Auto/Manual                                       |
|                                  |       |       |       |    | 4     | Control 2 Auto/Manual                                       |
|                                  |       |       |       |    | 5     | Control 1 Setpoint Selection                                |
|                                  |       |       |       |    | 6     | Control 2 Setpoint Selection                                |
|                                  |       |       |       |    | 7     | Control 1 Pretune Enable/Disable                            |
|                                  |       |       |       |    | 8     | Control 2 Pretune Enable/Disable                            |
|                                  |       |       |       |    | 9     | Control 1 Selftune Enable/Disable                           |
|                                  |       |       |       |    | 10    | Control 2 Selftune Enable/Disable                           |
|                                  |       |       |       |    | 11    | Clear All Latched Outputs                                   |
|                                  |       |       |       |    | 12    | Recorder Digital Start/Stop Trigger                         |
|                                  |       |       |       |    | 13    | Profile Run/Hold                                            |
|                                  |       |       |       |    | 14    | Profile Abort                                               |
|                                  |       |       |       |    | 15    | Profile Hold Release                                        |
|                                  |       |       |       |    | 16    | Force Output 1 on/off                                       |
|                                  |       |       |       |    | 17    | Force Output 2 on/off                                       |
|                                  |       |       |       |    | 18    | Force Output 2B on/off                                      |
|                                  |       |       |       |    | 19    | Force Output 3 on/off                                       |
|                                  |       |       |       |    | 20    | Force Output 3B on/off                                      |
|                                  |       |       |       |    | 21    | Force Output 4 on/off                                       |
|                                  |       |       |       |    | 22    | Force Output 5 on/off                                       |
|                                  |       |       |       |    | 23    | Output 1 Clear Latch                                        |
|                                  |       |       |       |    | 24    | Output 2 Clear Latch                                        |
|                                  |       |       |       |    | 25    | Output 2B Clear Latch                                       |
|                                  |       |       |       |    | 26    | Output 3 Clear Latch                                        |
|                                  |       |       |       |    | 27    | Output 3B Clear Latch                                       |
|                                  |       |       |       |    | 28    | Output 4 Clear Latch                                        |
|                                  |       |       |       |    | 29    | Output 5 Clear Latch                                        |
|                                  |       |       |       |    | 30    | Up Key Press Mimic                                          |
|                                  |       |       |       |    | 31    | Down Key Press Mimic                                        |
|                                  |       |       |       |    | 32    | Back Key Press Mimic                                        |
|                                  |       |       |       |    | 33    | Right Key Press Mimic                                       |
| Soft Digital 2 OR Digital Inputs |       |       |       |    | Bit   | If Bit value = 1 Input <i>n</i> Is Included in OR Selection |
| Dec                              | 10042 | 26426 | 52852 | RW | 0     | Digital Input A                                             |
| Hex                              | 273A  | 673A  | CE74  |    | 1     | Digital Input C1                                            |
|                                  |       |       |       |    | 2     | Digital Input C2                                            |
|                                  |       |       |       |    | 3     | Digital Input C3                                            |
|                                  |       |       |       |    | 4     | Digital Input C4                                            |
|                                  |       |       |       |    | 5     | Digital Input C5                                            |
|                                  |       |       |       |    | 6     | Digital Input C6                                            |
|                                  |       |       |       |    | 7     | Digital Input C7                                            |
|                                  |       |       |       |    | 8     | Digital Input C8                                            |

| Soft Digital 2 AND Digital Inputs |       |       |       |    | Bit   | If Bit value = 1 Input <i>n</i> Is Included in AND Selection |
|-----------------------------------|-------|-------|-------|----|-------|--------------------------------------------------------------|
| Dec                               | 10043 | 26427 | 52854 | RW | 0     | Digital Input A                                              |
| Hex                               | 273B  | 673B  | CE76  |    | 1     | Digital Input C1                                             |
|                                   |       |       |       |    | 2     | Digital Input C2                                             |
|                                   |       |       |       |    | 3     | Digital Input C3                                             |
|                                   |       |       |       |    | 4     | Digital Input C4                                             |
|                                   |       |       |       |    | 5     | Digital Input C5                                             |
|                                   |       |       |       |    | 6     | Digital Input C6                                             |
|                                   |       |       |       |    | 7     | Digital Input C7                                             |
|                                   |       |       |       |    | 8     | Digital Input C8                                             |
| Soft Digital 2 OR Alarms          |       |       |       |    | Bit   | If Bit value = 1 Alarm <i>n</i> Is Included in OR Selection  |
| Dec                               | 10052 | 26436 | 52872 | RW | 0     | Alarm 1                                                      |
| Hex                               | 2744  | 6744  | CE88  |    | 1     | Alarm 2                                                      |
|                                   |       |       |       |    | 2     | Alarm 3                                                      |
|                                   |       |       |       |    | 3     | Alarm 4                                                      |
|                                   |       |       |       |    | 4     | Alarm 5                                                      |
|                                   |       |       |       |    | 5     | Alarm 6                                                      |
|                                   |       |       |       |    | 6     | Alarm 7                                                      |
| Soft Digital 1 OR Events          |       |       |       |    | Bit   | If Bit value = 1 Event <i>n</i> Is Included in OR Selection  |
| Dec                               | 10053 | 26437 | 52874 | RW | 0     | Event 1                                                      |
| Hex                               | 2745  | 6745  | CE8A  |    | 1     | Event 2                                                      |
|                                   |       |       |       |    | 2     | Event 3                                                      |
|                                   |       |       |       |    | 3     | Event 4                                                      |
|                                   |       |       |       |    | 4     | Event 5                                                      |
|                                   |       |       |       |    | 5     | Profile Running                                              |
|                                   |       |       |       |    | 6     | Profile End                                                  |
| Soft Digital 3 Usage              |       |       |       |    | Value | Usage for "Soft" Digital Input S3                            |
| Dec                               | 10038 | 26422 | 52844 | RW | 0     | Unused                                                       |
| Hex                               | 2736  | 6736  | CE6C  |    | 1     | Control 1 Enable Disable                                     |
|                                   |       |       |       |    | 2     | Control 2 Enable Disable                                     |
|                                   |       |       |       |    | 3     | Control 1 Auto/Manual                                        |
|                                   |       |       |       |    | 4     | Control 2 Auto/Manual                                        |
|                                   |       |       |       |    | 5     | Control 1 Setpoint Selection                                 |
|                                   |       |       |       |    | 6     | Control 2 Setpoint Selection                                 |
|                                   |       |       |       |    | 7     | Control 1 Pretune Enable/Disable                             |
|                                   |       |       |       |    | 8     | Control 2 Pretune Enable/Disable                             |
|                                   |       |       |       |    | 9     | Control 1 Selftune Enable/Disable                            |
|                                   |       |       |       |    | 10    | Control 2 Selftune Enable/Disable                            |
|                                   |       |       |       |    | 11    | Clear All Latched Outputs                                    |
|                                   |       |       |       |    | 12    | Recorder Digital Start/Stop Trigger                          |
|                                   |       |       |       |    | 13    | Profile Run/Hold                                             |
|                                   |       |       |       |    | 14    | Profile Abort                                                |
|                                   |       |       |       |    | 15    | Profile Hold Release                                         |
|                                   |       |       |       |    | 16    | Force Output 1 on/off                                        |
|                                   |       |       |       |    | 17    | Force Output 2 on/off                                        |
|                                   |       |       |       |    | 18    | Force Output 2B on/off                                       |
|                                   |       |       |       |    | 19    | Force Output 3 on/off                                        |
|                                   |       |       |       |    | 20    | Force Output 3B on/off                                       |
|                                   |       |       |       |    | 21    | Force Output 4 on/off                                        |

|                                   |       |       |       |    |     |                                                              |
|-----------------------------------|-------|-------|-------|----|-----|--------------------------------------------------------------|
|                                   |       |       |       |    | 22  | Force Output 5 on/off                                        |
|                                   |       |       |       |    | 23  | Output 1 Clear Latch                                         |
|                                   |       |       |       |    | 24  | Output 2 Clear Latch                                         |
|                                   |       |       |       |    | 25  | Output 2B Clear Latch                                        |
|                                   |       |       |       |    | 26  | Output 3 Clear Latch                                         |
|                                   |       |       |       |    | 27  | Output 3B Clear Latch                                        |
|                                   |       |       |       |    | 28  | Output 4 Clear Latch                                         |
|                                   |       |       |       |    | 29  | Output 5 Clear Latch                                         |
|                                   |       |       |       |    | 30  | Up Key Press Mimic                                           |
|                                   |       |       |       |    | 31  | Down Key Press Mimic                                         |
|                                   |       |       |       |    | 32  | Back Key Press Mimic                                         |
|                                   |       |       |       |    | 33  | Right Key Press Mimic                                        |
| Soft Digital 3 OR Digital Inputs  |       |       |       |    | Bit | If Bit value = 1 Input <i>n</i> Is Included in OR Selection  |
| Dec                               | 10044 | 26428 | 52856 | RW | 0   | Digital Input A                                              |
| Hex                               | 273C  | 673C  | CE78  |    | 1   | Digital Input C1                                             |
|                                   |       |       |       |    | 2   | Digital Input C2                                             |
|                                   |       |       |       |    | 3   | Digital Input C3                                             |
|                                   |       |       |       |    | 4   | Digital Input C4                                             |
|                                   |       |       |       |    | 5   | Digital Input C5                                             |
|                                   |       |       |       |    | 6   | Digital Input C6                                             |
|                                   |       |       |       |    | 7   | Digital Input C7                                             |
|                                   |       |       |       |    | 8   | Digital Input C8                                             |
| Soft Digital 3 AND Digital Inputs |       |       |       |    | Bit | If Bit value = 1 Input <i>n</i> Is Included in AND Selection |
| Dec                               | 10045 | 26429 | 52858 | RW | 0   | Digital Input A                                              |
| Hex                               | 273D  | 673D  | CE7A  |    | 1   | Digital Input C1                                             |
|                                   |       |       |       |    | 2   | Digital Input C2                                             |
|                                   |       |       |       |    | 3   | Digital Input C3                                             |
|                                   |       |       |       |    | 4   | Digital Input C4                                             |
|                                   |       |       |       |    | 5   | Digital Input C5                                             |
|                                   |       |       |       |    | 6   | Digital Input C6                                             |
|                                   |       |       |       |    | 7   | Digital Input C7                                             |
|                                   |       |       |       |    | 8   | Digital Input C8                                             |
| Soft Digital 3 OR Alarms          |       |       |       |    | Bit | If Bit value = 1 Alarm <i>n</i> Is Included in OR Selection  |
| Dec                               | 10054 | 26438 | 52876 | RW | 0   | Alarm 1                                                      |
| Hex                               | 2746  | 6746  | CE8C  |    | 1   | Alarm 2                                                      |
|                                   |       |       |       |    | 2   | Alarm 3                                                      |
|                                   |       |       |       |    | 3   | Alarm 4                                                      |
|                                   |       |       |       |    | 4   | Alarm 5                                                      |
|                                   |       |       |       |    | 5   | Alarm 6                                                      |
|                                   |       |       |       |    | 6   | Alarm 7                                                      |
| Soft Digital 3 OR Events          |       |       |       |    | Bit | If Bit value = 1 Event <i>n</i> Is Included in OR Selection  |
| Dec                               | 10055 | 26439 | 52878 | RW | 0   | Event 1                                                      |
| Hex                               | 2747  | 6747  | CE8E  |    | 1   | Event 2                                                      |
|                                   |       |       |       |    | 2   | Event 3                                                      |
|                                   |       |       |       |    | 3   | Event 4                                                      |
|                                   |       |       |       |    | 4   | Event 5                                                      |
|                                   |       |       |       |    | 5   | Profile Running                                              |
|                                   |       |       |       |    | 6   | Profile End                                                  |

| Soft Digital 4 Usage             |       |       |       |    | Value | Usage for "Soft" Digital Input S4                           |
|----------------------------------|-------|-------|-------|----|-------|-------------------------------------------------------------|
| Dec                              | 10039 | 26423 | 52846 | RW | 0     | Unused                                                      |
| Hex                              | 2737  | 6737  | CE6E  |    | 1     | Control 1 Enable Disable                                    |
|                                  |       |       |       |    | 2     | Control 2 Enable Disable                                    |
|                                  |       |       |       |    | 3     | Control 1 Auto/Manual                                       |
|                                  |       |       |       |    | 4     | Control 2 Auto/Manual                                       |
|                                  |       |       |       |    | 5     | Control 1 Setpoint Selection                                |
|                                  |       |       |       |    | 6     | Control 2 Setpoint Selection                                |
|                                  |       |       |       |    | 7     | Control 1 Pretune Enable/Disable                            |
|                                  |       |       |       |    | 8     | Control 2 Pretune Enable/Disable                            |
|                                  |       |       |       |    | 9     | Control 1 Selftune Enable/Disable                           |
|                                  |       |       |       |    | 10    | Control 2 Selftune Enable/Disable                           |
|                                  |       |       |       |    | 11    | Clear All Latched Outputs                                   |
|                                  |       |       |       |    | 12    | Recorder Digital Start/Stop Trigger                         |
|                                  |       |       |       |    | 13    | Profile Run/Hold                                            |
|                                  |       |       |       |    | 14    | Profile Abort                                               |
|                                  |       |       |       |    | 15    | Profile Hold Release                                        |
|                                  |       |       |       |    | 16    | Force Output 1 on/off                                       |
|                                  |       |       |       |    | 17    | Force Output 2 on/off                                       |
|                                  |       |       |       |    | 18    | Force Output 2B on/off                                      |
|                                  |       |       |       |    | 19    | Force Output 3 on/off                                       |
|                                  |       |       |       |    | 20    | Force Output 3B on/off                                      |
|                                  |       |       |       |    | 21    | Force Output 4 on/off                                       |
|                                  |       |       |       |    | 22    | Force Output 5 on/off                                       |
|                                  |       |       |       |    | 23    | Output 1 Clear Latch                                        |
|                                  |       |       |       |    | 24    | Output 2 Clear Latch                                        |
|                                  |       |       |       |    | 25    | Output 2B Clear Latch                                       |
|                                  |       |       |       |    | 26    | Output 3 Clear Latch                                        |
|                                  |       |       |       |    | 27    | Output 3B Clear Latch                                       |
|                                  |       |       |       |    | 28    | Output 4 Clear Latch                                        |
|                                  |       |       |       |    | 29    | Output 5 Clear Latch                                        |
|                                  |       |       |       |    | 30    | Up Key Press Mimic                                          |
|                                  |       |       |       |    | 31    | Down Key Press Mimic                                        |
|                                  |       |       |       |    | 32    | Back Key Press Mimic                                        |
|                                  |       |       |       |    | 33    | Right Key Press Mimic                                       |
| Soft Digital 4 OR Digital Inputs |       |       |       |    | Bit   | If Bit value = 1 Input <i>n</i> Is Included in OR Selection |
| Dec                              | 10046 | 26430 | 52860 | RW | 0     | Digital Input A                                             |
| Hex                              | 273E  | 673E  | CE7C  |    | 1     | Digital Input C1                                            |
|                                  |       |       |       |    | 2     | Digital Input C2                                            |
|                                  |       |       |       |    | 3     | Digital Input C3                                            |
|                                  |       |       |       |    | 4     | Digital Input C4                                            |
|                                  |       |       |       |    | 5     | Digital Input C5                                            |
|                                  |       |       |       |    | 6     | Digital Input C6                                            |
|                                  |       |       |       |    | 7     | Digital Input C7                                            |
|                                  |       |       |       |    | 8     | Digital Input C8                                            |

| Soft Digital 4 AND Digital Inputs |       |       |       | Bit | If Bit value = 1 Input <i>n</i> Is Included in AND Selection |
|-----------------------------------|-------|-------|-------|-----|--------------------------------------------------------------|
| Dec                               | 10047 | 26431 | 52862 | RW  | 0 Digital Input A                                            |
| Hex                               | 273F  | 673F  | CE7E  |     | 1 Digital Input C1                                           |
|                                   |       |       |       |     | 2 Digital Input C2                                           |
|                                   |       |       |       |     | 3 Digital Input C3                                           |
|                                   |       |       |       |     | 4 Digital Input C4                                           |
|                                   |       |       |       |     | 5 Digital Input C5                                           |
|                                   |       |       |       |     | 6 Digital Input C6                                           |
|                                   |       |       |       |     | 7 Digital Input C7                                           |
|                                   |       |       |       |     | 8 Digital Input C8                                           |
| Soft Digital 4 OR Alarms          |       |       |       | Bit | If Bit value = 1 Alarm <i>n</i> Is Included in OR Selection  |
| Dec                               | 10056 | 26440 | 52880 | RW  | 0 Alarm 1                                                    |
| Hex                               | 2748  | 6748  | CE90  |     | 1 Alarm 2                                                    |
|                                   |       |       |       |     | 2 Alarm 3                                                    |
|                                   |       |       |       |     | 3 Alarm 4                                                    |
|                                   |       |       |       |     | 4 Alarm 5                                                    |
|                                   |       |       |       |     | 5 Alarm 6                                                    |
|                                   |       |       |       |     | 6 Alarm 7                                                    |
| Soft Digital 4 OR Events          |       |       |       | Bit | If Bit value = 1 Event <i>n</i> Is Included in OR Selection  |
| Dec                               | 10057 | 26441 | 52882 | RW  | 0 Event 1                                                    |
| Hex                               | 2749  | 6749  | CE92  |     | 1 Event 2                                                    |
|                                   |       |       |       |     | 2 Event 3                                                    |
|                                   |       |       |       |     | 3 Event 4                                                    |
|                                   |       |       |       |     | 4 Event 5                                                    |
|                                   |       |       |       |     | 5 Profile Running                                            |
|                                   |       |       |       |     | 6 Profile End                                                |

#### 20.4.5 Plug-in Module Slot A Parameters

| Parameter Name & Register Address |         |        |       |        |          |                                      |
|-----------------------------------|---------|--------|-------|--------|----------|--------------------------------------|
|                                   | Integer | Int +1 | Float | Access | Values   | & Descriptions                       |
| Digital Input A Status            |         |        |       |        | Value    | Digital Input A Status               |
| Dec                               | 2115    | 18499  | 36998 | RO     | 0        | Inactive                             |
| Hex                               | 0843    | 4843   | 9086  |        | 1        | Active                               |
| Option Slot A Module Type         |         |        |       |        | Value    | Module Fitted In Slot A              |
| Dec                               | 2116    | 18500  | 37000 | RO     | 0        | None Fitted                          |
| Hex                               | 0844    | 4844   | 9088  |        | 1        | RS485 Communications                 |
|                                   |         |        |       |        | 3        | Digital Input A                      |
|                                   |         |        |       |        | 4        | Auxiliary Input A                    |
|                                   |         |        |       |        | 5        | Ethernet Communications              |
|                                   |         |        |       |        | 255      | Error ( <i>unrecognised module</i> ) |
| RS485 Address                     |         |        |       |        | Value    | RS485 Communications Address         |
| Dec                               | 2117    | 18501  | 37002 | RW     | 0        | Modbus Master mode                   |
| Hex                               | 0845    | 4845   | 908A  |        | 1 to 255 | Modbus Slave Address                 |

| RS485 Data Rate                      |      |       |       | Value                                        | RS485 Communications Baud Rate                                                         |
|--------------------------------------|------|-------|-------|----------------------------------------------|----------------------------------------------------------------------------------------|
| Dec                                  | 2118 | 18502 | 37004 | RW                                           | 0 4800                                                                                 |
| Hex                                  | 0846 | 4846  | 908C  |                                              | 1 9600                                                                                 |
|                                      |      |       |       |                                              | 2 19200 (Default)                                                                      |
|                                      |      |       |       |                                              | 3 38400                                                                                |
|                                      |      |       |       |                                              | 4 57600                                                                                |
|                                      |      |       |       |                                              | 5 115200                                                                               |
| RS485 Parity                         |      |       |       | Value                                        | Parity Used For RS485 Communications                                                   |
| Dec                                  | 2119 | 18503 | 37006 | RW                                           | 0 None                                                                                 |
| Hex                                  | 0847 | 4847  | 908E  |                                              | 1 Even                                                                                 |
|                                      |      |       |       |                                              | 2 Odd                                                                                  |
| Auxiliary Input A Type               |      |       |       | Value                                        | Auxiliary Analog A Input Type                                                          |
| Dec                                  | 2120 | 18504 | 37008 | RW                                           | 0 0 to 20mA DC                                                                         |
| Hex                                  | 0848 | 4848  | 9090  |                                              | 1 4 to 20mA DC                                                                         |
|                                      |      |       |       |                                              | 2 0 to 10V DC                                                                          |
|                                      |      |       |       |                                              | 3 2 to 10V DC                                                                          |
|                                      |      |       |       |                                              | 4 0 to 5V DC                                                                           |
|                                      |      |       |       |                                              | 5 1 to 5V DC                                                                           |
| Target Setpoint Address              |      |       |       | Slave Controller's Setpoint Register Address |                                                                                        |
| Dec                                  | 2121 | 18505 | 37010 | RW                                           | Target setpoint parameter address for master mode<br>(as required by slave controller) |
| Hex                                  | 0849 | 4849  | 9092  |                                              |                                                                                        |
| Master Transmit Format               |      |       |       | Value                                        | Data Format For Setpoint Broadcast                                                     |
| Dec                                  | 2123 | 18507 | 37014 | RW                                           | 0 Integer                                                                              |
| Hex                                  | 084B | 484B  | 9096  |                                              | 1 Integer with 1 decimal place                                                         |
|                                      |      |       |       |                                              | 2 Floating point number                                                                |
| Master Transmit Setpoint Selection   |      |       |       | Value                                        | Source Loop Of Setpoint For Broadcast                                                  |
| Dec                                  | 2110 | 18494 | 36988 | RW                                           | 0 Loop 1 Setpoint                                                                      |
| Hex                                  | 083E | 483E  | 907C  |                                              | 1 Loop 2 Setpoint                                                                      |
| Comms Write Enable/Disable           |      |       |       | Value                                        | Communications Status                                                                  |
| Dec                                  | 2124 | 18508 | 37016 | RW                                           | 0 Writing via serial communications disabled                                           |
| Hex                                  | 084C | 484C  | 9098  |                                              | 1 Writing via serial communications enabled                                            |
| Auxiliary Input A Signal Break       |      |       |       | Value                                        | Auxiliary Input A Break Status                                                         |
| Dec                                  | 2127 | 18511 | 37022 | RO                                           | 0 Inactive                                                                             |
| Hex                                  | 084F | 484F  | 909E  |                                              | 1 Active (break detected)                                                              |
| Auxiliary Input A Signal Under Range |      |       |       | Value                                        | Auxiliary Input A Under Range Status                                                   |
| Dec                                  | 2128 | 18512 | 37024 | RO                                           | 0 Inactive                                                                             |
| Hex                                  | 0850 | 4850  | 90A0  |                                              | 1 Active (under-range detected)                                                        |
| Auxiliary Input A Signal Over Range  |      |       |       | Value                                        | Auxiliary Input A Over Range Status                                                    |
| Dec                                  | 2129 | 18513 | 37026 | RO                                           | 0 Inactive                                                                             |
| Hex                                  | 0851 | 4851  | 90A2  |                                              | 1 Active (over-range detected)                                                         |

## 20.4.6 Plug-in Module Slot 1 Parameters

| Parameter Name & Register Address |        |       |        |        |                         |                   |
|-----------------------------------|--------|-------|--------|--------|-------------------------|-------------------|
| Integer                           | Int +1 | Float | Access | Values | & Descriptions          |                   |
| Plug-in Module 1 Type             |        |       |        | Value  | Module Fitted In Slot 1 |                   |
| Dec                               | 2130   | 18514 | 37028  | RO     | 0                       | None Fitted       |
| Hex                               | 0852   | 4852  | 90A4   |        | 1                       | Single Relay      |
|                                   |        |       |        |        | 2                       | Single SSR Driver |
|                                   |        |       |        |        | 3                       | Linear mA/V DC    |

|                               |       |       |       |    |                                                                                                   |                                                        |
|-------------------------------|-------|-------|-------|----|---------------------------------------------------------------------------------------------------|--------------------------------------------------------|
|                               |       |       |       |    | 8                                                                                                 | Triac                                                  |
|                               |       |       |       |    | 255                                                                                               | Error ( <i>unrecognised module</i> )                   |
| Linear mA/V DC Output 1 Type  |       |       |       |    | Value                                                                                             | Linear Output 1 Type                                   |
| Dec                           | 2131  | 18515 | 37030 | RW | 0                                                                                                 | 0 to 5V DC                                             |
| Hex                           | 0853  | 4853  | 90A6  |    | 1                                                                                                 | 0 to 10V DC                                            |
|                               |       |       |       |    | 2                                                                                                 | 2 to 10V DC                                            |
|                               |       |       |       |    | 3                                                                                                 | 0 to 20mA DC                                           |
|                               |       |       |       |    | 4                                                                                                 | 4 to 20mA DC                                           |
|                               |       |       |       |    | 5                                                                                                 | Variable 0 to 10VDC Transmitter PSU                    |
| Digital Output 1 Status       |       |       |       |    | Value                                                                                             | Output 1 Status (Relay, SSR Driver or Triac only)      |
| Dec                           | 2132  | 18516 | 37032 | RO | 0                                                                                                 | Inactive                                               |
| Hex                           | 0854  | 4854  | 90A8  |    | 1                                                                                                 | Active                                                 |
| Digital Output 1 Latch Enable |       |       |       |    | Value                                                                                             | Enable / Disable Latching Of Output                    |
| Dec                           | 2135  | 18519 | 37038 | RW | 0                                                                                                 | Disable                                                |
| Hex                           | 0857  | 4857  | 90AE  |    | 1                                                                                                 | Enable                                                 |
| Digital Output 1 Clear Latch  |       |       |       |    | Value                                                                                             | Latch Clear                                            |
| Dec                           | 2136  | 18520 | 37040 | RW | 0                                                                                                 | Do Nothing                                             |
| Hex                           | 0858  | 4858  | 90B0  |    | 1                                                                                                 | Clear Latch                                            |
| Digital Output 1 Latch State  |       |       |       |    | Value                                                                                             | Latch State                                            |
| Dec                           | 2137  | 18521 | 37042 | RO | 0                                                                                                 | Unlatched                                              |
| Hex                           | 0859  | 4859  | 90B2  |    | 1                                                                                                 | Latched                                                |
| Linear Output 1 Level Status  |       |       |       |    | Linear Output % Value                                                                             |                                                        |
| Dec                           | 2134  | 18518 | 37036 | RO | -2.0% to 102.0% of output nominal range<br>( <i>control output will over/under drive by 2%</i> ). |                                                        |
| Hex                           | 0856  | 4856  | 90AC  |    |                                                                                                   |                                                        |
| Linear Output 1 Function      |       |       |       |    | Value                                                                                             | Linear Output 1 Function                               |
| Dec                           | 2144  | 18528 | 37056 | RW | 0                                                                                                 | Disabled                                               |
| Hex                           | 0860  | 4860  | 90C0  |    | 1                                                                                                 | Loop 1 Primary Output Power                            |
|                               |       |       |       |    | 2                                                                                                 | Loop 1 Secondary Output Power                          |
|                               |       |       |       |    | 3                                                                                                 | Retransmit Loop 1 Actual Setpoint Value                |
|                               |       |       |       |    | 4                                                                                                 | Retransmit Input 1 Process Variable Value              |
|                               |       |       |       |    | 5                                                                                                 | Loop 2 Primary Output Power                            |
|                               |       |       |       |    | 6                                                                                                 | Loop 2 Secondary Output Power                          |
|                               |       |       |       |    | 7                                                                                                 | Retransmit Loop 2 Actual Setpoint Value                |
|                               |       |       |       |    | 8                                                                                                 | Retransmit Input 2 Process Variable Value              |
| Digital Output 1 Function     |       |       |       |    | Value                                                                                             | Digital Output 1 Function                              |
| Dec                           | 10100 | 26484 | 52968 | RW | 0                                                                                                 | Disabled                                               |
| Hex                           | 2774  | 6774  | CEE8  |    | 1                                                                                                 | Loop 1 Primary Output Power                            |
|                               |       |       |       |    | 2                                                                                                 | Loop 1 Secondary Output Power                          |
|                               |       |       |       |    | 3                                                                                                 | Loop 1 VMD Open                                        |
|                               |       |       |       |    | 4                                                                                                 | Loop 1 VMD Close                                       |
|                               |       |       |       |    | 5                                                                                                 | Loop 2 Primary Output Power                            |
|                               |       |       |       |    | 6                                                                                                 | Loop 2 Secondary Output Power                          |
|                               |       |       |       |    | 7                                                                                                 | Loop 2 VMD Open                                        |
|                               |       |       |       |    | 8                                                                                                 | Loop 2 VMD Close                                       |
|                               |       |       |       |    | 9                                                                                                 | OR Alarm Event Direct                                  |
|                               |       |       |       |    | 10                                                                                                | OR Alarm Event Reverse                                 |
|                               |       |       |       |    | 11                                                                                                | AND Alarm Event Direct                                 |
|                               |       |       |       |    | 12                                                                                                | AND Alarm Event Reverse                                |
| Output 1 OR Alarm Selection   |       |       |       |    | Bit                                                                                               | If Bit = 1, Alarm <i>n</i> Is Included in OR Selection |

|                                     |       |       |       |    |                                                                                                                                               |                                                         |
|-------------------------------------|-------|-------|-------|----|-----------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------|
| Dec                                 | 10107 | 26491 | 52982 | RW | 2                                                                                                                                             | Alarm 1                                                 |
| Hex                                 | 277B  | 677B  | CEF6  |    | 3                                                                                                                                             | Alarm 2                                                 |
|                                     |       |       |       |    | 4                                                                                                                                             | Alarm 3                                                 |
|                                     |       |       |       |    | 5                                                                                                                                             | Alarm 4                                                 |
|                                     |       |       |       |    | 6                                                                                                                                             | Alarm 5                                                 |
|                                     |       |       |       |    | 7                                                                                                                                             | Alarm 6                                                 |
|                                     |       |       |       |    | 8                                                                                                                                             | Alarm 7                                                 |
| Output 1 OR Event Selection         |       |       |       |    | Bit                                                                                                                                           | If Bit = 1, Event <i>n</i> Is Included in OR Selection  |
| Dec                                 | 10108 | 26492 | 52984 | RW | 2                                                                                                                                             | Event 1                                                 |
| Hex                                 | 277C  | 677C  | CEF8  |    | 3                                                                                                                                             | Event 2                                                 |
|                                     |       |       |       |    | 4                                                                                                                                             | Event 3                                                 |
|                                     |       |       |       |    | 5                                                                                                                                             | Event 4                                                 |
|                                     |       |       |       |    | 6                                                                                                                                             | Event 5                                                 |
|                                     |       |       |       |    | 7                                                                                                                                             | Profile Running                                         |
|                                     |       |       |       |    | 8                                                                                                                                             | Profile End                                             |
| Output 1 AND Alarm Selection        |       |       |       |    | Bit                                                                                                                                           | If Bit = 1, Alarm <i>n</i> Is Included in AND Selection |
| Dec                                 | 10109 | 26493 | 52986 | RW | 2                                                                                                                                             | Alarm 1                                                 |
| Hex                                 | 277D  | 677D  | CEFA  |    | 3                                                                                                                                             | Alarm 2                                                 |
|                                     |       |       |       |    | 4                                                                                                                                             | Alarm 3                                                 |
|                                     |       |       |       |    | 5                                                                                                                                             | Alarm 4                                                 |
|                                     |       |       |       |    | 6                                                                                                                                             | Alarm 5                                                 |
|                                     |       |       |       |    | 7                                                                                                                                             | Alarm 6                                                 |
|                                     |       |       |       |    | 8                                                                                                                                             | Alarm 7                                                 |
| Output 1 AND Event Selection        |       |       |       |    | Bit                                                                                                                                           | If Bit = 1, Event <i>n</i> Is Included in AND Selection |
| Dec                                 | 10110 | 26494 | 52988 | RW | 2                                                                                                                                             | Event 1                                                 |
| Hex                                 | 277E  | 677E  | CEFC  |    | 3                                                                                                                                             | Event 2                                                 |
|                                     |       |       |       |    | 4                                                                                                                                             | Event 3                                                 |
|                                     |       |       |       |    | 5                                                                                                                                             | Event 4                                                 |
|                                     |       |       |       |    | 6                                                                                                                                             | Event 5                                                 |
|                                     |       |       |       |    | 7                                                                                                                                             | Profile Running                                         |
|                                     |       |       |       |    | 8                                                                                                                                             | Profile End                                             |
| Output 1 Retransmit Input 1 Minimum |       |       |       |    | Value For Loop 1 Retransmit Minimum                                                                                                           |                                                         |
| Dec                                 | 2152  | 18536 | 37072 | RW | Displayed value at which the retransmission output reaches its minimum level (e.g. 4mA if type is 4-20mA).<br>Adjustable from -9999 to 9999.9 |                                                         |
| Hex                                 | 0868  | 4868  | 90D0  |    |                                                                                                                                               |                                                         |
| Output 1 Retransmit Input 1 Maximum |       |       |       |    | Value For Loop 1 Retransmit Maximum                                                                                                           |                                                         |
| Dec                                 | 2153  | 18537 | 37074 | RW | Displayed value at which the retransmission output reaches its maximum level (e.g. 2mA if type is 4-20mA).<br>Adjustable from -9999 to 9999.9 |                                                         |
| Hex                                 | 0869  | 4869  | 90D2  |    |                                                                                                                                               |                                                         |

| Output 1 Retransmit Input 2 Minimum |      |       |       |    | Value For Loop 2 Retransmit Minimum                                                                                                           |
|-------------------------------------|------|-------|-------|----|-----------------------------------------------------------------------------------------------------------------------------------------------|
| Dec                                 | 2400 | 18784 | 37568 | RW | Displayed value at which the retransmission output reaches its minimum level (e.g. 4mA if type is 4-20mA).<br>Adjustable from -9999 to 9999.9 |
| Hex                                 | 0960 | 4960  | 92C0  |    |                                                                                                                                               |
| Output 1 Retransmit Input 2 Maximum |      |       |       |    | Value For Loop 2 Retransmit Maximum                                                                                                           |
| Dec                                 | 2410 | 18794 | 37588 | RW | Displayed value at which the retransmission output reaches its maximum level (e.g. 2mA if type is 4-20mA).<br>Adjustable from -9999 to 9999.9 |
| Hex                                 | 096A | 496A  | 92D4  |    |                                                                                                                                               |

### 20.4.7 Plug-in Module Slot 2 Parameters

| Parameter Name & Register Address |        |       |        |        |                                          |                                               |
|-----------------------------------|--------|-------|--------|--------|------------------------------------------|-----------------------------------------------|
| Integer                           | Int +1 | Float | Access | Values | & Descriptions                           |                                               |
| Plug-in Module 2 Type             |        |       |        | Value  | Module Fitted In Slot 2                  |                                               |
| Dec                               | 2160   | 18544 | 37088  | RO     | 0                                        | None Fitted                                   |
| Hex                               | 0870   | 4870  | 90E0   |        | 1                                        | Single Relay                                  |
|                                   |        |       |        |        | 2                                        | Single SSR Driver                             |
|                                   |        |       |        |        | 3                                        | Error ( <i>invalid module for this slot</i> ) |
|                                   |        |       |        |        | 8                                        | Triac                                         |
|                                   |        |       |        |        | 9                                        | Dual Relay                                    |
|                                   |        |       |        |        | 10                                       | Dual SSR Driver                               |
|                                   |        |       |        |        | 11                                       | 24VDC Transmitter PSU                         |
|                                   |        |       |        |        | 255                                      | Error ( <i>unrecognised module</i> )          |
| Output 2 or 2A Status             |        |       |        | Value  | Output 2 or 2A Status                    |                                               |
| Dec                               | 2162   | 18546 | 37092  | RO     | 0                                        | Inactive                                      |
| Hex                               | 0872   | 4872  | 90E4   |        | 1                                        | Active                                        |
| Output 2B Status                  |        |       |        | Value  | Output 2B Status                         |                                               |
| Dec                               | 2163   | 18547 | 37094  | RO     | 0                                        | Inactive                                      |
| Hex                               | 0873   | 4873  | 90E6   |        | 1                                        | Active                                        |
| Digital Output 2 Latch Enable     |        |       |        | Value  | Output 2 or 2A Enable / Disable Latching |                                               |
| Dec                               | 2165   | 18549 | 37098  | RW     | 0                                        | Disable                                       |
| Hex                               | 0875   | 4875  | 90EA   |        | 1                                        | Enable                                        |
| Digital Output 2 Clear Latch      |        |       |        | Value  | Output 2 or 2A Latch Clear               |                                               |
| Dec                               | 2166   | 18550 | 37100  | RW     | 0                                        | Do Nothing                                    |
| Hex                               | 0876   | 4876  | 90EC   |        | 1                                        | Clear Latch                                   |
| Digital Output 2 Latch State      |        |       |        | Value  | Output 2 or 2A Latch State               |                                               |
| Dec                               | 2167   | 18551 | 37102  | RO     | 0                                        | Unlatched                                     |
| Hex                               | 0877   | 4877  | 90EE   |        | 1                                        | Latched                                       |
| Digital Output 2B Latch Enable    |        |       |        | Value  | Output 2B Enable / Disable Latching      |                                               |
| Dec                               | 2168   | 18552 | 37104  | RW     | 0                                        | Disable                                       |
| Hex                               | 0878   | 4878  | 90F0   |        | 1                                        | Enable                                        |
| Digital Output 2B Clear Latch     |        |       |        | Value  | Output 2B Latch Clear                    |                                               |
| Dec                               | 2169   | 18553 | 37106  | RW     | 0                                        | Do Nothing                                    |
| Hex                               | 0879   | 4879  | 90F2   |        | 1                                        | Clear Latch                                   |
| Digital Output 2B Latch State     |        |       |        | Value  | Output 2B Latch State                    |                                               |
| Dec                               | 2170   | 18554 | 37108  | RO     | 0                                        | Unlatched                                     |
| Hex                               | 087A   | 487A  | 90F4   |        | 1                                        | Latched                                       |

| Output 2 or 2A Function     |       |       |       |    | Value | Output 2 or 2A Function                                |  |
|-----------------------------|-------|-------|-------|----|-------|--------------------------------------------------------|--|
| Dec                         | 10101 | 26485 | 52970 | RW | 0     | Disabled                                               |  |
| Hex                         | 2775  | 6775  | CEEA  |    | 1     | Loop 1 Primary Output Power                            |  |
|                             |       |       |       |    | 2     | Loop 1 Secondary Output Power                          |  |
|                             |       |       |       |    | 3     | Loop 1 VMD Open                                        |  |
|                             |       |       |       |    | 4     | Loop 1 VMD Close                                       |  |
|                             |       |       |       |    | 5     | Loop 2 Primary Output Power                            |  |
|                             |       |       |       |    | 6     | Loop 2 Secondary Output Power                          |  |
|                             |       |       |       |    | 7     | Loop 2 VMD Open                                        |  |
|                             |       |       |       |    | 8     | Loop 2 VMD Close                                       |  |
|                             |       |       |       |    | 9     | OR Alarm Event Direct                                  |  |
|                             |       |       |       |    | 10    | OR Alarm Event Reverse                                 |  |
|                             |       |       |       |    | 11    | AND Alarm Event Direct                                 |  |
|                             |       |       |       |    | 12    | AND Alarm Event Reverse                                |  |
|                             |       |       |       |    |       |                                                        |  |
| Output 2B Function          |       |       |       |    | Value | Output 2B Function                                     |  |
| Dec                         | 10102 | 26486 | 52972 | RW | 0     | Disabled                                               |  |
| Hex                         | 2776  | 6776  | CEEC  |    | 1     | Loop 1 Primary Output Power                            |  |
|                             |       |       |       |    | 2     | Loop 1 Secondary Output Power                          |  |
|                             |       |       |       |    | 3     | Loop 1 VMD Open                                        |  |
|                             |       |       |       |    | 4     | Loop 1 VMD Close                                       |  |
|                             |       |       |       |    | 5     | Loop 2 Primary Output Power                            |  |
|                             |       |       |       |    | 6     | Loop 2 Secondary Output Power                          |  |
|                             |       |       |       |    | 7     | Loop 2 VMD Open                                        |  |
|                             |       |       |       |    | 8     | Loop 2 VMD Close                                       |  |
|                             |       |       |       |    | 9     | OR Alarm Event Direct                                  |  |
|                             |       |       |       |    | 10    | OR Alarm Event Reverse                                 |  |
|                             |       |       |       |    | 11    | AND Alarm Event Direct                                 |  |
|                             |       |       |       |    | 12    | AND Alarm Event Reverse                                |  |
|                             |       |       |       |    |       |                                                        |  |
| Output 2 OR Alarm Selection |       |       |       |    | Bit   | If Bit = 1, Alarm <i>n</i> Is Included in OR Selection |  |
| Dec                         | 10111 | 26495 | 52990 | RW | 2     | Alarm 1                                                |  |
| Hex                         | 277F  | 677F  | CEFE  |    | 3     | Alarm 2                                                |  |
|                             |       |       |       |    | 4     | Alarm 3                                                |  |
|                             |       |       |       |    | 5     | Alarm 4                                                |  |
|                             |       |       |       |    | 6     | Alarm 5                                                |  |
|                             |       |       |       |    | 7     | Alarm 6                                                |  |
|                             |       |       |       |    | 8     | Alarm 7                                                |  |
|                             |       |       |       |    |       |                                                        |  |
|                             |       |       |       |    |       |                                                        |  |
| Output 2 OR Event Selection |       |       |       |    | Bit   | If Bit = 1, Event <i>n</i> Is Included in OR Selection |  |
| Dec                         | 10112 | 26496 | 52992 | RW | 2     | Event 1                                                |  |
| Hex                         | 2780  | 6780  | CF00  |    | 3     | Event 2                                                |  |
|                             |       |       |       |    | 4     | Event 3                                                |  |
|                             |       |       |       |    | 5     | Event 4                                                |  |
|                             |       |       |       |    | 6     | Event 5                                                |  |
|                             |       |       |       |    | 7     | Profile Running                                        |  |
|                             |       |       |       |    | 8     | Profile End                                            |  |
|                             |       |       |       |    |       |                                                        |  |

| Output 2 AND Alarm Selection  |       |       |       | Bit | If Bit = 1, Alarm <i>n</i> Is Included in AND Selection |
|-------------------------------|-------|-------|-------|-----|---------------------------------------------------------|
| Dec                           | 10113 | 26497 | 52994 | RW  | 2 Alarm 1                                               |
| Hex                           | 2781  | 6781  | CF02  |     | 3 Alarm 2                                               |
|                               |       |       |       |     | 4 Alarm 3                                               |
|                               |       |       |       |     | 5 Alarm 4                                               |
|                               |       |       |       |     | 6 Alarm 5                                               |
|                               |       |       |       |     | 7 Alarm 6                                               |
|                               |       |       |       |     | 8 Alarm 7                                               |
|                               |       |       |       |     |                                                         |
| Output 2 AND Event Selection  |       |       |       | Bit | If Bit = 1, Event <i>n</i> Is Included in AND Selection |
| Dec                           | 10114 | 26498 | 52996 | RW  | 2 Event 1                                               |
| Hex                           | 2782  | 6782  | CF04  |     | 3 Event 2                                               |
|                               |       |       |       |     | 4 Event 3                                               |
|                               |       |       |       |     | 5 Event 4                                               |
|                               |       |       |       |     | 6 Event 5                                               |
|                               |       |       |       |     | 7 Profile Running                                       |
|                               |       |       |       |     | 8 Profile End                                           |
|                               |       |       |       |     |                                                         |
| Output 2B OR Alarm Selection  |       |       |       | Bit | If Bit = 1, Alarm <i>n</i> Is Included in OR Selection  |
| Dec                           | 10115 | 26499 | 52998 | RW  | 2 Alarm 1                                               |
| Hex                           | 2783  | 6783  | CF06  |     | 3 Alarm 2                                               |
|                               |       |       |       |     | 4 Alarm 3                                               |
|                               |       |       |       |     | 5 Alarm 4                                               |
|                               |       |       |       |     | 6 Alarm 5                                               |
|                               |       |       |       |     | 7 Alarm 6                                               |
|                               |       |       |       |     | 8 Alarm 7                                               |
|                               |       |       |       |     |                                                         |
| Output 2B OR Event Selection  |       |       |       | Bit | If Bit = 1, Event <i>n</i> Is Included in OR Selection  |
| Dec                           | 10116 | 26500 | 53000 | RW  | 2 Event 1                                               |
| Hex                           | 2784  | 6784  | CF08  |     | 3 Event 2                                               |
|                               |       |       |       |     | 4 Event 3                                               |
|                               |       |       |       |     | 5 Event 4                                               |
|                               |       |       |       |     | 6 Event 5                                               |
|                               |       |       |       |     | 7 Profile Running                                       |
|                               |       |       |       |     | 8 Profile End                                           |
|                               |       |       |       |     |                                                         |
| Output 2B AND Alarm Selection |       |       |       | Bit | If Bit = 1, Alarm <i>n</i> Is Included in AND Selection |
| Dec                           | 10117 | 26501 | 53002 | RW  | 2 Alarm 1                                               |
| Hex                           | 2785  | 6785  | CF0A  |     | 3 Alarm 2                                               |
|                               |       |       |       |     | 4 Alarm 3                                               |
|                               |       |       |       |     | 5 Alarm 4                                               |
|                               |       |       |       |     | 6 Alarm 5                                               |
|                               |       |       |       |     | 7 Alarm 6                                               |
|                               |       |       |       |     | 8 Alarm 7                                               |
|                               |       |       |       |     |                                                         |
| Output 2B AND Event Selection |       |       |       | Bit | If Bit = 1, Event <i>n</i> Is Included in AND Selection |
| Dec                           | 10118 | 26502 | 53004 | RW  | 2 Event 1                                               |
| Hex                           | 2786  | 6786  | CF0C  |     | 3 Event 2                                               |
|                               |       |       |       |     | 4 Event 3                                               |
|                               |       |       |       |     | 5 Event 4                                               |
|                               |       |       |       |     | 6 Event 5                                               |
|                               |       |       |       |     | 7 Profile Running                                       |
|                               |       |       |       |     | 8 Profile End                                           |
|                               |       |       |       |     |                                                         |

## 20.4.8 Plug-in Module Slot 3 Parameters

| Parameter Name & Register Address |         |        |       |        |        |                                               |
|-----------------------------------|---------|--------|-------|--------|--------|-----------------------------------------------|
|                                   | Integer | Int +1 | Float | Access | Values | & Descriptions                                |
| Plug-in Module 3 Type             |         |        |       |        | Value  | Module Fitted In Slot 3                       |
| Dec                               | 2192    | 18576  | 37152 | RO     | 0      | None Fitted                                   |
| Hex                               | 0890    | 4890   | 9120  |        | 1      | Single Relay                                  |
|                                   |         |        |       |        | 2      | Single SSR Driver                             |
|                                   |         |        |       |        | 3      | Error ( <i>invalid module for this slot</i> ) |
|                                   |         |        |       |        | 8      | Triac                                         |
|                                   |         |        |       |        | 9      | Dual Relay                                    |
|                                   |         |        |       |        | 10     | Dual SSR Driver                               |
|                                   |         |        |       |        | 11     | 24VDC Transmitter PSU                         |
|                                   |         |        |       |        | 255    | Error ( <i>unrecognised module</i> )          |
| Output 3 or 3A Status             |         |        |       |        | Value  | Output 3 or 3A Status                         |
| Dec                               | 2194    | 18578  | 37156 | RO     | 0      | Inactive                                      |
| Hex                               | 0892    | 4892   | 9124  |        | 1      | Active                                        |
| Output 3B Status                  |         |        |       |        | Value  | Output 3B Status                              |
| Dec                               | 2195    | 18579  | 37158 | RO     | 0      | Inactive                                      |
| Hex                               | 0893    | 4893   | 9126  |        | 1      | Active                                        |
| Digital Output 3 Latch Enable     |         |        |       |        | Value  | Output 3 or 3A Enable / Disable Latching      |
| Dec                               | 2197    | 18581  | 37162 | RW     | 0      | Disabled                                      |
| Hex                               | 0895    | 4895   | 912A  |        | 1      | Enabled                                       |
| Digital Output 3 Clear Latch      |         |        |       |        | Value  | Output 3 or 3A Latch Clear                    |
| Dec                               | 2198    | 18582  | 37164 | RW     | 0      | Do Nothing                                    |
| Hex                               | 0896    | 4896   | 912C  |        | 1      | Clear Latch                                   |
| Digital Output 3 Latch State      |         |        |       |        | Value  | Output 3 or 3A Latch State                    |
| Dec                               | 2199    | 18583  | 37166 | RO     | 0      | Unlatched                                     |
| Hex                               | 0897    | 4897   | 912E  |        | 1      | Latched                                       |
| Digital Output 3B Latch Enable    |         |        |       |        | Value  | Output 3B Enable / Disable Latching           |
| Dec                               | 2200    | 18584  | 37168 | RW     | 0      | Disabled                                      |
| Hex                               | 0898    | 4898   | 9130  |        | 1      | Enabled                                       |
| Digital Output 3B Clear Latch     |         |        |       |        | Value  | Output 3B Latch Clear                         |
| Dec                               | 2201    | 18585  | 37170 | RW     | 0      | Do Nothing                                    |
| Hex                               | 0899    | 4899   | 9132  |        | 1      | Clear Latch                                   |
| Digital Output 3B Latch State     |         |        |       |        | Value  | Output 3B Latch State                         |
| Dec                               | 2202    | 18586  | 37172 | RO     | 0      | Unlatched                                     |
| Hex                               | 089A    | 489A   | 9134  |        | 1      | Latched                                       |
| Output 3 Function                 |         |        |       |        | Value  | Output 3 or 3A Function                       |
| Dec                               | 10103   | 26487  | 52974 | RW     | 0      | Disabled                                      |
| Hex                               | 2777    | 6777   | CEEE  |        | 1      | Loop 1 Primary Output Power                   |
|                                   |         |        |       |        | 2      | Loop 1 Secondary Output Power                 |
|                                   |         |        |       |        | 3      | Loop 1 VMD Open                               |
|                                   |         |        |       |        | 4      | Loop 1 VMD Close                              |
|                                   |         |        |       |        | 5      | Loop 2 Primary Output Power                   |
|                                   |         |        |       |        | 6      | Loop 2 Secondary Output Power                 |
|                                   |         |        |       |        | 7      | Loop 2 VMD Open                               |
|                                   |         |        |       |        | 8      | Loop 2 VMD Close                              |
|                                   |         |        |       |        | 9      | OR Alarm Event Direct                         |

|                              |       |       |       |    |       |                                                         |
|------------------------------|-------|-------|-------|----|-------|---------------------------------------------------------|
|                              |       |       |       |    | 10    | OR Alarm Event Reverse                                  |
|                              |       |       |       |    | 11    | AND Alarm Event Direct                                  |
|                              |       |       |       |    | 12    | AND Alarm Event Reverse                                 |
| Output 3B Function           |       |       |       |    | Value | Output 3B Function                                      |
| Dec                          | 10104 | 26488 | 52976 | RW | 0     | Disabled                                                |
| Hex                          | 2778  | 6778  | CEF0  |    | 1     | Loop 1 Primary Output Power                             |
|                              |       |       |       |    | 2     | Loop 1 Secondary Output Power                           |
|                              |       |       |       |    | 3     | Loop 1 VMD Open                                         |
|                              |       |       |       |    | 4     | Loop 1 VMD Close                                        |
|                              |       |       |       |    | 5     | Loop 2 Primary Output Power                             |
|                              |       |       |       |    | 6     | Loop 2 Secondary Output Power                           |
|                              |       |       |       |    | 7     | Loop 2 VMD Open                                         |
|                              |       |       |       |    | 8     | Loop 2 VMD Close                                        |
|                              |       |       |       |    | 9     | OR Alarm Event Direct                                   |
|                              |       |       |       |    | 10    | OR Alarm Event Reverse                                  |
|                              |       |       |       |    | 11    | AND Alarm Event Direct                                  |
|                              |       |       |       |    | 12    | AND Alarm Event Reverse                                 |
| Output 3 OR Alarm Selection  |       |       |       |    | Bit   | If Bit = 1, Alarm <i>n</i> Is Included in OR Selection  |
| Dec                          | 10119 | 26503 | 53006 | RW | 2     | Alarm 1                                                 |
| Hex                          | 2787  | 6787  | CF0E  |    | 3     | Alarm 2                                                 |
|                              |       |       |       |    | 4     | Alarm 3                                                 |
|                              |       |       |       |    | 5     | Alarm 4                                                 |
|                              |       |       |       |    | 6     | Alarm 5                                                 |
|                              |       |       |       |    | 7     | Alarm 6                                                 |
|                              |       |       |       |    | 8     | Alarm 7                                                 |
| Output 3 OR Event Selection  |       |       |       |    | Bit   | If Bit = 1, Event <i>n</i> Is Included in OR Selection  |
| Dec                          | 10120 | 26504 | 53008 | RW | 2     | Event 1                                                 |
| Hex                          | 2788  | 6788  | CF10  |    | 3     | Event 2                                                 |
|                              |       |       |       |    | 4     | Event 3                                                 |
|                              |       |       |       |    | 5     | Event 4                                                 |
|                              |       |       |       |    | 6     | Event 5                                                 |
|                              |       |       |       |    | 7     | Profile Running                                         |
|                              |       |       |       |    | 8     | Profile End                                             |
| Output 3 AND Alarm Selection |       |       |       |    | Bit   | If Bit = 1, Alarm <i>n</i> Is Included in AND Selection |
| Dec                          | 10121 | 26505 | 53010 | RW | 2     | Alarm 1                                                 |
| Hex                          | 2789  | 6789  | CF12  |    | 3     | Alarm 2                                                 |
|                              |       |       |       |    | 4     | Alarm 3                                                 |
|                              |       |       |       |    | 5     | Alarm 4                                                 |
|                              |       |       |       |    | 6     | Alarm 5                                                 |
|                              |       |       |       |    | 7     | Alarm 6                                                 |
|                              |       |       |       |    | 8     | Alarm 7                                                 |
| Output 3 AND Event Selection |       |       |       |    | Bit   | If Bit = 1, Event <i>n</i> Is Included in AND Selection |
| Dec                          | 10122 | 26506 | 53012 | RW | 2     | Event 1                                                 |
| Hex                          | 278A  | 678A  | CF14  |    | 3     | Event 2                                                 |
|                              |       |       |       |    | 4     | Event 3                                                 |
|                              |       |       |       |    | 5     | Event 4                                                 |
|                              |       |       |       |    | 6     | Event 5                                                 |
|                              |       |       |       |    | 7     | Profile Running                                         |
|                              |       |       |       |    | 8     | Profile End                                             |

| Output 3B OR Alarm Selection  |       |       |       | Bit | If Bit = 1, Alarm <i>n</i> Is Included in OR Selection  |                 |
|-------------------------------|-------|-------|-------|-----|---------------------------------------------------------|-----------------|
| Dec                           | 10123 | 26507 | 53014 | RW  | 2                                                       | Alarm 1         |
| Hex                           | 278B  | 678B  | CF16  |     | 3                                                       | Alarm 2         |
|                               |       |       |       |     | 4                                                       | Alarm 3         |
|                               |       |       |       |     | 5                                                       | Alarm 4         |
|                               |       |       |       |     | 6                                                       | Alarm 5         |
|                               |       |       |       |     | 7                                                       | Alarm 6         |
|                               |       |       |       |     | 8                                                       | Alarm 7         |
|                               |       |       |       |     |                                                         |                 |
| Output 3B OR Event Selection  |       |       |       | Bit | If Bit = 1, Event <i>n</i> Is Included in OR Selection  |                 |
| Dec                           | 10124 | 26508 | 53016 | RW  | 2                                                       | Event 1         |
| Hex                           | 278C  | 678C  | CF18  |     | 3                                                       | Event 2         |
|                               |       |       |       |     | 4                                                       | Event 3         |
|                               |       |       |       |     | 5                                                       | Event 4         |
|                               |       |       |       |     | 6                                                       | Event 5         |
|                               |       |       |       |     | 7                                                       | Profile Running |
|                               |       |       |       |     | 8                                                       | Profile End     |
|                               |       |       |       |     |                                                         |                 |
| Output 3B AND Alarm Selection |       |       |       | Bit | If Bit = 1, Alarm <i>n</i> Is Included in AND Selection |                 |
| Dec                           | 10125 | 26509 | 53018 | RW  | 2                                                       | Alarm 1         |
| Hex                           | 278D  | 678D  | CF1A  |     | 3                                                       | Alarm 2         |
|                               |       |       |       |     | 4                                                       | Alarm 3         |
|                               |       |       |       |     | 5                                                       | Alarm 4         |
|                               |       |       |       |     | 6                                                       | Alarm 5         |
|                               |       |       |       |     | 7                                                       | Alarm 6         |
|                               |       |       |       |     | 8                                                       | Alarm 7         |
|                               |       |       |       |     |                                                         |                 |
| Output 3B AND Event Selection |       |       |       | Bit | If Bit = 1, Event <i>n</i> Is Included in AND Selection |                 |
| Dec                           | 10126 | 26510 | 53020 | RW  | 2                                                       | Event 1         |
| Hex                           | 278E  | 678E  | CF1C  |     | 3                                                       | Event 2         |
|                               |       |       |       |     | 4                                                       | Event 3         |
|                               |       |       |       |     | 5                                                       | Event 4         |
|                               |       |       |       |     | 6                                                       | Event 5         |
|                               |       |       |       |     | 7                                                       | Profile Running |
|                               |       |       |       |     | 8                                                       | Profile End     |
|                               |       |       |       |     |                                                         |                 |

### 20.4.9 Output 4 Parameters

| Parameter Name & Register Address |         |        |       |        |        |                               |
|-----------------------------------|---------|--------|-------|--------|--------|-------------------------------|
|                                   | Integer | Int +1 | Float | Access | Values | & Descriptions                |
| Linear Output 4 Fitted            |         |        |       |        | Value  | Linear Output 4 Fitted        |
| Dec                               | 3000    | 19384  | 38768 | RO     | 0      | Not fitted                    |
| Hex                               | 0BB8    | 4BB8   | 9770  |        | 1      | Fitted                        |
| Output 4 Usage                    |         |        |       |        | Value  | Output 4 Function             |
| Dec                               | 10105   | 26489  | 52978 | RW     | 0      | Disabled                      |
| Hex                               | 2779    | 6779   | CEF2  |        | 1      | Loop 1 Primary Output Power   |
|                                   |         |        |       |        | 2      | Loop 1 Secondary Output Power |
|                                   |         |        |       |        | 3      | Loop 1 VMD Open               |
|                                   |         |        |       |        | 4      | Loop 1 VMD Close              |
|                                   |         |        |       |        | 5      | Loop 2 Primary Output Power   |
|                                   |         |        |       |        | 6      | Loop 2 Secondary Output Power |
|                                   |         |        |       |        | 7      | Loop 2 VMD Open               |

|                                      |       |       |       |              |                                                                |                         |
|--------------------------------------|-------|-------|-------|--------------|----------------------------------------------------------------|-------------------------|
|                                      |       |       |       |              | 8                                                              | Loop 2 VMD Close        |
|                                      |       |       |       |              | 9                                                              | OR Alarm Event Direct   |
|                                      |       |       |       |              | 10                                                             | OR Alarm Event Reverse  |
|                                      |       |       |       |              | 11                                                             | AND Alarm Event Direct  |
|                                      |       |       |       |              | 12                                                             | AND Alarm Event Reverse |
| <b>Output 4 Status</b>               |       |       |       | <b>Value</b> | <b>Output 4 Status</b>                                         |                         |
| Dec                                  | 3001  | 19385 | 38770 | RO           | 0                                                              | Inactive                |
| Hex                                  | 0BB9  | 4BB9  | 9772  |              | 1                                                              | Active                  |
| <b>Digital Output 4 Latch Enable</b> |       |       |       | <b>Value</b> | <b>Output 4 Latch Enable / Disable</b>                         |                         |
| Dec                                  | 3002  | 19386 | 38772 | RW           | 0                                                              | Disable                 |
| Hex                                  | 0BBA  | 4BBA  | 9774  |              | 1                                                              | Enable                  |
| <b>Digital Output 4 Clear Latch</b>  |       |       |       | <b>Value</b> | <b>Output 4 Latch Clear</b>                                    |                         |
| Dec                                  | 3004  | 19388 | 38776 | RW           | 0                                                              | Do Nothing              |
| Hex                                  | 0BBC  | 4BBC  | 9778  |              | 1                                                              | Clear Latch             |
| <b>Digital Output 4 Latch State</b>  |       |       |       | <b>Value</b> | <b>Output 4 Latch State</b>                                    |                         |
| Dec                                  | 3003  | 19387 | 38774 | RO           | 0                                                              | Unlatched               |
| Hex                                  | 0BBB  | 4BBB  | 9776  |              | 1                                                              | Latched                 |
| <b>Output 4 OR Alarm Selection</b>   |       |       |       | <b>Bit</b>   | <b>If Bit = 1, Alarm <i>n</i> Is Included in OR Selection</b>  |                         |
| Dec                                  | 10127 | 26511 | 53022 | RW           | 2                                                              | Alarm 1                 |
| Hex                                  | 278F  | 678F  | CF1E  |              | 3                                                              | Alarm 2                 |
|                                      |       |       |       |              | 4                                                              | Alarm 3                 |
|                                      |       |       |       |              | 5                                                              | Alarm 4                 |
|                                      |       |       |       |              | 6                                                              | Alarm 5                 |
|                                      |       |       |       |              | 7                                                              | Alarm 6                 |
|                                      |       |       |       |              | 8                                                              | Alarm 7                 |
|                                      |       |       |       |              |                                                                |                         |
| <b>Output 4 OR Event Selection</b>   |       |       |       | <b>Bit</b>   | <b>If Bit = 1, Event <i>n</i> Is Included in OR Selection</b>  |                         |
| Dec                                  | 10128 | 26512 | 53024 | RW           | 2                                                              | Event 1                 |
| Hex                                  | 2790  | 6790  | CF20  |              | 3                                                              | Event 2                 |
|                                      |       |       |       |              | 4                                                              | Event 3                 |
|                                      |       |       |       |              | 5                                                              | Event 4                 |
|                                      |       |       |       |              | 6                                                              | Event 5                 |
|                                      |       |       |       |              | 7                                                              | Profile Running         |
|                                      |       |       |       |              | 8                                                              | Profile End             |
|                                      |       |       |       |              |                                                                |                         |
| <b>Output 4 AND Alarm Selection</b>  |       |       |       | <b>Bit</b>   | <b>If Bit = 1, Alarm <i>n</i> Is Included in AND Selection</b> |                         |
| Dec                                  | 10129 | 26513 | 53026 | RW           | 2                                                              | Alarm 1                 |
| Hex                                  | 2791  | 6791  | CF22  |              | 3                                                              | Alarm 2                 |
|                                      |       |       |       |              | 4                                                              | Alarm 3                 |
|                                      |       |       |       |              | 5                                                              | Alarm 4                 |
|                                      |       |       |       |              | 6                                                              | Alarm 5                 |
|                                      |       |       |       |              | 7                                                              | Alarm 6                 |
|                                      |       |       |       |              | 8                                                              | Alarm 7                 |
|                                      |       |       |       |              |                                                                |                         |
| <b>Output 4 AND Event Selection</b>  |       |       |       | <b>Bit</b>   | <b>If Bit = 1, Event <i>n</i> Is Included in AND Selection</b> |                         |
| Dec                                  | 10130 | 26514 | 53028 | RW           | 2                                                              | Event 1                 |
| Hex                                  | 2792  | 6792  | CF24  |              | 3                                                              | Event 2                 |
|                                      |       |       |       |              | 4                                                              | Event 3                 |
|                                      |       |       |       |              | 5                                                              | Event 4                 |
|                                      |       |       |       |              | 6                                                              | Event 5                 |
|                                      |       |       |       |              | 7                                                              | Profile Running         |
|                                      |       |       |       |              | 8                                                              | Profile End             |
|                                      |       |       |       |              |                                                                |                         |

## 20.4.10 Output 5 Parameters

| Parameter Name & Register Address |         |        |       |        |        |                                                        |
|-----------------------------------|---------|--------|-------|--------|--------|--------------------------------------------------------|
|                                   | Integer | Int +1 | Float | Access | Values | & Descriptions                                         |
| Linear Output 5 Fitted            |         |        |       |        | Value  | Linear Output 5 Fitted                                 |
| Dec                               | 3005    | 19389  | 38778 | RO     | 0      | Not fitted                                             |
| Hex                               | 0BBD    | 4BBD   | 977A  |        | 1      | Fitted                                                 |
| Output 5 Usage                    |         |        |       |        | Value  | Output 5 Function                                      |
| Dec                               | 10106   | 26490  | 52980 | RW     | 0      | Disabled                                               |
| Hex                               | 277A    | 677A   | CEF4  |        | 1      | Loop 1 Primary Output Power                            |
|                                   |         |        |       |        | 2      | Loop 1 Secondary Output Power                          |
|                                   |         |        |       |        | 3      | Loop 1 VMD Open                                        |
|                                   |         |        |       |        | 4      | Loop 1 VMD Close                                       |
|                                   |         |        |       |        | 5      | Loop 2 Primary Output Power                            |
|                                   |         |        |       |        | 6      | Loop 2 Secondary Output Power                          |
|                                   |         |        |       |        | 7      | Loop 2 VMD Open                                        |
|                                   |         |        |       |        | 8      | Loop 2 VMD Close                                       |
|                                   |         |        |       |        | 9      | OR Alarm Event Direct                                  |
|                                   |         |        |       |        | 10     | OR Alarm Event Reverse                                 |
|                                   |         |        |       |        | 11     | AND Alarm Event Direct                                 |
|                                   |         |        |       |        | 12     | AND Alarm Event Reverse                                |
| Output 5 Status                   |         |        |       |        |        | Value                                                  |
| Dec                               | 3006    | 19390  | 38780 | RO     | 0      | Inactive                                               |
| Hex                               | 0BBE    | 4BBE   | 977C  |        | 1      | Active                                                 |
| Digital Output 5 Latch Enable     |         |        |       |        | Value  | Latch Enable                                           |
| Dec                               | 3007    | 19391  | 38782 | RW     | 0      | Disable                                                |
| Hex                               | 0BBF    | 4BBF   | 977E  |        | 1      | Enable                                                 |
| Digital Output 5 Clear Latch      |         |        |       |        | Value  | Latch Clear                                            |
| Dec                               | 3009    | 19393  | 38786 | RW     | 0      | Do Nothing                                             |
| Hex                               | 0BC1    | 4BC1   | 9782  |        | 1      | Clear Latch                                            |
| Digital Output 5 Latch State      |         |        |       |        | Value  | Latch State                                            |
| Dec                               | 3008    | 19392  | 38784 | RO     | 0      | Unlatched                                              |
| Hex                               | 0BC0    | 4BC0   | 9780  |        | 1      | Latched                                                |
| Output 5 OR Alarm Selection       |         |        |       |        | Bit    | If Bit = 1, Alarm <i>n</i> Is Included in OR Selection |
| Dec                               | 10131   | 26515  | 53030 | RW     | 2      | Alarm 1                                                |
| Hex                               | 2793    | 6793   | CF26  |        | 3      | Alarm 2                                                |
|                                   |         |        |       |        | 4      | Alarm 3                                                |
|                                   |         |        |       |        | 5      | Alarm 4                                                |
|                                   |         |        |       |        | 6      | Alarm 5                                                |
|                                   |         |        |       |        | 7      | Alarm 6                                                |
|                                   |         |        |       |        | 8      | Alarm 7                                                |
|                                   |         |        |       |        |        |                                                        |
| Output 5 OR Event Selection       |         |        |       |        | Bit    | If Bit = 1, Event <i>n</i> Is Included in OR Selection |
| Dec                               | 10132   | 26516  | 53032 | RW     | 2      | Event 1                                                |
| Hex                               | 2794    | 6794   | CF28  |        | 3      | Event 2                                                |
|                                   |         |        |       |        | 4      | Event 3                                                |
|                                   |         |        |       |        | 5      | Event 4                                                |
|                                   |         |        |       |        | 6      | Event 5                                                |
|                                   |         |        |       |        | 7      | Profile Running                                        |
|                                   |         |        |       |        | 8      | Profile End                                            |
|                                   |         |        |       |        |        |                                                        |

| Output 5 AND Alarm Selection |       |       |       | Bit | If Bit = 1, Alarm <i>n</i> Is Included in AND Selection |
|------------------------------|-------|-------|-------|-----|---------------------------------------------------------|
| Dec                          | 10133 | 26517 | 53034 | RW  | 2 Alarm 1                                               |
| Hex                          | 2795  | 6795  | CF2A  |     | 3 Alarm 2                                               |
|                              |       |       |       |     | 4 Alarm 3                                               |
|                              |       |       |       |     | 5 Alarm 4                                               |
|                              |       |       |       |     | 6 Alarm 5                                               |
|                              |       |       |       |     | 7 Alarm 6                                               |
|                              |       |       |       |     | 8 Alarm 7                                               |
| Output 5 AND Event Selection |       |       |       | Bit | If Bit = 1, Event <i>n</i> Is Included in AND Selection |
| Dec                          | 10134 | 26518 | 53036 | RW  | 2 Event 1                                               |
| Hex                          | 2796  | 6796  | CF2C  |     | 3 Event 2                                               |
|                              |       |       |       |     | 4 Event 3                                               |
|                              |       |       |       |     | 5 Event 4                                               |
|                              |       |       |       |     | 6 Event 5                                               |
|                              |       |       |       |     | 7 Profile Running                                       |
|                              |       |       |       |     | 8 Profile End                                           |

#### 20.4.11 Linear Output 6 Parameters

| Parameter Name & Register Address   |         |        |       |        |                                                                                                                                               |                                           |
|-------------------------------------|---------|--------|-------|--------|-----------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------|
|                                     | Integer | Int +1 | Float | Access | Values                                                                                                                                        | & Descriptions                            |
| Linear Output 6 Fitted              |         |        |       |        | Value                                                                                                                                         | Linear Output 6 Fitted                    |
| Dec                                 | 3016    | 19400  | 38800 | RO     | 0                                                                                                                                             | Not fitted                                |
| Hex                                 | 0BC8    | 4BC8   | 9790  |        | 1                                                                                                                                             | Fitted                                    |
| Linear Output 6 Usage               |         |        |       |        | Value                                                                                                                                         | Output 6 Function                         |
| Dec                                 | 2174    | 18558  | 37116 | RW     | 0                                                                                                                                             | Disabled                                  |
| Hex                                 | 087E    | 487E   | 90FC  |        | 1                                                                                                                                             | Loop 1 Primary Output Power               |
|                                     |         |        |       |        | 2                                                                                                                                             | Loop 1 Secondary Output Power             |
|                                     |         |        |       |        | 3                                                                                                                                             | Retransmit Loop 1 Actual Setpoint Value   |
|                                     |         |        |       |        | 4                                                                                                                                             | Retransmit Input 1 Process Variable Value |
|                                     |         |        |       |        | 5                                                                                                                                             | Loop 2 Primary Output Power               |
|                                     |         |        |       |        | 6                                                                                                                                             | Loop 2 Secondary Output Power             |
|                                     |         |        |       |        | 7                                                                                                                                             | Retransmit Loop 2 Actual Setpoint Value   |
|                                     |         |        |       | 8      | Retransmit Input 2 Process Variable Value                                                                                                     |                                           |
| Linear mA/V DC Output 6 Type        |         |        |       |        | Value                                                                                                                                         | Linear Output 6 Type                      |
| Dec                                 | 3011    | 19395  | 38790 | RW     | 0                                                                                                                                             | 0 to 5V DC                                |
| Hex                                 | 0BC3    | 4BC3   | 9786  |        | 1                                                                                                                                             | 0 to 10V DC                               |
|                                     |         |        |       |        | 2                                                                                                                                             | 2 to 10V DC                               |
|                                     |         |        |       |        | 3                                                                                                                                             | 0 to 20mA DC                              |
|                                     |         |        |       |        | 4                                                                                                                                             | 4 to 20mA DC                              |
|                                     |         |        |       |        | 5                                                                                                                                             | Variable 0 to 10VDC Transmitter PSU       |
| Linear Output 6 Level Status        |         |        |       |        | Linear Output % Value                                                                                                                         |                                           |
| Dec                                 | 3014    | 19398  | 38796 | RO     | -2.0% to 102.0% of output nominal range<br>(control output will over/under drive by 2%).                                                      |                                           |
| Hex                                 | 0BC6    | 4BC6   | 978C  |        |                                                                                                                                               |                                           |
| Output 6 Retransmit Input 1 Minimum |         |        |       |        | Value For Loop 1 Retransmit Minimum                                                                                                           |                                           |
| Dec                                 | 2182    | 18566  | 37132 | RW     | Displayed value at which the retransmission output reaches its minimum level (e.g. 4mA if type is 4-20mA).<br>Adjustable from -9999 to 9999.9 |                                           |
| Hex                                 | 0886    | 4886   | 910C  |        |                                                                                                                                               |                                           |

| Output 6 Retransmit Input 1 Maximum |      |       |       |    | Value For Loop 1 Retransmit Maximum                                                                                                           |  |
|-------------------------------------|------|-------|-------|----|-----------------------------------------------------------------------------------------------------------------------------------------------|--|
| Dec                                 | 2183 | 18567 | 37134 | RW | Displayed value at which the retransmission output reaches its maximum level (e.g. 2mA if type is 4-20mA).<br>Adjustable from -9999 to 9999.9 |  |
| Hex                                 | 0887 | 4887  | 910E  |    |                                                                                                                                               |  |
| Output 6 Retransmit Input 2 Minimum |      |       |       |    | Value For Loop 2 Retransmit Minimum                                                                                                           |  |
| Dec                                 | 2430 | 18814 | 37628 | RW | Displayed value at which the retransmission output reaches its minimum level (e.g. 4mA if type is 4-20mA).<br>Adjustable from -9999 to 9999.9 |  |
| Hex                                 | 097E | 497E  | 92FC  |    |                                                                                                                                               |  |
| Output 6 Retransmit Input 2 Maximum |      |       |       |    | Value For Loop 2 Retransmit Maximum                                                                                                           |  |
| Dec                                 | 2431 | 18815 | 37630 | RW | Displayed value at which the retransmission output reaches its maximum level (e.g. 2mA if type is 4-20mA).<br>Adjustable from -9999 to 9999.9 |  |
| Hex                                 | 097F | 497F  | 92FE  |    |                                                                                                                                               |  |

## 20.4.12 Linear Output 7 Parameters

| Parameter Name & Register Address   |         |        |       |        |                                                                                                                                               |                                           |
|-------------------------------------|---------|--------|-------|--------|-----------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------|
|                                     | Integer | Int +1 | Float | Access | Values                                                                                                                                        | & Descriptions                            |
| Linear Output 7 Fitted              |         |        |       |        | Value                                                                                                                                         | Linear Output 7 Fitted                    |
| Dec                                 | 3026    | 19410  | 38820 | RO     | 0                                                                                                                                             | Not fitted                                |
| Hex                                 | 0BD2    | 4BD2   | 97A4  |        | 1                                                                                                                                             | Fitted                                    |
| Linear Output 7 Usage               |         |        |       |        | Value                                                                                                                                         | Output 6 Function                         |
| Dec                                 | 2203    | 18587  | 37174 | RW     | 0                                                                                                                                             | Disabled                                  |
| Hex                                 | 089B    | 489B   | 9136  |        | 1                                                                                                                                             | Loop 1 Primary Output Power               |
|                                     |         |        |       |        | 2                                                                                                                                             | Loop 1 Secondary Output Power             |
|                                     |         |        |       |        | 3                                                                                                                                             | Retransmit Loop 1 Actual Setpoint Value   |
|                                     |         |        |       |        | 4                                                                                                                                             | Retransmit Input 1 Process Variable Value |
|                                     |         |        |       |        | 5                                                                                                                                             | Loop 2 Primary Output Power               |
|                                     |         |        |       |        | 6                                                                                                                                             | Loop 2 Secondary Output Power             |
|                                     |         |        |       |        | 7                                                                                                                                             | Retransmit Loop 2 Actual Setpoint Value   |
|                                     |         |        |       |        | 8                                                                                                                                             | Retransmit Input 2 Process Variable Value |
| Linear mA/V DC Output 7 Type        |         |        |       |        | Value                                                                                                                                         | Linear Output 6 Type                      |
| Dec                                 | 3021    | 19405  | 38810 | RW     | 0                                                                                                                                             | 0 to 5V DC                                |
| Hex                                 | 0BCD    | 4BCD   | 979A  |        | 1                                                                                                                                             | 0 to 10V DC                               |
|                                     |         |        |       |        | 2                                                                                                                                             | 2 to 10V DC                               |
|                                     |         |        |       |        | 3                                                                                                                                             | 0 to 20mA DC                              |
|                                     |         |        |       |        | 4                                                                                                                                             | 4 to 20mA DC                              |
|                                     |         |        |       |        | 5                                                                                                                                             | Variable 0 to 10VDC Transmitter PSU       |
| Linear Output 7 Level Status        |         |        |       |        | Linear Output % Value                                                                                                                         |                                           |
| Dec                                 | 3024    | 19408  | 38816 | RO     | -2.0% to 102.0% of output nominal range<br>(control output will over/under drive by 2%).                                                      |                                           |
| Hex                                 | 0BD0    | 4BD0   | 97A0  |        |                                                                                                                                               |                                           |
| Output 7 Retransmit Input 1 Minimum |         |        |       |        | Value For Loop 1 Retransmit Minimum                                                                                                           |                                           |
| Dec                                 | 2211    | 18595  | 37190 | RW     | Displayed value at which the retransmission output reaches its minimum level (e.g. 4mA if type is 4-20mA).<br>Adjustable from -9999 to 9999.9 |                                           |
| Hex                                 | 08A3    | 48A3   | 9146  |        |                                                                                                                                               |                                           |
| Output 7 Retransmit Input 1 Maximum |         |        |       |        | Value For Loop 1 Retransmit Maximum                                                                                                           |                                           |
| Dec                                 | 2212    | 18596  | 37192 | RW     | Displayed value at which the retransmission output reaches its maximum level (e.g. 2mA if type is 4-20mA).<br>Adjustable from -9999 to 9999.9 |                                           |
| Hex                                 | 08A4    | 48A4   | 9148  |        |                                                                                                                                               |                                           |
| Output 7 Retransmit Input 2 Minimum |         |        |       |        | Value For Loop 2 Retransmit Minimum                                                                                                           |                                           |
| Dec                                 | 2460    | 18844  | 37688 | RW     | Displayed value at which the retransmission output reaches its minimum level (e.g. 4mA if type is 4-20mA).<br>Adjustable from -9999 to 9999.9 |                                           |
| Hex                                 | 099C    | 499C   | 9338  |        |                                                                                                                                               |                                           |

| Output 7 Retransmit Input 2 Maximum |      |       |       | Value For Loop 2 Retransmit Maximum |                                                                                                                                               |
|-------------------------------------|------|-------|-------|-------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------|
| Dec                                 | 2461 | 18845 | 37690 | RW                                  | Displayed value at which the retransmission output reaches its maximum level (e.g. 2mA if type is 4-20mA).<br>Adjustable from -9999 to 9999.9 |
| Hex                                 | 099D | 499D  | 933A  |                                     |                                                                                                                                               |

### 20.4.13 Loop 1 Setpoint Parameters

| Parameter Name & Register Address      |         |        |       |        |                                                                                                                                                |                                              |
|----------------------------------------|---------|--------|-------|--------|------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------|
|                                        | Integer | Int +1 | Float | Access | Values                                                                                                                                         | & Descriptions                               |
| Loop 1 Setpoint Minimum                |         |        |       |        | Minimum Allowed Setpoint For Loop 1                                                                                                            |                                              |
| Dec                                    | 3944    | 20328  | 40656 | RW     | Valid between the scaled input lower & upper limits                                                                                            |                                              |
| Hex                                    | 0F68    | 4F68   | 9ED0  |        |                                                                                                                                                |                                              |
| Loop 1 Setpoint Maximum                |         |        |       |        | Maximum Allowed Setpoint For Loop 1                                                                                                            |                                              |
| Dec                                    | 3945    | 20329  | 40658 | RW     | Valid between the scaled input lower & upper limits                                                                                            |                                              |
| Hex                                    | 0F69    | 4F69   | 9ED2  |        |                                                                                                                                                |                                              |
| Loop 1 Main Local Setpoint Value       |         |        |       |        | Main Setpoint Value For Loop 1                                                                                                                 |                                              |
| Dec                                    | 3960    | 20344  | 40688 | RW     | Valid between Setpoint Maximum and Minimum                                                                                                     |                                              |
| Hex                                    | 0F78    | 4F78   | 9EF0  |        |                                                                                                                                                |                                              |
| Loop 1 Main Local Setpoint Offset      |         |        |       |        | Offset Of Main Setpoint Of Loop 1                                                                                                              |                                              |
| Dec                                    | 3961    | 20345  | 40690 | RW     | Changes effective setpoint (for multi-zone slaves. +ve values added -ve values subtracted.<br>Setpoint always limited by Setpoint Max and Min. |                                              |
| Hex                                    | 0F79    | 4F79   | 9EF2  |        |                                                                                                                                                |                                              |
| Loop 1 Alternate Local Setpoint Value  |         |        |       |        | Alternate Setpoint Value For Loop 1                                                                                                            |                                              |
| Dec                                    | 3962    | 20346  | 40692 | RW     | Valid between Setpoint Maximum and Minimum                                                                                                     |                                              |
| Hex                                    | 0F7A    | 4F7A   | 9EF4  |        |                                                                                                                                                |                                              |
| Loop 1 Alternate Local Setpoint Offset |         |        |       |        | Offset Of Alternate setpoint Of Loop 1                                                                                                         |                                              |
| Dec                                    | 3963    | 20347  | 40694 | RW     | Changes effective setpoint (for multi-zone slaves. +ve values added -ve values subtracted.<br>Setpoint always limited by Setpoint Max and Min. |                                              |
| Hex                                    | 0F7B    | 4F7B   | 9EF6  |        |                                                                                                                                                |                                              |
| Loop 1 Main Setpoint Source            |         |        |       |        | Value                                                                                                                                          | Main Setpoint Source For Loop 1              |
| Dec                                    | 4050    | 20434  | 40868 | RW     | 0                                                                                                                                              | Local Setpoint 1                             |
| Hex                                    | 0FD2    | 4FD2   | 9FA4  |        | 1                                                                                                                                              | Not Used                                     |
| Loop 1 Alternate Setpoint Source       |         |        |       |        | Value                                                                                                                                          | Alternate Setpoint Source For Loop 1         |
| Dec                                    | 4051    | 20435  | 40870 | RW     | 0                                                                                                                                              | Not Used                                     |
| Hex                                    | 0FD3    | 4FD3   | 9FA6  |        | 1                                                                                                                                              | Local Setpoint 2                             |
|                                        |         |        |       |        | 2                                                                                                                                              | Input 2 Remote Setpoint                      |
|                                        |         |        |       |        | 3                                                                                                                                              | Input A Remote Setpoint                      |
| Loop 1 Setpoint Select                 |         |        |       |        | Value                                                                                                                                          | Setpoint Select For Loop 1                   |
| Dec                                    | 4122    | 20506  | 41012 | RW     | 0                                                                                                                                              | Main Setpoint                                |
| Hex                                    | 101A    | 501A   | A034  |        | 1                                                                                                                                              | Alternate setpoint                           |
| Loop 1 Setpoint Ramp Rate              |         |        |       |        | Setpoint Ramp Rate For Loop 1                                                                                                                  |                                              |
| Dec                                    | 4123    | 20507  | 41014 | RW     | 0 to 10000 display units per hour<br>(1 to 9999 is ramp rate per hour, either 0 or >10000 = Off)                                               |                                              |
| Hex                                    | 101B    | 501B   | A036  |        |                                                                                                                                                |                                              |
| Loop 1 Target Setpoint                 |         |        |       |        | Actual Setpoint Value Of Selected Loop 1 Setpoint                                                                                              |                                              |
| Dec                                    | 4125    | 20509  | 41018 | RO     | The Loop 1 target setpoint value when ramping                                                                                                  |                                              |
| Hex                                    | 101D    | 501D   | A03A  |        |                                                                                                                                                |                                              |
| Operator Access Setpoint Ramp Rate     |         |        |       |        | Value                                                                                                                                          | Operator Access To Loop 1 Setpoint Ramp Rate |
| Dec                                    | 4126    | 20510  | 41020 | RW     | 0                                                                                                                                              | No                                           |
| Hex                                    | 101E    | 501E   | A03C  |        | 1                                                                                                                                              | Yes                                          |

| Operator Access To Setpoint Edit |      |       |       | Value                                                | Operator Access To Edit Loop 1 Setpoint                                                          |
|----------------------------------|------|-------|-------|------------------------------------------------------|--------------------------------------------------------------------------------------------------|
| Dec                              | 4128 | 20512 | 41024 | RW                                                   | 0 No                                                                                             |
| Hex                              | 1020 | 5020  | A040  |                                                      | 1 Yes                                                                                            |
| Loop 1 Selected Setpoint         |      |       |       | Value                                                | Selected Setpoint For Loop 1                                                                     |
| Dec                              | 4127 | 20511 | 41022 | RO                                                   | 0 Main Setpoint                                                                                  |
| Hex                              | 101F | 501F  | A03E  |                                                      | 1 Alternate setpoint                                                                             |
| Loop 1 Actual Setpoint           |      |       |       | Effective Setpoint Value Of Selected Loop 1 Setpoint |                                                                                                  |
| Dec                              | 8256 | 24640 | 49280 | RO                                                   | The effective setpoint for loop 1<br>(current instantaneous value of the active setpoint source) |
| Hex                              | 2040 | 6040  | C080  |                                                      |                                                                                                  |

#### 20.4.14 Loop 2 Setpoint Parameters

| Parameter Name & Register Address      |         |        |       |                                        |                                                                                                                                                |                         |
|----------------------------------------|---------|--------|-------|----------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------|
|                                        | Integer | Int +1 | Float | Access                                 | Values                                                                                                                                         | & Descriptions          |
| Loop 2 Setpoint Minimum                |         |        |       | Minimum Allowed Setpoint For Loop 2    |                                                                                                                                                |                         |
| Dec                                    | 3950    | 20334  | 40668 | RW                                     | Valid between the scaled input lower & upper limits                                                                                            |                         |
| Hex                                    | 0F6E    | 4F6E   | 9EDC  |                                        |                                                                                                                                                |                         |
| Loop 2 Setpoint Maximum                |         |        |       | Maximum Allowed Setpoint For Loop 2    |                                                                                                                                                |                         |
| Dec                                    | 3951    | 20335  | 40670 | RW                                     | Valid between the scaled input lower & upper limits                                                                                            |                         |
| Hex                                    | 0F6F    | 4F6F   | 9EDE  |                                        |                                                                                                                                                |                         |
| Loop 2 Main Local Setpoint Value       |         |        |       | Main Setpoint Value For Loop 2         |                                                                                                                                                |                         |
| Dec                                    | 3964    | 20348  | 40696 | RW                                     | Valid between Setpoint Maximum and Minimum                                                                                                     |                         |
| Hex                                    | 0F7C    | 4F7C   | 9EF8  |                                        |                                                                                                                                                |                         |
| Loop 2 Main Local Setpoint Offset      |         |        |       | Offset Of Main Setpoint Of Loop 2      |                                                                                                                                                |                         |
| Dec                                    | 3965    | 20349  | 40698 | RW                                     | Changes effective setpoint (for multi-zone slaves. +ve values added -ve values subtracted.<br>Setpoint always limited by Setpoint Max and Min. |                         |
| Hex                                    | 0F7D    | 4F7D   | 9EFA  |                                        |                                                                                                                                                |                         |
| Loop 2 Alternate Local Setpoint Value  |         |        |       | Alternate Setpoint Value For Loop 2    |                                                                                                                                                |                         |
| Dec                                    | 3966    | 20350  | 40700 | RW                                     | Valid between Setpoint Maximum and Minimum                                                                                                     |                         |
| Hex                                    | 0F7E    | 4F7E   | 9EFC  |                                        |                                                                                                                                                |                         |
| Loop 2 Alternate Local Setpoint Offset |         |        |       | Offset Of Alternate setpoint Of Loop 2 |                                                                                                                                                |                         |
| Dec                                    | 3967    | 20351  | 40702 | RW                                     | Changes effective setpoint (for multi-zone slaves. +ve values added -ve values subtracted.<br>Setpoint always limited by Setpoint Max and Min. |                         |
| Hex                                    | 0F7F    | 4F7F   | 9EFE  |                                        |                                                                                                                                                |                         |
| Loop 2 Main Setpoint Source            |         |        |       | Value                                  | Main Setpoint Source For Loop 2                                                                                                                |                         |
| Dec                                    | 4052    | 20436  | 40872 | RW                                     | 0                                                                                                                                              | Local Setpoint 1        |
| Hex                                    | 0FD4    | 4FD4   | 9FA8  |                                        | 1                                                                                                                                              | Not Used                |
| Loop 2 Alternate Setpoint Source       |         |        |       | Value                                  | Alternate Setpoint Source For Loop 2                                                                                                           |                         |
| Dec                                    | 4053    | 20437  | 40874 | RW                                     | 0                                                                                                                                              | Not Used                |
| Hex                                    | 0FD5    | 4FD5   | 9FAA  |                                        | 1                                                                                                                                              | Local Setpoint 2        |
|                                        |         |        |       |                                        | 3                                                                                                                                              | Input A Remote Setpoint |
| Loop 2 Setpoint Select                 |         |        |       | Value                                  | Setpoint Select For Loop 2                                                                                                                     |                         |
| Dec                                    | 4200    | 20584  | 41168 | RW                                     | 0                                                                                                                                              | Local Setpoint 1        |
| Hex                                    | 1068    | 5068   | A0D0  |                                        | 1                                                                                                                                              | Alternate setpoint      |
| Loop 2 Setpoint Ramp Rate              |         |        |       | Setpoint Ramp Rate For Loop 2          |                                                                                                                                                |                         |
| Dec                                    | 4201    | 20585  | 41170 | RW                                     | 0 to 10000 display units per hour                                                                                                              |                         |
| Hex                                    | 1069    | 5069   | A0D2  |                                        | (1 to 9999 is ramp rate per hour, either 0 or >10000 = Off)                                                                                    |                         |

| Loop 2 Target Setpoint                |      |       |       | Actual Setpoint Value Of Selected Loop 2 Setpoint    |                                                                                                  |                    |
|---------------------------------------|------|-------|-------|------------------------------------------------------|--------------------------------------------------------------------------------------------------|--------------------|
| Dec                                   | 4203 | 20587 | 41174 | RO                                                   | The Loop 1 target setpoint value when ramping                                                    |                    |
| Hex                                   | 106B | 506B  | A0D6  |                                                      |                                                                                                  |                    |
| Operator Access To Setpoint Ramp Rate |      |       |       | Value                                                | Operator Access To Loop 2 Setpoint Ramp Rate                                                     |                    |
| Dec                                   | 4204 | 20588 | 41176 | RW                                                   | 0                                                                                                | No                 |
| Hex                                   | 106C | 506C  | A0D8  |                                                      | 1                                                                                                | Yes                |
| Operator Access To Setpoint Edit      |      |       |       | Value                                                | Operator Access To Edit Loop 2 Setpoint                                                          |                    |
| Dec                                   | 4206 | 20590 | 41180 | RW                                                   | 0                                                                                                | No                 |
| Hex                                   | 106E | 506E  | A0DC  |                                                      | 1                                                                                                | Yes                |
| Loop 2 Selected Setpoint              |      |       |       | Value                                                | Selected Setpoint For Loop 2                                                                     |                    |
| Dec                                   | 4205 | 20589 | 41178 | RO                                                   | 0                                                                                                | Main Setpoint      |
| Hex                                   | 106D | 506D  | A0DA  |                                                      | 1                                                                                                | Alternate setpoint |
| Loop 2 Actual Setpoint                |      |       |       | Effective Setpoint Value Of Selected Loop 2 Setpoint |                                                                                                  |                    |
| Dec                                   | 8269 | 24653 | 49306 | RO                                                   | The effective setpoint for loop 1<br>(current instantaneous value of the active setpoint source) |                    |
| Hex                                   | 204D | 604D  | C09A  |                                                      |                                                                                                  |                    |

#### 20.4.15 Aux A Input Parameters

| Parameter Name & Register Address |         |        |       |        |                                                                                                                                              |  |
|-----------------------------------|---------|--------|-------|--------|----------------------------------------------------------------------------------------------------------------------------------------------|--|
|                                   | Integer | Int +1 | Float | Access | Values & Descriptions                                                                                                                        |  |
| Auxiliary Input A Scale Minimum   |         |        |       |        | Minimum Input Scaling Value                                                                                                                  |  |
| Dec                               | 2111    | 18495  | 36990 | RW     | Scale value (between ±0.001 & ±10000) when input A is at minimum value. When used for RSP, setpoint is still constrained by setpoint limits. |  |
| Hex                               | 083F    | 483F   | 907E  |        |                                                                                                                                              |  |
| Auxiliary Input A Scale Maximum   |         |        |       |        | Maximum Input Scaling Value                                                                                                                  |  |
| Dec                               | 2112    | 18496  | 36992 | RW     | Scale value (between ±0.001 & ±10000) when input A is at maximum value. When used for RSP, setpoint is still constrained by setpoint limits. |  |
| Hex                               | 0840    | 4840   | 9080  |        |                                                                                                                                              |  |
| Auxiliary Input A Offset          |         |        |       |        | Offset Applied To Scaled Aux A Value                                                                                                         |  |
| Dec                               | 2113    | 18497  | 36994 | RW     | Changes effective setpoint (for multi-zone slaves. +ve values added -ve values subtracted. from +/-0.001 to 20000 units or OFF               |  |
| Hex                               | 0841    | 4841   | 9082  |        |                                                                                                                                              |  |
| Auxiliary Input A Value           |         |        |       |        | Auxiliary Input A Measured Value                                                                                                             |  |
| Dec                               | 2114    | 18498  | 36996 | RO     | The current input A value (scaled).                                                                                                          |  |
| Hex                               | 0842    | 4842   | 9084  |        |                                                                                                                                              |  |

#### 20.4.16 Loop 1 Control Parameters

| Parameter Name & Register Address  |         |        |       |        |        |                                        |
|------------------------------------|---------|--------|-------|--------|--------|----------------------------------------|
|                                    | Integer | Int +1 | Float | Access | Values | & Descriptions                         |
| Loop 1 Manual Control Select       |         |        |       | RW     | Value  | Auto/Manual Mode Selection             |
| Dec                                | 4308    | 20692  | 41384 |        | 0      | Automatic Mode                         |
| Hex                                | 10D4    | 50D4   | A1A8  |        | 1      | Manual Mode                            |
| Loop 1 Control Enable Select       |         |        |       | RW     | Value  | Loop Control Enable/Disable            |
| Dec                                | 4309    | 20693  | 41386 |        | 0      | Disable                                |
| Hex                                | 10D5    | 50D5   | A1AA  |        | 1      | Enable                                 |
| Loop 1 Auto/Manual Operator Access |         |        |       | RW     | Value  | Operator Access To Auto/Manual Control |
| Dec                                | 4394    | 20778  | 41556 |        | 0      | Off                                    |
| Hex                                | 112A    | 512A   | A254  |        | 1      | On                                     |

| Loop 1 Control Enable Access    |      |       |       | Value                                              | Operator Access To Control Enable/Disable                                                                                                             |                                                                |
|---------------------------------|------|-------|-------|----------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------|
| Dec                             | 4395 | 20779 | 41558 | RW                                                 | 0                                                                                                                                                     | Off                                                            |
| Hex                             | 112B | 512B  | A256  |                                                    | 1                                                                                                                                                     | On                                                             |
| Loop 1 Primary Cycle Time       |      |       |       | Cycle Time For Primary Control Outputs             |                                                                                                                                                       |                                                                |
| Dec                             | 4301 | 20685 | 41370 | RW                                                 | 0.5 to 512.0 Seconds                                                                                                                                  |                                                                |
| Hex                             | 10CD | 50CD  | A19A  |                                                    |                                                                                                                                                       |                                                                |
| Loop 1 Secondary Cycle Time     |      |       |       | Cycle Time For Secondary Control Outputs           |                                                                                                                                                       |                                                                |
| Dec                             | 4302 | 20686 | 41372 | RW                                                 | 0.5 to 512.0 Seconds                                                                                                                                  |                                                                |
| Hex                             | 10CE | 50CE  | A19C  |                                                    |                                                                                                                                                       |                                                                |
| Loop 1 Control Mode             |      |       |       | Value                                              | Control Mode For Loop 1                                                                                                                               |                                                                |
| Dec                             | 4390 | 20774 | 41548 | RW                                                 | 0                                                                                                                                                     | Standard                                                       |
| Hex                             | 1126 | 5126  | A24C  |                                                    | 1                                                                                                                                                     | Cascade Mode                                                   |
|                                 |      |       |       |                                                    | 2                                                                                                                                                     | Ratio Mode                                                     |
| Loop 1 Control Selection        |      |       |       | Value                                              | Control Actuator Type Selection                                                                                                                       |                                                                |
| Dec                             | 4307 | 20691 | 41382 | RW                                                 | 0                                                                                                                                                     | Standard ( <i>Time Proportioned or Continuous Linear PID</i> ) |
| Hex                             | 10D3 | 50D3  | A1A6  |                                                    | 1                                                                                                                                                     | VMD ( <i>3-Point Stepping For Valve Motor Drive</i> )          |
| Loop 1 Control type             |      |       |       | Value                                              | Primary Only or Primary & Secondary                                                                                                                   |                                                                |
| Dec                             | 4310 | 20694 | 41388 | RW                                                 | 0                                                                                                                                                     | Single ( <i>Primary Only Control</i> )                         |
| Hex                             | 10D6 | 50D6  | A1AC  |                                                    | 1                                                                                                                                                     | Dual Control ( <i>Primary &amp; Secondary Control</i> )        |
| Loop 1 Control Action           |      |       |       | Value                                              | Direction Of Control Action                                                                                                                           |                                                                |
| Dec                             | 4311 | 20695 | 41390 | RW                                                 | 0                                                                                                                                                     | Direct Acting                                                  |
| Hex                             | 10D7 | 50D7  | A1AE  |                                                    | 1                                                                                                                                                     | Reverse Acting                                                 |
| PID Set 1 - Primary Prop Band   |      |       |       | PID Set 1 Primary Proportional Band For Loop 1     |                                                                                                                                                       |                                                                |
| Dec                             | 4312 | 20696 | 41392 | RW                                                 | Primary Proportional Band for Gain Set 1.<br>1 display unit to 9999 units,<br>but limited to 10 x scaled input span. 0 = On-Off control               |                                                                |
| Hex                             | 10D8 | 50D8  | A1B0  |                                                    |                                                                                                                                                       |                                                                |
| PID Set 1 - Secondary Prop Band |      |       |       | PID Set 1 Secondary Proportional Band For Loop 1   |                                                                                                                                                       |                                                                |
| Dec                             | 4313 | 20697 | 41394 | RW                                                 | Secondary Proportional Band for Gain Set 1.<br>1 display unit to 9999 units,<br>but limited to 10 x scaled input span. 0 = On-Off control             |                                                                |
| Hex                             | 10D9 | 50D9  | A1B2  |                                                    |                                                                                                                                                       |                                                                |
| PID Set 1 - Integral Time       |      |       |       | PID Set 1 Integral Time For Loop 1                 |                                                                                                                                                       |                                                                |
| Dec                             | 4314 | 20698 | 41396 | RW                                                 | Gain Set 1 integral time constant for loop 1<br>0.1 to 5999 Seconds. 0 or 6000 = OFF                                                                  |                                                                |
| Hex                             | 10DA | 50DA  | A1B4  |                                                    |                                                                                                                                                       |                                                                |
| PID Set 1 - Derivative Time     |      |       |       | PID Set 1 Derivative Time For Loop 1               |                                                                                                                                                       |                                                                |
| Dec                             | 4315 | 20699 | 41398 | RW                                                 | Gain Set 1 derivative time constant for loop 1<br>0.1 to 5999 Seconds. 0 or 6000 = OFF                                                                |                                                                |
| Hex                             | 10DB | 50DB  | A1B6  |                                                    |                                                                                                                                                       |                                                                |
| Loop 1 Manual Reset             |      |       |       | PID Set 1 Manual Reset (Bias) For Loop 1           |                                                                                                                                                       |                                                                |
| Dec                             | 4316 | 20700 | 41400 | RW                                                 | Working point from 0 to 100 for single control or<br>-100 to 100 for dual control (primary & secondary)                                               |                                                                |
| Hex                             | 10DC | 50DC  | A1B8  |                                                    |                                                                                                                                                       |                                                                |
| PID Set 1 - Overlap/Deadband    |      |       |       | PID Set 1 - Overlap or Deadband For Loop 1         |                                                                                                                                                       |                                                                |
| Dec                             | 4317 | 20701 | 41402 | RW                                                 | PID Set 1 overlap (+ve) or deadband (-ve) between primary &<br>secondary prop bands. In display units - limited to 20% of the<br>combined band width. |                                                                |
| Hex                             | 10DD | 50DD  | A1BA  |                                                    |                                                                                                                                                       |                                                                |
| PID Set 1 - On/Off Differential |      |       |       | PID Set 1 - On/Off Control Differential For Loop 1 |                                                                                                                                                       |                                                                |
| Dec                             | 4320 | 20704 | 41408 | RW                                                 | The on-off control hysteresis (deadband) for PID Set 1.<br>1 to 300 display units, centred about the setpoint.                                        |                                                                |
| Hex                             | 10E0 | 50E0  | A1C0  |                                                    |                                                                                                                                                       |                                                                |

| Loop 1 Primary Power Upper limit   |      |       |       |    | Loop 1 Primary Power Upper limit                                                                               |                                                      |
|------------------------------------|------|-------|-------|----|----------------------------------------------------------------------------------------------------------------|------------------------------------------------------|
| Dec                                | 4321 | 20705 | 41410 | RW | 10 to 100%                                                                                                     |                                                      |
| Hex                                | 10E1 | 50E1  | A1C2  |    | but must be at least 10% above the primary power lower limit.                                                  |                                                      |
| Loop 1 Primary Power Lower Limit   |      |       |       |    | Loop 1 Primary Power Lower Limit                                                                               |                                                      |
| Dec                                | 4322 | 20706 | 41412 | RW | 0 to 90%                                                                                                       |                                                      |
| Hex                                | 10E2 | 50E2  | A1C4  |    | but must be at least 10% below the primary power upper limit.                                                  |                                                      |
| Loop 1 Secondary Upper Power limit |      |       |       |    | Loop 1 Secondary Upper Power limit                                                                             |                                                      |
| Dec                                | 4323 | 20707 | 41414 | RW | 10 to 100%                                                                                                     |                                                      |
| Hex                                | 10E3 | 50E3  | A1C6  |    | but must be at least 10% above the secondary power lower limit.                                                |                                                      |
| Loop 1 Secondary Power Lower limit |      |       |       |    | Loop 1 Secondary Power Lower limit                                                                             |                                                      |
| Dec                                | 4324 | 20708 | 41416 | RW | 0 to 90%                                                                                                       |                                                      |
| Hex                                | 10E4 | 50E4  | A1C8  |    | but must be at least 10% below the primary power upper limit.                                                  |                                                      |
| Loop 1 Pre-Tune Method             |      |       |       |    | Value                                                                                                          | Pre-tune type                                        |
| Dec                                | 4396 | 20780 | 41560 | RW | 0                                                                                                              | Standard                                             |
| Hex                                | 112C | 512C  | A258  |    | 1                                                                                                              | Pretune at Value                                     |
| Loop 1 Pretune at Value            |      |       |       |    | Value To Pre-tune Loop 1                                                                                       |                                                      |
| Dec                                | 4399 | 20783 | 41566 | RW | Valid between the scaled input lower & upper limits<br>( <i>applies if Pre-Tune Type = Pre-tune at Value</i> ) |                                                      |
| Hex                                | 112F | 512F  | A25E  |    |                                                                                                                |                                                      |
| Loop 1 Pretune Set                 |      |       |       |    | Value                                                                                                          | PID Set Pre-tune Will Optimize                       |
| Dec                                | 4397 | 20781 | 41562 | RW | 0                                                                                                              | PID Set 1                                            |
| Hex                                | 112D | 512D  | A25A  |    | 1                                                                                                              | PID Set 2                                            |
|                                    |      |       |       |    | 2                                                                                                              | PID Set 3                                            |
|                                    |      |       |       |    | 3                                                                                                              | PID Set 4                                            |
|                                    |      |       |       |    | 4                                                                                                              | PID Set 5                                            |
|                                    |      |       |       |    |                                                                                                                |                                                      |
| Loop 1 Pretune Cascade Loop        |      |       |       |    | Value                                                                                                          | Cascade Loop To Be Pre-Tuned                         |
| Dec                                | 4398 | 20782 | 41564 | RW | 0                                                                                                              | Slave ( <i>opens cascade - close when finished</i> ) |
| Hex                                | 112E | 512E  | A25C  |    | 1                                                                                                              | Master ( <i>tunes master/slave combination</i> )     |
| Loop 1 Pre-Tune Engage/disengage   |      |       |       |    | Value                                                                                                          | Pre-Tune Engage/Disengage For Loop 1                 |
| Dec                                | 4325 | 20709 | 41418 | RW | 0                                                                                                              | Pre-Tune OFF                                         |
| Hex                                | 10E5 | 50E5  | A1CA  |    | 1                                                                                                              | Run Pre-Tune                                         |
| Loop 1 Self-Tune Engage/disengage  |      |       |       |    | Value                                                                                                          | Self-Tune Engage/Disengage For Loop 1                |
| Dec                                | 4326 | 20710 | 41420 | RW | 0                                                                                                              | Self-Tune OFF                                        |
| Hex                                | 10E6 | 50E6  | A1CC  |    | 1                                                                                                              | Self-Tune ON                                         |
| Loop 1 Loop Alarm Type             |      |       |       |    | Value                                                                                                          | Loop Alarm Type For Loop 1                           |
| Dec                                | 4327 | 20711 | 41422 | RW | 1                                                                                                              | User Defined Time                                    |
| Hex                                | 10E7 | 50E7  | A1CE  |    | 2                                                                                                              | Automatic ( <i>2x Integral Time</i> )                |
| Loop Alarm Time                    |      |       |       |    | Loop Alarm Activation Time                                                                                     |                                                      |
| Dec                                | 4328 | 20712 | 41424 | RW | 1 to 5999 Seconds after output loop 1 power reaches saturation                                                 |                                                      |
| Hex                                | 10E8 | 50E8  | A1D0  |    |                                                                                                                |                                                      |
| Loop 1 Primary Power               |      |       |       |    | Loop 1 Primary Power Level                                                                                     |                                                      |
| Dec                                | 4329 | 20713 | 41426 | RO | The current loop 1 primary power level (0 to 100%)                                                             |                                                      |
| Hex                                | 10E9 | 50E9  | A1D2  |    |                                                                                                                |                                                      |
| Loop 1 Secondary Power             |      |       |       |    | Loop 1 Secondary Power Level                                                                                   |                                                      |
| Dec                                | 4330 | 20714 | 41428 | RO | The current loop 1 secondary power level (0 to 100%)                                                           |                                                      |
| Hex                                | 10EA | 50EA  | A1D4  |    |                                                                                                                |                                                      |

|                                           |      |       |       |                                                            |                                                                                                                                 |                                                            |
|-------------------------------------------|------|-------|-------|------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------|
| <b>Loop 1 Combined Power</b>              |      |       |       | <b>Loop 1 Combined Primary &amp; Secondary Power Level</b> |                                                                                                                                 |                                                            |
| Dec                                       | 4331 | 20715 | 41430 | RO                                                         | The current loop 1 combined PID power level (-100 to 100%)                                                                      |                                                            |
| Hex                                       | 10EB | 50EB  | A1D6  |                                                            |                                                                                                                                 |                                                            |
| <b>Loop 1 Pre-Tune Status</b>             |      |       |       | RO                                                         | <b>Value</b>                                                                                                                    | <b>Pre-Tune Status For Loop 1</b>                          |
| Dec                                       | 4332 | 20716 | 41432 |                                                            | 0                                                                                                                               | Inactive                                                   |
| Hex                                       | 10EC | 50EC  | A1D8  |                                                            | 1                                                                                                                               | Active                                                     |
| <b>Loop 1 Self-Tune Status</b>            |      |       |       | RO                                                         | <b>Value</b>                                                                                                                    | <b>Self-Tune Status For Loop 1</b>                         |
| Dec                                       | 4333 | 20717 | 41434 |                                                            | 0                                                                                                                               | Inactive                                                   |
| Hex                                       | 10ED | 50ED  | A1DA  |                                                            | 1                                                                                                                               | Active                                                     |
| <b>Loop 1 Loop Alarm status</b>           |      |       |       | RO                                                         | <b>Value</b>                                                                                                                    | <b>Loop Alarm Status For Loop 1</b>                        |
| Dec                                       | 4334 | 20718 | 41436 |                                                            | 0                                                                                                                               | Inactive                                                   |
| Hex                                       | 10EE | 50EE  | A1DC  |                                                            | 1                                                                                                                               | Active                                                     |
| <b>Loop 1 Input Failure Pre-set Power</b> |      |       |       | <b>Loop 1 Input Sensor Break Pre-set Power</b>             |                                                                                                                                 |                                                            |
| Dec                                       | 4335 | 20719 | 41438 | RW                                                         | The pre-defined power output applied if input signal is lost 0 to 100% (-100% to 100% for dual control).                        |                                                            |
| Hex                                       | 10EF | 50EF  | A1DE  |                                                            |                                                                                                                                 |                                                            |
| <b>Loop 1 Auto Pre-tune</b>               |      |       |       | RW                                                         | <b>Value</b>                                                                                                                    | <b>Auto Pre-Tune At Every Power-up For Loop 1</b>          |
| Dec                                       | 4336 | 20720 | 41440 |                                                            | 0                                                                                                                               | Disabled                                                   |
| Hex                                       | 10F0 | 50F0  | A1E0  |                                                            | 1                                                                                                                               | Enabled                                                    |
| <b>Pre-tune Secondary Status</b>          |      |       |       | RO                                                         | <b>Value</b>                                                                                                                    | <b>Pre-tune Secondary Status</b>                           |
| Dec                                       | 4341 | 20725 | 41450 |                                                            | 0                                                                                                                               | No Additional Information                                  |
| Hex                                       | 10F5 | 50F5  | A1EA  |                                                            | 1                                                                                                                               | PV within 5% ( <i>Pre-Tune cannot run</i> )                |
|                                           |      |       |       |                                                            | 2                                                                                                                               | Manual Control Enabled ( <i>Pre-Tune cannot run</i> )      |
|                                           |      |       |       |                                                            | 3                                                                                                                               | Control has On/Off element ( <i>Pre-Tune cannot run</i> )  |
|                                           |      |       |       |                                                            | 4                                                                                                                               | Input not valid ( <i>Pre-Tune cannot run</i> )             |
|                                           |      |       |       |                                                            | 5                                                                                                                               | Control Disabled ( <i>Pre-Tune cannot run</i> )            |
|                                           |      |       |       |                                                            | 6                                                                                                                               | Profile Running ( <i>Pre-Tune cannot run</i> )             |
|                                           |      |       |       |                                                            | 7                                                                                                                               | Setpoint Ramping ( <i>Pre-Tune cannot run</i> )            |
| <b>Self-tune Secondary Status</b>         |      |       |       | RO                                                         | <b>Value</b>                                                                                                                    | <b>Self-tune Secondary Status</b>                          |
| Dec                                       | 4342 | 20726 | 41452 |                                                            | 0                                                                                                                               | No Additional Information                                  |
| Hex                                       | 10F6 | 50F6  | A1EC  |                                                            | 2                                                                                                                               | Manual Control Enabled ( <i>Self-Tune cannot run</i> )     |
|                                           |      |       |       |                                                            | 3                                                                                                                               | Control has On/Off element ( <i>Self-Tune cannot run</i> ) |
|                                           |      |       |       |                                                            | 4                                                                                                                               | Input not valid ( <i>Self-Tune cannot run</i> )            |
|                                           |      |       |       |                                                            | 5                                                                                                                               | Control Disabled ( <i>Self-Tune cannot run</i> )           |
| <b>Loop 1 Anti Wind-up Limit</b>          |      |       |       | <b>Loop 1 Anti Wind-up Limit</b>                           |                                                                                                                                 |                                                            |
| Dec                                       | 4391 | 20775 | 41550 | RW                                                         | Power level where integral action is suspended. Adjustable from 10.0 to 100.0% of PID power.                                    |                                                            |
| Hex                                       | 1127 | 5127  | A24E  |                                                            |                                                                                                                                 |                                                            |
| <b>Loop 1 Motor Travel Time</b>           |      |       |       | RW                                                         | <b>Loop 1 Motor Travel Time</b>                                                                                                 |                                                            |
| Dec                                       | 4343 | 20727 | 41454 |                                                            | The motor travel time (from fully open to fully closed) for 3-point stepping VMD control. Adjustable from 5 to 300 seconds.     |                                                            |
| Hex                                       | 10F7 | 50F7  | A1EE  |                                                            |                                                                                                                                 |                                                            |
| <b>Loop 1 Minimum Motor On Time</b>       |      |       |       | RW                                                         | <b>Loop 1 Minimum Motor On Time</b>                                                                                             |                                                            |
| Dec                                       | 4344 | 20728 | 41456 |                                                            | Minimum drive effort to begin moving valve for 3-point stepping VMD control. In seconds, from 0.02 to 1/10 of Motor Travel Time |                                                            |
| Hex                                       | 10F8 | 50F8  | A1F0  |                                                            |                                                                                                                                 |                                                            |
| <b>Loop 1 VMD Break Action</b>            |      |       |       | RW                                                         | <b>Value</b>                                                                                                                    | <b>Loop 1 Sensor Break Action For VMD Control</b>          |
| Dec                                       | 4401 | 20785 | 41570 |                                                            | 0                                                                                                                               | Close Valve Output On                                      |
| Hex                                       | 1131 | 5131  | A262  |                                                            | 1                                                                                                                               | Open Valve Output On                                       |
| <b>Loop 1 Valve Close Limit</b>           |      |       |       | RW                                                         | <b>Loop 1 Minimum Valve Position</b>                                                                                            |                                                            |
| Dec                                       | 4376 | 20760 | 41520 |                                                            | Minimum position to drive valve in VMD Mode from the valve close limit+1% to 100.0%                                             |                                                            |
| Hex                                       | 1118 | 5118  | A230  |                                                            |                                                                                                                                 |                                                            |

| Loop 1 Valve Open Limit         |      |       |       | Loop 1 Maximum Valve Position                    |                                                                                                                                                       |
|---------------------------------|------|-------|-------|--------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------|
| Dec                             | 4377 | 20761 | 41522 | RW                                               | Maximum position to drive valve in VMD Mode.<br>From 0.0% to the valve open limit-1%                                                                  |
| Hex                             | 1119 | 5119  | A232  |                                                  |                                                                                                                                                       |
| Loop 1 PID Set Select           |      |       |       | Value                                            | Loop 1 PID Set Selection                                                                                                                              |
| Dec                             | 4367 | 20751 | 41502 | RW                                               | 0 PID Set 1                                                                                                                                           |
| Hex                             | 110F | 510F  | A21E  |                                                  | 1 Gain Schedule Selected by SP                                                                                                                        |
|                                 |      |       |       |                                                  | 2 Gain Schedule Selected by PV                                                                                                                        |
|                                 |      |       |       |                                                  | 3 PID Set 2                                                                                                                                           |
|                                 |      |       |       |                                                  | 4 PID Set 3                                                                                                                                           |
|                                 |      |       |       |                                                  | 5 PID Set 4                                                                                                                                           |
|                                 |      |       |       | 6 PID Set 5                                      |                                                                                                                                                       |
| PID Set 2 - Primary Prop Band   |      |       |       | PID Set 2 Primary Proportional Band For Loop 1   |                                                                                                                                                       |
| Dec                             | 4347 | 20731 | 41462 | RW                                               | Primary Proportional Band for Gain Set 2.<br>1 display unit to 9999 units,<br>but limited to 10 x scaled input span. 0 = On-Off control               |
| Hex                             | 10FB | 50FB  | A1F6  |                                                  |                                                                                                                                                       |
| PID Set 2 - Secondary Prop Band |      |       |       | PID Set 2 Secondary Proportional Band For Loop1  |                                                                                                                                                       |
| Dec                             | 4348 | 20732 | 41464 | RW                                               | Secondary Proportional Band for Gain Set 2.<br>1 display unit to 9999 units,<br>but limited to 10 x scaled input span. 0 = On-Off control             |
| Hex                             | 10FC | 50FC  | A1F8  |                                                  |                                                                                                                                                       |
| PID Set 2 - Integral Time       |      |       |       | PID Set 2 - Integral Time For Loop 1             |                                                                                                                                                       |
| Dec                             | 4349 | 20733 | 41466 | RW                                               | Gain Set 2 integral time constant for loop 1<br>0.1 to 5999 Seconds. 0 or 6000 = OFF                                                                  |
| Hex                             | 10FD | 50FD  | A1FA  |                                                  |                                                                                                                                                       |
| PID Set 2 - Derivative Time     |      |       |       | PID Set 2 - Derivative Time For Loop 1           |                                                                                                                                                       |
| Dec                             | 4350 | 20734 | 41468 | RW                                               | Gain Set 2 derivative time constant for loop 1<br>0.1 to 5999 Seconds. 0 or 6000 = OFF                                                                |
| Hex                             | 10FE | 50FE  | A1FC  |                                                  |                                                                                                                                                       |
| PID Set 2 - Overlap/Deadband    |      |       |       | PID Set 2 - Overlap/Deadband For Loop 1          |                                                                                                                                                       |
| Dec                             | 4351 | 20735 | 41470 | RW                                               | PID Set 2 overlap (+ve) or deadband (-ve) between primary &<br>secondary prop bands. In display units - limited to 20% of the<br>combined band width. |
| Hex                             | 10FF | 50FF  | A1FE  |                                                  |                                                                                                                                                       |
| PID Set 2 - On/Off Differential |      |       |       | PID Set 2 - On/Off Differential For Loop 1       |                                                                                                                                                       |
| Dec                             | 4378 | 20762 | 41524 | RW                                               | The on-off control hysteresis (deadband) for PID Set 2.<br>1 to 300 display units, centred about the setpoint.                                        |
| Hex                             | 111A | 511A  | A234  |                                                  |                                                                                                                                                       |
| PID Set 3 - Primary Prop Band   |      |       |       | PID Set 3 Primary Proportional Band For Loop 1   |                                                                                                                                                       |
| Dec                             | 4352 | 20736 | 41472 | RW                                               | Primary Proportional Band for Gain Set 3.<br>1 display unit to 9999 units,<br>but limited to 10 x scaled input span. 0 = On-Off control               |
| Hex                             | 1100 | 5100  | A200  |                                                  |                                                                                                                                                       |
| PID Set 3 - Secondary Prop Band |      |       |       | PID Set 3 Secondary Proportional Band For Loop 1 |                                                                                                                                                       |
| Dec                             | 4353 | 20737 | 41474 | RW                                               | Secondary Proportional Band for Gain Set 3.<br>1 display unit to 9999 units,<br>but limited to 10 x scaled input span. 0 = On-Off control             |
| Hex                             | 1101 | 5101  | A202  |                                                  |                                                                                                                                                       |
| PID Set 3 - Integral Time       |      |       |       | PID Set 3 - Integral Time For Loop 1             |                                                                                                                                                       |
| Dec                             | 4354 | 20738 | 41476 | RW                                               | Gain Set 3 integral time constant for loop 1<br>0.1 to 5999 Seconds. 0 or 6000 = OFF                                                                  |
| Hex                             | 1102 | 5102  | A204  |                                                  |                                                                                                                                                       |
| PID Set 3 - Derivative Time     |      |       |       | PID Set 3 - Derivative Time For Loop 1           |                                                                                                                                                       |
| Dec                             | 4355 | 20739 | 41478 | RW                                               | Gain Set 3 derivative time constant for loop 1<br>0.1 to 5999 Seconds. 0 or 6000 = OFF                                                                |
| Hex                             | 1103 | 5103  | A206  |                                                  |                                                                                                                                                       |
| PID Set 3 - Overlap/Deadband    |      |       |       | PID Set 3 - Overlap/Deadband For Loop 1          |                                                                                                                                                       |
| Dec                             | 4356 | 20740 | 41480 | RW                                               | PID Set 3 overlap (+ve) or deadband (-ve) between primary &<br>secondary prop bands. In display units - limited to 20% of the<br>combined band width. |
| Hex                             | 1104 | 5104  | A208  |                                                  |                                                                                                                                                       |

|                                 |      |       |       |                                                  |                                                                                                                                                       |
|---------------------------------|------|-------|-------|--------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------|
| PID Set 3 - On/Off Differential |      |       |       | PID Set 3 - On/Off Differential For Loop 1       |                                                                                                                                                       |
| Dec                             | 4379 | 20763 | 41526 | RW                                               | The on-off control hysteresis (deadband) for PID Set 3.<br>1 to 300 display units, centred about the setpoint.                                        |
| Hex                             | 111B | 511B  | A236  |                                                  |                                                                                                                                                       |
| PID Set 4 - Primary Prop Band   |      |       |       | PID Set 4 Primary Proportional Band For Loop 1   |                                                                                                                                                       |
| Dec                             | 4357 | 20741 | 41482 | RW                                               | Primary Proportional Band for Gain Set 4.<br>1 display unit to 9999 units,<br>but limited to 10 x scaled input span. 0 = On-Off control               |
| Hex                             | 1105 | 5105  | A20A  |                                                  |                                                                                                                                                       |
| PID Set 4 - Secondary Prop Band |      |       |       | PID Set 4 Secondary Proportional Band For Loop 1 |                                                                                                                                                       |
| Dec                             | 4358 | 20742 | 41484 | RW                                               | Secondary Proportional Band for Gain Set 4.<br>1 display unit to 9999 units,<br>but limited to 10 x scaled input span. 0 = On-Off control             |
| Hex                             | 1106 | 5106  | A20C  |                                                  |                                                                                                                                                       |
| PID Set 4 - Integral Time       |      |       |       | PID Set 4 - Integral Time For Loop 1             |                                                                                                                                                       |
| Dec                             | 4359 | 20743 | 41486 | RW                                               | Gain Set 4 integral time constant for loop 1<br>0.1 to 5999 Seconds. 0 or 6000 = OFF                                                                  |
| Hex                             | 1107 | 5107  | A20E  |                                                  |                                                                                                                                                       |
| PID Set 4 - Derivative Time     |      |       |       | PID Set 4 - Derivative Time For Loop 1           |                                                                                                                                                       |
| Dec                             | 4360 | 20744 | 41488 | RW                                               | Gain Set 4 derivative time constant for loop 1<br>0.1 to 5999 Seconds. 0 or 6000 = OFF                                                                |
| Hex                             | 1108 | 5108  | A210  |                                                  |                                                                                                                                                       |
| PID Set 4 - Overlap/Deadband    |      |       |       | PID Set 4 - Overlap/Deadband For Loop 1          |                                                                                                                                                       |
| Dec                             | 4361 | 20745 | 41490 | RW                                               | PID Set 4 overlap (+ve) or deadband (-ve) between primary &<br>secondary prop bands. In display units - limited to 20% of the<br>combined band width. |
| Hex                             | 1109 | 5109  | A212  |                                                  |                                                                                                                                                       |
| PID Set 4 - On/Off Differential |      |       |       | PID Set 4 - On/Off Differential For Loop 1       |                                                                                                                                                       |
| Dec                             | 4380 | 20764 | 41528 | RW                                               | The on-off control hysteresis (deadband) for PID Set 4.<br>1 to 300 display units, centred about the setpoint.                                        |
| Hex                             | 111C | 511C  | A238  |                                                  |                                                                                                                                                       |
| PID Set 5 - Primary Prop Band   |      |       |       | PID Set 5 Primary Proportional Band For Loop 1   |                                                                                                                                                       |
| Dec                             | 4362 | 20746 | 41492 | RW                                               | Primary Proportional Band for Gain Set 5.<br>1 display unit to 9999 units,<br>but limited to 10 x scaled input span. 0 = On-Off control               |
| Hex                             | 110A | 510A  | A214  |                                                  |                                                                                                                                                       |
| PID Set 5 - Secondary Prop Band |      |       |       | PID Set 5 Secondary Proportional Band For Loop 1 |                                                                                                                                                       |
| Dec                             | 4363 | 20747 | 41494 | RW                                               | Secondary Proportional Band for Gain Set 5.<br>1 display unit to 9999 units,<br>but limited to 10 x scaled input span. 0 = On-Off control             |
| Hex                             | 110B | 510B  | A216  |                                                  |                                                                                                                                                       |
| PID Set 5 - Integral Time       |      |       |       | PID Set 5 - Integral Time For Loop 1             |                                                                                                                                                       |
| Dec                             | 4364 | 20748 | 41496 | RW                                               | Gain Set 5 integral time constant for loop 1<br>0.1 to 5999 Seconds. 0 or 6000 = OFF                                                                  |
| Hex                             | 110C | 510C  | A218  |                                                  |                                                                                                                                                       |
| PID Set 5 - Derivative Time     |      |       |       | PID Set 5 - Derivative Time For Loop 1           |                                                                                                                                                       |
| Dec                             | 4365 | 20749 | 41498 | RW                                               | Gain Set 5 derivative time constant for loop 1<br>0.1 to 5999 Seconds. 0 or 6000 = OFF                                                                |
| Hex                             | 110D | 510D  | A21A  |                                                  |                                                                                                                                                       |
| PID Set 5 - Overlap/Deadband    |      |       |       | PID Set 5 - Overlap/Deadband For Loop 1          |                                                                                                                                                       |
| Dec                             | 4366 | 20750 | 41500 | RW                                               | PID Set 5 overlap (+ve) or deadband (-ve) between primary &<br>secondary prop bands. In display units - limited to 20% of the<br>combined band width. |
| Hex                             | 110E | 510E  | A21C  |                                                  |                                                                                                                                                       |
| PID Set 5 - Overlap/Deadband    |      |       |       | PID Set 5 - On/Off Differential For Loop 1       |                                                                                                                                                       |
| Dec                             | 4381 | 20765 | 41530 | RW                                               | The on-off control hysteresis (deadband) for PID Set 5.<br>1 to 300 display units, centred about the setpoint.                                        |
| Hex                             | 111D | 511D  | A23A  |                                                  |                                                                                                                                                       |
| Loop 1 Gain Set 2 Breakpoint    |      |       |       | Gain Scheduling PID Set 1 To 2 Switch Point      |                                                                                                                                                       |
| Dec                             | 4369 | 20753 | 41506 | RW                                               | Value (SP or PV) gain scheduling switches from PID Set 1 To 2.<br>Value between Scaled Input 1 Lower & Upper Limits                                   |
| Hex                             | 1111 | 5111  | A222  |                                                  |                                                                                                                                                       |
| Loop 1 Gain Set 3 Breakpoint    |      |       |       | Gain Scheduling PID Set 2 To 3 Switch Point      |                                                                                                                                                       |
| Dec                             | 4370 | 20754 | 41508 | RW                                               | Value (SP or PV) gain scheduling switches from PID Set 2 To 3.<br>Value between Set 2 Breakpoint & Scaled Input 1 Upper Limit.                        |
| Hex                             | 1112 | 5112  | A224  |                                                  |                                                                                                                                                       |

| Loop 1 Gain Set 4 Breakpoint |      |       |       | Gain Scheduling PID Set 3 To 4 Switch Point |                                                                                                                                |
|------------------------------|------|-------|-------|---------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------|
| Dec                          | 4371 | 20755 | 41510 | RW                                          | Value (SP or PV) gain scheduling switches from PID Set 3 To 4.<br>Value between Set 3 Breakpoint & Scaled Input 1 Upper Limit. |
| Hex                          | 1113 | 5113  | A226  |                                             |                                                                                                                                |
| Loop 1 Gain Set 5 Breakpoint |      |       |       | Gain Scheduling PID Set 4 To 5 Switch Point |                                                                                                                                |
| Dec                          | 4372 | 20756 | 41512 | RW                                          | Value (SP or PV) gain scheduling switches from PID Set 4 To 5.<br>Value between Set 4 Breakpoint & Scaled Input 1 Upper Limit. |
| Hex                          | 1114 | 5114  | A228  |                                             |                                                                                                                                |
| Loop 1 Cascade Mode          |      |       |       | Value                                       | Cascade Master/Slave Link Status                                                                                               |
| Dec                          | 4393 | 20777 | 41554 | RW                                          | 0 Cascade Closed                                                                                                               |
| Hex                          | 1129 | 5129  | A252  |                                             | 1 Cascade Open                                                                                                                 |
| Loop 1 Ratio NO Constant     |      |       |       | Ratio NO Constant For Atomizing Air         |                                                                                                                                |
| Dec                          | 4387 | 20771 | 41542 | RW                                          | 0 to 9999 atomizing air value,<br>Added to the x1 value in ratio mode (air flow is x1 + NO).                                   |
| Hex                          | 1123 | 5123  | A246  |                                             |                                                                                                                                |
| Loop 1 Ratio Sfac Constant   |      |       |       | Ratio Sfac Constant                         |                                                                                                                                |
| Dec                          | 4388 | 20772 | 41544 | RW                                          | Ratio control mode scaling factor. Adjustable from 0.010 to<br>99.999                                                          |
| Hex                          | 1124 | 5124  | A248  |                                             |                                                                                                                                |

## 20.4.17 Loop 2 Control Parameters

| Parameter Name & Register Address |         |        |       |        |                                          |                                                         |
|-----------------------------------|---------|--------|-------|--------|------------------------------------------|---------------------------------------------------------|
|                                   | Integer | Int +1 | Float | Access | Values                                   | & Descriptions                                          |
| Loop 2 Manual Control Select      |         |        |       |        | Value                                    | Selection                                               |
| Dec                               | 4408    | 20792  | 41584 | RW     | 0                                        | Automatic Mode                                          |
| Hex                               | 1138    | 5138   | A270  |        | 1                                        | Manual Mode                                             |
| Loop 2 Control Enable Select      |         |        |       |        | Value                                    | Control Enable Selection                                |
| Dec                               | 4409    | 20793  | 41586 | RW     | 0                                        | Disabled                                                |
| Hex                               | 1139    | 5139   | A272  |        | 1                                        | Enabled                                                 |
| Loop 2 Auto/Manual Access         |         |        |       |        | Value                                    | Operator Access To Auto/Manual Control                  |
| Dec                               | 4494    | 20878  | 41756 | RW     | 0                                        | Off                                                     |
| Hex                               | 118E    | 518E   | A31C  |        | 1                                        | On                                                      |
| Loop 2 Control Enable Access      |         |        |       |        | Value                                    | Operator Access To Control Enable/Disable               |
| Dec                               | 4495    | 20879  | 41758 | RW     | 0                                        | Off                                                     |
| Hex                               | 118F    | 518F   | A31E  |        | 1                                        | On                                                      |
| Loop 2 Primary Cycle Time         |         |        |       |        | Cycle Time For Primary Control Outputs   |                                                         |
| Dec                               | 4303    | 20687  | 41374 | RW     | 0.5 to 512.0 Seconds                     |                                                         |
| Hex                               | 10CF    | 50CF   | A19E  |        |                                          |                                                         |
| Loop 2 Secondary Cycle Time       |         |        |       |        | Cycle Time For Secondary Control Outputs |                                                         |
| Dec                               | 4304    | 20688  | 41376 | RW     | 0.5 to 512.0 Seconds                     |                                                         |
| Hex                               | 10D0    | 50D0   | A1A0  |        |                                          |                                                         |
| Loop 2 Control Selection          |         |        |       |        | Value                                    | Control Actuator Type Selection                         |
| Dec                               | 4407    | 20791  | 41582 | RW     | 0                                        | Standard ( <i>Time Proportioned or Continuous PID</i> ) |
| Hex                               | 1137    | 5137   | A26E  |        | 1                                        | VMD ( <i>3-Point Stepping for Valve Motor Drive</i> )   |
| Loop 2 Control type               |         |        |       |        | Value                                    | Primary Only or Primary & Secondary                     |
| Dec                               | 4410    | 20794  | 41588 | RW     | 0                                        | Single ( <i>Primary Only Control</i> )                  |
| Hex                               | 113A    | 513A   | A274  |        | 1                                        | Dual Control ( <i>Primary &amp; Secondary Control</i> ) |

| Loop 2 Control Action              |      |       |       |    | Value                                                                                                                                                 | Direction Of Control Action |
|------------------------------------|------|-------|-------|----|-------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|
| Dec                                | 4411 | 20795 | 41590 | RW | 0                                                                                                                                                     | Direct Acting               |
| Hex                                | 113B | 513B  | A276  |    | 1                                                                                                                                                     | Reverse Acting              |
| PID Set 1 - Primary Prop Band      |      |       |       |    | PID Set 1 Primary Proportional Band For Loop 2                                                                                                        |                             |
| Dec                                | 4412 | 20796 | 41592 | RW | Primary Proportional Band for Gain Set 1.<br>1 display unit to 9999 units,<br>but limited to 10 x scaled input span. 0 = On-Off control               |                             |
| Hex                                | 113C | 513C  | A278  |    |                                                                                                                                                       |                             |
| PID Set 1 - Secondary Prop Band    |      |       |       |    | PID Set 1 Secondary Proportional Band For Loop 2                                                                                                      |                             |
| Dec                                | 4413 | 20797 | 41594 | RW | Secondary Proportional Band for Gain Set 1.<br>1 display unit to 9999 units,<br>but limited to 10 x scaled input span. 0 = On-Off control             |                             |
| Hex                                | 113D | 513D  | A27A  |    |                                                                                                                                                       |                             |
| PID Set 1 - Integral Time          |      |       |       |    | PID Set 1 Integral Time For Loop 2                                                                                                                    |                             |
| Dec                                | 4414 | 20798 | 41596 | RW | Gain Set 1 integral time constant for loop 2<br>0.1 to 5999 Seconds. 0 or 6000 = OFF                                                                  |                             |
| Hex                                | 113E | 513E  | A27C  |    |                                                                                                                                                       |                             |
| PID Set 1 - Derivative Time        |      |       |       |    | PID Set 1 Derivative Time For Loop 2                                                                                                                  |                             |
| Dec                                | 4415 | 20799 | 41598 | RW | Gain Set 1 derivative time constant for loop 2<br>0.1 to 5999 Seconds. 0 or 6000 = OFF                                                                |                             |
| Hex                                | 113F | 513F  | A27E  |    |                                                                                                                                                       |                             |
| Loop 2 Manual Reset (Bias)         |      |       |       |    | PID Set 1 Manual Reset (Bias) For Loop 2                                                                                                              |                             |
| Dec                                | 4416 | 20800 | 41600 | RW | Working point from 0 to 100 for single control or<br>-100 to 100 for dual control (primary & secondary)                                               |                             |
| Hex                                | 1140 | 5140  | A280  |    |                                                                                                                                                       |                             |
| PID Set 1 - Overlap/Deadband       |      |       |       |    | PID Set 1 - Overlap or Deadband For Loop 2                                                                                                            |                             |
| Dec                                | 4417 | 20801 | 41602 | RW | PID Set 1 overlap (+ve) or deadband (-ve) between primary &<br>secondary prop bands. In display units - limited to 20% of the<br>combined band width. |                             |
| Hex                                | 1141 | 5141  | A282  |    |                                                                                                                                                       |                             |
| PID Set 1 - On/Off Differential    |      |       |       |    | PID Set 1 - On/Off Control Differential For Loop 2                                                                                                    |                             |
| Dec                                | 4420 | 20804 | 41608 | RW | The on-off control hysteresis (deadband) for PID Set 1.<br>1 to 300 display units, centred about the setpoint.                                        |                             |
| Hex                                | 1144 | 5144  | A288  |    |                                                                                                                                                       |                             |
| Loop 2 Primary Power Upper limit   |      |       |       |    | Loop 2 Primary Power Upper limit                                                                                                                      |                             |
| Dec                                | 4421 | 20805 | 41610 | RW | 10 to 100%<br>but must be at least 10% above the primary power lower limit.                                                                           |                             |
| Hex                                | 1145 | 5145  | A28A  |    |                                                                                                                                                       |                             |
| Loop 2 Primary Power Lower Limit   |      |       |       |    | Loop 2 Primary Power Lower Limit                                                                                                                      |                             |
| Dec                                | 4422 | 20806 | 41612 | RW | 0 to 90%<br>but must be at least 10% below the primary power upper limit.                                                                             |                             |
| Hex                                | 1146 | 5146  | A28C  |    |                                                                                                                                                       |                             |
| Loop 2 Secondary Upper Power limit |      |       |       |    | Loop 2 Secondary Upper Power limit                                                                                                                    |                             |
| Dec                                | 4423 | 20807 | 41614 | RW | 10 to 100%<br>but must be at least 10% above the secondary power lower limit.                                                                         |                             |
| Hex                                | 1147 | 5147  | A28E  |    |                                                                                                                                                       |                             |
| Loop 2 Secondary Power Lower limit |      |       |       |    | Loop 2 Secondary Power Lower limit                                                                                                                    |                             |
| Dec                                | 4424 | 20808 | 41616 | RW | 0 to 90%<br>but must be at least 10% below the primary power upper limit.                                                                             |                             |
| Hex                                | 1148 | 5148  | A290  |    |                                                                                                                                                       |                             |
| Loop 2 Pre-Tune Method             |      |       |       |    | Value                                                                                                                                                 | Pre-Tune type               |
| Dec                                | 4496 | 20880 | 41760 | RW | 0                                                                                                                                                     | Standard                    |
| Hex                                | 1190 | 5190  | A320  |    | 1                                                                                                                                                     | Pre-tune at Value           |
| Loop 2 Pre-Tune at Value           |      |       |       |    | Value To Pre-Tune Loop 2                                                                                                                              |                             |
| Dec                                | 4499 | 20883 | 41766 | RW | Valid between the scaled input lower & upper limits<br>(applies if Pre-Tune Type = Pre-Tune at Value)                                                 |                             |
| Hex                                | 1193 | 5193  | A326  |    |                                                                                                                                                       |                             |

| Loop 2 Pre-Tune Set                |      |       |       |    | Value                                                                                                       | PID Set Pre-tune Will Optimize             |
|------------------------------------|------|-------|-------|----|-------------------------------------------------------------------------------------------------------------|--------------------------------------------|
| Dec                                | 4497 | 20881 | 41762 | RW | 0                                                                                                           | PID Set 1                                  |
| Hex                                | 1191 | 5191  | A322  |    | 1                                                                                                           | PID Set 2                                  |
|                                    |      |       |       |    | 2                                                                                                           | PID Set 3                                  |
|                                    |      |       |       |    | 3                                                                                                           | PID Set 4                                  |
|                                    |      |       |       |    | 4                                                                                                           | PID Set 5                                  |
| Loop 2 Pre-Tune Engage/disengage   |      |       |       |    | Value                                                                                                       | Pre-Tune Engage/disengage For Loop 2       |
| Dec                                | 4425 | 20809 | 41618 | RW | 0                                                                                                           | Pre-Tune OFF                               |
| Hex                                | 1149 | 5149  | A292  |    | 1                                                                                                           | Run Pre-Tune                               |
| Loop 2 Self-Tune Engage/disengage  |      |       |       |    | Value                                                                                                       | Self-Tune Engage/disengage For Loop 2      |
| Dec                                | 4426 | 20810 | 41620 | RW | 0                                                                                                           | Self-Tune OFF                              |
| Hex                                | 114A | 514A  | A294  |    | 1                                                                                                           | Self-Tune ON                               |
| Loop 2 Loop Alarm Type             |      |       |       |    | Value                                                                                                       | Loop Alarm Type For Loop 2                 |
| Dec                                | 4427 | 20811 | 41622 | RW | 1                                                                                                           | User Defined Time                          |
| Hex                                | 114B | 514B  | A296  |    | 2                                                                                                           | Automatic (2x <i>Integral Time</i> )       |
| Loop Alarm Time                    |      |       |       |    | Loop Alarm Activation Time                                                                                  |                                            |
| Dec                                | 4428 | 20812 | 41624 | RW | 1 to 5999 Seconds after output loop 2 power reaches saturation                                              |                                            |
| Hex                                | 114C | 514C  | A298  |    |                                                                                                             |                                            |
| Loop 2 Primary Power               |      |       |       |    | Loop 2 Primary Power Level                                                                                  |                                            |
| Dec                                | 4429 | 20813 | 41626 | RO | The current loop 2 primary power level (0 to 100%)                                                          |                                            |
| Hex                                | 114D | 514D  | A29A  |    |                                                                                                             |                                            |
| Loop 2 Secondary Power             |      |       |       |    | Loop 2 Secondary Power Level                                                                                |                                            |
| Dec                                | 4430 | 20814 | 41628 | RO | The current loop 2 secondary power level (0 to 100%)                                                        |                                            |
| Hex                                | 114E | 514E  | A29C  |    |                                                                                                             |                                            |
| Loop 2 Combined Power              |      |       |       |    | Loop 2 Combined Primary & Secondary Power Level                                                             |                                            |
| Dec                                | 4431 | 20815 | 41630 | RO | The current loop 2 combined PID power level (-100 to 100%)                                                  |                                            |
| Hex                                | 114F | 514F  | A29E  |    |                                                                                                             |                                            |
| Loop 2 Pre-Tune Status             |      |       |       |    | Value                                                                                                       | Pre-Tune Status For Loop 2                 |
| Dec                                | 4432 | 20816 | 41632 | RO | 0                                                                                                           | Inactive                                   |
| Hex                                | 1150 | 5150  | A2A0  |    | 1                                                                                                           | Active                                     |
| Loop 2 Self-Tune Status            |      |       |       |    | Value                                                                                                       | Self-Tune Status For Loop 2                |
| Dec                                | 4433 | 20817 | 41634 | RO | 0                                                                                                           | Inactive                                   |
| Hex                                | 1151 | 5151  | A2A2  |    | 1                                                                                                           | Active                                     |
| Loop 2 Loop Alarm status           |      |       |       |    | Value                                                                                                       | Loop Alarm Status For Loop 2               |
| Dec                                | 4434 | 20818 | 41636 | RO | 0                                                                                                           | Inactive                                   |
| Hex                                | 1152 | 5152  | A2A4  |    | 1                                                                                                           | Active                                     |
| Loop 2 Input Failure Pre-set Power |      |       |       |    | Loop 2 Input Sensor Break Pre-set Power                                                                     |                                            |
| Dec                                | 4435 | 20819 | 41638 | RW | The pre-defined power output applied if input signal is lost<br>0 to 100% (-100% to 100% for dual control). |                                            |
| Hex                                | 1153 | 5153  | A2A6  |    |                                                                                                             |                                            |
| Loop 2 Auto Pre-tune               |      |       |       |    | Value                                                                                                       | Auto Pre-Tune At Every Power-up For Loop 2 |
| Dec                                | 4436 | 20820 | 41640 | RW | 0                                                                                                           | Disabled                                   |
| Hex                                | 1154 | 5154  | A2A8  |    | 1                                                                                                           | Enabled                                    |

| Pre-Tune Secondary Status       |      |       |       |    | Value                                                                                                                                     | Loop 2 Pre-Tune Secondary Status                  |
|---------------------------------|------|-------|-------|----|-------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------|
| Dec                             | 4441 | 20825 | 41650 | RW | 0                                                                                                                                         | No Additional Information                         |
| Hex                             | 1159 | 5159  | A2B2  |    | 1                                                                                                                                         | PV within 5% (Pre-Tune cannot run)                |
|                                 |      |       |       |    | 2                                                                                                                                         | Manual Control Enabled (Pre-Tune cannot run)      |
|                                 |      |       |       |    | 3                                                                                                                                         | Control has On/Off element (Pre-Tune cannot run)  |
|                                 |      |       |       |    | 4                                                                                                                                         | Input not valid (Pre-Tune cannot run)             |
|                                 |      |       |       |    | 5                                                                                                                                         | Control Disabled (Pre-Tune cannot run)            |
|                                 |      |       |       |    | 6                                                                                                                                         | Profile Running (Pre-Tune cannot run)             |
|                                 |      |       |       |    | 7                                                                                                                                         | Setpoint Ramping (Pre-Tune cannot run)            |
| Self-Tune Secondary Status      |      |       |       |    | Value                                                                                                                                     | Loop 2 Self-Tune Secondary Status                 |
| Dec                             | 4442 | 20826 | 41652 | RW | 0                                                                                                                                         | No Additional Information                         |
| Hex                             | 115A | 515A  | A2B4  |    | 2                                                                                                                                         | Manual Control Enabled (Self-Tune cannot run)     |
|                                 |      |       |       |    | 3                                                                                                                                         | Control has On/Off element (Self-Tune cannot run) |
|                                 |      |       |       |    | 4                                                                                                                                         | Input not valid (Self-Tune cannot run)            |
|                                 |      |       |       |    | 5                                                                                                                                         | Control Disabled (Self-Tune cannot run)           |
| Loop 2 Anti Wind-up Limit       |      |       |       |    | Loop 2 Anti Wind-up Limit                                                                                                                 |                                                   |
| Dec                             | 4491 | 20875 | 41750 | RW | Power level where integral action is suspended.<br>Adjustable from 10.0 to 100.0% of PID power.                                           |                                                   |
| Hex                             | 118B | 518B  | A316  |    |                                                                                                                                           |                                                   |
| Loop 2 Motor Travel Time        |      |       |       |    | Loop 2 Motor Travel Time                                                                                                                  |                                                   |
| Dec                             | 4443 | 20827 | 41654 | RW | The motor travel time (from fully open to fully closed) for 3-point stepping VMD control. Adjustable from 5 to 300 seconds.               |                                                   |
| Hex                             | 115B | 515B  | A2B6  |    |                                                                                                                                           |                                                   |
| Loop 2 Minimum Motor On Time    |      |       |       |    | Loop 2 Minimum Motor On Time                                                                                                              |                                                   |
| Dec                             | 4444 | 20828 | 41656 | RW | Minimum drive effort to begin moving valve for 3-point stepping VMD control. In seconds, from 0.02 to 1/10 of Motor Travel Time           |                                                   |
| Hex                             | 115C | 515C  | A2B8  |    |                                                                                                                                           |                                                   |
| Loop 2 Valve Break Action       |      |       |       |    | Value                                                                                                                                     | Loop 2 Sensor Break Action For VMD Control        |
| Dec                             | 4501 | 20885 | 41770 | RW | 0                                                                                                                                         | Close Valve Output On                             |
| Hex                             | 1195 | 5195  | A32A  |    | 1                                                                                                                                         | Open Valve Output On                              |
| Loop 2 Minimum Valve Position   |      |       |       |    | Loop 2 Minimum Valve Position                                                                                                             |                                                   |
| Dec                             | 4476 | 20860 | 41720 | RW | Minimum position to drive valve in VMD Mode<br>from the valve close limit+1% to 100.0%                                                    |                                                   |
| Hex                             | 117C | 517C  | A2F8  |    |                                                                                                                                           |                                                   |
| Loop 2 Maximum Valve Position   |      |       |       |    | Loop 2 Maximum Valve Position                                                                                                             |                                                   |
| Dec                             | 4477 | 20861 | 41722 | RW | Maximum position to drive valve in VMD Mode.<br>From 0.0% to the valve open limit-1%                                                      |                                                   |
| Hex                             | 117D | 517D  | A2FA  |    |                                                                                                                                           |                                                   |
| Loop 2 PID Set Select           |      |       |       |    | Value                                                                                                                                     | Loop 2 PID Set Selection                          |
| Dec                             | 4467 | 20851 | 41702 | RW | 0                                                                                                                                         | PID Set 1                                         |
| Hex                             | 1173 | 5173  | A2E6  |    | 1                                                                                                                                         | Gain Schedule Selected by SP                      |
|                                 |      |       |       |    | 2                                                                                                                                         | Gain Schedule Selected by PV                      |
|                                 |      |       |       |    | 3                                                                                                                                         | PID Set 2                                         |
|                                 |      |       |       |    | 4                                                                                                                                         | PID Set 3                                         |
|                                 |      |       |       |    | 5                                                                                                                                         | PID Set 4                                         |
|                                 |      |       |       |    | 6                                                                                                                                         | PID Set 5                                         |
| PID Set 2 - Primary Prop Band   |      |       |       |    | PID Set 2 Primary Proportional Band For Loop 2                                                                                            |                                                   |
| Dec                             | 4447 | 20831 | 41662 | RW | Primary Proportional Band for Gain Set 2.<br>1 display unit to 9999 units,<br>but limited to 10 x scaled input span. 0 = On-Off control   |                                                   |
| Hex                             | 115F | 515F  | A2BE  |    |                                                                                                                                           |                                                   |
| PID Set 2 - Secondary Prop Band |      |       |       |    | PID Set 2 Secondary Proportional Band For Loop1                                                                                           |                                                   |
| Dec                             | 4448 | 20832 | 41664 | RW | Secondary Proportional Band for Gain Set 2.<br>1 display unit to 9999 units,<br>but limited to 10 x scaled input span. 0 = On-Off control |                                                   |
| Hex                             | 1160 | 5160  | A2C0  |    |                                                                                                                                           |                                                   |

| PID Set 2 - Integral Time       |      |       |       | PID Set 2 - Integral Time For Loop 2             |                                                                                                                                                 |
|---------------------------------|------|-------|-------|--------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------|
| Dec                             | 4449 | 20833 | 41666 | RW                                               | Gain Set 2 integral time constant for Loop 2<br>0.1 to 5999 Seconds. 0 or 6000 = OFF                                                            |
| Hex                             | 1161 | 5161  | A2C2  |                                                  |                                                                                                                                                 |
| PID Set 2 - Derivative Time     |      |       |       | PID Set 2 - Derivative Time For Loop 2           |                                                                                                                                                 |
| Dec                             | 4450 | 20834 | 41668 | RW                                               | Gain Set 2 derivative time constant for Loop 2<br>0.1 to 5999 Seconds. 0 or 6000 = OFF                                                          |
| Hex                             | 1162 | 5162  | A2C4  |                                                  |                                                                                                                                                 |
| PID Set 2 - Overlap/Deadband    |      |       |       | PID Set 2 - Overlap/Deadband For Loop 2          |                                                                                                                                                 |
| Dec                             | 4451 | 20835 | 41670 | RW                                               | PID Set 2 overlap (+ve) or deadband (-ve) between primary & secondary prop bands. In display units - limited to 20% of the combined band width. |
| Hex                             | 1163 | 5163  | A2C6  |                                                  |                                                                                                                                                 |
| PID Set 2 - On/Off Differential |      |       |       | PID Set 2 - On/Off Differential For Loop 2       |                                                                                                                                                 |
| Dec                             | 4478 | 20862 | 41724 | RW                                               | The on-off control hysteresis (deadband) for PID Set 2.<br>1 to 300 display units, centred about the setpoint.                                  |
| Hex                             | 117E | 517E  | A2FC  |                                                  |                                                                                                                                                 |
| PID Set 3 - Primary Prop Band   |      |       |       | PID Set 3 Primary Proportional Band For Loop 2   |                                                                                                                                                 |
| Dec                             | 4452 | 20836 | 41672 | RW                                               | Primary Proportional Band for Gain Set 3.<br>1 display unit to 9999 units,<br>but limited to 10 x scaled input span. 0 = On-Off control         |
| Hex                             | 1164 | 5164  | A2C8  |                                                  |                                                                                                                                                 |
| PID Set 3 - Secondary Prop Band |      |       |       | PID Set 3 Secondary Proportional Band For Loop 2 |                                                                                                                                                 |
| Dec                             | 4453 | 20837 | 41674 | RW                                               | Secondary Proportional Band for Gain Set 3.<br>1 display unit to 9999 units,<br>but limited to 10 x scaled input span. 0 = On-Off control       |
| Hex                             | 1165 | 5165  | A2CA  |                                                  |                                                                                                                                                 |
| PID Set 3 - Integral Time       |      |       |       | PID Set 3 - Integral Time For Loop 2             |                                                                                                                                                 |
| Dec                             | 4454 | 20838 | 41676 | RW                                               | Gain Set 3 integral time constant for Loop 2<br>0.1 to 5999 Seconds. 0 or 6000 = OFF                                                            |
| Hex                             | 1166 | 5166  | A2CC  |                                                  |                                                                                                                                                 |
| PID Set 3 - Derivative Time     |      |       |       | PID Set 3 - Derivative Time For Loop 2           |                                                                                                                                                 |
| Dec                             | 4455 | 20839 | 41678 | RW                                               | Gain Set 3 derivative time constant for Loop 2<br>0.1 to 5999 Seconds. 0 or 6000 = OFF                                                          |
| Hex                             | 1167 | 5167  | A2CE  |                                                  |                                                                                                                                                 |
| PID Set 3 - Overlap/Deadband    |      |       |       | PID Set 3 - Overlap/Deadband For Loop 2          |                                                                                                                                                 |
| Dec                             | 4456 | 20840 | 41680 | RW                                               | PID Set 3 overlap (+ve) or deadband (-ve) between primary & secondary prop bands. In display units - limited to 20% of the combined band width. |
| Hex                             | 1168 | 5168  | A2D0  |                                                  |                                                                                                                                                 |
| PID Set 3 - On/Off Differential |      |       |       | PID Set 3 - On/Off Differential For Loop 2       |                                                                                                                                                 |
| Dec                             | 4479 | 20863 | 41726 | RW                                               | The on-off control hysteresis (deadband) for PID Set 3.<br>1 to 300 display units, centred about the setpoint.                                  |
| Hex                             | 117F | 517F  | A2FE  |                                                  |                                                                                                                                                 |
| PID Set 4 - Primary Prop Band   |      |       |       | PID Set 4 Primary Proportional Band For Loop 2   |                                                                                                                                                 |
| Dec                             | 4457 | 20841 | 41682 | RW                                               | Primary Proportional Band for Gain Set 4.<br>1 display unit to 9999 units,<br>but limited to 10 x scaled input span. 0 = On-Off control         |
| Hex                             | 1169 | 5169  | A2D2  |                                                  |                                                                                                                                                 |
| PID Set 4 - Secondary Prop Band |      |       |       | PID Set 4 Secondary Proportional Band For Loop 2 |                                                                                                                                                 |
| Dec                             | 4458 | 20842 | 41684 | RW                                               | Secondary Proportional Band for Gain Set 4.<br>1 display unit to 9999 units,<br>but limited to 10 x scaled input span. 0 = On-Off control       |
| Hex                             | 116A | 516A  | A2D4  |                                                  |                                                                                                                                                 |
| PID Set 4 - Integral Time       |      |       |       | PID Set 4 - Integral Time For Loop 2             |                                                                                                                                                 |
| Dec                             | 4459 | 20843 | 41686 | RW                                               | Gain Set 4 integral time constant for Loop 2<br>0.1 to 5999 Seconds. 0 or 6000 = OFF                                                            |
| Hex                             | 116B | 516B  | A2D6  |                                                  |                                                                                                                                                 |
| PID Set 4 - Derivative Time     |      |       |       | PID Set 4 - Derivative Time For Loop 2           |                                                                                                                                                 |
| Dec                             | 4460 | 20844 | 41688 | RW                                               | Gain Set 4 derivative time constant for Loop 2<br>0.1 to 5999 Seconds. 0 or 6000 = OFF                                                          |
| Hex                             | 116C | 516C  | A2D8  |                                                  |                                                                                                                                                 |

|                                 |      |       |       |    |                                                                                                                                                      |  |  |  |  |
|---------------------------------|------|-------|-------|----|------------------------------------------------------------------------------------------------------------------------------------------------------|--|--|--|--|
| PID Set 4 - Overlap/Deadband    |      |       |       |    | PID Set 4 - Overlap/Deadband For Loop 2                                                                                                              |  |  |  |  |
| Dec                             | 4461 | 20845 | 41690 | RW | PID Set 4 overlap (+ve) or deadband (-ve) between primary & secondary prop bands. In display units - limited to 20% of the combined band width.      |  |  |  |  |
| Hex                             | 116D | 516D  | A2DA  |    |                                                                                                                                                      |  |  |  |  |
| PID Set 4 - On/Off Differential |      |       |       |    | PID Set 4 - On/Off Differential For Loop 2                                                                                                           |  |  |  |  |
| Dec                             | 4480 | 20864 | 41728 | RW | The on-off control hysteresis (deadband) for PID Set 4. 1 to 300 display units, centred about the setpoint.                                          |  |  |  |  |
| Hex                             | 1180 | 5180  | A300  |    |                                                                                                                                                      |  |  |  |  |
| PID Set 5 - Primary Prop Band   |      |       |       |    | PID Set 5 Primary Proportional Band For Loop 2                                                                                                       |  |  |  |  |
| Dec                             | 4462 | 20846 | 41692 | RW | Primary Proportional Band for Gain Set 5. 1 display unit to 9999 units, but limited to 10 x scaled input span. 0 = On-Off control                    |  |  |  |  |
| Hex                             | 116E | 516E  | A2DC  |    |                                                                                                                                                      |  |  |  |  |
| PID Set 5 - Secondary Prop Band |      |       |       |    | PID Set 5 Secondary Proportional Band For Loop 2                                                                                                     |  |  |  |  |
| Dec                             | 4463 | 20847 | 41694 | RW | Secondary Proportional Band for Gain Set 5. 1 display unit to 9999 units, but limited to 10 x scaled input span. 0 = On-Off control                  |  |  |  |  |
| Hex                             | 116F | 516F  | A2DE  |    |                                                                                                                                                      |  |  |  |  |
| PID Set 5 - Integral Time       |      |       |       |    | PID Set 5 - Integral Time For Loop 2                                                                                                                 |  |  |  |  |
| Dec                             | 4464 | 20848 | 41696 | RW | Gain Set 5 integral time constant for Loop 2 0.1 to 5999 Seconds. 0 or 6000 = OFF                                                                    |  |  |  |  |
| Hex                             | 1170 | 5170  | A2E0  |    |                                                                                                                                                      |  |  |  |  |
| PID Set 5 - Derivative Time     |      |       |       |    | PID Set 5 - Derivative Time For Loop 2                                                                                                               |  |  |  |  |
| Dec                             | 4465 | 20849 | 41698 | RW | Gain Set 5 derivative time constant for Loop 2 0.1 to 5999 Seconds. 0 or 6000 = OFF                                                                  |  |  |  |  |
| Hex                             | 1171 | 5171  | A2E2  |    |                                                                                                                                                      |  |  |  |  |
| PID Set 5 - Overlap/Deadband    |      |       |       |    | PID Set 5 - Overlap/Deadband For Loop 2                                                                                                              |  |  |  |  |
| Dec                             | 4466 | 20850 | 41700 | RW | PID Set 5 overlap (+ve) or deadband (-ve) between primary & secondary prop bands. In display units - limited to 20% of the combined band width.      |  |  |  |  |
| Hex                             | 1172 | 5172  | A2E4  |    |                                                                                                                                                      |  |  |  |  |
| PID Set 5 - On/Off Differential |      |       |       |    | PID Set 5 - On/Off Differential For Loop 2                                                                                                           |  |  |  |  |
| Dec                             | 4481 | 20865 | 41730 | RW | The on-off control hysteresis (deadband) for PID Set 5. 1 to 300 display units, centred about the setpoint.                                          |  |  |  |  |
| Hex                             | 1181 | 5181  | A302  |    |                                                                                                                                                      |  |  |  |  |
| Loop 2 Gain Set 2 Breakpoint    |      |       |       |    | Gain Scheduling PID Set 1 To 2 Switch Point                                                                                                          |  |  |  |  |
| Dec                             | 4469 | 20853 | 41706 | RW | Value (SP or PV) gain scheduling switches from PID Set 1 to 2. Value between Scaled Input 2 Lower & Upper Limits                                     |  |  |  |  |
| Hex                             | 1175 | 5175  | A2EA  |    |                                                                                                                                                      |  |  |  |  |
| Loop 2 Gain Set 3 Breakpoint    |      |       |       |    | Gain Scheduling PID Set 2 To 3 Switch Point                                                                                                          |  |  |  |  |
| Dec                             | 4470 | 20854 | 41708 | RW | Value (SP or PV) gain scheduling switches from PID Set 2 to 3. Value between Set 2 Breakpoint & Scaled Input 2 Upper Limit.                          |  |  |  |  |
| Hex                             | 1176 | 5176  | A2EC  |    |                                                                                                                                                      |  |  |  |  |
| Loop 2 Gain Set 4 Breakpoint    |      |       |       |    | Gain Scheduling PID Set 3 To 4 Switch Point                                                                                                          |  |  |  |  |
| Dec                             | 4471 | 20855 | 41710 | RW | Value (SP or PV) gain scheduling switches from PID Set 3 to 4. Value between Set 3 Breakpoint & Scaled Input 2 Upper Limit.                          |  |  |  |  |
| Hex                             | 1177 | 5177  | A2EE  |    |                                                                                                                                                      |  |  |  |  |
| Loop 2 Gain Set 5 Breakpoint    |      |       |       |    | Gain Scheduling PID Set 4 To 5 Switch Point                                                                                                          |  |  |  |  |
| Dec                             | 4472 | 20856 | 41712 | RW | Value (SP or PV) gain scheduling switches from PID Set 4 to 5. Value between Set 4 Breakpoint & Scaled Input 2 Upper Limit.                          |  |  |  |  |
| Hex                             | 1178 | 5178  | A2F0  |    |                                                                                                                                                      |  |  |  |  |
| Slave Setpoint Scale Minimum    |      |       |       |    | 0% Master Power Demand to Slave Setpoint Scaling                                                                                                     |  |  |  |  |
| Dec                             | 4485 | 20869 | 41738 | RW | The effective cascade slave setpoint value equating to 0% power demand from the master loop.                                                         |  |  |  |  |
| Hex                             | 1185 | 5185  | A30A  |    |                                                                                                                                                      |  |  |  |  |
| Slave Setpoint Scale Maximum    |      |       |       |    | 100% Master Power Demand to Slave Setpoint Scaling                                                                                                   |  |  |  |  |
| Dec                             | 4486 | 20870 | 41740 | RW | The effective cascade slave setpoint value equating to 100% power demand from the master loop.                                                       |  |  |  |  |
| Hex                             | 1186 | 5186  | A30C  |    |                                                                                                                                                      |  |  |  |  |
| Slave Setpoint                  |      |       |       |    | Slave Setpoint Value for Cascade Control                                                                                                             |  |  |  |  |
| Dec                             | 4492 | 20876 | 41752 | RW | The slave setpoint valve when in Cascade Control Mode. Only write to this parameter if the unit is cascade status is OPEN (e.g. when tuning slave).. |  |  |  |  |
| Hex                             | 118C | 518C  | A318  |    |                                                                                                                                                      |  |  |  |  |

## 20.4.18 Alarm Parameters

| Parameter Name & Register Address |         |        |       |        |                                                                                                                                                    |                                                                                                                      |  |
|-----------------------------------|---------|--------|-------|--------|----------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------|--|
|                                   | Integer | Int +1 | Float | Access | Values                                                                                                                                             | & Descriptions                                                                                                       |  |
| Alarm 1 Input Source              |         |        |       |        | Value                                                                                                                                              | Alarm 1 Source                                                                                                       |  |
| Dec                               | 6143    | 22527  | 45054 | RW     | 0                                                                                                                                                  | Input 1                                                                                                              |  |
| Hex                               | 17FF    | 57FF   | AFFE  |        | 1                                                                                                                                                  | Input 2                                                                                                              |  |
|                                   |         |        |       |        | 2                                                                                                                                                  | Aux A Input                                                                                                          |  |
|                                   |         |        |       |        | 3                                                                                                                                                  | Control Loop 1 Primary Power                                                                                         |  |
|                                   |         |        |       |        | 4                                                                                                                                                  | Control Loop 1 Secondary Power                                                                                       |  |
|                                   |         |        |       |        | 5                                                                                                                                                  | Control Loop 2 Primary Power                                                                                         |  |
|                                   |         |        |       |        | 6                                                                                                                                                  | Control Loop 2 Secondary Power                                                                                       |  |
|                                   |         |        |       |        | 7                                                                                                                                                  | Loop 1                                                                                                               |  |
|                                   |         |        |       |        | 8                                                                                                                                                  | Loop 2                                                                                                               |  |
| Alarm 1 Type                      |         |        |       |        | Value                                                                                                                                              | Alarm 1 Type                                                                                                         |  |
| Dec                               | 6144    | 22528  | 45056 | RW     | 0                                                                                                                                                  | Unused                                                                                                               |  |
| Hex                               | 1800    | 5800   | B000  |        | 1                                                                                                                                                  | Process High Alarm                                                                                                   |  |
|                                   |         |        |       |        | 2                                                                                                                                                  | Process Low Alarm                                                                                                    |  |
|                                   |         |        |       |        | 3                                                                                                                                                  | Deviation Alarm (SP-PV)                                                                                              |  |
|                                   |         |        |       |        | 4                                                                                                                                                  | Band Alarm                                                                                                           |  |
|                                   |         |        |       |        | 5                                                                                                                                                  | Input Rate of Change                                                                                                 |  |
|                                   |         |        |       |        | 6                                                                                                                                                  | Input/Sensor Break Alarm                                                                                             |  |
|                                   |         |        |       |        | 7                                                                                                                                                  | Loop Alarm                                                                                                           |  |
|                                   |         |        |       |        | 10                                                                                                                                                 | % memory used                                                                                                        |  |
|                                   |         |        |       |        | 11                                                                                                                                                 | High Power Alarm                                                                                                     |  |
|                                   |         |        |       |        | 12                                                                                                                                                 | Low Power Alarm                                                                                                      |  |
| Alarm 1 Value                     |         |        |       |        | Value At Which Alarm 1 Activates                                                                                                                   |                                                                                                                      |  |
| Dec                               | 6145    | 22529  | 45058 |        | RW                                                                                                                                                 | Limited by input scaling for alarm types 1 to 4.<br>Not used for alarms 5, 6 or 7.<br>0 to 100% for alarms 10 to 12. |  |
| Hex                               | 1801    | 5801   | B002  |        |                                                                                                                                                    |                                                                                                                      |  |
|                                   |         |        |       |        |                                                                                                                                                    |                                                                                                                      |  |
| Alarm 1 Rate of Change Value      |         |        |       |        | Process Variable Rate of Change Alarm Threshold                                                                                                    |                                                                                                                      |  |
| Dec                               | 6150    | 22534  | 45068 | RW     | Value for Rate of Change Alarm. Alarm 1 activates when PV change exceeds this level. From 0.0 to 99999                                             |                                                                                                                      |  |
| Hex                               | 1806    | 5806   | B00C  |        |                                                                                                                                                    |                                                                                                                      |  |
| Alarm 1 Hysteresis                |         |        |       |        | Alarm 1 Hysteresis Value                                                                                                                           |                                                                                                                      |  |
| Dec                               | 6146    | 22530  | 45060 | RW     | Deadband value ( <i>on “safe” side of alarm</i> ), through which signal must pass before alarm 1 deactivates.<br>Limited by the input scaling span |                                                                                                                      |  |
| Hex                               | 1802    | 5802   | B004  |        |                                                                                                                                                    |                                                                                                                      |  |
| Alarm 1 Inhibit Enable            |         |        |       |        | Value                                                                                                                                              | Alarm 1 Power-up/Setpoint Change Inhibit                                                                             |  |
| Dec                               | 6147    | 22531  | 45062 | RW     | 0                                                                                                                                                  | Disabled                                                                                                             |  |
| Hex                               | 1803    | 5803   | B006  |        | 1                                                                                                                                                  | Enabled                                                                                                              |  |
| Alarm 1 Status                    |         |        |       |        | Value                                                                                                                                              | Alarm 1 Status                                                                                                       |  |
| Dec                               | 6148    | 22532  | 45064 | RO     | 0                                                                                                                                                  | Inactive                                                                                                             |  |
| Hex                               | 1804    | 5804   | B008  |        | 1                                                                                                                                                  | Active                                                                                                               |  |
| Alarm 1 Inhibit Status            |         |        |       |        | Value                                                                                                                                              | Alarm 1 Inhibit Status                                                                                               |  |
| Dec                               | 6149    | 22533  | 45066 | RO     | 0                                                                                                                                                  | Not Inhibited                                                                                                        |  |
| Hex                               | 1805    | 5805   | B00A  |        | 1                                                                                                                                                  | Inhibited                                                                                                            |  |

| Alarm 1 Main Label             |      |       |       |    | Main Language Name For Alarm 1 In Status Screen                                                                                                                                                                                       |                                          |
|--------------------------------|------|-------|-------|----|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|
| Dec                            | 6151 | 22535 | 45070 | RW | 8 ASCII characters replacing the title "Alarm 1" in alarm status screens when main display language is used, read/written with Modbus functions 16 or 23. Valid characters are <b>0 to 9, a to z, A to Z, plus ß ö ( ) - and _</b> .  |                                          |
| Hex                            | 1807 | 5807  | B00E  |    |                                                                                                                                                                                                                                       |                                          |
|                                |      |       |       |    |                                                                                                                                                                                                                                       |                                          |
| Alarm 1 Alternate Label        |      |       |       |    | Alternate Language Name For Alarm 1 In Status Screen                                                                                                                                                                                  |                                          |
| Dec                            | 6152 | 22536 | 45072 | RW | 8 ASCII characters replacing the title "Alarm 1" in alarm status screens when the alternate language is used, read/written with Modbus functions 16 or 23. Valid characters are <b>0 to 9, a to z, A to Z, plus ß ö ( ) - and _</b> . |                                          |
| Hex                            | 1808 | 5808  | B010  |    |                                                                                                                                                                                                                                       |                                          |
|                                |      |       |       |    |                                                                                                                                                                                                                                       |                                          |
| Alarm 1 Minimum Duration       |      |       |       |    | Alarm 1 Minimum Duration                                                                                                                                                                                                              |                                          |
| Dec                            | 6153 | 22537 | 45074 | RW | Minimum time alarm 1 must be passed its threshold before activating (deactivation is not affected by this parameter).<br>From 0 to 9999 secs                                                                                          |                                          |
| Hex                            | 1809 | 5809  | B012  |    |                                                                                                                                                                                                                                       |                                          |
| Alarm 2 Input Source           |      |       |       |    | Value                                                                                                                                                                                                                                 | Source                                   |
| Dec                            | 6159 | 22543 | 45086 | RW | 0                                                                                                                                                                                                                                     | Input 1                                  |
| Hex                            | 180F | 580F  | B01E  |    | 1                                                                                                                                                                                                                                     | Input 2                                  |
|                                |      |       |       |    | 2                                                                                                                                                                                                                                     | Aux A Input                              |
|                                |      |       |       |    | 3                                                                                                                                                                                                                                     | Control Loop 1 Primary Power             |
|                                |      |       |       |    | 4                                                                                                                                                                                                                                     | Control Loop 1 Secondary Power           |
|                                |      |       |       |    | 5                                                                                                                                                                                                                                     | Control Loop 2 Primary Power             |
|                                |      |       |       |    | 6                                                                                                                                                                                                                                     | Control Loop 2 Secondary Power           |
|                                |      |       |       |    | 7                                                                                                                                                                                                                                     | Loop 1                                   |
|                                |      |       |       |    | 8                                                                                                                                                                                                                                     | Loop 2                                   |
| Alarm 2 Type                   |      |       |       |    | Value                                                                                                                                                                                                                                 | Alarm 2 Type                             |
| Dec                            | 6160 | 22544 | 45088 | RW | 0                                                                                                                                                                                                                                     | Unused                                   |
| Hex                            | 1810 | 5810  | B020  |    | 1                                                                                                                                                                                                                                     | Process High Alarm                       |
|                                |      |       |       |    | 2                                                                                                                                                                                                                                     | Process Low Alarm                        |
|                                |      |       |       |    | 3                                                                                                                                                                                                                                     | Deviation Alarm (SP-PV)                  |
|                                |      |       |       |    | 4                                                                                                                                                                                                                                     | Band Alarm                               |
|                                |      |       |       |    | 5                                                                                                                                                                                                                                     | Input Rate of Change                     |
|                                |      |       |       |    | 6                                                                                                                                                                                                                                     | Input/Sensor Break Alarm                 |
|                                |      |       |       |    | 7                                                                                                                                                                                                                                     | Loop Alarm                               |
|                                |      |       |       |    | 10                                                                                                                                                                                                                                    | % memory used                            |
|                                |      |       |       |    | 11                                                                                                                                                                                                                                    | High Power Alarm                         |
|                                |      |       |       |    | 12                                                                                                                                                                                                                                    | Low Power Alarm                          |
| Alarm 2 Value                  |      |       |       |    | Value At Which Alarm 2 Activates                                                                                                                                                                                                      |                                          |
| Dec                            | 6161 | 22545 | 45090 | RW | Limited by input scaling for alarm types 1 to 4.<br>Not used for alarms 5, 6 or 7.<br>0 to 100% for alarms 10 to 12.                                                                                                                  |                                          |
| Hex                            | 1811 | 5811  | B022  |    |                                                                                                                                                                                                                                       |                                          |
|                                |      |       |       |    |                                                                                                                                                                                                                                       |                                          |
| Alarm 2 Rate of Change Value   |      |       |       |    | Process Variable Rate of Change Alarm Threshold                                                                                                                                                                                       |                                          |
| Dec                            | 6166 | 22550 | 45100 | RW | Value for Rate of Change Alarm. Alarm 2 activates when PV change exceeds this level. From 0.0 to 99999                                                                                                                                |                                          |
| Hex                            | 1816 | 5816  | B02C  |    |                                                                                                                                                                                                                                       |                                          |
| Alarm 2 Hysteresis             |      |       |       |    | Alarm 2 Hysteresis Value                                                                                                                                                                                                              |                                          |
| Dec                            | 6162 | 22546 | 45092 | RW | Deadband value (on “safe” side of alarm), through which signal must pass before Alarm 2 deactivates.<br>Limited by the input scaling span                                                                                             |                                          |
| Hex                            | 1812 | 5812  | B024  |    |                                                                                                                                                                                                                                       |                                          |
| Alarm 2 Inhibit Enable/disable |      |       |       |    | Value                                                                                                                                                                                                                                 | Alarm 2 Power-up/Setpoint Change Inhibit |
| Dec                            | 6163 | 22547 | 45094 | RW | 0                                                                                                                                                                                                                                     | Disabled                                 |
| Hex                            | 1813 | 5813  | B026  |    | 1                                                                                                                                                                                                                                     | Enabled                                  |

| Alarm 2 Status           |      |       |       |    | Value                                                                                                                                                                                                                                 | Alarm 2 Status                 |
|--------------------------|------|-------|-------|----|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------|
| Dec                      | 6164 | 22548 | 45096 | RO | 0                                                                                                                                                                                                                                     | Inactive                       |
| Hex                      | 1814 | 5814  | B028  |    | 1                                                                                                                                                                                                                                     | Active                         |
| Alarm 2 Inhibit Status   |      |       |       |    | Value                                                                                                                                                                                                                                 | Alarm 2 Inhibit Status         |
| Dec                      | 6165 | 22549 | 45098 | RO | 0                                                                                                                                                                                                                                     | Not Inhibited                  |
| Hex                      | 1815 | 5815  | B02A  |    | 1                                                                                                                                                                                                                                     | Inhibited                      |
| Alarm 2 Label            |      |       |       |    | Main Language Name for Alarm 2 In Status Screen                                                                                                                                                                                       |                                |
| Dec                      | 6167 | 22551 | 45102 | RW | 8 ASCII characters replacing the title "Alarm 2" in alarm status screens when main display language is used, read/written with Modbus functions 16 or 23. Valid characters are <b>0 to 9, a to z, A to Z, plus ß ö ( ) - and _</b> .  |                                |
| Hex                      | 1817 | 5817  | B02E  |    |                                                                                                                                                                                                                                       |                                |
|                          |      |       |       |    |                                                                                                                                                                                                                                       |                                |
| Alarm 2 Alternate Label  |      |       |       |    | Alternate Language Name for Alarm 2 In Status Screen                                                                                                                                                                                  |                                |
| Dec                      | 6168 | 22552 | 45104 | RW | 8 ASCII characters replacing the title "Alarm 2" in alarm status screens when the alternate language is used, read/written with Modbus functions 16 or 23. Valid characters are <b>0 to 9, a to z, A to Z, plus ß ö ( ) - and _</b> . |                                |
| Hex                      | 1818 | 5818  | B030  |    |                                                                                                                                                                                                                                       |                                |
|                          |      |       |       |    |                                                                                                                                                                                                                                       |                                |
| Alarm 2 Minimum Duration |      |       |       |    | Alarm 2 Minimum Duration                                                                                                                                                                                                              |                                |
| Dec                      | 6169 | 22553 | 45106 | RW | Minimum time alarm 2 must be passed its threshold before activating (deactivation is not affected by this parameter).<br>From 0 to 9999 secs                                                                                          |                                |
| Hex                      | 1819 | 5819  | B032  |    |                                                                                                                                                                                                                                       |                                |
| Alarm 3 Input Source     |      |       |       |    | Value                                                                                                                                                                                                                                 | Source                         |
| Dec                      | 6175 | 22559 | 45118 | RW | 0                                                                                                                                                                                                                                     | Input 1                        |
| Hex                      | 181F | 581F  | B03E  |    | 1                                                                                                                                                                                                                                     | Input 2                        |
|                          |      |       |       |    | 2                                                                                                                                                                                                                                     | Aux A Input                    |
|                          |      |       |       |    | 3                                                                                                                                                                                                                                     | Control Loop 1 Primary Power   |
|                          |      |       |       |    | 4                                                                                                                                                                                                                                     | Control Loop 1 Secondary Power |
|                          |      |       |       |    | 5                                                                                                                                                                                                                                     | Control Loop 2 Primary Power   |
|                          |      |       |       |    | 6                                                                                                                                                                                                                                     | Control Loop 2 Secondary Power |
|                          |      |       |       |    | 7                                                                                                                                                                                                                                     | Loop 1                         |
|                          |      |       |       |    | 8                                                                                                                                                                                                                                     | Loop 2                         |
| Alarm 3 Type             |      |       |       |    | Value                                                                                                                                                                                                                                 | Alarm 3 Type                   |
| Dec                      | 6176 | 22560 | 45120 | RW | 0                                                                                                                                                                                                                                     | Unused                         |
| Hex                      | 1820 | 5820  | B040  |    | 1                                                                                                                                                                                                                                     | Process High Alarm             |
|                          |      |       |       |    | 2                                                                                                                                                                                                                                     | Process Low Alarm              |
|                          |      |       |       |    | 3                                                                                                                                                                                                                                     | Deviation Alarm (SP-PV)        |
|                          |      |       |       |    | 4                                                                                                                                                                                                                                     | Band Alarm                     |
|                          |      |       |       |    | 5                                                                                                                                                                                                                                     | Input Rate of Change           |
|                          |      |       |       |    | 6                                                                                                                                                                                                                                     | Input/Sensor Break Alarm       |
|                          |      |       |       |    | 7                                                                                                                                                                                                                                     | Loop Alarm                     |
|                          |      |       |       |    | 10                                                                                                                                                                                                                                    | % memory used                  |
|                          |      |       |       |    | 11                                                                                                                                                                                                                                    | High Power Alarm               |
|                          |      |       |       |    | 12                                                                                                                                                                                                                                    | Low Power Alarm                |

| Alarm 3 Value                  |      |       |       | Value At Which Alarm 3 Activates                     |                                                                                                                                                                                                                                       |               |
|--------------------------------|------|-------|-------|------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| Dec                            | 6177 | 22561 | 45122 | RW                                                   | Limited by input scaling for alarm types 1 to 4.<br>Not used for alarms 5, 6 or 7.<br>0 to 100% for alarms 10 to 12.                                                                                                                  |               |
| Hex                            | 1821 | 5821  | B042  |                                                      |                                                                                                                                                                                                                                       |               |
|                                |      |       |       |                                                      |                                                                                                                                                                                                                                       |               |
| Alarm 3 Rate of Change Value   |      |       |       | Process Variable Rate of Change Alarm Threshold      |                                                                                                                                                                                                                                       |               |
| Dec                            | 6182 | 22566 | 45132 | RW                                                   | Value for Rate of Change Alarm. Alarm 3 activates when PV change exceeds this level. From 0.0 to 99999                                                                                                                                |               |
| Hex                            | 1826 | 5826  | B04C  |                                                      |                                                                                                                                                                                                                                       |               |
|                                |      |       |       |                                                      |                                                                                                                                                                                                                                       |               |
| Alarm 3 Hysteresis             |      |       |       | Alarm 3 Hysteresis Value                             |                                                                                                                                                                                                                                       |               |
| Dec                            | 6178 | 22562 | 45124 | RW                                                   | Deadband value (on “safe” side of alarm), through which signal must pass before Alarm 3 deactivates.<br>Limited by the input scaling span                                                                                             |               |
| Hex                            | 1822 | 5822  | B044  |                                                      |                                                                                                                                                                                                                                       |               |
|                                |      |       |       |                                                      |                                                                                                                                                                                                                                       |               |
| Alarm 3 Inhibit Enable/disable |      |       |       | Value                                                | Alarm 3 Power-up/Setpoint Change Inhibit                                                                                                                                                                                              |               |
| Dec                            | 6179 | 22563 | 45126 | RW                                                   | 0                                                                                                                                                                                                                                     | Disabled      |
| Hex                            | 1823 | 5823  | B046  |                                                      | 1                                                                                                                                                                                                                                     | Enabled       |
|                                |      |       |       |                                                      |                                                                                                                                                                                                                                       |               |
| Alarm 3 Status                 |      |       |       | Value                                                | Alarm 3 Status                                                                                                                                                                                                                        |               |
| Dec                            | 6180 | 22564 | 45128 | RO                                                   | 0                                                                                                                                                                                                                                     | Inactive      |
| Hex                            | 1824 | 5824  | B048  |                                                      | 1                                                                                                                                                                                                                                     | Active        |
|                                |      |       |       |                                                      |                                                                                                                                                                                                                                       |               |
| Alarm 3 Inhibit Status         |      |       |       | Value                                                | Alarm 3 Inhibit Status                                                                                                                                                                                                                |               |
| Dec                            | 6181 | 22565 | 45130 | RO                                                   | 0                                                                                                                                                                                                                                     | Not Inhibited |
| Hex                            | 1825 | 5825  | B04A  |                                                      | 1                                                                                                                                                                                                                                     | Inhibited     |
|                                |      |       |       |                                                      |                                                                                                                                                                                                                                       |               |
| Alarm 3 Label                  |      |       |       | Main Language Name For Alarm 3 In Status Screen      |                                                                                                                                                                                                                                       |               |
| Dec                            | 6183 | 22567 | 45134 | RW                                                   | 8 ASCII characters replacing the title "Alarm 3" in alarm status screens when main display language is used, read/written with Modbus functions 16 or 23. Valid characters are <b>0 to 9, a to z, A to Z, plus ß ö ( ) - and _</b> .  |               |
| Hex                            | 1827 | 5827  | B04E  |                                                      |                                                                                                                                                                                                                                       |               |
|                                |      |       |       |                                                      |                                                                                                                                                                                                                                       |               |
| Alarm 3 Alternate Label        |      |       |       | Alternate Language Name For Alarm 3 In Status Screen |                                                                                                                                                                                                                                       |               |
| Dec                            | 6184 | 22568 | 45136 | RW                                                   | 8 ASCII characters replacing the title "Alarm 3" in alarm status screens when the alternate language is used, read/written with Modbus functions 16 or 23. Valid characters are <b>0 to 9, a to z, A to Z, plus ß ö ( ) - and _</b> . |               |
| Hex                            | 1828 | 5828  | B050  |                                                      |                                                                                                                                                                                                                                       |               |
|                                |      |       |       |                                                      |                                                                                                                                                                                                                                       |               |
| Alarm 3 Minimum Duration       |      |       |       | Alarm 3 Minimum Duration                             |                                                                                                                                                                                                                                       |               |
| Dec                            | 6185 | 22569 | 45138 | RW                                                   | Minimum time alarm 3 must be passed its threshold before activating (deactivation is not affected by this parameter).<br>From 0 to 9999 secs                                                                                          |               |
| Hex                            | 1829 | 5829  | B052  |                                                      |                                                                                                                                                                                                                                       |               |
|                                |      |       |       |                                                      |                                                                                                                                                                                                                                       |               |
| Alarm 4 Input Source           |      |       |       | Value                                                | Source                                                                                                                                                                                                                                |               |
| Dec                            | 6191 | 22575 | 45150 | RW                                                   | 0                                                                                                                                                                                                                                     | Input 1       |
| Hex                            | 182F | 582F  | B05E  |                                                      | 1                                                                                                                                                                                                                                     | Input 2       |
|                                |      |       | 2     |                                                      | Aux A Input                                                                                                                                                                                                                           |               |
|                                |      |       | 3     |                                                      | Control Loop 1 Primary Power                                                                                                                                                                                                          |               |
|                                |      |       | 4     |                                                      | Control Loop 1 Secondary Power                                                                                                                                                                                                        |               |
|                                |      |       | 5     |                                                      | Control Loop 2 Primary Power                                                                                                                                                                                                          |               |
|                                |      |       | 6     |                                                      | Control Loop 2 Secondary Power                                                                                                                                                                                                        |               |
|                                |      |       | 7     |                                                      | Loop 1                                                                                                                                                                                                                                |               |
|                                |      |       | 8     |                                                      | Loop 2                                                                                                                                                                                                                                |               |

| Alarm 4 Type                   |      |       |       |    | Value                                                                                                                                                                                                                                 | Alarm 4 Type                             |
|--------------------------------|------|-------|-------|----|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|
| Dec                            | 6192 | 22576 | 45152 | RW | 0                                                                                                                                                                                                                                     | Unused                                   |
| Hex                            | 1830 | 5830  | B060  |    | 1                                                                                                                                                                                                                                     | Process High Alarm                       |
|                                |      |       |       |    | 2                                                                                                                                                                                                                                     | Process Low Alarm                        |
|                                |      |       |       |    | 3                                                                                                                                                                                                                                     | Deviation Alarm (SP-PV)                  |
|                                |      |       |       |    | 4                                                                                                                                                                                                                                     | Band Alarm                               |
|                                |      |       |       |    | 5                                                                                                                                                                                                                                     | Input Rate of Change                     |
|                                |      |       |       |    | 6                                                                                                                                                                                                                                     | Input/Sensor Break Alarm                 |
|                                |      |       |       |    | 7                                                                                                                                                                                                                                     | Loop Alarm                               |
|                                |      |       |       |    | 10                                                                                                                                                                                                                                    | % memory used                            |
|                                |      |       |       |    | 11                                                                                                                                                                                                                                    | High Power Alarm                         |
|                                |      |       |       |    | 12                                                                                                                                                                                                                                    | Low Power Alarm                          |
|                                |      |       |       |    |                                                                                                                                                                                                                                       |                                          |
| Alarm 4 Value                  |      |       |       |    | Value At Which Alarm 4 Activates                                                                                                                                                                                                      |                                          |
| Dec                            | 6193 | 22577 | 45154 | RW | Limited by input scaling for alarm types 1 to 4.<br>Not used for alarms 5, 6 or 7.<br>0 to 100% for alarms 10 to 12.                                                                                                                  |                                          |
| Hex                            | 1831 | 5831  | B062  |    |                                                                                                                                                                                                                                       |                                          |
|                                |      |       |       |    |                                                                                                                                                                                                                                       |                                          |
| Alarm 4 Rate of Change Value   |      |       |       |    | Process Variable Rate of Change Alarm Threshold                                                                                                                                                                                       |                                          |
| Dec                            | 6198 | 22582 | 45164 | RW | Value for Rate of Change Alarm. Alarm 4 activates when PV change exceeds this level. From 0.0 to 99999                                                                                                                                |                                          |
| Hex                            | 1836 | 5836  | B06C  |    |                                                                                                                                                                                                                                       |                                          |
| Alarm 4 Hysteresis             |      |       |       |    | Alarm 4 Hysteresis Value                                                                                                                                                                                                              |                                          |
| Dec                            | 6194 | 22578 | 45156 | RW | Deadband value (on “safe” side of alarm), through which signal must pass before Alarm 4 deactivates.<br>Limited by the input scaling span                                                                                             |                                          |
| Hex                            | 1832 | 5832  | B064  |    |                                                                                                                                                                                                                                       |                                          |
| Alarm 4 Inhibit Enable/disable |      |       |       |    | Value                                                                                                                                                                                                                                 | Alarm 4 Power-up/Setpoint Change Inhibit |
| Dec                            | 6195 | 22579 | 45158 | RW | 0                                                                                                                                                                                                                                     | Disabled                                 |
| Hex                            | 1833 | 5833  | B066  |    | 1                                                                                                                                                                                                                                     | Enabled                                  |
| Alarm 4 Status                 |      |       |       |    | Value                                                                                                                                                                                                                                 | Alarm 4 Status                           |
| Dec                            | 6196 | 22580 | 45160 | RO | 0                                                                                                                                                                                                                                     | Inactive                                 |
| Hex                            | 1834 | 5834  | B068  |    | 1                                                                                                                                                                                                                                     | Active                                   |
| Alarm 4 Inhibit Status         |      |       |       |    | Value                                                                                                                                                                                                                                 | Alarm 4 Inhibit Status                   |
| Dec                            | 6197 | 22581 | 45162 | RO | 0                                                                                                                                                                                                                                     | Not Inhibited                            |
| Hex                            | 1835 | 5835  | B06A  |    | 1                                                                                                                                                                                                                                     | Inhibited                                |
| Alarm 4 Label                  |      |       |       |    | Main Language Name For Alarm 4 In Status Screen                                                                                                                                                                                       |                                          |
| Dec                            | 6199 | 22583 | 45166 | RW | 8 ASCII characters replacing the title "Alarm 4" in alarm status screens when main display language is used, read/written with Modbus functions 16 or 23. Valid characters are <b>0 to 9, a to z, A to Z, plus ß ö ( ) - and _</b> .  |                                          |
| Hex                            | 1837 | 5837  | B06E  |    |                                                                                                                                                                                                                                       |                                          |
|                                |      |       |       |    |                                                                                                                                                                                                                                       |                                          |
| Alarm 4 Alternate Label        |      |       |       |    | Alternate Language Name For Alarm 4 In Status Screen                                                                                                                                                                                  |                                          |
| Dec                            | 6200 | 22584 | 45168 | RW | 8 ASCII characters replacing the title "Alarm 4" in alarm status screens when the alternate language is used, read/written with Modbus functions 16 or 23. Valid characters are <b>0 to 9, a to z, A to Z, plus ß ö ( ) - and _</b> . |                                          |
| Hex                            | 1838 | 5838  | B070  |    |                                                                                                                                                                                                                                       |                                          |
|                                |      |       |       |    |                                                                                                                                                                                                                                       |                                          |
| Alarm 4 Minimum Duration       |      |       |       |    | Alarm 4 Minimum Duration                                                                                                                                                                                                              |                                          |
| Dec                            | 6201 | 22585 | 45170 | RW | Minimum time alarm 4 must be passed its threshold before activating (deactivation is not affected by this parameter).<br>From 0 to 9999 secs                                                                                          |                                          |
| Hex                            | 1839 | 5839  | B072  |    |                                                                                                                                                                                                                                       |                                          |

| Alarm 5 Input Source           |      |       |       |    | Value                                                                                                                                                                                                                                | Source                                                                                                               |  |
|--------------------------------|------|-------|-------|----|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------|--|
| Dec                            | 6207 | 22591 | 45182 | RW | 0                                                                                                                                                                                                                                    | Input 1                                                                                                              |  |
| Hex                            | 183F | 583F  | B07E  |    | 1                                                                                                                                                                                                                                    | Input 2                                                                                                              |  |
|                                |      |       |       |    | 2                                                                                                                                                                                                                                    | Aux A Input                                                                                                          |  |
|                                |      |       |       |    | 3                                                                                                                                                                                                                                    | Control Loop 1 Primary Power                                                                                         |  |
|                                |      |       |       |    | 4                                                                                                                                                                                                                                    | Control Loop 1 Secondary Power                                                                                       |  |
|                                |      |       |       |    | 5                                                                                                                                                                                                                                    | Control Loop 2 Primary Power                                                                                         |  |
|                                |      |       |       |    | 6                                                                                                                                                                                                                                    | Control Loop 2 Secondary Power                                                                                       |  |
|                                |      |       |       |    | 7                                                                                                                                                                                                                                    | Loop 1                                                                                                               |  |
|                                |      |       |       |    | 8                                                                                                                                                                                                                                    | Loop 2                                                                                                               |  |
| Alarm 5 Type                   |      |       |       |    | Value                                                                                                                                                                                                                                | Alarm 5 Type                                                                                                         |  |
| Dec                            | 6208 | 22592 | 45184 | RW | 0                                                                                                                                                                                                                                    | Unused                                                                                                               |  |
| Hex                            | 1840 | 5840  | B080  |    | 1                                                                                                                                                                                                                                    | Process High Alarm                                                                                                   |  |
|                                |      |       |       |    | 2                                                                                                                                                                                                                                    | Process Low Alarm                                                                                                    |  |
|                                |      |       |       |    | 3                                                                                                                                                                                                                                    | Deviation Alarm (SP-PV)                                                                                              |  |
|                                |      |       |       |    | 4                                                                                                                                                                                                                                    | Band Alarm                                                                                                           |  |
|                                |      |       |       |    | 5                                                                                                                                                                                                                                    | Input Rate of Change                                                                                                 |  |
|                                |      |       |       |    | 6                                                                                                                                                                                                                                    | Input/Sensor Break Alarm                                                                                             |  |
|                                |      |       |       |    | 7                                                                                                                                                                                                                                    | Loop Alarm                                                                                                           |  |
|                                |      |       |       |    | 10                                                                                                                                                                                                                                   | % memory used                                                                                                        |  |
|                                |      |       |       |    | 11                                                                                                                                                                                                                                   | High Power Alarm                                                                                                     |  |
|                                |      |       |       |    | 12                                                                                                                                                                                                                                   | Low Power Alarm                                                                                                      |  |
| Alarm 5 Value                  |      |       |       |    | Value At Which Alarm 5 Activates                                                                                                                                                                                                     |                                                                                                                      |  |
| Dec                            | 6209 | 22593 | 45186 |    | RW                                                                                                                                                                                                                                   | Limited by input scaling for alarm types 1 to 4.<br>Not used for alarms 5, 6 or 7.<br>0 to 100% for alarms 10 to 12. |  |
| Hex                            | 1841 | 5841  | B082  |    |                                                                                                                                                                                                                                      |                                                                                                                      |  |
|                                |      |       |       |    |                                                                                                                                                                                                                                      |                                                                                                                      |  |
| Alarm 5 Rate of Change Value   |      |       |       |    | Process Variable Rate of Change Alarm Threshold                                                                                                                                                                                      |                                                                                                                      |  |
| Dec                            | 6214 | 22598 | 45196 | RW | Value for Rate of Change Alarm. Alarm 5 activates when PV change exceeds this level. From 0.0 to 99999                                                                                                                               |                                                                                                                      |  |
| Hex                            | 1846 | 5846  | B08C  |    |                                                                                                                                                                                                                                      |                                                                                                                      |  |
| Alarm 5 Hysteresis             |      |       |       |    | Alarm 5 Hysteresis Value                                                                                                                                                                                                             |                                                                                                                      |  |
| Dec                            | 6210 | 22594 | 45188 | RW | Deadband value (on “safe” side of alarm), through which signal must pass before Alarm 5 deactivates.<br>Limited by the input scaling span                                                                                            |                                                                                                                      |  |
| Hex                            | 1842 | 5842  | B084  |    |                                                                                                                                                                                                                                      |                                                                                                                      |  |
| Alarm 5 Inhibit Enable/disable |      |       |       |    | Value                                                                                                                                                                                                                                | Alarm 5 Power-up/Setpoint Change Inhibit                                                                             |  |
| Dec                            | 6211 | 22595 | 45190 | RW | 0                                                                                                                                                                                                                                    | Disabled                                                                                                             |  |
| Hex                            | 1843 | 5843  | B086  |    | 1                                                                                                                                                                                                                                    | Enabled                                                                                                              |  |
| Alarm 5 Status                 |      |       |       |    | Value                                                                                                                                                                                                                                | Alarm 5 Status                                                                                                       |  |
| Dec                            | 6212 | 22596 | 45192 | RO | 0                                                                                                                                                                                                                                    | Inactive                                                                                                             |  |
| Hex                            | 1844 | 5844  | B088  |    | 1                                                                                                                                                                                                                                    | Active                                                                                                               |  |
| Alarm 5 Inhibit Status         |      |       |       |    | Value                                                                                                                                                                                                                                | Alarm 5 Inhibit Status                                                                                               |  |
| Dec                            | 6213 | 22597 | 45194 | RO | 0                                                                                                                                                                                                                                    | Not Inhibited                                                                                                        |  |
| Hex                            | 1845 | 5845  | B08A  |    | 1                                                                                                                                                                                                                                    | Inhibited                                                                                                            |  |
| Alarm 5 Label                  |      |       |       |    | Main Language Name For Alarm 5 In Status Screen                                                                                                                                                                                      |                                                                                                                      |  |
| Dec                            | 6215 | 22599 | 45198 | RW | 8 ASCII characters replacing the title "Alarm 5" in alarm status screens when main display language is used, read/written with Modbus functions 16 or 23. Valid characters are <b>0 to 9, a to z, A to Z, plus ß ö ( ) - and _</b> . |                                                                                                                      |  |
| Hex                            | 1847 | 5847  | B08E  |    |                                                                                                                                                                                                                                      |                                                                                                                      |  |

| Alarm 5 Alternate Label        |      |       |       |    | Alternate Language Name For Alarm 5 In Status Screen                                                                                                                                                                                  |                                          |
|--------------------------------|------|-------|-------|----|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|
| Dec                            | 6216 | 22600 | 45200 | RW | 8 ASCII characters replacing the title "Alarm 5" in alarm status screens when the alternate language is used, read/written with Modbus functions 16 or 23. Valid characters are <b>0 to 9, a to z, A to Z, plus ß ö ( ) - and _</b> . |                                          |
| Hex                            | 1848 | 5848  | B090  |    |                                                                                                                                                                                                                                       |                                          |
| Alarm 5 Minimum Duration       |      |       |       |    | Alarm 5 Minimum Duration                                                                                                                                                                                                              |                                          |
| Dec                            | 6217 | 22601 | 45202 | RW | Minimum time alarm 5 must be passed its threshold before activating (deactivation is not affected by this parameter).<br>From 0 to 9999 secs                                                                                          |                                          |
| Hex                            | 1849 | 5849  | B092  |    |                                                                                                                                                                                                                                       |                                          |
| Alarm 6 Input Source           |      |       |       |    | Value                                                                                                                                                                                                                                 | Source                                   |
| Dec                            | 6223 | 22607 | 45214 | RW | 0                                                                                                                                                                                                                                     | Input 1                                  |
| Hex                            | 184F | 584F  | B09E  |    | 1                                                                                                                                                                                                                                     | Input 2                                  |
|                                |      |       |       |    | 2                                                                                                                                                                                                                                     | Aux A Input                              |
|                                |      |       |       |    | 3                                                                                                                                                                                                                                     | Control Loop 1 Primary Power             |
|                                |      |       |       |    | 4                                                                                                                                                                                                                                     | Control Loop 1 Secondary Power           |
|                                |      |       |       |    | 5                                                                                                                                                                                                                                     | Control Loop 2 Primary Power             |
|                                |      |       |       |    | 6                                                                                                                                                                                                                                     | Control Loop 2 Secondary Power           |
|                                |      |       |       |    | 7                                                                                                                                                                                                                                     | Loop 1                                   |
|                                |      |       |       | 8  | Loop 2                                                                                                                                                                                                                                |                                          |
| Alarm 5 Type                   |      |       |       |    | Value                                                                                                                                                                                                                                 | Alarm 5 Type                             |
| Dec                            | 6224 | 22608 | 45216 | RW | 0                                                                                                                                                                                                                                     | Unused                                   |
| Hex                            | 1850 | 5850  | B0A0  |    | 1                                                                                                                                                                                                                                     | Process High Alarm                       |
|                                |      |       |       |    | 2                                                                                                                                                                                                                                     | Process Low Alarm                        |
|                                |      |       |       |    | 3                                                                                                                                                                                                                                     | Deviation Alarm (SP-PV)                  |
|                                |      |       |       |    | 4                                                                                                                                                                                                                                     | Band Alarm                               |
|                                |      |       |       |    | 5                                                                                                                                                                                                                                     | Input Rate of Change                     |
|                                |      |       |       |    | 6                                                                                                                                                                                                                                     | Input/Sensor Break Alarm                 |
|                                |      |       |       |    | 7                                                                                                                                                                                                                                     | Loop Alarm                               |
|                                |      |       |       |    | 10                                                                                                                                                                                                                                    | % memory used                            |
|                                |      |       |       |    | 11                                                                                                                                                                                                                                    | High Power Alarm                         |
|                                |      |       |       |    | 12                                                                                                                                                                                                                                    | Low Power Alarm                          |
|                                |      |       |       |    |                                                                                                                                                                                                                                       |                                          |
| Alarm 6 Value                  |      |       |       |    | Value At Which Alarm 6 Activates                                                                                                                                                                                                      |                                          |
| Dec                            | 6225 | 22609 | 45218 | RW | Limited by input scaling for alarm types 1 to 4.<br>Not used for alarms 5, 6 or 7.<br>0 to 100% for alarms 10 to 12.                                                                                                                  |                                          |
| Hex                            | 1851 | 5851  | B0A2  |    |                                                                                                                                                                                                                                       |                                          |
|                                |      |       |       |    |                                                                                                                                                                                                                                       |                                          |
| Alarm 6 Rate of Change Value   |      |       |       |    | Process Variable Rate of Change Alarm Threshold                                                                                                                                                                                       |                                          |
| Dec                            | 6230 | 22614 | 45228 | RW | Value for Rate of Change Alarm. Alarm 6 activates when PV change exceeds this level. From 0.0 to 99999                                                                                                                                |                                          |
| Hex                            | 1856 | 5856  | B0AC  |    |                                                                                                                                                                                                                                       |                                          |
| Alarm 6 Hysteresis             |      |       |       |    | Alarm 6 Hysteresis Value                                                                                                                                                                                                              |                                          |
| Dec                            | 6226 | 22610 | 45220 | RW | Deadband value (on “safe” side of alarm), through which signal must pass before Alarm 6 deactivates.<br>Limited by the input scaling span                                                                                             |                                          |
| Hex                            | 1852 | 5852  | B0A4  |    |                                                                                                                                                                                                                                       |                                          |
| Alarm 6 Inhibit Enable/disable |      |       |       |    | Value                                                                                                                                                                                                                                 | Alarm 6 Power-up/Setpoint Change Inhibit |
| Dec                            | 6227 | 22611 | 45222 | RW | 0                                                                                                                                                                                                                                     | Disabled                                 |
| Hex                            | 1853 | 5853  | B0A6  |    | 1                                                                                                                                                                                                                                     | Enabled                                  |
| Alarm 6 Status                 |      |       |       |    | Value                                                                                                                                                                                                                                 | Alarm 6 Status                           |
| Dec                            | 6228 | 22612 | 45224 | RO | 0                                                                                                                                                                                                                                     | Inactive                                 |
| Hex                            | 1854 | 5854  | B0A8  |    | 1                                                                                                                                                                                                                                     | Active                                   |

| Alarm 6 Inhibit Status       |      |       |       |    | Value                                                                                                                                                                                                                                | Alarm 6 Inhibit Status         |
|------------------------------|------|-------|-------|----|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------|
| Dec                          | 6229 | 22613 | 45226 | RO | 0                                                                                                                                                                                                                                    | Not Inhibited                  |
| Hex                          | 1855 | 5855  | B0AA  |    | 1                                                                                                                                                                                                                                    | Inhibited                      |
| Alarm 6 Label                |      |       |       |    | Main Language Name For Alarm 6 In Status Screen                                                                                                                                                                                      |                                |
| Dec                          | 6231 | 22615 | 45230 | RW | 8 ASCII characters replacing the title "Alarm 6" in alarm status screens when main display language is used, read/written with Modbus functions 16 or 23. Valid characters are <b>0 to 9, a to z, A to Z, plus ß ö ( ) - and _.</b>  |                                |
| Hex                          | 1857 | 5857  | B0AE  |    |                                                                                                                                                                                                                                      |                                |
| Alarm 6 Alternate Label      |      |       |       |    | Alternate Language Name For Alarm 6 In Status Screen                                                                                                                                                                                 |                                |
| Dec                          | 6232 | 22616 | 45232 | RW | 8 ASCII characters replacing the title "Alarm 6" in alarm status screens when the alternate language is used, read/written with Modbus functions 16 or 23. Valid characters are <b>0 to 9, a to z, A to Z, plus ß ö ( ) - and _.</b> |                                |
| Hex                          | 1858 | 5858  | B0B0  |    |                                                                                                                                                                                                                                      |                                |
| Alarm 6 Minimum Duration     |      |       |       |    | Alarm 6 Minimum Duration                                                                                                                                                                                                             |                                |
| Dec                          | 6233 | 22617 | 45234 | RW | Minimum time alarm 6 must be passed its threshold before activating (deactivation is not affected by this parameter).<br>From 0 to 9999 secs                                                                                         |                                |
| Hex                          | 1859 | 5859  | B0B2  |    |                                                                                                                                                                                                                                      |                                |
| Alarm 7 Input Source         |      |       |       |    | Value                                                                                                                                                                                                                                | Source                         |
| Dec                          | 6239 | 22623 | 45246 | RW | 0                                                                                                                                                                                                                                    | Input 1                        |
| Hex                          | 185F | 585F  | B0BE  |    | 1                                                                                                                                                                                                                                    | Input 2                        |
|                              |      |       |       |    | 2                                                                                                                                                                                                                                    | Aux A Input                    |
|                              |      |       |       |    | 3                                                                                                                                                                                                                                    | Control Loop 1 Primary Power   |
|                              |      |       |       |    | 4                                                                                                                                                                                                                                    | Control Loop 1 Secondary Power |
|                              |      |       |       |    | 5                                                                                                                                                                                                                                    | Control Loop 2 Primary Power   |
|                              |      |       |       |    | 6                                                                                                                                                                                                                                    | Control Loop 2 Secondary Power |
|                              |      |       |       |    | 7                                                                                                                                                                                                                                    | Loop 1                         |
|                              |      |       |       |    | 8                                                                                                                                                                                                                                    | Loop 2                         |
| Alarm 7 Type                 |      |       |       |    | Value                                                                                                                                                                                                                                | Alarm 7 Type                   |
| Dec                          | 6240 | 22624 | 45248 | RW | 0                                                                                                                                                                                                                                    | Unused                         |
| Hex                          | 1860 | 5860  | B0C0  |    | 1                                                                                                                                                                                                                                    | Process High Alarm             |
|                              |      |       |       |    | 2                                                                                                                                                                                                                                    | Process Low Alarm              |
|                              |      |       |       |    | 3                                                                                                                                                                                                                                    | Deviation Alarm (SP-PV)        |
|                              |      |       |       |    | 4                                                                                                                                                                                                                                    | Band Alarm                     |
|                              |      |       |       |    | 5                                                                                                                                                                                                                                    | Input Rate of Change           |
|                              |      |       |       |    | 6                                                                                                                                                                                                                                    | Input/Sensor Break Alarm       |
|                              |      |       |       |    | 7                                                                                                                                                                                                                                    | Loop Alarm                     |
|                              |      |       |       |    | 10                                                                                                                                                                                                                                   | % memory used                  |
|                              |      |       |       |    | 11                                                                                                                                                                                                                                   | High Power Alarm               |
|                              |      |       |       |    | 12                                                                                                                                                                                                                                   | Low Power Alarm                |
|                              |      |       |       |    |                                                                                                                                                                                                                                      |                                |
| Alarm 7 Value                |      |       |       |    | Value At Which Alarm 7 Activates                                                                                                                                                                                                     |                                |
| Dec                          | 6241 | 22625 | 45250 | RW | Limited by input scaling for alarm types 1 to 4.<br>Not used for alarms 5, 6 or 7.<br>0 to 100% for alarms 10 to 12.                                                                                                                 |                                |
| Hex                          | 1861 | 5861  | B0C2  |    |                                                                                                                                                                                                                                      |                                |
|                              |      |       |       |    |                                                                                                                                                                                                                                      |                                |
| Alarm 7 Rate of Change Value |      |       |       |    | Process Variable Rate of Change Alarm Threshold                                                                                                                                                                                      |                                |
| Dec                          | 6246 | 22630 | 45260 | RW | Value for Rate of Change Alarm. Alarm 7 activates when PV change exceeds this level. From 0.0 to 99999                                                                                                                               |                                |
| Hex                          | 1866 | 5866  | B0CC  |    |                                                                                                                                                                                                                                      |                                |
|                              |      |       |       |    |                                                                                                                                                                                                                                      |                                |
| Alarm 7 Hysteresis           |      |       |       |    | Alarm 7 Hysteresis Value                                                                                                                                                                                                             |                                |
| Dec                          | 6242 | 22626 | 45252 | RW | Deadband value (on “safe” side of alarm), through which signal must pass before Alarm 7 deactivates.<br>Limited by the input scaling span                                                                                            |                                |
| Hex                          | 1862 | 5862  | B0C4  |    |                                                                                                                                                                                                                                      |                                |

| Alarm 7 Inhibit Enable/disable |      |       |       | Value                                                | Alarm 7 Power-up/Setpoint Change Inhibit                                                                                                                                                                                              |
|--------------------------------|------|-------|-------|------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Dec                            | 6243 | 22627 | 45254 | RW                                                   | 0 Disabled                                                                                                                                                                                                                            |
| Hex                            | 1863 | 5863  | B0C6  |                                                      | 1 Enabled                                                                                                                                                                                                                             |
| Alarm 7 Status                 |      |       |       | Value                                                | Alarm 7 Status                                                                                                                                                                                                                        |
| Dec                            | 6244 | 22628 | 45256 | RO                                                   | 0 Inactive                                                                                                                                                                                                                            |
| Hex                            | 1864 | 5864  | B0C8  |                                                      | 1 Active                                                                                                                                                                                                                              |
| Alarm 7 Inhibit Status         |      |       |       | Value                                                | Alarm 7 Inhibit Status                                                                                                                                                                                                                |
| Dec                            | 6245 | 22629 | 45258 | RO                                                   | 0 Not Inhibited                                                                                                                                                                                                                       |
| Hex                            | 1865 | 5865  | B0CA  |                                                      | 1 Inhibited                                                                                                                                                                                                                           |
| Alarm 7 Label                  |      |       |       | Main Language Name For Alarm 7 In Status Screen      |                                                                                                                                                                                                                                       |
| Dec                            | 6247 | 22631 | 45262 | RW                                                   | 8 ASCII characters replacing the title "Alarm 7" in alarm status screens when main display language is used, read/written with Modbus functions 16 or 23. Valid characters are <b>0 to 9, a to z, A to Z, plus ß ö ( ) - and _</b> .  |
| Hex                            | 1867 | 5867  | B0CE  |                                                      |                                                                                                                                                                                                                                       |
| Alarm 7 Alternate Label        |      |       |       | Alternate Language Name For Alarm 7 In Status Screen |                                                                                                                                                                                                                                       |
| Dec                            | 6248 | 22632 | 45264 | RW                                                   | 8 ASCII characters replacing the title "Alarm 7" in alarm status screens when the alternate language is used, read/written with Modbus functions 16 or 23. Valid characters are <b>0 to 9, a to z, A to Z, plus ß ö ( ) - and _</b> . |
| Hex                            | 1868 | 5868  | B0D0  |                                                      |                                                                                                                                                                                                                                       |
| Alarm 7 Minimum Duration       |      |       |       | Alarm 7 Minimum Duration                             |                                                                                                                                                                                                                                       |
| Dec                            | 6249 | 22633 | 45266 | RW                                                   | Minimum time alarm 7 must be passed its threshold before activating (deactivation is not affected by this parameter).<br>From 0 to 9999 secs                                                                                          |
| Hex                            | 1869 | 5869  | B0D2  |                                                      |                                                                                                                                                                                                                                       |

## 20.4.19 Recorder & Clock Parameters

| Parameter Name & Register Address |        |       |        |        |                           |                              |
|-----------------------------------|--------|-------|--------|--------|---------------------------|------------------------------|
| Integer                           | Int +1 | Float | Access | Values | & Descriptions            |                              |
| Recording Sample Interval         |        |       |        | Value  | Recording Sample Interval |                              |
| Dec                               | 7550   | 23934 | 47868  | RW     | 0                         | Every Second                 |
| Hex                               | 1D7E   | 5D7E  | BAFC   |        | 1                         | Every 2 Seconds              |
|                                   |        |       |        |        | 2                         | Every 5 Seconds              |
|                                   |        |       |        |        | 3                         | Every 10 Seconds             |
|                                   |        |       |        |        | 4                         | Every 15 Seconds             |
|                                   |        |       |        |        | 5                         | Every 30 Seconds             |
|                                   |        |       |        |        | 6                         | Every Minute                 |
|                                   |        |       |        |        | 7                         | Every 2 Minutes              |
|                                   |        |       |        |        | 8                         | Every 5 Minutes              |
|                                   |        |       |        |        | 9                         | Every 10 Minutes             |
|                                   |        |       |        |        | 10                        | Every 15 Minutes             |
|                                   |        |       |        |        | 11                        | Every 30 Minutes             |
| Recording Mode                    |        |       |        | Value  | Recording Mode            |                              |
| Dec                               | 7551   | 23935 | 47870  | RW     | 0                         | Record until memory used     |
| Hex                               | 1D7F   | 5D7F  | BAFE   |        | 1                         | Continuous FIFO buffer       |
| Manual Recording Trigger          |        |       |        | Value  | Manual Recording Trigger  |                              |
| Dec                               | 7552   | 23936 | 47872  | RW     | 0                         | Manual Recording Trigger Off |
| Hex                               | 1D80   | 5D80  | BB00   |        | 1                         | Manual Recording Trigger On  |
| Data Recorder Fitted              |        |       |        | Value  | Data Recorder Fitted      |                              |
| Dec                               | 7553   | 23937 | 47874  | RO     | 0                         | Not Fitted                   |
| Hex                               | 1D81   | 5D81  | BB02   |        | 1                         | Recorder Fitted              |

| Memory Remaining                   |      |       |       | Remaining Data Recorder Capacity |                                                                                                                             |                                   |
|------------------------------------|------|-------|-------|----------------------------------|-----------------------------------------------------------------------------------------------------------------------------|-----------------------------------|
| Dec                                | 7554 | 23938 | 47876 | RO                               | The unused memory remaining, in bytes.                                                                                      |                                   |
| Hex                                | 1D82 | 5D82  | BB04  |                                  |                                                                                                                             |                                   |
| Time Remaining                     |      |       |       | Remaining Data Recorder Time     |                                                                                                                             |                                   |
| Dec                                | 7555 | 23939 | 47878 | RO                               | Approximate recording time remaining until memory filled, in seconds. Based on the current recorder settings & sample rate. |                                   |
| Hex                                | 1D83 | 5D83  | BB06  |                                  |                                                                                                                             |                                   |
| Recorder Auto-Alarm Trigger        |      |       |       | Value                            | Automatic Data Recorder Trigger                                                                                             |                                   |
| Dec                                | 7563 | 23947 | 47894 | RW                               | 0                                                                                                                           | None                              |
| Hex                                | 1D8B | 5D8B  | BB16  |                                  | 1                                                                                                                           | On Alarm                          |
|                                    |      |       |       |                                  | 2                                                                                                                           | On Profile Run                    |
|                                    |      |       |       |                                  | 3                                                                                                                           | On Alarm or Profile Running       |
| Operator Access To Record Trigger  |      |       |       | Value                            | Operator Access To Manual Record Trigger                                                                                    |                                   |
| Dec                                | 7559 | 23943 | 47886 | RW                               | 0                                                                                                                           | No                                |
| Hex                                | 1D87 | 5D87  | BB0E  |                                  | 1                                                                                                                           | Yes                               |
| Recorder Status In Operator Mode   |      |       |       | Value                            | Recorder Status Visible In Operator Mode                                                                                    |                                   |
| Dec                                | 7560 | 23944 | 47888 | RW                               | 0                                                                                                                           | No                                |
| Hex                                | 1D88 | 5D88  | BB10  |                                  | 1                                                                                                                           | Yes                               |
| Record Input 1 Process Variable    |      |       |       | Value                            | Record Process Variable Of Input 1                                                                                          |                                   |
| Dec                                | 7572 | 23956 | 47912 | RW                               | 0                                                                                                                           | Do Not Record PV                  |
| Hex                                | 1D94 | 5D94  | BB28  |                                  | 1                                                                                                                           | Record PV Value                   |
| Record Input 1 Max Between Samples |      |       |       | Value                            | Record Max PV For Input 1 Since Last Sample                                                                                 |                                   |
| Dec                                | 7573 | 23957 | 47914 | RW                               | 0                                                                                                                           | Do Not Record Maximum PV          |
| Hex                                | 1D95 | 5D95  | BB2A  |                                  | 1                                                                                                                           | Record Maximum PV Between Samples |
| Record Input 1 Min Between Samples |      |       |       | Value                            | Record Min PV For Input 1 Since Last Sample                                                                                 |                                   |
| Dec                                | 7574 | 23958 | 47916 | RW                               | 0                                                                                                                           | Do Not Record Minimum PV          |
| Hex                                | 1D96 | 5D96  | BB2C  |                                  | 1                                                                                                                           | Record Minimum PV Between Samples |
| Record Input 2 Process Variable    |      |       |       | Value                            | Record Process Variable Of Input 2                                                                                          |                                   |
| Dec                                | 7607 | 23991 | 47982 | RW                               | 0                                                                                                                           | Do Not Record PV                  |
| Hex                                | 1DB7 | 5DB7  | BB6E  |                                  | 1                                                                                                                           | Record PV Value                   |
| Record Input 2 Max Between Samples |      |       |       | Value                            | Record Max PV For Input 2 Since Last Sample                                                                                 |                                   |
| Dec                                | 7608 | 23992 | 47984 | RW                               | 0                                                                                                                           | Do Not Record Maximum PV          |
| Hex                                | 1DB8 | 5DB8  | BB70  |                                  | 1                                                                                                                           | Record Maximum PV Between Samples |
| Record Input 2 Min Between Samples |      |       |       | Value                            | Record Min PV For Input 2 Since Last Sample                                                                                 |                                   |
| Dec                                | 7609 | 23993 | 47986 | RW                               | 0                                                                                                                           | Do Not Record Minimum PV          |
| Hex                                | 1DB9 | 5DB9  | BB72  |                                  | 1                                                                                                                           | Record Minimum PV Between Samples |
| Record Aux A Input                 |      |       |       | Value                            | Record Auxiliary A Input Value                                                                                              |                                   |
| Dec                                | 7606 | 23990 | 47980 | RW                               | 0                                                                                                                           | Do Not Record Aux A               |
| Hex                                | 1DB6 | 5DB6  | BB6C  |                                  | 1                                                                                                                           | Record Aux A Value                |
| Record Loop 1 Actual Setpoint      |      |       |       | Value                            | Record Effective Value of Loop 1 Setpoint                                                                                   |                                   |
| Dec                                | 7575 | 23959 | 47918 | RW                               | 0                                                                                                                           | Do Not Record Setpoint            |
| Hex                                | 1D97 | 5D97  | BB2E  |                                  | 1                                                                                                                           | Record Actual Setpoint            |
| Record Loop 2 Actual Setpoint      |      |       |       | Value                            | Record Effective Value of Loop 2 Setpoint                                                                                   |                                   |
| Dec                                | 7610 | 23994 | 47988 | RW                               | 0                                                                                                                           | Do Not Record Setpoint            |
| Hex                                | 1DBA | 5DBA  | BB74  |                                  | 1                                                                                                                           | Record Actual Setpoint            |

|                                      |      |       |       |              |                                                 |
|--------------------------------------|------|-------|-------|--------------|-------------------------------------------------|
| <b>Record Loop 1 Primary Power</b>   |      |       |       | <b>Value</b> | <b>Record Primary Power Value For Loop 1</b>    |
| Dec                                  | 7576 | 23960 | 47920 | RW           | 0 Do Not Record Primary Power                   |
| Hex                                  | 1D98 | 5D98  | BB30  |              | 1 Record Primary Power                          |
| <b>Record Loop 1 Secondary Power</b> |      |       |       | <b>Value</b> | <b>Record Secondary Power Value For Loop 1</b>  |
| Dec                                  | 7577 | 23961 | 47922 | RW           | 0 Do Not Record Secondary Power                 |
| Hex                                  | 1D99 | 5D99  | BB32  |              | 1 Record Secondary Power                        |
| <b>Record Loop 2 Primary Power</b>   |      |       |       | <b>Value</b> | <b>Record Primary Power Value For Loop 2</b>    |
| Dec                                  | 7611 | 23995 | 47990 | RW           | 0 Do Not Record Primary Power                   |
| Hex                                  | 1DBB | 5DBB  | BB76  |              | 1 Record Primary Power                          |
| <b>Record Loop 2 Secondary Power</b> |      |       |       | <b>Value</b> | <b>Record Secondary Power Value For Loop 2</b>  |
| Dec                                  | 7612 | 23996 | 47992 | RW           | 0 Do Not Record Secondary Power                 |
| Hex                                  | 1DBC | 5DBC  | BB78  |              | 1 Record Secondary Power                        |
| <b>Record Alarm 1 Status</b>         |      |       |       | <b>Value</b> | <b>Record Change Of State For Alarm 1</b>       |
| Dec                                  | 7578 | 23962 | 47924 | RW           | 0 Do Not Record Alarm 1                         |
| Hex                                  | 1D9A | 5D9A  | BB34  |              | 1 Record Alarm 1                                |
| <b>Record Alarm 2 Status</b>         |      |       |       | <b>Value</b> | <b>Record Change Of State For Alarm 2</b>       |
| Dec                                  | 7579 | 23963 | 47926 | RW           | 0 Do Not Record Alarm 2                         |
| Hex                                  | 1D9B | 5D9B  | BB36  |              | 1 Record Alarm 2                                |
| <b>Record Alarm 3 Status</b>         |      |       |       | <b>Value</b> | <b>Record Change Of State For Alarm 3</b>       |
| Dec                                  | 7580 | 23964 | 47928 | RW           | 0 Do Not Record Alarm 3                         |
| Hex                                  | 1D9C | 5D9C  | BB38  |              | 1 Record Alarm 3                                |
| <b>Record Alarm 4 Status</b>         |      |       |       | <b>Value</b> | <b>Record Change Of State For Alarm 4</b>       |
| Dec                                  | 7581 | 23965 | 47930 | RW           | 0 Do Not Record Alarm 4                         |
| Hex                                  | 1D9D | 5D9D  | BB3A  |              | 1 Record Alarm 4                                |
| <b>Record Alarm 5 Status</b>         |      |       |       | <b>Value</b> | <b>Record Change Of State For Alarm 5</b>       |
| Dec                                  | 7582 | 23966 | 47932 | RW           | 0 Do Not Record Alarm 5                         |
| Hex                                  | 1D9E | 5D9E  | BB3C  |              | 1 Record Alarm 5                                |
| <b>Record Alarm 6 Status</b>         |      |       |       | <b>Value</b> | <b>Record Change Of State For Alarm 6</b>       |
| Dec                                  | 7615 | 23999 | 47998 | RW           | 0 Do Not Record Alarm 6                         |
| Hex                                  | 1DBF | 5DBF  | BB7E  |              | 1 Record Alarm 6                                |
| <b>Record Alarm 7 Status</b>         |      |       |       | <b>Value</b> | <b>Record Change Of State For Alarm 7</b>       |
| Dec                                  | 7616 | 24000 | 48000 | RW           | 0 Do Not Record Alarm 7                         |
| Hex                                  | 1DC0 | 5DC0  | BB80  |              | 1 Record Alarm 7                                |
| <b>Record Power</b>                  |      |       |       | <b>Value</b> | <b>Record Instrument Power Turned On/Off</b>    |
| Dec                                  | 7583 | 23967 | 47934 | RW           | 0 Do Not Record Power On/Off                    |
| Hex                                  | 1D9F | 5D9F  | BB3E  |              | 1 Record Power On/Off                           |
| <b>Record Cascade Master PV</b>      |      |       |       | <b>Value</b> | <b>Record Cascade Mode Master Process Value</b> |
| Dec                                  | 7530 | 23914 | 47828 | RW           | 0 Do Not Record PV                              |
| Hex                                  | 1D6A | 5D6A  | BAD4  |              | 1 Record PV Value Of Master                     |
| <b>Record Cascade Master SP</b>      |      |       |       | <b>Value</b> | <b>Record Cascade Mode Master Setpoint</b>      |
| Dec                                  | 7531 | 23915 | 47830 | RW           | 0 Do Not Record SP                              |
| Hex                                  | 1D6B | 5D6B  | BAD6  |              | 1 Record SP Value Of Master                     |
| <b>Record Cascade Slave PV</b>       |      |       |       | <b>Value</b> | <b>Record Cascade Mode Slave Process Value</b>  |
| Dec                                  | 7532 | 23916 | 47832 | RW           | 0 Do Not Record PV                              |
| Hex                                  | 1D6C | 5D6C  | BAD8  |              | 1 Record PV Value Of Slave                      |

|                                           |      |       |       |                                   |                                                                |
|-------------------------------------------|------|-------|-------|-----------------------------------|----------------------------------------------------------------|
| <b>Record Cascade Slave Primary Power</b> |      |       |       | <b>Value</b>                      | <b>Record Primary Power Value of Cascade Slave</b>             |
| Dec                                       | 7533 | 23917 | 47834 | RW                                | 0 Do Not Record Primary Power                                  |
| Hex                                       | 1D6D | 5D6D  | BADA  |                                   | 1 Record Primary Power Of Slave                                |
| <b>Record Slave Secondary Power</b>       |      |       |       | <b>Value</b>                      | <b>Record Slave Secondary Power in Cascade Mode</b>            |
| Dec                                       | 7538 | 23922 | 47844 | RW                                | 0 Do Not Record Secondary Power                                |
| Hex                                       | 1D72 | 5D72  | BAE4  |                                   | 1 Record Secondary Power Of Slave                              |
| <b>Record Ratio PV Input 1</b>            |      |       |       | <b>Value</b>                      | <b>Record Ratio Mode Input 1 Process Value</b>                 |
| Dec                                       | 7534 | 23918 | 47836 | RW                                | 0 Do Not Record PV                                             |
| Hex                                       | 1D6E | 5D6E  | BADC  |                                   | 1 Record Ratio Input 1 PV Value                                |
| <b>Record Ratio PV Input 2</b>            |      |       |       | <b>Value</b>                      | <b>Record Ratio Mode Input 2 Process Value</b>                 |
| Dec                                       | 7535 | 23919 | 47838 | RW                                | 0 Do Not Record PV                                             |
| Hex                                       | 1D6F | 5D6F  | BADE  |                                   | 1 Record Ration Input 2 PV Value                               |
| <b>Record Ratio SP</b>                    |      |       |       | <b>Value</b>                      | <b>Record Ratio Mode Setpoint</b>                              |
| Dec                                       | 7536 | 23920 | 47840 | RW                                | 0 Do Not Record SP                                             |
| Hex                                       | 1D70 | 5D70  | BAE0  |                                   | 1 Record Ratio Mode SP Value                                   |
| <b>Record Ratio Power</b>                 |      |       |       | <b>Value</b>                      | <b>Record Ratio Mode Power Output Value</b>                    |
| Dec                                       | 7537 | 23921 | 47842 | RW                                | 0 Do Not Record Ratio Power                                    |
| Hex                                       | 1D71 | 5D71  | BAE2  |                                   | 1 Record Ratio Mode Power                                      |
| <b>Trigger Recording On Alarm 1</b>       |      |       |       | <b>Value</b>                      | <b>Alarm 1 To Trigger Recording</b>                            |
| Dec                                       | 7584 | 23968 | 47936 | RW                                | 0 Off                                                          |
| Hex                                       | 1DA0 | 5DA0  | BB40  |                                   | 1 Trigger On Alarm 1 (if auto-trigger = profile or alarm)      |
| <b>Trigger Recording On Alarm 2</b>       |      |       |       | <b>Value</b>                      | <b>Alarm 2 To Trigger Recording</b>                            |
| Dec                                       | 7685 | 24069 | 48138 | RW                                | 0 Off                                                          |
| Hex                                       | 1E05 | 5E05  | BC0A  |                                   | 1 Trigger On Alarm 2 (if auto-trigger = profile or alarm)      |
| <b>Trigger Recording On Alarm 3</b>       |      |       |       | <b>Value</b>                      | <b>Alarm 3 To Trigger Recording</b>                            |
| Dec                                       | 7686 | 24070 | 48140 | RW                                | 0 Off                                                          |
| Hex                                       | 1E06 | 5E06  | BC0C  |                                   | 1 Trigger On Alarm 3 (if auto-trigger = profile or alarm)      |
| <b>Trigger Recording On Alarm 4</b>       |      |       |       | <b>Value</b>                      | <b>Alarm 4 To Trigger Recording</b>                            |
| Dec                                       | 7687 | 24071 | 48142 | RW                                | 0 Off                                                          |
| Hex                                       | 1E07 | 5E07  | BC0E  |                                   | 1 Trigger On Alarm 4 (if auto-trigger = profile or alarm)      |
| <b>Trigger Recording On Alarm 5</b>       |      |       |       | <b>Value</b>                      | <b>Alarm 5 To Trigger Recording</b>                            |
| Dec                                       | 7688 | 24072 | 48144 | RW                                | 0 Off                                                          |
| Hex                                       | 1E08 | 5E08  | BC10  |                                   | 1 Trigger On Alarm 5 (if auto-trigger = profile or alarm)      |
| <b>Trigger Recording On Alarm 6</b>       |      |       |       | <b>Value</b>                      | <b>Alarm 6 To Trigger Recording</b>                            |
| Dec                                       | 7613 | 23997 | 47994 | RW                                | 0 Off                                                          |
| Hex                                       | 1DBD | 5DBD  | BB7A  |                                   | 1 Trigger On Alarm 6 (if auto-trigger = profile or alarm)      |
| <b>Trigger Recording On Alarm 7</b>       |      |       |       | <b>Value</b>                      | <b>Alarm 7 To Trigger Recording</b>                            |
| Dec                                       | 7614 | 23998 | 47996 | RW                                | 0 Off                                                          |
| Hex                                       | 1DBE | 5DBE  | BB7C  |                                   | 1 Trigger On Alarm 7 (if auto-trigger = profile or alarm)      |
| <b>Sample Size</b>                        |      |       |       | <b>Data Recording Sample Size</b> |                                                                |
| Dec                                       | 7595 | 23979 | 47958 | RO                                | The size (in bytes) for recording sample with current settings |
| Hex                                       | 1DAB | 5DAB  | BB56  |                                   |                                                                |

| Record Event 1                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |      |       |       |    | Value                                                                                                                                          | Record Change Of State For Event 1 |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|-------|-------|----|------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------|
| Dec                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | 7599 | 23983 | 47966 | RW | 0                                                                                                                                              | Do Not Record Event 1              |
| Hex                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | 1DAF | 5DAF  | BB5E  |    | 1                                                                                                                                              | Record Event 1                     |
| Record Event 2                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |      |       |       |    | Value                                                                                                                                          | Record Change Of State For Event 2 |
| Dec                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | 7600 | 23984 | 47968 | RW | 0                                                                                                                                              | Do Not Record Event 2              |
| Hex                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | 1DB0 | 5DB0  | BB60  |    | 1                                                                                                                                              | Record Event 2                     |
| Record Event 3                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |      |       |       |    | Value                                                                                                                                          | Record Change Of State For Event 3 |
| Dec                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | 7601 | 23985 | 47970 | RW | 0                                                                                                                                              | Do Not Record Event 3              |
| Hex                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | 1DB1 | 5DB1  | BB62  |    | 1                                                                                                                                              | Record Event 3                     |
| Record Event 4                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |      |       |       |    | Value                                                                                                                                          | Record Change Of State For Event 4 |
| Dec                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | 7602 | 23986 | 47972 | RW | 0                                                                                                                                              | Do Not Record Event 4              |
| Hex                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | 1DB2 | 5DB2  | BB64  |    | 1                                                                                                                                              | Record Event 4                     |
| Record Event 5                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |      |       |       |    | Value                                                                                                                                          | Record Change Of State For Event 5 |
| Dec                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | 7603 | 23987 | 47974 | RW | 0                                                                                                                                              | Do Not Record Event 5              |
| Hex                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | 1DB3 | 5DB3  | BB66  |    | 1                                                                                                                                              | Record Event 5                     |
| Memory Used                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |      |       |       |    | Percentage Data Recorder Memory Used                                                                                                           |                                    |
| Dec                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | 7605 | 23989 | 47978 | RO | Recorder Memory Used. 0 (Empty) to 100% (Full)                                                                                                 |                                    |
| Hex                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | 1DB5 | 5DB5  | BB6A  |    |                                                                                                                                                |                                    |
| Date format                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |      |       |       |    | Value                                                                                                                                          | Display Date Format                |
| Dec                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | 7868 | 24252 | 48504 | RW | 0                                                                                                                                              | dd/mm/yyyy (European Default)      |
| Hex                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | 1EBC | 5EBC  | BD78  |    | 1                                                                                                                                              | mm/dd/yyyy (USA Default)           |
| Clock Time                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |      |       |       |    | Real Time Clock Time Of Day Setting                                                                                                            |                                    |
| Dec                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | 7869 | 24253 | 48506 | RW | Format is the number of seconds since midnight.                                                                                                |                                    |
| Hex                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | 1EBD | 5EBD  | BD7A  |    |                                                                                                                                                |                                    |
| Clock Date                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |      |       |       |    | Real Time Clock Date Setting                                                                                                                   |                                    |
| Dec                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | n/a  | n/a   | 48508 | RW | This can be entered only as a floating point number. When converted to binary the least significant 19 bits represent the date in this format: |                                    |
| Hex                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          | n/a  | n/a   | BD7C  |    |                                                                                                                                                |                                    |
| <div>www DDDDD MMMM YYYYYYY</div> <div>YYYYYYY = YEAR</div> <div>MMMM = MONTH</div> <div>DDDDD = DAY OF MONTH (1-31 but must be valid)</div> <div>www = Day of the week The day of week portion is calculated from the date (Read Only).</div> <div>Example with date set to 31/07/2012</div> <div>Day (31) = 11111</div> <div>Month (7) = 0111</div> <div>Year (12) = 0001100</div> <div>Bits 17 and higher are ignored when writing so 11111 0111 0001100 (64396 decimal) is just one of many possible numbers to write as 31/07/2012, and when reading the date back, the number returned is</div> <div>10 11111 0111 0001100 (195468 decimal) because bits 17-19 are 010 (to represent “Tuesday”).</div> |      |       |       |    |                                                                                                                                                |                                    |

| Real Time Clock Fitted |      |       |       | Value | Real Time Clock Fitted                           |
|------------------------|------|-------|-------|-------|--------------------------------------------------|
| Dec                    | 7871 | 24255 | 48510 | RO    | 0 Not Fitted                                     |
| Hex                    | 1EBF | 5EBF  | BD7E  |       | 1 Fitted                                         |
| Day Of The Week        |      |       |       | Value | Day Of Week (calculated from clock date setting) |
| Dec                    | 7872 | 24256 | 48512 | RO    | 1 Monday                                         |
| Hex                    | 1EC0 | 5EC0  | BD80  |       | 2 Tuesday                                        |
|                        |      |       |       |       | 3 Wednesday                                      |
|                        |      |       |       |       | 4 Thursday                                       |
|                        |      |       |       |       | 5 Friday                                         |
|                        |      |       |       |       | 6 Saturday                                       |
|                        |      |       |       |       | 7 Sunday                                         |

## 20.4.20 Display & Security

| Parameter Name & Register Address |         |        |       |        |                                                                                                                                                                                                                                                                                                                                                            |  |
|-----------------------------------|---------|--------|-------|--------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|
|                                   | Integer | Int +1 | Float | Access | Values & Descriptions                                                                                                                                                                                                                                                                                                                                      |  |
| LED 1 Label                       |         |        |       |        |                                                                                                                                                                                                                                                                                                                                                            |  |
| Dec                               | 7656    | 24040  | 48080 | RW     | <p>Labels shown in display immediately below the 4 red LED indicators.</p> <p>With up to 5 ASCII characters, which can read or written using Modbus functions 16 or 23.</p> <p>Valid characters are <b>0 to 9, a to z, A to Z, plus ß ö ( ) - and _</b>.</p> <p>Defaults: 1 = PRI (Primary); 2 = SEC (Secondary); 3 = TUNE (Tuning); 4 = ALARM (Alarm)</p> |  |
| Hex                               | 1DE8    | 5DE8   | BBD0  |        |                                                                                                                                                                                                                                                                                                                                                            |  |
| LED 1 Alternate Label             |         |        |       |        |                                                                                                                                                                                                                                                                                                                                                            |  |
| Dec                               | 7660    | 24044  | 48088 | RW     |                                                                                                                                                                                                                                                                                                                                                            |  |
| Hex                               | 1DEC    | 5DEC   | BBD8  |        |                                                                                                                                                                                                                                                                                                                                                            |  |
| LED 2 Label                       |         |        |       |        |                                                                                                                                                                                                                                                                                                                                                            |  |
| Dec                               | 7657    | 24041  | 48082 | RW     |                                                                                                                                                                                                                                                                                                                                                            |  |
| Hex                               | 1DE9    | 5DE9   | BBD2  |        |                                                                                                                                                                                                                                                                                                                                                            |  |
| LED 2 Alternate Label             |         |        |       |        |                                                                                                                                                                                                                                                                                                                                                            |  |
| Dec                               | 7661    | 24045  | 48090 | RW     |                                                                                                                                                                                                                                                                                                                                                            |  |
| Hex                               | 1DED    | 5DED   | BBDA  |        |                                                                                                                                                                                                                                                                                                                                                            |  |
| LED 3 Label                       |         |        |       |        |                                                                                                                                                                                                                                                                                                                                                            |  |
| Dec                               | 7658    | 24042  | 48084 | RW     |                                                                                                                                                                                                                                                                                                                                                            |  |
| Hex                               | 1DEA    | 5DEA   | BBD4  |        |                                                                                                                                                                                                                                                                                                                                                            |  |
| LED 3 Alternate Label             |         |        |       |        |                                                                                                                                                                                                                                                                                                                                                            |  |
| Dec                               | 7662    | 24046  | 48092 | RW     |                                                                                                                                                                                                                                                                                                                                                            |  |
| Hex                               | 1DEE    | 5DEE   | BBDC  |        |                                                                                                                                                                                                                                                                                                                                                            |  |
| LED 4 Label                       |         |        |       |        |                                                                                                                                                                                                                                                                                                                                                            |  |
| Dec                               | 7659    | 24043  | 48086 | RW     |                                                                                                                                                                                                                                                                                                                                                            |  |
| Hex                               | 1DEB    | 5DEB   | BBD6  |        |                                                                                                                                                                                                                                                                                                                                                            |  |
| LED 4 Alternate Label             |         |        |       |        |                                                                                                                                                                                                                                                                                                                                                            |  |
| Dec                               | 7663    | 24047  | 48094 | RW     |                                                                                                                                                                                                                                                                                                                                                            |  |
| Hex                               | 1DEF    | 5DEF   | BBDE  |        |                                                                                                                                                                                                                                                                                                                                                            |  |

| LED 1 Usage                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |      |       |       | Value | LED 1 Usage. For 8 & 9 see also LED 1 Selections.             |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|-------|-------|-------|---------------------------------------------------------------|
| Dec                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | 7664 | 24048 | 48096 | RW    | 0 Loop 1 Primary Control ON = LED 1 ON                        |
| Hex                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | 1DF0 | 5DF0  | BBE0  |       | 1 Loop 1 Secondary Control ON = LED 1 ON                      |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 2 Loop 2 Primary Control ON = LED 1 ON                        |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 3 Loop 2 Secondary Control ON = LED 1 ON                      |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 4 Loop 1 VMD Open ON = LED 1 ON                               |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 5 Loop 1 VMD Close ON = LED 1 ON                              |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 6 Loop 2 VMD Open ON = LED 1 ON                               |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 7 Loop 2 VMD Close ON = LED 1 ON                              |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 8 Alarm/Event/Digital/Control (Logical <b>OR</b> )            |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 9 Alarm/Event/Digital/Control inverted (Logical <b>NOR</b> )  |
| <p>Value 8 (Logical <b>OR</b> selection of Alarm/Events/Digital/Control) turns <b>ON</b> the LED if <u>any</u> of the selected alarms, events, inputs or functions are active.</p> <p>Value 9 (Logical <b>NOR</b> selection of Alarm/Events/Digital/Control) turns <b>OFF</b> the LED if any of the selected alarms, events, inputs or functions are active.</p> <p><b>Note:</b> Pre-tune will flash the LED instead of turning it on, but flashing will be obscured if used in conjunction with other functions when they are on.</p> |      |       |       |       |                                                               |
| LED 1 Alarm Indication                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |      |       |       | Bit   | If bit =1, Alarm <i>n</i> status is selected                  |
| Dec                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | 7690 | 24074 | 48148 | RW    | 0 Alarm 1                                                     |
| Hex                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | 1E0A | 5E0A  | BC14  |       | 1 Alarm 2                                                     |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 2 Alarm 3                                                     |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 3 Alarm 4                                                     |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 4 Alarm 5                                                     |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 5 Alarm 6                                                     |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 6 Alarm 7                                                     |
| LED 1 Profiler Event Indication                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       | Bit   | If bit =1, Event <i>n</i> status is selected                  |
| Dec                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | 7692 | 24076 | 48152 | RW    | 0 Event 1                                                     |
| Hex                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | 1E0C | 5E0C  | BC18  |       | 1 Event 2                                                     |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 2 Event 3                                                     |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 3 Event 4                                                     |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 4 Event 5                                                     |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 5 Profile Running                                             |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 6 Profile End                                                 |
| LED 1 Slot A & Soft Input Indication                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |      |       |       | Bit   | If bit =1, Digital A / Soft Input <i>n</i> status is selected |
| Dec                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | 7694 | 24078 | 48156 | RW    | 0 Digital Input A                                             |
| Hex                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | 1E0E | 5E0E  | BC1C  |       | 1 Soft Digital 1                                              |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 2 Soft Digital 2                                              |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 3 Soft Digital 3                                              |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |      |       |       |       | 4 Soft Digital 4                                              |

| LED 1 Option C Digital Indication                                                                                                                                           |      |       |       | Bit   | If bit =1, Digital Cn status is selected                           |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|-------|-------|-------|--------------------------------------------------------------------|
| Dec                                                                                                                                                                         | 7696 | 24080 | 48160 | RW    | 0 Digital Input C1                                                 |
| Hex                                                                                                                                                                         | 1E10 | 5E10  | BC20  |       | 1 Digital Input C2                                                 |
|                                                                                                                                                                             |      |       |       |       | 2 Digital Input C3                                                 |
|                                                                                                                                                                             |      |       |       |       | 3 Digital Input C4                                                 |
|                                                                                                                                                                             |      |       |       |       | 4 Digital Input C5                                                 |
|                                                                                                                                                                             |      |       |       |       | 5 Digital Input C6                                                 |
|                                                                                                                                                                             |      |       |       |       | 6 Digital Input C7                                                 |
| LED 1 Control Indication                                                                                                                                                    |      |       |       | Bit   | If bit =1, the function's status is selected                       |
| Dec                                                                                                                                                                         | 7644 | 24028 | 48056 | RW    | 0 Loop 1 Auto Tune (self-tune=On, pre-tune=flashing)               |
| Hex                                                                                                                                                                         | 1DDC | 5DDC  | BBB8  |       | 1 Loop 1 Manual Control                                            |
|                                                                                                                                                                             |      |       |       |       | 2 Loop 2 Auto Tune (self-tune=On, pre-tune=flashing)               |
|                                                                                                                                                                             |      |       |       |       | 3 Loop 2 Manual Control                                            |
| LED 2 Usage                                                                                                                                                                 |      |       |       | Value | LED 2 Usage. For 8 & 9 see also LED 2 Selections.                  |
| Dec                                                                                                                                                                         | 7665 | 24049 | 48098 | RW    | 0 Loop 1 Primary Control ON = LED 1 ON                             |
| Hex                                                                                                                                                                         | 1DF1 | 5DF1  | BBE2  |       | 1 Loop 1 Secondary Control ON = LED 1 ON                           |
|                                                                                                                                                                             |      |       |       |       | 2 Loop 2 Primary Control ON = LED 1 ON                             |
|                                                                                                                                                                             |      |       |       |       | 3 Loop 2 Secondary Control ON = LED 1 ON                           |
|                                                                                                                                                                             |      |       |       |       | 4 Loop 1 VMD Open ON = LED 1 ON                                    |
|                                                                                                                                                                             |      |       |       |       | 5 Loop 1 VMD Close ON = LED 1 ON                                   |
|                                                                                                                                                                             |      |       |       |       | 6 Loop 2 VMD Open ON = LED 1 ON                                    |
|                                                                                                                                                                             |      |       |       |       | 7 Loop 2 VMD Close ON = LED 1 ON                                   |
|                                                                                                                                                                             |      |       |       |       | 8 Alarm/Events/Digital/Control (Logical OR of selection below)     |
|                                                                                                                                                                             |      |       |       |       | 9 Alarm/Events/Digital/Control inverted (Logical NOR of selection) |
| Value 8 (Logical <b>OR</b> selection of Alarm/Events/Digital/Control) turns <b>ON</b> the LED if <u>any</u> of the selected alarms, events, inputs or functions are active. |      |       |       |       |                                                                    |
| Value 9 (Logical <b>NOR</b> selection of Alarm/Events/Digital/Control) turns <b>OFF</b> the LED if any of the selected alarms, events, inputs or functions are active.      |      |       |       |       |                                                                    |
| <b>Note:</b> Pre-tune will flash the LED instead of turning it on, but flashing will be obscured if used in conjunction with other functions when they are on.              |      |       |       |       |                                                                    |
| LED 2 Alarm Indication                                                                                                                                                      |      |       |       | Bit   | If bit =1, Alarm n status is selected                              |
| Dec                                                                                                                                                                         | 7698 | 24082 | 48164 | RW    | 0 Alarm 1                                                          |
| Hex                                                                                                                                                                         | 1E12 | 5E12  | BC24  |       | 1 Alarm 2                                                          |
|                                                                                                                                                                             |      |       |       |       | 2 Alarm 3                                                          |
|                                                                                                                                                                             |      |       |       |       | 3 Alarm 4                                                          |
|                                                                                                                                                                             |      |       |       |       | 4 Alarm 5                                                          |
|                                                                                                                                                                             |      |       |       |       | 5 Alarm 6                                                          |
|                                                                                                                                                                             |      |       |       |       | 6 Alarm 7                                                          |

| LED 2 Event Indication               |      |       |       | Bit   | If bit =1, Event <i>n</i> status is selected                              |
|--------------------------------------|------|-------|-------|-------|---------------------------------------------------------------------------|
| Dec                                  | 7700 | 24084 | 48168 | RW    | 0 Event 1                                                                 |
| Hex                                  | 1E14 | 5E14  | BC28  |       | 1 Event 2                                                                 |
|                                      |      |       |       |       | 2 Event 3                                                                 |
|                                      |      |       |       |       | 3 Event 4                                                                 |
|                                      |      |       |       |       | 4 Event 5                                                                 |
|                                      |      |       |       |       | 5 Profile Running                                                         |
|                                      |      |       |       |       | 6 Profile End                                                             |
| LED 2 Slot A & Soft Input Indication |      |       |       | Bit   | If bit =1, Digital A / Soft Input <i>n</i> status is selected             |
| Dec                                  | 7702 | 24086 | 48172 | RW    | 0 Digital Input A                                                         |
| Hex                                  | 1E16 | 5E16  | BC2C  |       | 1 Soft Digital 1                                                          |
|                                      |      |       |       |       | 2 Soft Digital 2                                                          |
|                                      |      |       |       |       | 3 Soft Digital 3                                                          |
|                                      |      |       |       |       | 4 Soft Digital 4                                                          |
| LED 2 Option C Digital Indication    |      |       |       | Bit   | If bit =1, Digital <i>Cn</i> status is selected                           |
| Dec                                  | 7704 | 24088 | 48176 | RW    | 0 Digital Input C1                                                        |
| Hex                                  | 1E18 | 5E18  | BC30  |       | 1 Digital Input C2                                                        |
|                                      |      |       |       |       | 2 Digital Input C3                                                        |
|                                      |      |       |       |       | 3 Digital Input C4                                                        |
|                                      |      |       |       |       | 4 Digital Input C5                                                        |
|                                      |      |       |       |       | 5 Digital Input C6                                                        |
|                                      |      |       |       |       | 6 Digital Input C7                                                        |
| LED 2 Control Indication             |      |       |       | Bit   | If bit =1, the function's status is selected                              |
| Dec                                  | 7646 | 24030 | 48060 | RW    | 0 Loop 1 Auto Tune (self-tune=On, pre-tune=flashing)                      |
| Hex                                  | 1DDE | 5DDE  | BBBC  |       | 1 Loop 1 Manual Control                                                   |
|                                      |      |       |       |       | 2 Loop 2 Auto Tune (self-tune=On, pre-tune=flashing)                      |
|                                      |      |       |       |       | 3 Loop 2 Manual Control                                                   |
| LED 3 Usage                          |      |       |       | Value | LED 3 Usage. <i>For 8 &amp; 9 see also LED 3 Selections.</i>              |
| Dec                                  | 7666 | 24050 | 48100 | RW    | 0 Loop 1 Primary Control ON = LED 1 ON                                    |
| Hex                                  | 1DF2 | 5DF2  | BBE4  |       | 1 Loop 1 Secondary Control ON = LED 1 ON                                  |
|                                      |      |       |       |       | 2 Loop 2 Primary Control ON = LED 1 ON                                    |
|                                      |      |       |       |       | 3 Loop 2 Secondary Control ON = LED 1 ON                                  |
|                                      |      |       |       |       | 4 Loop 1 VMD Open ON = LED 1 ON                                           |
|                                      |      |       |       |       | 5 Loop 1 VMD Close ON = LED 1 ON                                          |
|                                      |      |       |       |       | 6 Loop 2 VMD Open ON = LED 1 ON                                           |
|                                      |      |       |       |       | 7 Loop 2 VMD Close ON = LED 1 ON                                          |
|                                      |      |       |       |       | 8 Alarm/Events/Digital/Control (Logical <b>OR</b> of selection below)     |
|                                      |      |       |       |       | 9 Alarm/Events/Digital/Control inverted (Logical <b>NOR</b> of selection) |

Value 8 (Logical **OR** selection of Alarm/Events/Digital/Control) turns **ON** the LED if any of the selected alarms, events, inputs or functions are active.

Value 9 (Logical **NOR** selection of Alarm/Events/Digital/Control) turns **OFF** the LED if any of the selected alarms, events, inputs or functions are active.

**Note:** Pre-tune will flash the LED instead of turning it on, but flashing will be obscured if used in conjunction with other functions when they are on.

| LED 3 Alarm Indication               |      |       |       | Bit   | If bit =1, Alarm <i>n</i> status is selected                          |
|--------------------------------------|------|-------|-------|-------|-----------------------------------------------------------------------|
| Dec                                  | 7706 | 24090 | 48180 | RW    | 0 Alarm 1                                                             |
| Hex                                  | 1E1A | 5E1A  | BC34  |       | 1 Alarm 2                                                             |
|                                      |      |       |       |       | 2 Alarm 3                                                             |
|                                      |      |       |       |       | 3 Alarm 4                                                             |
|                                      |      |       |       |       | 4 Alarm 5                                                             |
|                                      |      |       |       |       | 5 Alarm 6                                                             |
|                                      |      |       |       |       | 6 Alarm 7                                                             |
| LED 3 Event Indication               |      |       |       | Bit   | If bit =1, Event <i>n</i> status is selected                          |
| Dec                                  | 7708 | 24092 | 48184 | RW    | 0 Event 1                                                             |
| Hex                                  | 1E1C | 5E1C  | BC38  |       | 1 Event 2                                                             |
|                                      |      |       |       |       | 2 Event 3                                                             |
|                                      |      |       |       |       | 3 Event 4                                                             |
|                                      |      |       |       |       | 4 Event 5                                                             |
|                                      |      |       |       |       | 5 Profile Running                                                     |
|                                      |      |       |       |       | 6 Profile End                                                         |
| LED 3 Slot A & Soft Input Indication |      |       |       | Bit   | If bit =1, Digital A / Soft Input <i>n</i> status is selected         |
| Dec                                  | 7710 | 24094 | 48188 | RW    | 0 Digital Input A                                                     |
| Hex                                  | 1E1E | 5E1E  | BC3C  |       | 1 Soft Digital 1                                                      |
|                                      |      |       |       |       | 2 Soft Digital 2                                                      |
|                                      |      |       |       |       | 3 Soft Digital 3                                                      |
|                                      |      |       |       |       | 4 Soft Digital 4                                                      |
| LED 3 Option C Digital Indication    |      |       |       | Bit   | If bit =1, Digital <i>Cn</i> status is selected                       |
| Dec                                  | 7712 | 24096 | 48192 | RW    | 0 Digital Input C1                                                    |
| Hex                                  | 1E20 | 5E20  | BC40  |       | 1 Digital Input C2                                                    |
|                                      |      |       |       |       | 2 Digital Input C3                                                    |
|                                      |      |       |       |       | 3 Digital Input C4                                                    |
|                                      |      |       |       |       | 4 Digital Input C5                                                    |
|                                      |      |       |       |       | 5 Digital Input C6                                                    |
|                                      |      |       |       |       | 6 Digital Input C7                                                    |
| LED 3 Control Indication             |      |       |       | Bit   | If bit =1, the function's status is selected                          |
| Dec                                  | 7648 | 24032 | 48064 | RW    | 0 Loop 1 Auto Tune (self-tune=On, pre-tune=flashing)                  |
| Hex                                  | 1DE0 | 5DE0  | BBC0  |       | 1 Loop 1 Manual Control                                               |
|                                      |      |       |       |       | 2 Loop 2 Auto Tune (self-tune=On, pre-tune=flashing)                  |
|                                      |      |       |       |       | 3 Loop 2 Manual Control                                               |
| LED 4 Usage                          |      |       |       | Value | LED 4 Usage. For 8 & 9 see also LED 4 Selections.                     |
| Dec                                  | 7667 | 24051 | 48102 | RW    | 0 Loop 1 Primary Control ON = LED 1 ON                                |
| Hex                                  | 1DF3 | 5DF3  | BBE6  |       | 1 Loop 1 Secondary Control ON = LED 1 ON                              |
|                                      |      |       |       |       | 2 Loop 2 Primary Control ON = LED 1 ON                                |
|                                      |      |       |       |       | 3 Loop 2 Secondary Control ON = LED 1 ON                              |
|                                      |      |       |       |       | 4 Loop 1 VMD Open ON = LED 1 ON                                       |
|                                      |      |       |       |       | 5 Loop 1 VMD Close ON = LED 1 ON                                      |
|                                      |      |       |       |       | 6 Loop 2 VMD Open ON = LED 1 ON                                       |
|                                      |      |       |       |       | 7 Loop 2 VMD Close ON = LED 1 ON                                      |
|                                      |      |       |       |       | 8 Alarm/Events/Digital/Control (Logical <b>OR</b> of selection below) |

|                                                                                                                                                                             |      |       |       |            |                                                                         |                                                    |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|-------|-------|------------|-------------------------------------------------------------------------|----------------------------------------------------|
|                                                                                                                                                                             |      |       |       | 9          | Alarm/Events/Digital/Control inverted (Logical <b>NOR</b> of selection) |                                                    |
| Value 8 (Logical <b>OR</b> selection of Alarm/Events/Digital/Control) turns <b>ON</b> the LED if <u>any</u> of the selected alarms, events, inputs or functions are active. |      |       |       |            |                                                                         |                                                    |
| Value 9 (Logical <b>NOR</b> selection of Alarm/Events/Digital/Control) turns <b>OFF</b> the LED if any of the selected alarms, events, inputs or functions are active.      |      |       |       |            |                                                                         |                                                    |
| <b>Note:</b> Pre-tune will flash the LED instead of turning it on, but flashing will be obscured if used in conjunction with other functions when they are on.              |      |       |       |            |                                                                         |                                                    |
| <b>LED 4 Alarm Indication</b>                                                                                                                                               |      |       |       | <b>Bit</b> | <b>If bit =1, Alarm <i>n</i> status is selected</b>                     |                                                    |
| Dec                                                                                                                                                                         | 7714 | 24098 | 48196 | RW         | 0                                                                       | Alarm 1                                            |
| Hex                                                                                                                                                                         | 1E22 | 5E22  | BC44  |            | 1                                                                       | Alarm 2                                            |
|                                                                                                                                                                             |      |       |       |            | 2                                                                       | Alarm 3                                            |
|                                                                                                                                                                             |      |       |       |            | 3                                                                       | Alarm 4                                            |
|                                                                                                                                                                             |      |       |       |            | 4                                                                       | Alarm 5                                            |
|                                                                                                                                                                             |      |       |       |            | 5                                                                       | Alarm 6                                            |
|                                                                                                                                                                             |      |       |       |            | 6                                                                       | Alarm 7                                            |
| <b>LED 4 Event Indication</b>                                                                                                                                               |      |       |       | <b>Bit</b> | <b>If bit =1, Event <i>n</i> status is selected</b>                     |                                                    |
| Dec                                                                                                                                                                         | 7716 | 24100 | 48200 | RW         | 0                                                                       | Event 1                                            |
| Hex                                                                                                                                                                         | 1E24 | 5E24  | BC48  |            | 1                                                                       | Event 2                                            |
|                                                                                                                                                                             |      |       |       |            | 2                                                                       | Event 3                                            |
|                                                                                                                                                                             |      |       |       |            | 3                                                                       | Event 4                                            |
|                                                                                                                                                                             |      |       |       |            | 4                                                                       | Event 5                                            |
|                                                                                                                                                                             |      |       |       |            | 5                                                                       | Profile Running                                    |
|                                                                                                                                                                             |      |       |       |            | 6                                                                       | Profile End                                        |
| <b>LED 4 Slot A &amp; Soft Input Indication</b>                                                                                                                             |      |       |       | <b>Bit</b> | <b>If bit =1, Digital A / Soft Input <i>n</i> status is selected</b>    |                                                    |
| Dec                                                                                                                                                                         | 7718 | 24102 | 48204 | RW         | 0                                                                       | Digital Input A                                    |
| Hex                                                                                                                                                                         | 1E26 | 5E26  | BC4C  |            | 1                                                                       | Soft Digital 1                                     |
|                                                                                                                                                                             |      |       |       |            | 2                                                                       | Soft Digital 2                                     |
|                                                                                                                                                                             |      |       |       |            | 3                                                                       | Soft Digital 3                                     |
|                                                                                                                                                                             |      |       |       |            | 4                                                                       | Soft Digital 4                                     |
| <b>LED 4 Option C Digital Indication</b>                                                                                                                                    |      |       |       | <b>Bit</b> | <b>If bit =1, Digital <i>Cn</i> status is selected</b>                  |                                                    |
| Dec                                                                                                                                                                         | 7720 | 24104 | 48208 | RW         | 0                                                                       | Digital Input C1                                   |
| Hex                                                                                                                                                                         | 1E28 | 5E28  | BC50  |            | 1                                                                       | Digital Input C2                                   |
|                                                                                                                                                                             |      |       |       |            | 2                                                                       | Digital Input C3                                   |
|                                                                                                                                                                             |      |       |       |            | 3                                                                       | Digital Input C4                                   |
|                                                                                                                                                                             |      |       |       |            | 4                                                                       | Digital Input C5                                   |
|                                                                                                                                                                             |      |       |       |            | 5                                                                       | Digital Input C6                                   |
|                                                                                                                                                                             |      |       |       |            | 6                                                                       | Digital Input C7                                   |
| <b>LED 4 Control Indication</b>                                                                                                                                             |      |       |       | <b>Bit</b> | <b>If bit =1, the function's status is selected</b>                     |                                                    |
| Dec                                                                                                                                                                         | 7650 | 24034 | 48068 | RW         | 0                                                                       | Loop 1 Auto Tune (self-tune=On, pre-tune=flashing) |
| Hex                                                                                                                                                                         | 1DE2 | 5DE2  | BBC4  |            | 1                                                                       | Loop 1 Manual Control                              |
|                                                                                                                                                                             |      |       |       |            | 2                                                                       | Loop 2 Auto Tune (self-tune=On, pre-tune=flashing) |
|                                                                                                                                                                             |      |       |       |            | 3                                                                       | Loop 2 Manual Control                              |

| Backlight Color           |      |       |       |    | Value                                                                                    | Display Backlight Color               |
|---------------------------|------|-------|-------|----|------------------------------------------------------------------------------------------|---------------------------------------|
| Dec                       | 7668 | 24052 | 48104 | RW | 0                                                                                        | Green to Red if any output is latched |
| Hex                       | 1DF4 | 5DF4  | BBE8  |    | 1                                                                                        | Red to Green if any output is latched |
|                           |      |       |       |    | 2                                                                                        | Green to Red if any alarm active      |
|                           |      |       |       |    | 3                                                                                        | Red to Green if any alarm active      |
|                           |      |       |       |    | 4                                                                                        | Permanent Green                       |
|                           |      |       |       |    | 5                                                                                        | Permanent Red                         |
| Display Language          |      |       |       |    | Value                                                                                    | Select Display Language               |
| Dec                       | 7675 | 24059 | 48118 | RW | 0                                                                                        | Main Display Language                 |
| Hex                       | 1DFB | 5DFB  | BBF6  |    | 1                                                                                        | Alternate Display Language            |
| Display Contrast          |      |       |       |    | Display Contrast Value                                                                   |                                       |
| Dec                       | 7676 | 24060 | 48120 | RW | Screen contrast adjustment to improve clarity.<br>10 to 100 with 100 = maximum contrast. |                                       |
| Hex                       | 1DFC | 5DFC  | BBF8  |    |                                                                                          |                                       |
| Invert Display            |      |       |       |    | Value                                                                                    | Normal Or Inverted Display            |
| Dec                       | 7677 | 24061 | 48122 | RW | 0                                                                                        | Normal Display                        |
| Hex                       | 1DFD | 5DFD  | BBFA  |    | 1                                                                                        | Inverted Display                      |
| Setup Lock Code           |      |       |       |    | Setup Mode Entry Passcode                                                                |                                       |
| Dec                       | 7678 | 24062 | 48124 | RW | 1 to 9999. Default is 10                                                                 |                                       |
| Hex                       | 1DFE | 5DFE  | BBFC  |    |                                                                                          |                                       |
| Configuration Lock Code   |      |       |       |    | Configuration Mode Entry Passcode                                                        |                                       |
| Dec                       | 7679 | 24063 | 48126 | RW | 1 to 9999. Default is 10                                                                 |                                       |
| Hex                       | 1DFF | 5DFF  | BBFE  |    |                                                                                          |                                       |
| Tuning Lock Code          |      |       |       |    | Automatic Tuning Mode Entry Passcode                                                     |                                       |
| Dec                       | 7680 | 24064 | 48128 | RW | 1 to 9999. Default is 10                                                                 |                                       |
| Hex                       | 1E00 | 5E00  | BC00  |    |                                                                                          |                                       |
| Supervisor Lock Code      |      |       |       |    | Supervisor Mode Entry Passcode                                                           |                                       |
| Dec                       | 7681 | 24065 | 48130 | RW | 1 to 9999. Default is 10                                                                 |                                       |
| Hex                       | 1E01 | 5E01  | BC02  |    |                                                                                          |                                       |
| Profiler Setup Lock Code  |      |       |       |    | Profiler Setup Mode Entry Passcode                                                       |                                       |
| Dec                       | 7682 | 24066 | 48132 | RW | 1 to 9999. Default is 10                                                                 |                                       |
| Hex                       | 1E02 | 5E02  | BC04  |    |                                                                                          |                                       |
| USB Lock Code             |      |       |       |    | USB Mode Entry Passcode                                                                  |                                       |
| Dec                       | 7683 | 24067 | 48134 | RW | 1 to 9999. Default is 10                                                                 |                                       |
| Hex                       | 1E03 | 5E03  | BC06  |    |                                                                                          |                                       |
| Recorder Lock Code        |      |       |       |    | Recorder Control Mode Entry Passcode                                                     |                                       |
| Dec                       | 7684 | 24068 | 48136 | RW | 1 to 9999. Default is 10                                                                 |                                       |
| Hex                       | 1E04 | 5E04  | BC08  |    |                                                                                          |                                       |
| Profile Control Lock Code |      |       |       |    | Profile Control Mode Entry Passcode                                                      |                                       |
| Dec                       | 7688 | 24072 | 48144 | RW | 1 to 9999. Default is 10                                                                 |                                       |
| Hex                       | 1E08 | 5E08  | BC10  |    |                                                                                          |                                       |
| Read Only Operation Mode  |      |       |       |    | Value                                                                                    | Read Only Operation Mode              |
| Dec                       | 7685 | 24069 | 48138 | RW | 0                                                                                        | Operation Mode Read/Write             |
| Hex                       | 1E05 | 5E05  | BC0A  |    | 1                                                                                        | Operation Mode Read Only              |

| Loop 1 Trend View Sample Rate      |      |       |       |    | Value | Trend Sample Interval For Loop 1               |
|------------------------------------|------|-------|-------|----|-------|------------------------------------------------|
| Dec                                | 9000 | 25384 | 50768 | RW | 0     | Every Second                                   |
| Hex                                | 2328 | 6328  | C650  |    | 1     | Every 2 Seconds                                |
|                                    |      |       |       |    | 2     | Every 5 Seconds                                |
|                                    |      |       |       |    | 3     | Every 10 Seconds                               |
|                                    |      |       |       |    | 4     | Every 15 Seconds                               |
|                                    |      |       |       |    | 5     | Every 30 Seconds                               |
|                                    |      |       |       |    | 6     | Every Minute                                   |
|                                    |      |       |       |    | 7     | Every 2 Minutes                                |
|                                    |      |       |       |    | 8     | Every 5 Minutes                                |
|                                    |      |       |       |    | 9     | Every 10 Minutes                               |
|                                    |      |       |       |    | 10    | Every 15 Minutes                               |
|                                    |      |       |       |    | 11    | Every 30 Minutes                               |
| Loop 1 Trend View Data             |      |       |       |    | Value | Values To Display In Loop 1 Trend View         |
| Dec                                | 9001 | 25385 | 50770 | RW | 1     | Process variable only                          |
| Hex                                | 2329 | 6329  | C652  |    | 2     | Process variable and setpoint                  |
|                                    |      |       |       |    | 3     | Max & min process value since last sample      |
| Loop 1 Trend View in Operator Mode |      |       |       |    | Value | Trend View For Loop 1 Visible In Operator Mode |
| Dec                                | 9007 | 25391 | 50782 | RW | 0     | No                                             |
| Hex                                | 232F | 632F  | C65E  |    | 1     | Yes                                            |
| Loop 2 Trend View Sample Rate      |      |       |       |    | Value | Trend Sample Interval For Loop 2               |
| Dec                                | 9010 | 25394 | 50788 | RW | 0     | Every Second                                   |
| Hex                                | 2332 | 6332  | C664  |    | 1     | Every 2 Seconds                                |
|                                    |      |       |       |    | 2     | Every 5 Seconds                                |
|                                    |      |       |       |    | 3     | Every 10 Seconds                               |
|                                    |      |       |       |    | 4     | Every 15 Seconds                               |
|                                    |      |       |       |    | 5     | Every 30 Seconds                               |
|                                    |      |       |       |    | 6     | Every Minute                                   |
|                                    |      |       |       |    | 7     | Every 2 Minutes                                |
|                                    |      |       |       |    | 8     | Every 5 Minutes                                |
|                                    |      |       |       |    | 9     | Every 10 Minutes                               |
|                                    |      |       |       |    | 10    | Every 15 Minutes                               |
|                                    |      |       |       |    | 11    | Every 30 Minutes                               |
| Loop 2 Trend View Data             |      |       |       |    | Value | Values To Display In Loop 2 Trend View         |
| Dec                                | 9011 | 25395 | 50790 | RW | 1     | Process variable only                          |
| Hex                                | 2333 | 6333  | C666  |    | 2     | Process variable and setpoint                  |
|                                    |      |       |       |    | 3     | Max & min process value since last sample      |
| Loop 1 Trend View in Operator Mode |      |       |       |    | Value | Trend View For Loop 2 Visible In Operator Mode |
| Dec                                | 9017 | 25401 | 50802 | RW | 0     | No                                             |
| Hex                                | 2339 | 6339  | C672  |    | 1     | Yes                                            |

#### 20.4.21 Instrument Data Parameters

| Parameter Name & Register Address |         |        |       |        |                                                       |                |
|-----------------------------------|---------|--------|-------|--------|-------------------------------------------------------|----------------|
|                                   | Integer | Int +1 | Float | Access | Values                                                | & Descriptions |
| Serial Number 1                   |         |        |       |        | Serial Number (part 1)                                |                |
| Dec                               | 210     | 16594  | 33188 | RO     | The first 4 digits of the instrument's Serial number. |                |
| Hex                               | 00D2    | 40D2   | 81A4  |        |                                                       |                |
| Serial Number 2                   |         |        |       |        | Serial Number (part 2)                                |                |

|                      |      |       |       |                                                                                                                                                                                                                      |                                                                                                                             |                      |    |
|----------------------|------|-------|-------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------|----------------------|----|
| Dec                  | 211  | 16595 | 33190 | RO                                                                                                                                                                                                                   | The digits 5 to 8 of the instrument's Serial number.                                                                        |                      |    |
| Hex                  | 00D3 | 40D3  | 81A6  |                                                                                                                                                                                                                      |                                                                                                                             |                      |    |
| Serial Number 3      |      |       |       | Serial Number (part 3)                                                                                                                                                                                               |                                                                                                                             |                      |    |
| Dec                  | 212  | 16596 | 33192 | RO                                                                                                                                                                                                                   | The digits 9 to 11 of the instrument's Serial number.                                                                       |                      |    |
| Hex                  | 00D4 | 40D4  | 81A8  |                                                                                                                                                                                                                      |                                                                                                                             |                      |    |
| Serial Number 4      |      |       |       | Serial Number (part 4)                                                                                                                                                                                               |                                                                                                                             |                      |    |
| Dec                  | 213  | 16597 | 33194 | RO                                                                                                                                                                                                                   | The digits 12 to 14 of the instrument's Serial number.                                                                      |                      |    |
| Hex                  | 00D5 | 40D5  | 81AA  |                                                                                                                                                                                                                      |                                                                                                                             |                      |    |
| Manufacture Day      |      |       |       | Day Of Manufacture                                                                                                                                                                                                   |                                                                                                                             |                      |    |
| Dec                  | 370  | 16754 | 33508 | RO                                                                                                                                                                                                                   | Date of manufacture – 1 to 31 (day of month)                                                                                |                      |    |
| Hex                  | 0172 | 4172  | 82E4  |                                                                                                                                                                                                                      |                                                                                                                             |                      |    |
| Manufacture Month    |      |       |       | Month Of Manufacture                                                                                                                                                                                                 |                                                                                                                             |                      |    |
| Dec                  | 371  | 16755 | 33510 | RO                                                                                                                                                                                                                   | Month of manufacture – 1 to 12                                                                                              |                      |    |
| Hex                  | 0173 | 4173  | 82E6  |                                                                                                                                                                                                                      |                                                                                                                             |                      |    |
| Manufacture Year     |      |       |       | Year Of Manufacture                                                                                                                                                                                                  |                                                                                                                             |                      |    |
| Dec                  | 372  | 16756 | 33512 | RO                                                                                                                                                                                                                   | 4 digit number = Year of manufacture (e.g. 2013)                                                                            |                      |    |
| Hex                  | 0174 | 4174  | 82E8  |                                                                                                                                                                                                                      |                                                                                                                             |                      |    |
| USB Option Fitted    |      |       |       | Value                                                                                                                                                                                                                | USB Option                                                                                                                  |                      |    |
| Dec                  | 7503 | 23887 | 47774 | RO                                                                                                                                                                                                                   | 0                                                                                                                           | Not Fitted           |    |
| Hex                  | 1D4F | 5D4F  | BA9E  |                                                                                                                                                                                                                      | 1                                                                                                                           | Fitted               |    |
| Data Recorder Fitted |      |       |       | Value                                                                                                                                                                                                                | Data Recorder Fitted                                                                                                        |                      |    |
| Dec                  | 7553 | 23937 | 47874 | RO                                                                                                                                                                                                                   | 0                                                                                                                           | Not Fitted           |    |
| Hex                  | 1D81 | 5D81  | BB02  |                                                                                                                                                                                                                      | 1                                                                                                                           | Fitted               |    |
| Profiler Enabled     |      |       |       | Value                                                                                                                                                                                                                | Profiler Feature Enabled                                                                                                    |                      |    |
| Dec                  | 8199 | 24583 | 49166 | RO                                                                                                                                                                                                                   | 0                                                                                                                           | Profiler Not Enabled |    |
| Hex                  | 2007 | 6007  | C00E  |                                                                                                                                                                                                                      | 1                                                                                                                           | Profiler Enabled     |    |
| Software PRL         |      |       |       | Product Revision Level (Firmware)                                                                                                                                                                                    |                                                                                                                             |                      |    |
| Dec                  | 208  | 16592 | 33184 | RO                                                                                                                                                                                                                   | A 4 character ASCII string incremented with each update. Starting 0x20 (space) & ending 0x0, (e.g “ 0P” is 20, 30, 50, 00)  |                      |    |
| Hex                  | 00D0 | 40D0  | 81A0  |                                                                                                                                                                                                                      |                                                                                                                             |                      |    |
| Hardware PRL         |      |       |       | Product Revision Level (Hardware)                                                                                                                                                                                    |                                                                                                                             |                      |    |
| Dec                  | 207  | 16591 | 33182 | RO                                                                                                                                                                                                                   | A 4 character ASCII string incremented with each update. Starting 0x20 (space) & ending 0x0, (e.g “ 02” is 20, 30, 32, 00)  |                      |    |
| Hex                  | 00CF | 40CF  | 819E  |                                                                                                                                                                                                                      |                                                                                                                             |                      |    |
| Firmware Type        |      |       |       | Product Firmware Type Reference Number                                                                                                                                                                               |                                                                                                                             |                      |    |
| Dec                  | 217  | 16601 | 33202 | RO                                                                                                                                                                                                                   | A 6 character ASCII string starting with 0x20 (space) & ending 0x0, (e.g type “ 406A” is 20, 34, 30, 36, 43, 00)            |                      |    |
| Hex                  | 00D9 | 40D9  | 81B2  |                                                                                                                                                                                                                      |                                                                                                                             |                      |    |
| Firmware Version     |      |       |       | Product Firmware Revision Number                                                                                                                                                                                     |                                                                                                                             |                      |    |
| Dec                  | 218  | 16602 | 33204 | RO                                                                                                                                                                                                                   | A 6 character ASCII string starting with 1 or more spaces (0x20), (e.g type “ 3.0” is 20, 20, 33, 2E, 36, 30, 00)           |                      |    |
| Hex                  | 00DA | 40DA  | 81B4  |                                                                                                                                                                                                                      |                                                                                                                             |                      |    |
| Contact Details 1    |      |       |       | “For Service” Contact Details - Lines 1 to 7                                                                                                                                                                         |                                                                                                                             |                      |    |
| Dec                  | 400  | 16784 | 33568 | RW                                                                                                                                                                                                                   | 7 lines of user definable text - 25 ASCII characters per line which can be read or written using Modbus functions 16 or 23. |                      |    |
| Hex                  | 0190 | 4190  | 8320  |                                                                                                                                                                                                                      |                                                                                                                             |                      |    |
| Contact Details 2    |      |       |       | <b>Note:</b> The number of ASCII characters transmitted per line must be EVEN. If the text string you wish to send has an odd number, place an additional space character at the end. The space character is 20 hex. |                                                                                                                             |                      |    |
| Dec                  | 401  | 16785 | 33570 |                                                                                                                                                                                                                      |                                                                                                                             |                      | RW |
| Hex                  | 0191 | 4191  | 8322  |                                                                                                                                                                                                                      |                                                                                                                             |                      |    |
| Contact Details 3    |      |       |       | Valid characters are 0 to 9, a to z, A to Z, plus ß ö ( ) - and _.                                                                                                                                                   |                                                                                                                             |                      |    |
| Dec                  | 402  | 16786 | 33572 |                                                                                                                                                                                                                      |                                                                                                                             |                      | RW |

|                   |      |       |       |    |
|-------------------|------|-------|-------|----|
| Hex               | 0192 | 4192  | 8324  |    |
| Contact Details 4 |      |       |       |    |
| Dec               | 403  | 16787 | 33574 | RW |
| Hex               | 0193 | 4193  | 8326  |    |
| Contact Details 5 |      |       |       |    |
| Dec               | 404  | 16788 | 33576 | RW |
| Hex               | 0194 | 4194  | 8328  |    |
| Contact Details 6 |      |       |       |    |
| Dec               | 405  | 16789 | 33578 | RW |
| Hex               | 0195 | 4195  | 832A  |    |
| Contact Details 7 |      |       |       |    |
| Dec               | 406  | 16790 | 33580 | RW |
| Hex               | 0196 | 4196  | 832C  |    |

Example. To write **"My Company Name"** to line 1 send:  
 [ADDRESS], 16, 01, 90, 00, 08, 10, **4D, 79, 20, 43, 6F, 6D, 70,**  
**61, 6E, 79, 20, 4E, 61, 6D, 65, 20,** [CRC]

## 20.4.22 Profiler Control & Status Parameters

| Parameter Name & Register Address                                                                                                                                    |         |        |       |                        |                                                               |                                               |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------|--------|-------|------------------------|---------------------------------------------------------------|-----------------------------------------------|
|                                                                                                                                                                      | Integer | Int +1 | Float | Access                 | Values                                                        | & Descriptions                                |
| Active Profiler                                                                                                                                                      |         |        |       | Active Profiler Number |                                                               |                                               |
| Dec                                                                                                                                                                  | 8243    | 24627  | 49254 | RW                     | Currently selected profile number (0 to 63)                   |                                               |
| Hex                                                                                                                                                                  | 2033    | 6033   | C066  |                        |                                                               |                                               |
| Active Segment                                                                                                                                                       |         |        |       | Active Segment Number  |                                                               |                                               |
| Dec                                                                                                                                                                  | 8244    | 24628  | 49256 | RO                     | The active segment number (1 to 255) of the selected profile. |                                               |
| Hex                                                                                                                                                                  | 2034    | 6034   | C068  |                        |                                                               |                                               |
| Profiler Control Commands                                                                                                                                            |         |        |       |                        | Value                                                         | Profiler Command                              |
| Dec                                                                                                                                                                  | 8245    | 24629  | 49258 | RW                     | 0                                                             | Do nothing                                    |
| Hex                                                                                                                                                                  | 2035    | 6035   | C06A  |                        | 1                                                             | Run the currently selected profile            |
| <b>Note:</b> The Profiler Control Commands <u>must</u> be followed by a Profiler Control Confirmation Action command, otherwise the command will not be implemented. |         |        |       |                        | 2                                                             | Hold the currently running profile            |
|                                                                                                                                                                      |         |        |       |                        | 3                                                             | Abort the currently running profile           |
|                                                                                                                                                                      |         |        |       |                        | 4                                                             | Jump to the next segment                      |
|                                                                                                                                                                      |         |        |       |                        | 5                                                             | Release the hold                              |
|                                                                                                                                                                      |         |        |       |                        | 6                                                             | Exit profiler, return to controller mode      |
|                                                                                                                                                                      |         |        |       |                        | 8                                                             | Select a profile to be run but not start it   |
| Profiler Control Confirmation Action                                                                                                                                 |         |        |       |                        | Value                                                         | Implement Profiler Command                    |
| Dec                                                                                                                                                                  | 8257    | 24641  | 49282 | RW                     | 0                                                             | Do not Implement Command                      |
| Hex                                                                                                                                                                  | 2041    | 6041   | C082  |                        | 1                                                             | Implement previous Profiler Command           |
| Enable Edit While Running                                                                                                                                            |         |        |       |                        | Value                                                         | Operator Editing of Current Running Profile   |
| Dec                                                                                                                                                                  | 8262    | 24646  | 49292 | RW                     | 0                                                             | Editing of running profile forbidden          |
| Hex                                                                                                                                                                  | 2046    | 6046   | C08C  |                        | 1                                                             | Editing of running profile via Keypad allowed |
| Operator Access To Profile Control                                                                                                                                   |         |        |       |                        | Value                                                         | Profile Control From Operation Mode           |
| Dec                                                                                                                                                                  | 8260    | 24644  | 49288 | RW                     | 0                                                             | Operation Mode profile control disabled       |
| Hex                                                                                                                                                                  | 2044    | 6044   | C088  |                        | 1                                                             | Operation Mode profile control enabled        |
| Profile Cycles Run                                                                                                                                                   |         |        |       |                        | Profile Cycles Run Status                                     |                                               |
| Dec                                                                                                                                                                  | 8247    | 24631  | 49262 | RO                     | The Number of times the currently running profile has cycled  |                                               |
| Hex                                                                                                                                                                  | 2037    | 6037   | C06E  |                        |                                                               |                                               |
| Event 1 Status                                                                                                                                                       |         |        |       |                        | Value                                                         | Status Of Event 1                             |
| Dec                                                                                                                                                                  | 8249    | 24633  | 49266 | RO                     | 0                                                             | Event 1 Inactive                              |
| Hex                                                                                                                                                                  | 2039    | 6039   | C072  |                        | 1                                                             | Event 1 Active                                |

| Event 2 Status           |      |       |       |    | Value                                                                                  | Status Of Event 2                                      |
|--------------------------|------|-------|-------|----|----------------------------------------------------------------------------------------|--------------------------------------------------------|
| Dec                      | 8250 | 24634 | 49268 | RO | 0                                                                                      | Event 2 Inactive                                       |
| Hex                      | 203A | 603A  | C074  |    | 1                                                                                      | Event 2 Active                                         |
| Event 3 Status           |      |       |       |    | Value                                                                                  | Status Of Event 3                                      |
| Dec                      | 8251 | 24635 | 49270 | RO | 0                                                                                      | Event 3 Inactive                                       |
| Hex                      | 203B | 603B  | C076  |    | 1                                                                                      | Event 3 Active                                         |
| Event 4 Status           |      |       |       |    | Value                                                                                  | Status Of Event 4                                      |
| Dec                      | 8252 | 24636 | 49272 | RO | 0                                                                                      | Event 4 Inactive                                       |
| Hex                      | 203C | 603C  | C078  |    | 1                                                                                      | Event 4 Active                                         |
| Event 5 Status           |      |       |       |    | Value                                                                                  | Status Of Event 5                                      |
| Dec                      | 8253 | 24637 | 49274 | RO | 0                                                                                      | Event 5 Inactive                                       |
| Hex                      | 203D | 603D  | C07A  |    | 1                                                                                      | Event 5 Active                                         |
| Segment Type Status      |      |       |       |    | Value                                                                                  | The Current Running Profile Segment Type               |
| Dec                      | 8258 | 24642 | 49284 | RO | 0                                                                                      | No segment                                             |
| Hex                      | 2042 | 6042  | C084  |    | 1                                                                                      | Setpoint ramping up                                    |
|                          |      |       |       |    | 2                                                                                      | Step                                                   |
|                          |      |       |       |    | 3                                                                                      | Dwell                                                  |
|                          |      |       |       |    | 4                                                                                      | Held                                                   |
|                          |      |       |       |    | 5                                                                                      | Loop                                                   |
|                          |      |       |       |    | 6                                                                                      | Join                                                   |
|                          |      |       |       |    | 7                                                                                      | End                                                    |
|                          |      |       |       |    | 8                                                                                      | Setpoint ramping down                                  |
| Active Profile Name      |      |       |       |    | Name of Currently Selected Profile                                                     |                                                        |
| Dec                      | 8259 | 24643 | 49286 | RO | The name of the currently selected profile                                             |                                                        |
| Hex                      | 2043 | 6043  | C086  |    |                                                                                        |                                                        |
| Secondary Profile Status |      |       |       |    | Value                                                                                  | Secondary Profile Status of Selected Profile           |
| Dec                      | 8232 | 24616 | 49232 | RO | 0                                                                                      | Profile running                                        |
| Hex                      | 2028 | 6028  | C050  |    | 1                                                                                      | Input sensor break                                     |
|                          |      |       |       |    | 2                                                                                      | Profile not valid                                      |
|                          |      |       |       |    | 3                                                                                      | Controller in manual mode                              |
|                          |      |       |       |    | 4                                                                                      | Profile finished and maintaining last profile setpoint |
|                          |      |       |       |    | 5                                                                                      | Profile finished with control outputs off              |
|                          |      |       |       | 6  | Profile control has ended. Unit is Controller Mode.                                    |                                                        |
| Delay time               |      |       |       |    | Remaining Profile Delay Time                                                           |                                                        |
| Dec                      | 8233 | 24617 | 49234 | RO | The current start delay time remaining in seconds, before selected profile will begin. |                                                        |
| Hex                      | 2029 | 6029  | C052  |    |                                                                                        |                                                        |

| Current Profile Running Time   |      |       |       | Current Profile Running Time         |                                                                                                  |
|--------------------------------|------|-------|-------|--------------------------------------|--------------------------------------------------------------------------------------------------|
| Dec                            | 8235 | 24619 | 49238 | RO                                   | The elapsed time of the current running profile in seconds since it began running.               |
| Hex                            | 202B | 602B  | C056  |                                      |                                                                                                  |
| Current Profile Remaining Time |      |       |       | Current Profile Remaining Time       |                                                                                                  |
| Dec                            | 8236 | 24620 | 49240 | RO                                   | The remaining time for the current running profile before reaching its end segment, in seconds   |
| Hex                            | 202C | 602C  | C058  |                                      |                                                                                                  |
| Current Segment Running Time   |      |       |       | Current Segment Running Time         |                                                                                                  |
| Dec                            | 8237 | 24621 | 49242 | RO                                   | The elapsed time of the current profile segment in seconds                                       |
| Hex                            | 202D | 602D  | C05A  |                                      |                                                                                                  |
| Current Segment Remaining Time |      |       |       | Current Segment Remaining Time       |                                                                                                  |
| Dec                            | 8238 | 24622 | 49244 | RO                                   | The remaining time for the current profile segment in seconds                                    |
| Hex                            | 202E | 602E  | C05C  |                                      |                                                                                                  |
| Total Hold Time                |      |       |       | Total Hold Time                      |                                                                                                  |
| Dec                            | 8239 | 24623 | 49246 | RO                                   | Total (accumulated) time the current profile has been held in seconds                            |
| Hex                            | 202F | 602F  | C05E  |                                      |                                                                                                  |
| Current Segment Loops Run      |      |       |       | Number of Current Segment Loop-backs |                                                                                                  |
| Dec                            | 8240 | 24624 | 49248 | RO                                   | The number of times the current looping segment has looped back                                  |
| Hex                            | 2030 | 6030  | C060  |                                      |                                                                                                  |
| Profile Setup                  |      |       |       | Profile Setup via Modbus             |                                                                                                  |
| Dec                            | 8198 | 24582 | 49164 | RW                                   | Note: Refer to the Profile Setup Over Modbus information below for setting up profiles via comms |
| Hex                            | 2006 | 6006  | C00C  |                                      |                                                                                                  |

### 20.4.23 Profile Setup via Modbus

The information in this section is intended for advanced users writing their own software code. Most users will create or edit profiles using the instrument keypad, or using the the PC software (available from your supplier). Either method allows quick and easy editing of profiles.



**Note:** There is a global block on profile creation or editing via Modbus while a profile is running. An attempt to do so returns the error code 0x15. The only profile related commands allowed while a profile runs are the Profile Control & Status Parameters in the previous section.

Advanced users can setup or edit profiles by writing to the Profile Configuration parameter at address 8198 (0x2006). This can only be accessed by using Modbus function code 23 (0x17). The instrument replies with a status message.

When creating a new profile the steps below must be followed exactly, either to create a profile at the next available position, or at the position you specify.

Each message in the sequence includes a 2 byte Command Code that tells the instrument the purpose of the message, and therefore the meaning of the data contained in it.

#### 20.4.23.1 Instruction Sequence to create a profile at the next available position

1. Create a profile by writing the profile header data using the Command Code value CP (0x43, 0x50). This starts the profile creation process by reserving a profile memory slot. The profile number is returned by the instrument in the Edit Response Message.
2. Write the first segment using the Command Code value Code WS (0x57, 0x53). This command will fill the next available segment position and link it to the profile created in step 1.
3. Write the second segment, again using Command Code WS. This fills the next available segment position and links it to the segment created in step 2.

4. Continue writing segments until the profile is complete (whilst remaining within the overall limit of 255 segments for all profiles combined). Each of these segments fills the next available position and links it to the previous segment specified.
5. The very last segment of the profile must be one of the end type segments. Thereafter, no more segments can be added to the specified profile. To add a segment to an existing profile the insert segment command must be used.

#### 20.4.23.2 Instruction Sequence to create a profile at a specified profile position



**CAUTION:** If this profile number is already in use then the profile header data is overwritten but the segments associated with it are kept.

1. Determine which profile positions are being used by using the Command Code value PS (0x50, 0x53). This command will return a list of all the profile positions currently being used.
2. Choose a location that is not being used and write the profile header data using the Command Code value WP (0x57, 0x50).  
The profile number is echoed back by the instrument in the Edit Response Message.
3. Write the first segment using the Command Code value Code WS (0x57, 0x53). This command will fill the next available segment position and link it to the profile created in step 1.
4. Write the second segment, again using Command Code WS. This fills the next available segment position and links it to the segment created in step 2.
5. Continue writing segments until the profile is complete (whilst remaining within the overall limit of 255 segments for all profiles combined). Each of these segments fills the next available position and links it to the previous segment specified.
6. The very last segment of the profile must be one of the end type segments. Thereafter, no more segments can be added to the specified profile. To add a segment to an existing profile the insert segment command must be used.

#### 20.4.23.3 Instruction Sequence to edit an existing Profile Header

When a profile header is changed, the segments associated with it remain unchanged. They must be edited separately if required.

1. Determine the number of the profile to be edited. Use the Command Code value PS (0x50, 0x53) which returns a list of all profile positions/numbers currently in use.
2. Write a new profile header data using the Command Code value EP (0x45, 0x50).  
The profile number is echoed back by the instrument in the Edit Response Message.

#### 20.4.23.4 Instruction Sequence to read a profile

1. Use the command RP to read the profile header data
2. Use the command RS to read the 1<sup>st</sup> segment's data
3. Use the command RS to read the 2<sup>nd</sup> segment's data.
4. Repeat steps 2 and 3 until an end segment is reached.

The following rules apply when creating a profile over communications:

- Profiles must always be terminated with an end segment.
- Segments cannot be added after an end segment has been added.
- All changes made to the selected profile are immediately saved in the instrument.

#### 20.4.23.5 Creating or Editing a Profile Header

| Creating Or Editing A Profile Header - Request ( <i>to instrument</i> ) |              |              |                                                                                                                                                                              |
|-------------------------------------------------------------------------|--------------|--------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Field Name                                                              | Data         |              | Comments                                                                                                                                                                     |
|                                                                         | Dec          | Hex          |                                                                                                                                                                              |
| Unit Address                                                            | A/R          | A/R          | The network address ID of the instrument.                                                                                                                                    |
| Function Code                                                           | 23           | 17           | Requires the multi read/write function.                                                                                                                                      |
| Read Start Address High Byte                                            | 32           | 20           |                                                                                                                                                                              |
| Read Start Address Low Byte                                             | 6            | 6            |                                                                                                                                                                              |
| Read Quantity Of Registers High Byte                                    | 0            | 0            |                                                                                                                                                                              |
| Read Quantity Of Registers Low Byte                                     | 1            | 1            |                                                                                                                                                                              |
| Write Start Address High Byte                                           | 32           | 20           |                                                                                                                                                                              |
| Write Start Address Low Byte                                            | 6            | 6            |                                                                                                                                                                              |
| Write Quantity Of Registers High Byte                                   | 0            | 0            |                                                                                                                                                                              |
| Write Quantity Of Registers Low Byte                                    | 20 or 21     | 14 or 15     | 20dec / 0x14hex if creating a profile at the next available location.<br>21dec / 0x15hex if creating a profile at a specified location, or editing a profile.                |
| Byte Count                                                              | 40 or 42     | 28 or 2A     | 40dec / 0x28hex if creating a profile at the next available location.<br>42dec / 0x2Ahex if creating a profile at a specified location, or editing a profile.                |
| Command Code High Byte                                                  | 67, 69 or 87 | 43, 45 or 57 | 0x43hex (67dec) if creating a profile at the next available location.<br>45hex (69 dec) / 57hex (87dec) if creating a profile at a specified location, or editing a profile. |
| Command Code Low Byte                                                   | 80           | 50           |                                                                                                                                                                              |
| Profile Number High Byte                                                | A/R          | A/R          | <b>Note:</b> The profile number is not included in the message when creating a profile at the next available position.                                                       |
| Profile Number Low Byte                                                 | A/R          | A/R          |                                                                                                                                                                              |

|                                       |                                |     |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
|---------------------------------------|--------------------------------|-----|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Profile Name Character 1              | A/R                            | A/R | <p>The ASCII codes equivalent to each of the 16 characters of the profile name, e.g.:</p> <p>A = 65dec / 0x41, B = 66dec / 0x42 etc.<br/>a = 97dec / 0x61, b = 98dec / 0x62 etc.</p> <p>Valid characters are <b>0 to 9, a to z, A to Z, plus ß ö ( ) - and _</b>.</p> <p><b>Note:</b> Only valid characters from the instruments supported character set should be used</p> <p>The space character (32dec / 0x20hex) is used to fill any unused characters at the end of the name.</p> |
| Profile Name Character 2              | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Name Character 3              | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Name Character 4              | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Name Character 5              | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Name Character 6              | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Name Character 7              | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Name Character 8              | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Name Character 9              | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Name Character 10             | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Name Character 11             | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Name Character 12             | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Name Character 13             | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Name Character 14             | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Name Character 15             | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Name Character 16             | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Start Signal High Byte        | 0                              | 0   | 0 = No delay, 1 = After delay, 2 = At Time/day *2 <i>only if recorder (RTC) fitted</i>                                                                                                                                                                                                                                                                                                                                                                                                 |
| Profile Start Signal Low Byte         | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Start Time (Byte 4 - High)    | A/R<br>(Floating point number) |     | The time, in elapsed seconds from the start trigger, before a profile will begin if Start Signal =1 (After Delay) or seconds from midnight if Start Signal =2 (Time of Day)<br>Use zero if Start Signal =0 (No Delay)                                                                                                                                                                                                                                                                  |
| Profile Start Time (Byte 3)           |                                |     |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Start Time (Byte 2)           |                                |     |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Start Time (Byte 1 - Low)     |                                |     |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Start Day High Byte           | 0                              | 0   | 1 = Monday, 2 = Tuesday, 3 = Wednesday, 4 = Thursday, 5 = Friday, 6 = Saturday, 7 = Sunday, 8 = Monday to Friday, 9 = Monday to Saturday, 10 = Saturday And Sunday, 11= All Week. <i>Use 1 if no recorder fitted.</i>                                                                                                                                                                                                                                                                  |
| Profile Start Day Low Byte            | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Starting Setpoint High        | 0                              | 0   | 0 = Current Setpoint, 1 = Current Process Variable Value                                                                                                                                                                                                                                                                                                                                                                                                                               |
| Profile Starting Setpoint Low         | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Recovery High Byte            | 0                              | 0   | 0 = Control to off, 1 = Restart profile, 2 = Maintain last profile setpoint, 3 = Use controller setpoint, 4 = Continue profile from where it was when power failed                                                                                                                                                                                                                                                                                                                     |
| Profile Recovery Low Byte             | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Recovery Time (Byte 4 - high) | A/R<br>(Floating point number) |     | The Profile Recovery Time (before the recovery action will be used after power/signal returns).<br>Entered as elapsed seconds.<br><i>Use zero if no recorder fitted.</i>                                                                                                                                                                                                                                                                                                               |
| Profile Recovery Time (Byte 3)        |                                |     |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Recovery Time (Byte 2)        |                                |     |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Recovery Time (Byte 1 - Low)  |                                |     |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Abort action High Byte        | 0                              | 0   | 0 = Control to off, 1 = Maintain last profile setpoint, 2 = Use controller setpoint                                                                                                                                                                                                                                                                                                                                                                                                    |
| Profile Abort Action Low Byte         | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Cycles High Byte              | A/R                            | A/R | 1 to 9999 or 10,000 for "Infinite"                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
| Profile Cycles Low Byte               | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| Profile Number of Loops High Byte     | 0                              | 0   | The number of loops to be controlled by the profile: 1 or 2                                                                                                                                                                                                                                                                                                                                                                                                                            |
| Profile Number of Loops Low Byte      | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| CRC High Byte                         | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
| CRC Low Byte                          | A/R                            | A/R |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |

**The instrument replies to this message with an Edit Response Message.**

### 20.4.23.6 Creating, Editing or Inserting Segments

Creating new segments is only possible when a new profile is being created (see above for instruction for creating a profile at the next available position, or at a position that you specify). An error is returned if the correct sequence is not followed.

The Insert Segment command is used to add segments to an existing profile (one that already has an end segment). This inserts a new segment at the position specified.

The Edit Segment command is used to alter segments of an existing profile.

The segment number is in relation to the profile number, e.g. to edit or insert a segment at position 3 of profile 1 the segment number will be 3, and to edit or insert a segment at position 3 of profile 6 the segment number will also be 3.

| Creating, Editing or Inserting Segments - Request (to instrument) |                                |              |                                                                                                                                                                      |
|-------------------------------------------------------------------|--------------------------------|--------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Field Name                                                        | Data                           |              | Comments                                                                                                                                                             |
|                                                                   | Dec                            | Hex          |                                                                                                                                                                      |
| Unit Address                                                      | A/R                            | A/R          | The network address ID of the instrument.                                                                                                                            |
| Function Code                                                     | 23                             | 17           | Requires the multi read/write function.                                                                                                                              |
| Read Start Address High Byte                                      | 32                             | 20           |                                                                                                                                                                      |
| Read Start Address Low Byte                                       | 6                              | 6            |                                                                                                                                                                      |
| Read Quantity Of Registers High                                   | 0                              | 0            |                                                                                                                                                                      |
| Read Quantity Of Registers Low                                    | 1                              | 1            |                                                                                                                                                                      |
| Write Start Address High                                          | 32                             | 20           |                                                                                                                                                                      |
| Write Start Address Low                                           | 6                              | 6            |                                                                                                                                                                      |
| Write Quantity Of Registers High                                  | 0                              | 0            |                                                                                                                                                                      |
| Write Quantity Of Registers Low                                   | 16 or 17                       | 10 or 11     | Create Segment (WS) = 16dec / 0x10hex<br>Insert Segment (IS) = 17dec / 0x11hex<br>Edit A Segment (ES) = 17dec / 0x11hex                                              |
| Byte Count                                                        | 32 or 34                       | 20 or 22     | Create Segment (WS) = 32dec / 0x20hex<br>Insert Segment (IS) = 34dec / 0x22hex<br>Edit A Segment (ES) = 34dec / 0x22hex                                              |
| Command Code High Byte                                            | 87, 69 or 73                   | 57, 45 or 49 | Create Segment (WS) = 87dec / 0x57hex<br>Insert Segment (IS) = 73dec / 0x49hex<br>Edit A Segment (ES) = 69dec / 0x45hex                                              |
| Command Code Low Byte                                             | 83                             | 53           |                                                                                                                                                                      |
| Profile Number High Byte                                          | A/R                            | A/R          | Profile number to place this segment in (IS, ES) or append to (WS)                                                                                                   |
| Profile Number Low Byte                                           | A/R                            | A/R          |                                                                                                                                                                      |
| Segment Position High Byte                                        | A/R                            | A/R          | <b>Note:</b> The Segment Position is not included in the message when creating a segment at the next available position.                                             |
| Segment Position Low Byte                                         | A/R                            | A/R          |                                                                                                                                                                      |
| Segment Type High Byte                                            | 0                              | 0            | 0 = Ramp Time, 1 = Ramp Rate*<br>2 = Step, 3 = Dwell, 4 = Hold, 5 = Loop<br>6 = Join, 7 = End, 8 = Repeat sequence then end<br>(*1 is not valid for 2 loop profiles) |
| Segment Type Low Byte                                             | A/R                            | A/R          |                                                                                                                                                                      |
| Segment Info A (Byte 4 - High)                                    | A/R<br>(Floating point number) |              | The meaning of the data contained in Segment Info A depends on the type of segment it relates to. See below.                                                         |
| Segment Info A (Byte 3)                                           |                                |              |                                                                                                                                                                      |
| Segment Info A (Byte 2)                                           |                                |              |                                                                                                                                                                      |
| Segment Info A (Byte 1 - Low)                                     |                                |              |                                                                                                                                                                      |

|                                        |                                              |            |                                                                                                                                                                                                                       |
|----------------------------------------|----------------------------------------------|------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Segment Info B (Byte 4 - High)         | <b>A/R</b><br><i>(Floating point number)</i> |            | The meaning of the data contained in Segment Info B depends on the type of segment it relates to. <i>See below.</i>                                                                                                   |
| Segment Info B (Byte 3)                |                                              |            |                                                                                                                                                                                                                       |
| Segment Info B (Byte 2)                |                                              |            |                                                                                                                                                                                                                       |
| Segment Info B (Byte 1 - Low)          |                                              |            |                                                                                                                                                                                                                       |
| Auto Hold Type Loop 1 High Byte        | <b>A/R</b>                                   | <b>A/R</b> | 0 = Auto-Hold Off, 1 = Hold above SP, 2 = Hold below SP,<br>3 = Hold above and below SP                                                                                                                               |
| Auto Hold Type Loop 1 Low Byte         | <b>A/R</b>                                   | <b>A/R</b> |                                                                                                                                                                                                                       |
| Auto Hold Value Loop 1 (Byte 4 - High) | <b>A/R</b><br><i>(Floating point number)</i> |            | The distance loop 1 can be way from setpoint before Auto-Hold activates.                                                                                                                                              |
| Auto Hold Value Loop 1 (Byte 3)        |                                              |            |                                                                                                                                                                                                                       |
| Auto Hold Value Loop 1 (Byte 2)        |                                              |            |                                                                                                                                                                                                                       |
| Auto Hold Value Loop 1 (Byte 1 - Low)  |                                              |            |                                                                                                                                                                                                                       |
| Events High Byte                       | <b>0</b>                                     | <b>0</b>   | The status of the five events are defined by the lowest 5 bits of the low byte. A bit value of 1 signifies the event is on.<br>Bit 0 = event 1, bit 1 = event 2, bit 2 = event 3 bit 3 = event 4 and bit 4 = event 5. |
| Events Low Byte                        | <b>A/R</b>                                   | <b>A/R</b> |                                                                                                                                                                                                                       |
| Segment Info B Loop 2 (Byte 4 - High)  | <b>A/R</b><br><i>(Floating point number)</i> |            | The meaning of the data contained in Segment Info B depends on the type of segment it relates to. <i>See below.</i><br>(write 0 for single loop profiles)                                                             |
| Segment Info B Loop 2 (Byte 3)         |                                              |            |                                                                                                                                                                                                                       |
| Segment Info B Loop 2 (Byte 2)         |                                              |            |                                                                                                                                                                                                                       |
| Segment Info B Loop 2 (Byte 1 - Low)   |                                              |            |                                                                                                                                                                                                                       |
| Auto Hold Type Loop 2 High Byte        | <b>A/R</b>                                   | <b>A/R</b> | 0 = Auto-Hold Off, 1 = Hold above SP, 2 = Hold below SP, 3 = Hold above and below SP <b>(write 0 for single loop profiles)</b> .                                                                                      |
| Auto Hold Type Loop 2 Low Byte         | <b>A/R</b>                                   | <b>A/R</b> |                                                                                                                                                                                                                       |
| Auto Hold Value Loop 2 (Byte 4 - High) | <b>A/R</b><br><i>(Floating point number)</i> |            | The distance loop 2 can be way from setpoint before Auto-Hold activates.<br><b>(write 0 for single loop profiles)</b> .                                                                                               |
| Auto Hold Value Loop 2 (Byte 3)        |                                              |            |                                                                                                                                                                                                                       |
| Auto Hold Value Loop 2 (Byte 2)        |                                              |            |                                                                                                                                                                                                                       |
| Auto Hold Value Loop 2 (Byte 1 - Low)  |                                              |            |                                                                                                                                                                                                                       |
| CRC High Byte                          | <b>A/R</b>                                   | <b>A/R</b> |                                                                                                                                                                                                                       |
| CRC Low Byte                           | <b>A/R</b>                                   | <b>A/R</b> |                                                                                                                                                                                                                       |

#### 20.4.23.7 Segment Data

The Segment Data is included in the command message when creating, editing or inserting segments (see above). It is provided in two parts (Segment Info A and B).

The meaning of the data contained in Segment Info A and B depends on the type of segment it relates to. *Null* is shown for unused data, these data values should be set to zero when writing the segment data.

| Segment Type | Segment Info    |                 | Description                                           |
|--------------|-----------------|-----------------|-------------------------------------------------------|
|              | A               | B               |                                                       |
| Ramp Time    | Time            | Target setpoint | Ramp to the target setpoint "B" in the time "A"       |
| Ramp Rate    | Ramp rate       | Target setpoint | Ramp to the target setpoint "B" at the ramp rate "A"  |
| Step         | <i>Null (0)</i> | Target setpoint | Step to a target setpoint "B"                         |
| Dwell        | Dwell time      | <i>Null (0)</i> | Stay at the current setpoint for a period of time "A" |
| Hold         | 0 = Operator    | <i>Null (0)</i> | Wait for the operator to release the hold             |

|                          |                                     |                                    |                                                                                                                                                                                                      |
|--------------------------|-------------------------------------|------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|                          | 1 = Time of day                     | Start Time                         | Wait until time of the day "B" in seconds since midnight ( <i>recorder only</i> ).                                                                                                                   |
|                          | 2 = Digital input                   | Null (0)                           | Wait for digital input signal                                                                                                                                                                        |
| Loop                     | Number of times to repeat 1 to 9999 | Segment number                     | Loop to the specified segment number "B" from this point. Repeat this "A" times.<br><b>Note:</b> Only segments below the current segment can be entered. Two "loop-backs" must not cross each other. |
| Join                     | Null (0)                            | Profile number                     | On completion of this profile jump run profile "B"                                                                                                                                                   |
| End                      | 0 = Control off                     | Null (0)                           | Turn off all control outputs on the loop(s) controlled by the profile. Doesn't affect loop 2 on single loop profiles.                                                                                |
|                          | 1 = Maintain profile setpoint       | Null (0)                           | Stay at the final setpoint of the profile                                                                                                                                                            |
|                          | 2 = Use controller setpoint         | Null (0)                           | Use the active controller setpoint (e.g. Main or Alternate as selected). This exits from Profiler Mode back to Controller Mode.                                                                      |
| Repeat Sequence Then End | 0 = Outputs off                     | Number of times to repeat sequence | Repeat the profile sequence number "B" times, then turn off the control outputs                                                                                                                      |
|                          | 1 = Maintain profile setpoint       |                                    | Repeat the profile sequence number "B" times, then hold the last profile setpoint.                                                                                                                   |
|                          | 2 = Use controller setpoint         |                                    | Repeat the profile sequence number "B" times, then use the active controller setpoint (e.g. Main or Alternate as selected). This exits from Profiler Mode back to Controller Mode.                   |

**The instrument replies to this message with an Edit Response Message.**

#### 20.4.23.8 Deleting All or Single Profiles

An individual profile can be deleted, or all profiles can be deleted with a single message.

Deleting a profile removes the header of the specified profile and any segments associated with it. Delete all profiles wipes all profiles and segments from the instrument.

| Delete Profiles - Request (to instrument) |          |          |                                                                                       |
|-------------------------------------------|----------|----------|---------------------------------------------------------------------------------------|
| Field Name                                | Data     |          | Comments                                                                              |
|                                           | Dec      | Hex      |                                                                                       |
| Unit Address                              | A/R      | A/R      | The network address ID of the instrument.                                             |
| Function Code                             | 23       | 17       | Requires the multi read/write function                                                |
| Read Start Address High Byte              | 32       | 20       |                                                                                       |
| Read Start Address Low Byte               | 6        | 6        |                                                                                       |
| Read Quantity Of Registers High           | 0        | 0        |                                                                                       |
| Read Quantity Of Registers Low            | 1        | 1        |                                                                                       |
| Write Start Address High                  | 32       | 20       |                                                                                       |
| Write Start Address Low                   | 6        | 6        |                                                                                       |
| Write Quantity Of Registers High          | 0        | 0        |                                                                                       |
| Write Quantity Of Registers Low           | 02 or 01 | 02 or 01 | Delete A Profile (DP) = 02dec / 0x02hex<br>Delete All Profiles (DA) = 01dec / 0x01hex |

|                          |          |          |                                                                                            |
|--------------------------|----------|----------|--------------------------------------------------------------------------------------------|
| Byte Count               | 04 or 02 | 04 or 02 | Delete A Profile (DP) = 04dec / 0x04hex<br>Delete All Profiles (DA) = 02dec / 0x02hex      |
| Command Code High Byte   | 68       | 44       |                                                                                            |
| Command Code Low Byte    | 80 or 65 | 50 or 41 | Delete A Profile (DP) = 80dec / 0x50hex<br>Delete All Profiles (DA) = 65dec / 0x41hex      |
| Profile Number High Byte | A/R      | A/R      | <b>Note:</b> The profile number is not included in the message when deleting all profiles. |
| Profile Number Low Byte  | A/R      | A/R      |                                                                                            |
| CRC High Byte            | A/R      | A/R      |                                                                                            |
| CRC Low Byte             | A/R      | A/R      |                                                                                            |

**The instrument replies to this message with an Edit Response Message.**

#### 20.4.23.9 Delete a Segment

The delete segment command deletes the specified segment from the specified profile. The following segments are moved up one place in the profile (e.g. if segment 6 is deleted segment 7 becomes segment 6).

| Delete A Segment - Request (to instrument) |       |       |                                        |
|--------------------------------------------|-------|-------|----------------------------------------|
| Field Name                                 | Data  |       | Comments                               |
|                                            | (Dec) | (Hex) |                                        |
| Unit Address                               | A/R   | A/R   | The ID address of the instrument       |
| Function Code                              | 23    | 17    | Requires the multi read/write function |
| Read Start Address High Byte               | 32    | 20    |                                        |
| Read Start Address Low Byte                | 6     | 6     |                                        |
| Read Quantity Of Registers High            | 0     | 0     |                                        |
| Read Quantity Of Registers Low             | 1     | 1     |                                        |
| Write Start Address High                   | 32    | 20    |                                        |
| Write Start Address Low                    | 6     | 6     |                                        |
| Write Quantity Of Registers High           | 0     | 0     |                                        |
| Write Quantity Of Registers Low            | 3     | 3     |                                        |
| Byte Count                                 | 6     | 6     |                                        |
| Command Code High Byte                     | 68    | 44    |                                        |
| Command Code Low Byte                      | 83    | 53    |                                        |
| Profile Number High Byte                   | A/R   | A/R   |                                        |
| Profile Number Low Byte                    | A/R   | A/R   |                                        |
| Segment Number High Byte                   | A/R   | A/R   |                                        |
| Segment Number Low Byte                    | A/R   | A/R   |                                        |
| CRC High Byte                              | A/R   | A/R   |                                        |
| CRC Low Byte                               | A/R   | A/R   |                                        |

**The instrument replies to this message with an Edit Response Message.**

### 20.4.23.10 Get Segments Remaining

Returns the number of unused segments remaining in the instrument. The number will be between 0 and 255, depending on how many have been used in the profiles so far created.

| Get Segments Remaining - Request (to instrument) |      |     |                                              |
|--------------------------------------------------|------|-----|----------------------------------------------|
| Field Name                                       | Data |     | Comments                                     |
|                                                  | Dec  | Hex |                                              |
| Unit Address                                     | A/R  | A/R | The ID address of the instrument as required |
| Function Code                                    | 23   | 17  | Requires the multi read/write function       |
| Read Start Address High Byte                     | 32   | 20  |                                              |
| Read Start Address Low Byte                      | 6    | 6   |                                              |
| Read Quantity Of Registers High                  | 0    | 0   |                                              |
| Read Quantity Of Registers Low                   | 1    | 1   |                                              |
| Write Start Address High                         | 32   | 20  |                                              |
| Write Start Address Low                          | 6    | 6   |                                              |
| Write Quantity Of Registers High                 | 0    | 0   |                                              |
| Write Quantity Of Registers Low                  | 1    | 1   |                                              |
| Byte Count                                       | 2    | 2   |                                              |
| Command Code High Byte                           | 83   | 53  |                                              |
| Command Code Low Byte                            | 82   | 52  |                                              |
| CRC High Byte                                    | A/R  | A/R |                                              |
| CRC Low Byte                                     | A/R  | A/R |                                              |

**The instrument replies to this message with an Edit Response Message.**

### 20.4.23.11 Edit Response Message from Instrument

The instrument replies to each profile or segment creation, edit or delete message with an Edit Response Message. The same format is used when replying to the Get Segments Remaining request.

| Edit Response Message - Response (from instrument) |      |     |                                                                        |
|----------------------------------------------------|------|-----|------------------------------------------------------------------------|
| Field Name                                         | Data |     | Comments                                                               |
|                                                    | Dec  | Hex |                                                                        |
| Unit Address                                       | A/R  | A/R | The ID address of the instrument                                       |
| Function Code                                      | 23   | 17  | The multi read/write function                                          |
| Byte Count                                         | 2    | 2   |                                                                        |
| Command Response High Byte                         | A/R  | A/R | <i>Two data bytes containing the Command Response data (see below)</i> |
| Command Response Low Byte                          | A/R  | A/R |                                                                        |
| CRC High Byte                                      | A/R  | A/R |                                                                        |
| CRC Low Byte                                       | A/R  | A/R |                                                                        |

### 20.4.23.12 Command Response Data

The data contained in the Edit Response Message returned after each profile or segment edit message is shown below. The data seen can be an error code, the number of unused segments or the profile number following a successful profile header creation/edit.

The error code shown will be as appropriate for the request message and instrument status.

| Command Response Name           | Response |           | Description                                                                                         |
|---------------------------------|----------|-----------|-----------------------------------------------------------------------------------------------------|
|                                 | Low Byte | High Byte |                                                                                                     |
| Profile Number                  | A/R      | A/R       | The number of the profile created or edited                                                         |
| Segments Remaining              | A/R      | A/R       | The number of unused segments remaining                                                             |
| Command Successfully            | 0x4F     | 0x4B      | The command requested was executed without error                                                    |
| Command Not Recognized          | 0xFF     | 0xFF      | The command is not recognized                                                                       |
| Profile Number Invalid          | 0xF0     | 0x00      | The profile number specified is not available.                                                      |
| Profile Name Invalid            | 0xF0     | 0x01      | The profile name/characters are not valid                                                           |
| Start Signal Invalid            | 0xF0     | 0x02      | The start signal is not recognized                                                                  |
| Start Time Invalid              | 0xF0     | 0x03      | The specified time is not within range                                                              |
| Start Day Invalid               | 0xF0     | 0x04      | The specified day is not recognized                                                                 |
| Starting Setpoint Invalid       | 0xF0     | 0x05      | The specified starting setpoint is not recognized                                                   |
| Profile Recovery Invalid        | 0xF0     | 0x06      | The profile recovery is not recognized                                                              |
| Recovery Time Invalid           | 0xF0     | 0x07      | The recovery time is not within limits                                                              |
| Abort Action Invalid            | 0xF0     | 0x08      | The abort action is not recognized                                                                  |
| Profile Cycles Invalid          | 0xF0     | 0x09      | The number of profile cycles is not within limits                                                   |
| Segment Number Invalid          | 0xF0     | 0x0A      | The segment number is not valid for this profile                                                    |
| Segment Type Invalid            | 0xF0     | 0x0B      | The segment type is not recognized                                                                  |
| Segment Info A Invalid          | 0xF0     | 0x0C      | Segment information A not valid for the type defined                                                |
| Segment Info B Invalid          | 0xF0     | 0x0D      | Segment information B is not valid for the type defined                                             |
| Write Length Invalid            | 0xF0     | 0x12      | The number of parameters to be written are invalid for the function requested                       |
| Segment Setpoint Clamped        | 0xF0     | 0x13      | The setpoint value entered was out of bounds. It has been clamped within the units setpoint limits. |
| Segment Not Written             | 0xF0     | 0x14      | The segment has not been written                                                                    |
| Profiler Running                | 0xF0     | 0x15      | The profiler is currently running so cannot be edited                                               |
| Loop 1 Auto Hold Value Invalid  | 0xF0     | 0x16      | The auto hold value is not within input span                                                        |
| Loop 2 Auto Hold Value Invalid  | 0xF0     | 0x17      | The auto hold value is not within input span                                                        |
| Invalid number of loops         | 0xF0     | 0x18      | The number of loops is not recognised                                                               |
| Deleting End Segment Is Invalid | 0xF0     | 0x19      | Deleting final segment (End, Join or Repeat) is denied                                              |
| Already Editing A Profile       | 0xF0     | 0x1A      | Finish editing the profile before starting another edit                                             |

#### 20.4.23.13 Read a Profile Header Request & Response Sequence

| Read A Profile Header - Request (to instrument) |      |     |                                        |
|-------------------------------------------------|------|-----|----------------------------------------|
| Field Name                                      | Data |     | Comments                               |
|                                                 | Dec  | Hex |                                        |
| Unit Address                                    | A/R  | A/R | The ID address of the instrument       |
| Function Code                                   | 23   | 17  | Requires the multi read/write function |
| Read Start Address High Byte                    | 32   | 20  |                                        |
| Read Start Address Low Byte                     | 6    | 6   |                                        |

|                                       |     |     |                             |
|---------------------------------------|-----|-----|-----------------------------|
| Read Quantity Of Registers High Byte  | 0   | 0   |                             |
| Read Quantity Of Registers Low Byte   | 19  | 13  |                             |
| Write Start Address High Byte         | 32  | 20  |                             |
| Write Start Address Low Byte          | 6   | 6   |                             |
| Write Quantity Of Registers High Byte | 0   | 0   |                             |
| Write Quantity Of Registers Low Byte  | 2   | 2   |                             |
| Byte Count                            | 4   | 4   |                             |
| Command Code High Byte                | 82  | 52  |                             |
| Command Code Low Byte                 | 80  | 50  |                             |
| Profile Number High Byte              | A/R | A/R | Profile number from 0 to 63 |
| Profile Number Low Byte               | A/R | A/R |                             |
| CRC High Byte                         | A/R | A/R |                             |
| CRC Low Byte                          | A/R | A/R |                             |

**The instrument replies to the Read A Profile Header request as follows:**

| Read Profile Header - Response (from instrument) |      |     |                                                                                                                                                                                       |
|--------------------------------------------------|------|-----|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Field Name                                       | Data |     | Comments                                                                                                                                                                              |
|                                                  | Dec  | Hex |                                                                                                                                                                                       |
| Unit Address                                     | A/R  | A/R | The ID address of the instrument                                                                                                                                                      |
| Function Code                                    | 23   | 17  | The multi read/write function                                                                                                                                                         |
| Byte Count                                       | 38   | 26  |                                                                                                                                                                                       |
| Profile Name Character 1                         | A/R  | A/R | <p>The ASCII codes equivalent to each of the 16 characters of the profile name, e.g.:</p> <p>A = 65dec / 0x41, B = 66dec / 0x42 etc.<br/> a = 97dec / 0x61, b = 98dec / 0x62 etc.</p> |
| Profile Name Character 2                         | A/R  | A/R |                                                                                                                                                                                       |
| Profile Name Character 3                         | A/R  | A/R |                                                                                                                                                                                       |
| Profile Name Character 4                         | A/R  | A/R |                                                                                                                                                                                       |
| Profile Name Character 5                         | A/R  | A/R |                                                                                                                                                                                       |
| Profile Name Character 6                         | A/R  | A/R |                                                                                                                                                                                       |
| Profile Name Character 7                         | A/R  | A/R |                                                                                                                                                                                       |
| Profile Name Character 8                         | A/R  | A/R |                                                                                                                                                                                       |
| Profile Name Character 9                         | A/R  | A/R |                                                                                                                                                                                       |
| Profile Name Character 10                        | A/R  | A/R |                                                                                                                                                                                       |
| Profile Name Character 11                        | A/R  | A/R |                                                                                                                                                                                       |
| Profile Name Character 12                        | A/R  | A/R |                                                                                                                                                                                       |
| Profile Name Character 13                        | A/R  | A/R |                                                                                                                                                                                       |
| Profile Name Character 14                        | A/R  | A/R |                                                                                                                                                                                       |
| Profile Name Character 15                        | A/R  | A/R |                                                                                                                                                                                       |
| Profile Name Character 16                        | A/R  | A/R |                                                                                                                                                                                       |
| Profile Start Signal High Byte                   | 0    | 0   | 0 = No delay, 1 = After delay, 2 = At Time/day                                                                                                                                        |
| Profile Start Signal Low Byte                    | A/R  | A/R |                                                                                                                                                                                       |

|                                       |                                                        |                                                                                                                                                                                                                      |                                                                                                                                                                                  |
|---------------------------------------|--------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Profile Start Time (Byte 4 - High)    | A/R<br>( <i><b>Floating<br/>point<br/>number</b></i> ) | The time, in elapsed seconds, from the start trigger before a profile will begin if Start Signal =1 (After Delay) or seconds from midnight if Start Signal =2 (Time of Day)<br>Is zero if Start Signal =0 (No Delay) |                                                                                                                                                                                  |
| Profile Start Time (Byte 3)           |                                                        |                                                                                                                                                                                                                      |                                                                                                                                                                                  |
| Profile Start Time (Byte 2)           |                                                        |                                                                                                                                                                                                                      |                                                                                                                                                                                  |
| Profile Start Time (Byte 1 - Low)     |                                                        |                                                                                                                                                                                                                      |                                                                                                                                                                                  |
| Profile Start Day High Byte           | 0                                                      | 0                                                                                                                                                                                                                    | 1 = Monday, 2 = Tuesday, 3 = Wednesday, 4 = Thursday, 5 = Friday, 6 = Saturday, 7 = Sunday, 8 = Monday to Friday, 9 = Monday to Saturday, 10 = Saturday And Sunday, 11= All Week |
| Profile Start Day Low Byte            | A/R                                                    | A/R                                                                                                                                                                                                                  |                                                                                                                                                                                  |
| Profile Starting Setpoint High        | 0                                                      | 0                                                                                                                                                                                                                    | 0 = Current Setpoint, 1 = Current Process Value                                                                                                                                  |
| Profile Starting Setpoint Low         | A/R                                                    | A/R                                                                                                                                                                                                                  |                                                                                                                                                                                  |
| Profile Recovery High Byte            | 0                                                      | 0                                                                                                                                                                                                                    | 0 = Control to off, 1 = Restart profile, 2 = Maintain last profile setpoint, 3 = Use controller setpoint, 4 = Continue profile from where it was when power failed               |
| Profile Recovery Low Byte             | A/R                                                    | A/R                                                                                                                                                                                                                  |                                                                                                                                                                                  |
| Profile Recovery Time (Byte 4 - high) | A/R<br>( <i><b>Floating<br/>point<br/>number</b></i> ) | The Profile Recovery Time (before the recovery action will be used after power/signal returns) in elapsed seconds.<br><i>Is zero if no recorder (RTC) fitted - function not possible</i>                             |                                                                                                                                                                                  |
| Profile Recovery Time (Byte 3)        |                                                        |                                                                                                                                                                                                                      |                                                                                                                                                                                  |
| Profile Recovery Time (Byte 2)        |                                                        |                                                                                                                                                                                                                      |                                                                                                                                                                                  |
| Profile Recovery Time (Byte 1 - Low)  |                                                        |                                                                                                                                                                                                                      |                                                                                                                                                                                  |
| Profile Abort action High Byte        | 0                                                      | 0                                                                                                                                                                                                                    | 0 = Control to off, 1 = Maintain last profile setpoint, 2 = Use controller setpoint                                                                                              |
| Profile Abort Action Low Byte         | A/R                                                    | A/R                                                                                                                                                                                                                  |                                                                                                                                                                                  |
| Profile Cycles High Byte              | A/R                                                    | A/R                                                                                                                                                                                                                  | 1 to 9999 or 10,000 for “Infinite”                                                                                                                                               |
| Profile Cycles Low Byte               | A/R                                                    | A/R                                                                                                                                                                                                                  |                                                                                                                                                                                  |
| Profile Number of Loops High Byte     | 0                                                      | 0                                                                                                                                                                                                                    | The number of loops controlled by the profile:<br>1 or 2                                                                                                                         |
| Profile Number of Loops Low Byte      | A/R                                                    | A/R                                                                                                                                                                                                                  |                                                                                                                                                                                  |
| CRC High Byte                         | A/R                                                    | A/R                                                                                                                                                                                                                  |                                                                                                                                                                                  |
| CRC Low Byte                          | A/R                                                    | A/R                                                                                                                                                                                                                  |                                                                                                                                                                                  |

#### 20.4.23.14 Read a Segment

| Read A Segment - Request (to instrument) |      |     |                                        |
|------------------------------------------|------|-----|----------------------------------------|
| Field Name                               | Data |     | Comments                               |
|                                          | Dec  | Hex |                                        |
| Unit Address                             | A/R  | A/R | The ID address of the instrument       |
| Function Code                            | 23   | 17  | Requires the multi read/write function |
| Read Start Address High Byte             | 32   | 20  |                                        |
| Read Start Address Low Byte              | 6    | 6   |                                        |
| Read Quantity Of Registers High Byte     | 0    | 0   |                                        |
| Read Quantity Of Registers Low Byte      | 17   | 11  |                                        |
| Write Start Address High Byte            | 22   | 16  |                                        |
| Write Start Address Low Byte             | 6    | 6   |                                        |
| Write Quantity Of Registers High Byte    | 0    | 0   |                                        |
| Write Quantity Of Registers Low Byte     | 3    | 3   |                                        |
| Byte Count                               | 6    | 6   |                                        |
| Command Code High Byte                   | 82   | 52  |                                        |
| Command Code Low Byte                    | 83   | 53  |                                        |

|                          |     |     |  |
|--------------------------|-----|-----|--|
| Profile Number High Byte | A/R | A/R |  |
| Profile Number Low Byte  | A/R | A/R |  |
| Segment Number High Byte | A/R | A/R |  |
| Segment Number Low Byte  | A/R | A/R |  |
| CRC High Byte            | A/R | A/R |  |
| CRC Low Byte             | A/R | A/R |  |

**The instrument replies to the Read A Segment request as follows:**

| Read A Segment - Response (from instrument) |                                |     |                                                                                                                                                                                                                        |
|---------------------------------------------|--------------------------------|-----|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Field Name                                  | Data                           |     | Comments                                                                                                                                                                                                               |
|                                             | Dec                            | Hex |                                                                                                                                                                                                                        |
| Unit Address                                | A/R                            | A/R | The ID address of the instrument                                                                                                                                                                                       |
| Function Code                               | 23                             | 17  | The multi read/write function                                                                                                                                                                                          |
| Byte Count                                  | 34                             | 22  |                                                                                                                                                                                                                        |
| Command Response High Byte                  | 82                             | 52  |                                                                                                                                                                                                                        |
| Command Response Low Byte                   | 83                             | 53  |                                                                                                                                                                                                                        |
| Profile Number High Byte                    | A/R                            | A/R |                                                                                                                                                                                                                        |
| Profile Number Low Byte                     | A/R                            | A/R |                                                                                                                                                                                                                        |
| Segment Number High Byte                    | A/R                            | A/R |                                                                                                                                                                                                                        |
| Segment Number Low Byte                     | A/R                            | A/R |                                                                                                                                                                                                                        |
| Segment Type High Byte                      | 0                              | 0   | 0 = Ramp Time, 1 = Ramp Rate, 2 = Step, 3 = Dwell, 4 = Hold, 5 = Loop, 6 = Join, 7 = End, 8 = Repeat sequence then end                                                                                                 |
| Segment Type Low Byte                       | A/R                            | A/R |                                                                                                                                                                                                                        |
| Segment Info A (Byte 4 - High)              | A/R<br>(Floating point number) |     | The meaning of the data contained in Segment Info A depends on the type of segment it relates to. See below.                                                                                                           |
| Segment Info A (Byte 3)                     |                                |     |                                                                                                                                                                                                                        |
| Segment Info A (Byte 2)                     |                                |     |                                                                                                                                                                                                                        |
| Segment Info A (Byte 1 - Low)               |                                |     |                                                                                                                                                                                                                        |
| Segment Info B (Byte 4 - High)              | A/R<br>(Floating point number) |     | The meaning of the data contained in Segment Info B depends on the type of segment it relates to. See below.                                                                                                           |
| Segment Info B (Byte 3)                     |                                |     |                                                                                                                                                                                                                        |
| Segment Info B (Byte 2)                     |                                |     |                                                                                                                                                                                                                        |
| Segment Info B (Byte 1 - Low)               |                                |     |                                                                                                                                                                                                                        |
| Auto Hold Type Loop 1 High Byte             | A/R                            | A/R | 0 = Auto-Hold Off, 1 = Hold above SP, 2 = Hold below SP, 3 = Hold above and below SP                                                                                                                                   |
| Auto Hold Type Loop 1 Low Byte              | A/R                            | A/R |                                                                                                                                                                                                                        |
| Auto Hold Value Loop 1 (Byte 4 - High)      | A/R<br>(Floating point number) |     | The distance loop 2 can be way from setpoint before Auto-Hold activates.                                                                                                                                               |
| Auto Hold Value Loop 1 (Byte 3)             |                                |     |                                                                                                                                                                                                                        |
| Auto Hold Value Loop 1 (Byte 2)             |                                |     |                                                                                                                                                                                                                        |
| Auto Hold Value Loop 1 (Byte 1 - Low)       |                                |     |                                                                                                                                                                                                                        |
| Events High Byte                            | 0                              | 0   | The status of the five events are defined by the lowest 5 bits of the low byte. A bit value of 1 signifies the event is on.<br>Bit 0 = event 1, bit 1 = event 2, bit 2 = event 3, bit 3 = event 4 and bit 4 = event 5. |
| Events Low Byte                             | A/R                            | A/R |                                                                                                                                                                                                                        |
| Segment Info B Loop 2 (Byte 4 - High)       | A/R<br>(Floating point number) |     | The meaning of the data contained in Segment Info B depends on the type of segment it relates to. See below.                                                                                                           |
| Segment Info B Loop 2 (Byte 3)              |                                |     |                                                                                                                                                                                                                        |
| Segment Info B Loop 2 (Byte 2)              |                                |     |                                                                                                                                                                                                                        |
| Segment Info B Loop 2 (Byte 1 - Low)        |                                |     |                                                                                                                                                                                                                        |

|                                        |                                      |     |                                                                                                                                 |
|----------------------------------------|--------------------------------------|-----|---------------------------------------------------------------------------------------------------------------------------------|
| Auto Hold Type Loop 2 High Byte        | A/R                                  | A/R | 0 = Auto-Hold Off, 1 = Hold above SP, 2 = Hold below SP, 3 - Hold above and below SP                                            |
| Auto Hold Type Loop 2 Low Byte         | A/R                                  | A/R |                                                                                                                                 |
| Auto Hold Value Loop 2 (Byte 4 - High) | A/R<br>(Floating<br>point<br>number) |     | The distance loop 2 can be way from setpoint before Auto-Hold activates.<br>(Always 0 when profile only controls a single loop) |
| Auto Hold Value Loop 2 (Byte 3)        |                                      |     |                                                                                                                                 |
| Auto Hold Value Loop 2 (Byte 2)        |                                      |     |                                                                                                                                 |
| Auto Hold Value Loop 2 (Byte 1 - Low)  |                                      |     |                                                                                                                                 |
| CRC High Byte                          | A/R                                  | A/R |                                                                                                                                 |
| CRC Low Byte                           | A/R                                  | A/R |                                                                                                                                 |

#### 20.4.23.15 Segment Data

The Segment Data is included in the response to a Read Segment request. It is provided in two parts (Segment Info A and B).

The meaning of the data contained in Segment Info A and B depends on the type of segment it relates to. *Null* is shown for unused data, this can be any value.

| Segment Type             | Segment Info                        |                                    | Description                                                                                                                                                                   |
|--------------------------|-------------------------------------|------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|                          | A                                   | B                                  |                                                                                                                                                                               |
| Ramp Time                | Time                                | Target setpoint                    | Ramp to the target setpoint "B" in the time "A"                                                                                                                               |
| Ramp Rate                | Ramp rate                           | Target setpoint                    | Ramp to the target setpoint "B" at the ramp rate "A"                                                                                                                          |
| Step                     | <i>Null (0)</i>                     | Target setpoint                    | Step to a target setpoint "B"                                                                                                                                                 |
| Dwell                    | Dwell time                          | <i>Null (0)</i>                    | Stay at the current setpoint for time "A"                                                                                                                                     |
| Hold<br><br>Loop         | 0 = Operator                        | <i>Null (0)</i>                    | Wait for the operator to release the hold or Digital Input                                                                                                                    |
|                          | 1 = Time of day                     | Start Time                         | Wait until time of the day "B" in seconds since midnight ( <i>recorder only</i> ).                                                                                            |
|                          | Number of times to repeat 1 to 9999 | Segment number                     | Loop to the specified segment number "B" from this point. Repeat this "A" times. Only segments below the current segment can be entered. Two loops must not cross each other. |
| Join                     | <i>Null (0)</i>                     | Profile number                     | On completion of this profile run profile "B"                                                                                                                                 |
| End                      | 0 = Control off                     | <i>Null (0)</i>                    | Turn off all control outputs.                                                                                                                                                 |
|                          | 1 = Maintain profile setpoint       | <i>Null (0)</i>                    | Stay at the final setpoint of the profile                                                                                                                                     |
|                          | 2 = Use controller setpoint         | <i>Null (0)</i>                    | Use the active controller setpoint.                                                                                                                                           |
| Repeat Sequence Then End | 0 = Outputs off                     | Number of times to repeat sequence | Repeat the profile sequence number "B" times, then turn off the control outputs                                                                                               |
|                          | 1 = Maintain profile setpoint       |                                    | Repeat the profile sequence number "B" times, then hold the last profile setpoint.                                                                                            |
|                          | 2 = Use controller setpoint         |                                    | Repeat the profile sequence number "B" times, then use the active controller setpoint.                                                                                        |

### 20.4.23.16 Read a Profile Name

This command requests the name of a specific profile. The instrument responds with the name of the profile number requested.

| Read Profile Name - Request ( <i>to instrument</i> )                |      |     |                                        |
|---------------------------------------------------------------------|------|-----|----------------------------------------|
| Field Name                                                          | Data |     | Comments                               |
|                                                                     | Dec  | Hex |                                        |
| Unit Address                                                        | A/R  | A/R | The ID address of the instrument       |
| Function Code                                                       | 23   | 17  | Requires the multi read/write function |
| Read Start Address High Byte                                        | 32   | 20  |                                        |
| Read Start Address Low Byte                                         | 6    | 6   |                                        |
| Read Quantity Of Registers High Byte                                | 0    | 0   |                                        |
| Read Quantity Of Registers Low Byte                                 | 8    | 8   |                                        |
| Write Start Address High Byte                                       | 32   | 20  |                                        |
| Write Start Address Low Byte                                        | 6    | 6   |                                        |
| Write Quantity Of Registers High Byte                               | 0    | 0   |                                        |
| Write Quantity Of Registers Low Byte                                | 2    | 2   |                                        |
| Byte Count                                                          | 4    | 4   |                                        |
| Command Code High Byte                                              | 80   | 50  |                                        |
| Command Code Low Byte                                               | 78   | 4E  |                                        |
| Profile Number High Byte                                            | A/R  | A/R |                                        |
| Profile Number Low Byte                                             | A/R  | A/R |                                        |
| CRC High Byte                                                       | A/R  | A/R |                                        |
| CRC Low Byte                                                        | A/R  | A/R |                                        |
| The instrument replies to the Read Profile Name request as follows: |      |     |                                        |

| Read Profile Name - Response ( <i>from instrument</i> ) |      |     |                                                                                                                                                                                                                                                                                            |
|---------------------------------------------------------|------|-----|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Field Name                                              | Data |     | Comments                                                                                                                                                                                                                                                                                   |
|                                                         | Dec  | Hex |                                                                                                                                                                                                                                                                                            |
| Unit Address                                            | A/R  | A/R | The ID address of the instrument                                                                                                                                                                                                                                                           |
| Function Code                                           | 23   | 17  | The multi read/write function                                                                                                                                                                                                                                                              |
| Byte Count                                              | 16   | 10  |                                                                                                                                                                                                                                                                                            |
| Profile Name Character 1                                | A/R  | A/R | <p>The ASCII codes equivalent to each of the 16 characters of the profile name, e.g. :<br/> A = 65dec / 0x41, B = 66dec / 0x42 etc.<br/> a = 97dec / 0x61, b = 98dec / 0x62</p> <p>The space character (32dec / 0x20hex) is used to fill any unused characters at the end of the name.</p> |
| Profile Name Character 2                                | A/R  | A/R |                                                                                                                                                                                                                                                                                            |
| Profile Name Character 3                                | A/R  | A/R |                                                                                                                                                                                                                                                                                            |
| Profile Name Character 4                                | A/R  | A/R |                                                                                                                                                                                                                                                                                            |
| Profile Name Character 5                                | A/R  | A/R |                                                                                                                                                                                                                                                                                            |
| Profile Name Character 6                                | A/R  | A/R |                                                                                                                                                                                                                                                                                            |
| Profile Name Character 7                                | A/R  | A/R |                                                                                                                                                                                                                                                                                            |
| Profile Name Character 8                                | A/R  | A/R |                                                                                                                                                                                                                                                                                            |
| Profile Name Character 9                                | A/R  | A/R |                                                                                                                                                                                                                                                                                            |
| Profile Name Character 10                               | A/R  | A/R |                                                                                                                                                                                                                                                                                            |
| Profile Name Character 11                               | A/R  | A/R |                                                                                                                                                                                                                                                                                            |

|                           |     |     |  |
|---------------------------|-----|-----|--|
| Profile Name Character 12 | A/R | A/R |  |
| Profile Name Character 13 | A/R | A/R |  |
| Profile Name Character 14 | A/R | A/R |  |
| Profile Name Character 15 | A/R | A/R |  |
| Profile Name Character 16 | A/R | A/R |  |
| CRC High Byte             | A/R | A/R |  |
| CRC Low Byte              | A/R | A/R |  |

#### 20.4.23.17 Read Profile Memory Status

This command returns the status of the profile memory used. The response to this command is to return a table of all the profile numbers that are in use. A value of 0x00 indicates that the profile position is free and value of 0x01 indicates that the position is used by a profile. Using this command in conjunction with the read profile name command can be used to create a directory of profile numbers and profile names.

| Read Profile Memory Status - Request (to instrument)                         |      |     |                                        |
|------------------------------------------------------------------------------|------|-----|----------------------------------------|
| Field Name                                                                   | Data |     | Comments                               |
|                                                                              | Dec  | Hex |                                        |
| Unit Address                                                                 | A/R  | A/R | The ID address of the instrument       |
| Function Code                                                                | 23   | 17  | Requires the multi read/write function |
| Read Start Address High Byte                                                 | 32   | 20  |                                        |
| Read Start Address Low Byte                                                  | 6    | 6   |                                        |
| Read Quantity Of Registers High Byte                                         | 0    | 0   |                                        |
| Read Quantity Of Registers Low Byte                                          | 32   | 20  |                                        |
| Write Start Address High Byte                                                | 32   | 20  |                                        |
| Write Start Address Low Byte                                                 | 6    | 6   |                                        |
| Write Quantity Of Registers High Byte                                        | 0    | 0   |                                        |
| Write Quantity Of Registers Low Byte                                         | 1    | 1   |                                        |
| Byte Count                                                                   | 2    | 2   |                                        |
| Command Code High Byte                                                       | 80   | 50  |                                        |
| Command Code Low Byte                                                        | 83   | 53  |                                        |
| CRC High Byte                                                                | A/R  | A/R |                                        |
| CRC Low Byte                                                                 | A/R  | A/R |                                        |
| The instrument replies to the Read Profile Memory Status request as follows: |      |     |                                        |

### 20.4.23.18 Read Profile Status

| Read Profile Memory Status - Response ( <i>from instrument</i> ) |        |        |                                                                                                                                 |
|------------------------------------------------------------------|--------|--------|---------------------------------------------------------------------------------------------------------------------------------|
| Field Name                                                       | Data   |        | Comments                                                                                                                        |
|                                                                  | Dec    | Hex    |                                                                                                                                 |
| Unit Address                                                     | A/R    | A/R    | The ID address of the instrument                                                                                                |
| Function Code                                                    | 23     | 17     | The multi read/write function                                                                                                   |
| Byte Count                                                       | 64     | 40     |                                                                                                                                 |
| Profile 0 Position                                               | 0 or 1 | 0 or 1 | For each of the 64 possible profile positions, a value of 0 is returned if the position is free, or 1 if the position is empty. |
| Profile 1 Position                                               | 0 or 1 | 0 or 1 |                                                                                                                                 |
| <i>etc.....</i>                                                  |        |        |                                                                                                                                 |
| Profile 62 Position                                              | 0 or 1 | 0 or 1 |                                                                                                                                 |
| Profile 63 Position                                              | 0 or 1 | 0 or 1 |                                                                                                                                 |
| CRC High Byte                                                    | A/R    | A/R    |                                                                                                                                 |
| CRC Low Byte                                                     | A/R    | A/R    |                                                                                                                                 |

# 21 Glossary

## 21.1 Active Setpoint

The term Active Setpoint is used to describe the currently selected setpoint when the instrument is in controller mode. Controllers can use the Main local setpoint and/or the Alternate Setpoint. Only one of the setpoints can be active at any time. During profiler control, the setpoint value is controlled by the profiler function.

*Also refer to: Actual Setpoint; Alternate Setpoint; Controller Mode; Local Setpoints; Profiler Mode; Remote Setpoint; Setpoint; and Setpoint Selection.*

## 21.2 Actual Setpoint

Actual Setpoint is the effective current value of the active setpoint. This will be different to the setpoints target value during setpoint ramps. The actual setpoint will rise or fall at the ramp-rate set, until it reaches its target setpoint value. During profile control, the actual setpoint value is controlled by the profiler function.

*Also refer to: Active Setpoint; Controller Mode; Profiler Mode; Setpoint; Setpoint Ramp Rate and Setpoint Selection.*

## 21.3 Alarm Activation Inhibit

Alarm Inhibit prevents unwanted alarm activation at power-up or when the controller setpoint is changed. The alarm activation is inhibited until a 'Safe' (non-alarm) condition is present. The alarm operates normally from that point onwards. E.g. if inhibited, a low alarm will not activate at power-up, until the process has first risen above the alarm point and then falls back below. This parameter is in addition to the alarm minimum duration setting.

*Also refer to: Alarm Duration Inhibit; Alarm Types and Alarm Operation.*

## 21.4 Alarm Configuration

A sub-menu of the configuration menu, used to adjust the alarm parameters (alarm types, values, hysteresis, minimum duration and inhibiting).

*Also refer to: Alarm Hysteresis; Alarm Inhibit; Alarm Operation; Alarm Types and Configuration Mode.*

## 21.5 Alarm Duration Inhibit

An adjustable alarm configuration time. After an alarm trigger point is passed, the alarm is inhibited from activation until this time has elapsed. If the alarm trigger is removed before the time has passed (e.g. the process falls back below a high alarm value) the alarm will not activate at all. The time duration inhibit is not applied when an alarm condition ends.

This parameter is in addition to the alarm activation inhibit.






*Also refer to: Alarm Hysteresis; Alarm Inhibit; Alarm Operation; Alarm Types and Configuration Mode.*

## Alarm Hysteresis

An adjustable band through which the process variable must pass before the alarm will change state. The band is always on the "safe" side of an alarm point, e.g. a high alarm's hysteresis band is below the high alarm value, and a low alarm's hysteresis is above the low alarm value.

Refer to the *Alarm Hysteresis Operation* diagram on the next page.

*Also refer to: Alarm Duration Inhibit; Alarm Types; Loop Alarm; Alarm Operation; LSD; Process Variable; and Rate Of Change Alarm.*



## 21.6 Alarm Operation

The process and control deviation alarm types are illustrated, together with the action of any associated outputs.

Also refer to: *Alarm Hysteresis; Alarm Inhibit; Alarm Types; Band Alarm Value; Deviation Alarm; Latching Relay; Logical Alarm Combinations; Loop Alarm; Process High Alarm and Process Low Alarm.*




Figure 64. Alarm Operation

## 21.7 Alarm Types

There are three basic alarm types, Process Alarms, Control Deviation Alarms and Event Based Alarms; plus some special condition alarms.

Process Alarms are based on the absolute value of the Process Variable. If the PV rises above a high alarm value, or falls below a low alarm value, the alarm will become active. Control Deviation Alarms are based on the value of the Control Deviation error. If the PV is more than the high deviation alarm value above setpoint, or more than the low deviation alarm value below setpoint, the alarm will become active.

Event based alarms activate when the condition for that alarm type is true. These can be Signal Break, Low Memory or Loop Alarms.

Rate of Signal Change Alarm is based on the rate of change of the PV. If the rate of change is greater than the alarm value for longer than the Minimum Duration time, the alarm will activate. Control Power High and Control Power Low alarms are based on the output power from the PID control algorithm.

*Also refer to: Alarm Operation; Band Alarm Value; Control Deviation; Control Power Alarm; Deviation Alarm; Loop Alarm; PID; Process High Alarm; Process Low Alarm; Process Variable; Rate Of Change Alarm; and Setpoint.*

## 21.8 Alternate Setpoint

The instrument can use one of two setpoints (Main or Alternate). The alternate setpoint can be chosen from Local Setpoint 2 or a remote setpoint input from Auxiliary Input A if fitted. One setpoint can be chosen as the active at using the setpoint selection screen.

*Also refer to: Auxiliary Input; Local Setpoints; Main Setpoint; Profiler; Remote Setpoints; Setpoint and Setpoint Select.*

## 21.9 Auto Pre-Tune

When the auto pre-tune is enabled, a pre-tune activation is attempted at every power-up (*Standard Pre-Tune activation rules apply*). Auto pre-tune is useful when the process to be controlled may vary significantly each time it is run. Auto pre-tune ensures that the process is tuned correctly each time the process is started. Self-tune may also be engaged to fine-tune the controller.

*Also refer to: Pre-Tune; Self-Tune; PID and Tuning.*

## 21.10 Automatic Reset

- Refer to *Integral Action*

## 21.11 Auxiliary Input

A secondary linear input module can be installed in option slot A to provide a remote setpoint input. Signals can be mA, or VDC. The 2<sup>nd</sup> Universal input can also be used as an auxiliary input if fitted.

*Also refer to: Alternate Setpoint; Digital Input; Linear Input; mADC; Remote Setpoint and VDC*

## 21.12 Auxiliary Input Lower Limit

When auxiliary input A is used to provide a remote setpoint (RSP), this setting defines the Alternate Setpoint value when the auxiliary input signal is at its minimum value (e.g. for 4 to 20mA, the value when 4mA is applied). However, the setpoint is always constrained by the setpoint limits.

*Also refer to: Alternate Setpoint; Auxiliary Input; Auxiliary Input Upper Limit; Auxiliary Input Offset; Remote Setpoint; Setpoint and Setpoint Upper Limit and Setpoint Lower Limit.*

## 21.13 Auxiliary Input Offset

Used to adjust the value of auxiliary input A if it provides a Remote Setpoint. Positive values are added to the remote setpoint value, negative values are subtracted, but the setpoint is still constrained by the setpoint limits.

*Also refer to: Auxiliary Input; Remote Setpoint; Scaled Input Upper Limit; Scaled Input Lower Limit Setpoint Lower Limit and Setpoint Upper Limit.*

## 21.14 Auxiliary Input Type

Defines the type and range of the linear input signal for auxiliary input A. It can be mADC or VDC. This can be used as a Remote Setpoint input.

*Also refer to: Remote Setpoint and Setpoint.*

### **21.15 Auxiliary Input Upper Limit**

When the auxiliary input is used to provide a Remote Setpoint (RSP), this setting defines the value of the RSP when the auxiliary input signal is at its maximum value (e.g. for 4 to 20mA, the value when 20mA is applied). However, the RSP value is always constrained by the setpoint limits.

*Also refer to: Auxiliary Input; Auxiliary Input Lower Limit; Auxiliary Input Offset; Remote Setpoint; Setpoint and Setpoint Upper Limit and Setpoint Lower Limit.*

### **21.16 Band Alarm Value**

The amount of control deviation that is acceptable before a Band Alarm is activated. If the process variable is more than the value of this band from the actual setpoint, the alarm will be active.

*Also refer to: Actual Setpoint; Alarm Operation; Alarm Types; Control Deviation; Input Span; LSD and Process Variable.*

### **21.17 Bar Graphs**

The instrument displays uni or bi-directional bar-graphs in the operation mode for loop 1 & 2 PID power (single control = 0 to 100%, dual control = -100% to +100%), control deviation (-5% to +5%) and % Recorder Memory Used (0 to 100%). In Profiler Mode, profile & current segment bar-graphs are shown (0 to 100%).

*Also refer to: Control Deviation; Data Recorder; Display Configuration; Operation Mode; Main Menu; PID and Profiler.*

### **21.18 Bias**

- Refer to *Manual Reset*.

### **21.19 Bumpless Transfer**

A method used to prevent sudden changes to the correcting variable, when switching between automatic PI or PID and Manual control modes. During a transition from PI or PID to manual control, the initial manual power value is set to the previous automatic mode value. The operator then adjusts the value as required. During a transition from manual control to PI or PID, the initial automatic value is set to the previous manual mode value. The correcting variable level will gradually adjusted by the control algorithm at a rate dependant on the integral action resulting from the integral time constant value. A similar Bumpless transfer is used with Gain Scheduling when switching PID Sets. Since integral action is essential to Bumpless Transfer, this feature is not available if integral is turned off.

*Also refer to: Correcting Variable; Gain Scheduling; Integral Action; Manual Mode; PI and PID.*

### **21.20 Calibration**

Adjustment or correction of the displayed values relative to the actual measured values.

Refer to the User Calibration section of this manual for calibration use and instructions.

*Also refer to: Multi-point Scaling and Process Variable.*

### **21.21 Cascade Control**

Applications with long time lags (e.g. indirect heat via hot water jackets) can be difficult to control with a single control loop. The solution is to split the process into two (or more) cascaded loops consisting of a Master and Slave acting on a common actuator. The 2-loop version with built-in cascade feature is ideal for this type of application, although it can be achieved with two discrete controllers, one with a setpoint retransmission output and the other with a remote setpoint input.

The master controller measures the main process variable and compares it to the desired product setpoint. Its PID output becomes the slave's effective setpoint (scaled to suit the process). This is compared the slave's process input, and the controlling actuator is adjusted accordingly.

Refer to the Cascade Control section of this manual for full details.

*Also refer to: Master & Slave; Proportional Control; PID; Remote Setpoint and Setpoint.*

## 21.22 Clock Configuration

A sub-menu of the configuration menu used to adjust the setting of the real time clock fitted with the data recorder option (e.g. date, time, and date format).

*Also refer to: Data Recorder and Configuration Mode*

## 21.23 Communications Write Enable

Enables/disables the changing of parameter values via the Serial Communications link, if a communication option such as Modbus RTU (RS485) or Modbus TCP (Ethernet) is installed. When disabled, communication becomes read-only.

*Also refer to: Ethernet; Modbus RTU; Modbus TCP; RS485 and Serial Communications*

## 21.24 Configuration Menu

A selection of sub-menus from which the user can adjust the major instrument settings. There are sub-menus for the Inputs, Control, Outputs, Alarms, Communications, Recorder, Clock, Display and Lock Codes. Configuration mode is entered from the main menu. An unlock code is required to access this mode.

*Refer to the Configuration Menu information in the Configuration & Use section.*

*Also refer to: Alarm Configuration, Lock Codes, Clock Configuration, Control Configuration, Display Configuration, Input Configuration, Main Menu, Output Configuration, Recorder Configuration, Serial Communications Configuration*

## 21.25 Contactor

- Refer to *Relay*

## 21.26 Continuous Control

Current or voltage correcting variables using linear outputs (4 to 20mA, 0-20mA, 0 to 5V, 0 to 10V or 2 - 10V DC) for proportional control, PI, PD or PID control modes. On-Off control cannot be used with linear outputs.

*Also refer to: Correcting Variable; Linear Output; On-Off Control; PD; PI; PID; Proportional Control; and Time Proportional Control.*

## 21.27 Control Configuration

A sub-menu of the configuration menu used to adjust the parameters that relate to the control of the process (enabling control, auto/manual mode, control type and action, PID tuning terms, power limits, sensor break action, setpoint values and setpoint selection).

*Also refer to: Configuration Mode; Control Action; Control Enable; Local Setpoints; Manual Mode; PID; Setpoint Selection and Tuning.*

## 21.28 Control Deviation

Control Deviation is the difference between the process variable value and the actual setpoint. The control deviation error is equal to  $PV - SP$ . This value can be monitored using the bar-graph ( $\pm 5\%$  of span). An excessive deviation warning can be given by using a deviation or band alarm.

*Also refer to: Actual Setpoint; Alarm Types; Band Alarm; Bar Graph; Deviation Alarm; Input Span; Process Variable and Setpoint*

## 21.29 Control Action

This refers to the control loop(s) primary power output direction. Reverse action is typically used with heating applications as it increases the correcting variable as the process variable falls. If a secondary output has been configured, its action is always the opposite of the primary output.

*Also refer to: Control Type; Correcting Variable; Direct Acting Control and Reverse Acting Control.*

## 21.30 Control Enable/Disable

The PID controller outputs can be temporarily turned off by disabling the control. When control is disabled the setpoint value is replaced by "OFF". All other functions continue as normal. The control enable/disable function can be controlled from the control configuration sub-menu, via a digital input or optionally from the operation menu if enabled in the display configuration sub-menu.

*Also refer to: Digital Input; Display Configuration; Operation Mode and PID*

### **21.31 Control Power Alarm**

A control power alarm is based on the output from the PID control algorithm. It can provide a warning if the PID output rises above or falls below a set value. This is often used in conjunction with the minimum alarm duration time so that very brief power output peaks can be ignored.

*Also refer to: Alarm Duration Minimum; Alarm Types and PID*

### **21.32 Control Type**

This defines if a control loop has Single (unidirectional) or Dual (bidirectional) control outputs. Single outputs have a primary output only. This can drive the process in one direction (e.g. heat only, cool only, increase humidity etc). Dual outputs have both primary and secondary outputs which can force the process to increase or decrease (e.g. heat & cool, humidify & dehumidify etc).

*Also refer to: Control Action; PID; Primary Proportional Band; Process Variable; and Secondary Proportional Band.*

### 21.33 Controller

An instrument that controls one or more process control loops. For each control loop it compares a process variable to a target setpoint, and attempts to make the process maintain the setpoint value by applying a correcting variable (e.g. turning on a heater or dosing with alkali if controlling pH). The controller uses proportional (P, PI, PD or PID) or On-Off control.

*Also refer to: Correcting Variable; Indicator; Limit Controller; On-Off Control; PD Control; PI Control; PID; Process Variable; Proportional Control; Profiler and Setpoint.*

### 21.34 Controller Mode

The normal operating mode when profiling is not fitted or it is not being used.

*Also refer to: Controller; Profiler and Profiler Mode*

### 21.35 Correcting Variable

The output level from a controller used to adjust the process variable up or down, in order to remove any control deviation. This might be turning on a chiller in a temperature application or increasing the variable speed drive of a pump in a flow application. The level of correcting variable is commonly referred to as the controller output power.

*Also refer to: Control Deviation; PID; Primary Power Output Limit and Process Variable*

### 21.36 CPU

This stands for Central Processing Unit and refers to the on-board microprocessor that controls the measurement, control, alarm, display and other functions of the instrument.

### 21.37 Custom Display Mode

The user can copy up to 50 Configuration Menu parameters into operation mode using the PC software. If enabled in the display configuration sub-menu, the configured parameters follow the normal operation mode screens. In this mode these screens are not protected by a lock code.

*Also refer to: Control Configuration; Display Configuration; Lock Codes and Operation Mode*

### 21.38 Cycle Time

For time proportioning outputs, the cycle time is the period over which the controller averages the ON vs. OFF time, in order to provide the required correcting variable. Each control loop has separate cycle times for the primary and secondary control outputs. Shorter cycle times give better control, but at the expense of reduce life for any electromechanical control devices (e.g. relays or solenoid valves). Short cycle times do not harm SSRs.

*Also refer to: Correcting Variable; PID; Primary Proportional Band; Proportional Control; Relay; Secondary Proportional Band; Solenoid Valve; SSRs and Time Proportioning.*

### 21.39 Data Recorder

The Data Recorder option can record the process values, setpoints, alarms and events over time. Recordings can be transferred to a USB memory stick or via the serial communications options for analysis in the PC software or spreadsheets. This option includes a battery backed-up real time clock (RTC) which continues to keep time when the instrument is powered down.

Refer to the Data Recorder Option section of this manual for full details.


*Also refer to: PC Software and Recorder Configuration.*

### 21.40 Deadband

- Refer to *Overlap/Deadband*.

### 21.41 Derivative Action

Derivative action biases the proportional control output to compensate for the rate of change in the process variable. In a typical reverse acting application, derivative power is increased if the PV is rising, or decreased if it is falling. The combined proportional and derivative values adjust the correcting variable until the process stabilises, at which point derivative power becomes zero. Increasing the derivative time increases the effect of derivative action.



The Derivative Time Constant is defined as the time interval in which the part of the output signal due to proportional action increases by the same amount as the immediate output change due to derivative action, when the control deviation error is changing at a constant rate\*. As the PV falls at a fixed rate, derivative action causes a step in power output (D%), and over time proportional power (P%) increases as the PV falls within the proportional band. \*For the purpose of the definition, the increased power does not affect the PV (in reality it would begin correcting the control error). Derivative must be set to OFF if PI control is required, and it is not available if the primary output is set to on-off.

Also refer to: *Modulating Valve; On-Off Control; PD Control; PI Control; PID; PID Sets; Process Variable and Tuning.*

### 21.42 Deviation Alarm

An alarm configured to activate once an unacceptable amount of control deviation error occurs. A positive value (deviation high) sets the alarm point above the current actual setpoint, a negative value (deviation low) sets the alarm point below actual setpoint. If the process variable deviates from the actual setpoint by a margin greater than this value, the alarm becomes active. If an alarm is required if the control deviation is either side of the setpoint, consider using a Band alarm or a logical combination of a deviation high and deviation low alarm.

Also refer to: *Actual Setpoint; Alarm Operation; Alarm Types; Band Alarm; Control Deviation; Logical Combination; Process Variable and Setpoint.*

### 21.43 Digital Input

An input that can be driven to one of two states (active or inactive) by an external voltage or a contact opening/closing. Digital Inputs can be used to set the instrument in to different states. Typical uses are to select auto/manual mode, active setpoint selection, control enable/disable, profile selection, profile run/hold/abort, hold segment release, recorder trigger, tuning start/stop and latching alarm reset. Digital inputs may be “inverted” so that they are inactive when on.

Also refer to: *Active Setpoint; Control Enable; Data Recording; Invert Digital Inputs; Manual Mode; Profiling and Segment Types.*

### 21.44 Direct Acting Control

Direct action is required for applications where the primary control output will be used to force the process variable down towards the setpoint. A typical application is a chiller. When the control action is selected as direct acting, primary proportional control outputs decrease the correcting variable as the process variable reduces within the proportional band, and primary On-Off outputs turn off when the process variable is less than the setpoint. The control action of a secondary output is always the opposite of the primary output.

Also refer to: *Control Action; Control Type; Correcting Variable; On-Off Control; Process Variable; Proportional Control and Reverse Acting Control.*

### 21.45 Display Configuration

A sub-menu of configuration mode used to adjust the display (color & contrast) and to enable access to selected parameters from operation mode. These are: Profile Control; Recorder Start/Stop; Recorder Status; Loop 1 & 2 Setpoint Select; Loop 1 & 2 Auto/Manual Select; Loop 1 & 2 Control Enable/Disable; Loop 1 & 2 Trend View; Loop 1 & 2 Setpoint Ramp Rate. It also has settings for language selection, to enable the custom menus or to make operation mode read-only.

Also refer to: *Configuration Mode; Control Enable; Custom Display Mode; Display Language; Manual Control; Operation Mode; Profile Control; Setpoint Ramp Rate; Recorder; Setpoint Select and Trend Display.*

## 21.46 Display Languages

The instrument supports two languages. The main language is English. The alternate language is chosen at time of order, but can also be changed by downloading a new file via the PC software. Supported languages include English, French, German, Italian and Spanish.

*Also refer to: Display Configuration; Operation Mode; Main Menu and PC Software.*

## 21.47 Display Resolution

The maximum number of digits that can be displayed and/or the maximum number of decimal places. Numeric values (e.g. process variable, setpoints etc) are limited to no more than 5 digits.

The maximum number of decimal places is selectable from 0 to 3 places, but the overall 5-digit limit means that larger values reduce the number of decimal places shown. For example, values >99.999 will show no more than 2 decimal places (e.g. 100.00).

*Also refer to: LSD.*

## 21.48 Effective Setpoint

- Refer to *Actual Setpoint*.

## 21.49 Engineering Units

The Process Variable and Setpoint displays can assigned engineering units to describe the signals connected to the process inputs. The engineering units for linear inputs can be: °C; °F; K; bar; %; %RH; pH; psi or none. For temperature inputs (RTD or Thermocouples) they can be °C; °F or K.

*Also refer to: Linear Input; Process Input; Process Variable RTD and Thermocouple.*

## 21.50 Ethernet

A networking technology for local area networks (LANs). Used to link computers and other equipment in order to share data or control such devices. If fitted with an Ethernet communications module in option slot A, this instrument can connect as a slave to a Modbus TCP master device via a wired Ethernet LAN connection.

*Also refer to: Modbus TCP and Serial Communications.*

## 21.51 Gain Scheduling

Gain scheduling bumplessly switches between pre-set PID values automatically at successively higher setpoint or process values. This allows optimal control across a wide range of process conditions, or if the controller is used in several different applications. It is especially useful if the process conditions change significantly during use, such as a process that becomes exothermic as the temperature rises.

*Also refer to: Bumpless Transfer; PID; PID Sets; Process Variable and Setpoint.*

## 21.52 Indicator

An instrument that displays process values, but lacks control features. Typically, alarm outputs are available that will activate at pre-set PV values.

*Also refer to: Controller; Limit Controller and Process Variable.*

## 21.53 Input Configuration

A sub-menu of configuration mode, used to adjust the parameters that relate to the process and auxiliary inputs (type, engineering units, decimal places, scaling, filtering etc.).

*Also refer to: Auxiliary Input; Configuration Mode and Process Input.*

## 21.54 Input Filter Time Constant

This parameter is used to filter out extraneous impulses affecting process variable values. The filtered PV is used for all PV dependent functions (display, control, alarm etc). Use this parameter with care as it will also slow the response to genuine process changes.

*Also refer to: Process Variable.*

### 21.55 Input Range

This is the overall process variable input range and type as selected by the Process Input Type parameter. This range can be scaled using the Scale Input Upper & Lower Limits.

*Also refer to: Input Span; Process Input; Scaled Input Lower Limit and Scaled Input Upper Limit.*


### 21.56 Input Span

The measuring and display limits, as defined by the Scale Input Lower and Scaled Input Upper Limits. The trimmed span value is also used as the basis for calculations that relate to the span of the instrument (e.g. proportional bands).

*Also refer to: Input Range; LSD; Primary Proportional Band; Scaled Input Lower Limit; Scaled Input Upper Limit and Secondary Proportional Band.*

### 21.57 Integral Action

Integral action biases the proportional control output to compensate for process load variations. Their combined values adjust the correcting variable, until the control deviation error is zero, at which point the integral value is held constant. Decreasing the integral time constant increases the integral action. Integral action is also known as “Automatic Reset”.



The time constant is defined as the interval in which the part of the output due to integral action increases by an amount equal to the part of the output due to the proportional action, when the control deviation is unchanging\*. For example, if a step change is made in the PV, the output immediately changes due to proportional action. The deviation error is integrated over time, steadily changing the integral output. The time it takes for integral power to change by the same amount due to proportional action ( $I\% = P\%$ ) is the “reset”, or integral time.

\*For the purpose of the definition, the power output change does not affect the PV (in reality it would begin correcting the control error). Integral must be set to OFF if PD control is required, and it is not available if the primary output is set to On-Off.

*Also refer to: Control Deviation; On-Off Control; PD Control; PI Control; PID; PID Sets; Primary Proportional Band; Secondary Proportional Band; Derivative Action; and Tuning.*

### 21.58 Invert Digital Input

Digital inputs may be “inverted” so that they are active when off and inactive when on. This is useful if the signal applied to the chosen digital input function is reversed in relation the digital input action.

*Also refer to: Digital Input.*

### 21.59 Latching Output

Alarm outputs can be set to latch on when they become active. If enabled, an output will remain latched ON even if the condition that caused it to be on is no-longer present and it remains latched even if the unit is powered off-on. The output latch must be reset to turn it off. The latch reset signal can be via a digital input or using the front keys in the clear latched output screen. The alarm condition that caused the output to switch must have cleared before the latch can be deactivated.

*Also refer to: Alarm Types; Digital Input and Relay*

### 21.60 LED

Light Emitting Diode. Four LED’s are used as indicator lights (e.g. for the alarm indication, automatic tuning stats, manual mode etc). Their function and labels can be changed with the PC software.

*Also refer to: Alarm Operation; Alarm Types; Automatic Tuning; Manual Mode and PC Software.*

### 21.61 Linear Input

A mVDC, mADC or voltage signal usually used to represent the value of the process variable for one of the PID control loops. This can be any variable that can be converted into a suitable DC linear signal. Common

examples are Humidity, pressure, pH or temperature. One or optionally two main inputs are available, and an auxiliary linear input can also be installed to provide a remote setpoint source.

*Also refer to: Auxiliary Input; Input Range; Linear Output; mVDC; mADC; PID; Process Variable; Remote Setpoint and VDC.*

### **21.62 Linear Output**

A mVDC, mADC or voltage signal used to provide a continuous proportional control output or to retransmit the process or setpoint values to an external device.

*Also refer to: Continuous Control; Linear Input mVDC; mADC; Process Variable; Proportional Control; Retransmit Output; Setpoint and VDC*

### **21.63 Limit Controller**

A process protection device that can shut down a process at a pre-set “exceed condition”. Limit controllers work independently of the normal process controller in order to prevent possible damage to equipment or products. A fail-safe latching relay is fitted, which cannot be reset by the operator until the process has returned to a safe condition. Limit controllers are especially recommended for any process that could potentially become hazardous under fault conditions. Ensure you choose a limit controller with the correct approvals for local regulations (e.g EN 14597 etc) if it is to be used as a safety limiter.

*Also refer to: Controller and Latching Relay.*

### **21.64 Local Setpoints**

Local setpoints are target setpoint values for the control loops that are entered by the user and stored in the controller. The value of local setpoints can be adjusted within the setpoint limits using the front keypad, or via a serial communications link.

The instrument can have two setpoints for each control loop. The main local setpoint and an alternate setpoint. The alternate setpoint can be a local setpoint or a remote setpoint from an auxiliary input. One setpoint at a time is chosen to be active using the setpoint selection.

*Also refer to: Alternate Setpoint; Auxiliary Input; PID; Remote Setpoint; Serial Communications; Setpoint; Setpoint Lower Limit; Setpoint Upper Limit; and Setpoint Select.*

### **21.65 Lock Codes**

The four-digit passwords required when entering the setup wizard, configuration mode, tuning menu, supervisor mode, USB menu, recorder menu and profiler setup menu. The correct code must be entered to gain access. If unrestricted access is required for a menu, its lock can be set to OFF.

Refer to the Lock Code Configuration sub-menu in the Configuration Menu.

*Also refer to: Configuration Mode; Main Menu; Profiler Setup Menu; Recorder Menu; Setup Wizard; Supervisor Mode; Tuning Menu and USB Menu.*

## 21.66 Logical Output Combinations

Any suitable output may be assigned as a logical OR or logical AND output of the alarm and profile event conditions, and can be configured for reverse or direct action. If OR is chosen, any of the selected alarms or profile events that are active will cause the output to turn on for direct acting outputs, or inactive for reverse acting outputs (NOR). If AND is chosen, all of the selected alarms or profile events must be active to cause the output to turn on for direct acting outputs, or inactive for reverse acting outputs.

The following table explains the concept of logical OR & AND outputs.

Also refer to: *Alarm Operation; Alarm Types; Output Configuration and Profile Events.*

### EXAMPLES OF LOGICAL OUTPUTS

| Logical OR: Alarm 1 OR Alarm 2 |     |         |     |        |     |                |     |         |     |        |     |
|--------------------------------|-----|---------|-----|--------|-----|----------------|-----|---------|-----|--------|-----|
| Direct Acting                  |     |         |     |        |     | Reverse-Acting |     |         |     |        |     |
| ALARM 1                        | OFF | ALARM 2 | OFF | OUTPUT | OFF | ALARM 1        | OFF | ALARM 2 | OFF | OUTPUT | ON  |
|                                | ON  |         | OFF |        | ON  |                | ON  |         | OFF |        | OFF |
|                                | OFF |         | ON  |        | ON  |                | OFF |         | ON  |        | OFF |
|                                | ON  |         | ON  |        | ON  |                | ON  |         | ON  |        | OFF |

| Logical AND: Event 3 AND Alarm 2 |     |         |     |        |     |                |     |         |     |        |     |
|----------------------------------|-----|---------|-----|--------|-----|----------------|-----|---------|-----|--------|-----|
| Direct Acting                    |     |         |     |        |     | Reverse-Acting |     |         |     |        |     |
| Event 3                          | OFF | ALARM 2 | OFF | OUTPUT | OFF | Event 3        | OFF | ALARM 2 | OFF | OUTPUT | ON  |
|                                  | ON  |         | OFF |        | OFF |                | ON  |         | OFF |        | ON  |
|                                  | OFF |         | ON  |        | OFF |                | OFF |         | ON  |        | ON  |
|                                  | ON  |         | ON  |        | ON  |                | ON  |         | ON  |        | OFF |

## 21.67 Loop Alarm

A loop alarm detects faults in the control feedback in the selected loop, by continuously monitoring the process variable response to the control outputs. If any alarm is setup as a loop alarm, it repeatedly checks if the control output is at saturation. If saturation is reached (0% or 100% power for single control type, -100% or +100% for dual control type), an internal timer is started. Thereafter, if the output has not caused the process variable to be corrected by a predetermined amount 'V' after time 'T' has elapsed, the alarm becomes active. The alarm repeatedly checks the process variable and the control output. If the process starts to change in the correct direction or the control output is no longer at the limit, the alarm deactivates.

For PI or PID control, the loop alarm time 'T' can be automatic (twice the Integral Time value) or set to a user defined value up to 99m 59s. Correct operation with the automatic loop alarm time depends upon reasonably accurate PID tuning. The user defined value is always used for P, PD or On-Off control. The timer starts as soon as an output turns on with on-off control.

The value of 'V' is dependent upon the input type. For Temperature inputs,  $V = 2^{\circ}\text{C}$  or  $3^{\circ}\text{F}$ . For Linear inputs,  $V = 10 \times \text{LSD}$

The loop alarm is automatically disabled in manual control mode and during execution of a pre-tune. Upon exit from manual mode or after completion of the pre-tune routine, the loop alarm is automatically re-enabled.

Also refer to: *Alarm Types; Control Type; Manual Loop Alarm Time; Linear Input; LSD; Manual Mode; On-Off Control; PD; PI; PID; Pre-Tune; Process Variable and Tuning.*

## 21.68 LSD

The Least Significant Digit (LSD) is the smallest incremental value that can be shown at the defined display resolution.

Also refer to: *Display Resolution.*

## 21.69 mADC

This stands for milliamp DC. It is used in reference to the linear DC milliamp input ranges and the linear DC milliamp outputs. Typically, these will be 0 to 20mA or 4 to 20mA.

*Also refer to: Input Range; Linear Input; Linear Output; mVDC; Process Variable and VDC*

## 21.70 Main Menu

The top-level menu that allows access to operation mode as well as all other menus. These are: configuration mode, profiler setup and recorder menus, the setup wizard, supervisor mode and the tuning and USB menus. Most menus require an unlock code to gain access.

Refer to the Main Menu information in the Configuration & Use section.

*Also refer to: Configuration Mode; Lock Codes; Operation Mode; Profiler Setup Menu; Recorder Menu; Setup Wizard; Supervisor Mode; Tuning Menu and USB Menu.*

## 21.71 Main Setpoint

The instrument can have two setpoints for each control loop. The main local setpoint and an alternate setpoint. If used, the main setpoint is always a “local” setpoint. One setpoint can be chosen to be active from the setpoint selection screen.

*Also refer to: Alternate Setpoint; Auxiliary Input; Local Setpoints; Profiler; Remote Setpoints; Setpoint and Setpoint Select.*

## 21.72 Manual Loop Alarm Time

The loop alarm time used is manually set whenever a loop alarm is defined to have a manually set time, or if P, PD or On-Off control is selected. This parameter determines the duration of the output saturation condition after which the loop alarm will be activated.

*Also refer to: Loop Alarm; On-Off Control; PD; PI and PID.*

## 21.73 Manual Mode

Manual Mode operates as follows:

The setpoint legend is replaced by the word **MAN** and setpoint value is replaced by a % output power value. This value may be adjusted using the keypad or via serial comms. The power value can be varied from 0% to 100% for controllers using single control type, and -100% to +100% for controllers using dual control type. Switching between automatic and manual modes is achieved using “bumpless transfer”.

Auto/manual mode can be selected from the control configuration sub-menu or via a digital input if one has been configured for this function. Alternatively, if enabled in the display configuration sub-menu, the user can switch between automatic and manual control from operation mode. It is possible to use a controller as a permanent “Manual Station” by permanently selecting manual control in the control configuration sub-menu.

**Caution: Manual Mode should be used with care because the power output level is set by the operator, therefore the PID algorithm is no longer in control of the process. Manual mode also ignores any output power limits, valve open/close limits and the control enable/disable setting. The operator is responsible for maintaining the process within safe limits.**

*Also refer to: Bumpless Transfer; Control Configuration; Control Type; Operation Mode; PID; Power Output Limits and Serial Communications.*

## 21.74 Manual Reset

Used to manually bias proportional outputs to compensate for control deviation errors due to process load variations. It is expressed as a percentage of output power. This parameter is not applicable if the primary output is set to On-Off control. If the process variable settles below setpoint use a higher value to remove the error, if the process variable settles above the setpoint use a lower value.

For PID or PI control, typically set manual reset to approximately 80% of power needed to maintain setpoint, although lower values can be used to inhibit start-up overshoot. Integral action will automatically remove any control deviation error.

*Also refer to: Control Deviation; Integral Action; ON/OFF Control; PI Control; PID; Proportional Control; Process Variable; and Setpoint.*

## 21.75 Master & Slave Controllers

The terms Master and Slave are often used in relation to serial communications. This instrument can be a communications slave if an Ethernet or RS485 module is fitted.

With RS485 it can also act as a setpoint master or slave in multi-zone applications. In this case, one instrument controls the setpoint of one or more others. This could be a simple master/slave application where the master controller transmits its setpoint to the slaves so that all operate at the same temperature. Alternatively, an offset can be applied to each zone using the slave's setpoint offset parameter, so each is offset slightly from the master.

A similar master/slave relationship can be achieved if the master retransmits its setpoint as an analog signal. In this case, the slave controllers must have matching remote setpoint inputs so that they can follow the masters' setpoint value. It is possible to apply an offset to each zone if the slave has an RSP offset parameter. If not the remote setpoint input scaling can be adjusted to achieve the offset.

Cascade Control is another type of Master & Slave application where the slaves setpoint is set using the master controllers PID power output.

*Also refer to: Cascade Control; Linear Output; Retransmit Output; Remote Setpoint; Auxiliary Input Offset; Serial Communications and Setpoint.*

## 21.76 Modbus RTU

Modbus RTU is the serial communications protocol used on instruments fitted with the RS485 Communications module into option slot A. Alternatively, the Modbus TCP protocol is available if the Ethernet communications module is fitted.

Modbus RTU is a Master/Slave protocol. Only the Master may initiate communications. Each slave is given a unique address, and the message contains the Modbus address of the intended slave. Only this slave will act on the command, even though other devices might receive it (an exception is "broadcast commands" sent to address 0, which are acted upon by all slaves). The commands can instruct the slave to change values in its memory registers, or ask it to send back values contained in the registers. Each query or response message includes a cyclic redundancy check (CRC) checksum to ensure that it arrives uncorrupted.

This instrument can act as a slave, or it can be a "setpoint master" over RS485. In this mode the unit continuously sends its setpoint value using broadcast messages.

Refer to the Serial Communications and Modbus Parameter sections for more information.

*Also refer to: Modbus TCP; RS485; Serial Communications and Setpoint.*

## 21.77 Modbus TCP

Modbus TCP is a version of the Modbus protocol for networks such as Ethernet, which support the Internet Protocol. It is available if an Ethernet communications module is fitted into option slot A.

This instrument can only act as a Slave when using Modbus TCP. A master device initiates the communications, and the instrument only acts on the command if it has been sent to its own IP address.

Modbus/TCP does not require a checksum to ensure that the message arrives intact. Apart from this, the data model and function calls used by Modbus TCP and RTU are identical; only the message encapsulation is different.

Refer to the Serial Communications and Modbus Parameter sections for more information.

*Also refer to: Ethernet; Modbus RTU and Serial Communications.*

## 21.78 Minimum Motor On Time

This defines the minimum drive effort needed to initiate valve movement if the valve was previously stationary. It ensures that frictional and inertial effects are taken into account when driving the valve, and reduces the actuator switching operations when close to setpoint.

If the pulse required to position the valve would be less than the minimum on time, the output is suppressed. Each of these short pulse times is accumulated until their value exceeds the minimum on time, and the output is turned on for this time.

When the control deviation error is inside a “neutral zone”, the PID algorithm inhibits integration in order to avoid oscillation. The neutral zone (symmetrical to setpoint) is:

$$2 * \text{PropBand} * (\text{MinOnTime} / \text{MotorTravelTime})$$

*Also refer to Motor Travel Time; Self-Tune and Valve Motor Drive Control.*

### 21.79 Modulating Valve

A valve that can be positioned anywhere between fully closed and fully open by means of an incorporated motor. A typical application would be controlling temperature in a furnace heated by gas burners. The controller moves the valve to the desired position in order to control the gas flow.

If the valve motor is directly driven with Open and Close outputs from the controller feeding power to the motor, valve motor drive (VMD) control mode must be used. Some modulating valves have positioning circuitry incorporated that requires linear (mA or VDC) signals to set the position. These use the standard control mode (using PI control) instead of VMD mode.

*Also refer to Linear Outputs; PI Control and Valve Motor Drive Control.*

### 21.80 Motor Travel Time

The Motor Travel Time parameter is used in Valve Motor Drive control mode. It must be set to the time the valve takes to travel from one physical end stop to the other. This time is used by the VMD algorithm when calculating how long to energise the “Valve Open” or “Valve Close” outputs in order to bring the process on to control.

It is important that the time set accurately reflects the time taken to travel between the physical limits, otherwise the control can be severely impaired. The motor travel time may be stated in your valve supplier’s specification or the valve can be timed from the fully closed to fully opened position. The controller can be placed in Manual Mode to assist with the timing of valve movement.

*Also refer to Manual Mode Enable*

### 21.81 Multi-Point Scaling

If the process input is connected to a linear input signal, multi-point scaling can be enabled in the input configuration sub-menu. This allows the linearization of non-linear signals.

The scale input limits define the values shown when the input is at minimum and maximum values, and up to 15 breakpoints can scale input vs. displayed value between these limits. It is advisable to concentrate the break points in the area of the range that has the greatest amount of non-linearity, or the area of particular interest in the application.

*Also refer to: Input Configuration; Linear Input; Process Input; Scaled Input Lower Limit and Scaled Input Upper Limit.*

### 21.82 mVDC

This stands for millivolt DC. It is used in reference to the linear DC millivolt input ranges of the main process inputs. These can be 0 to 50mV or 10 to 50mV

*Also refer to: Input Range; Linear Input; mADC; Process Variable and VDC*

### 21.83 On-Off Control

When operating in On-Off mode, the control output(s) turn on or off as the process variable crosses the setpoint in a manner similar to a simple thermostat. Some oscillation of the process variable is inevitable when using on-off control. The amount of oscillation is mainly defined by the process characteristics, but is also affected by the on-off differential setting.

On-off control can be implemented only with Relay, Triac or SSR driver outputs. It can be assigned to the primary output alone (secondary output not present), primary and secondary outputs or to a secondary output only (with the primary output set for time proportional or continuous control). On-off Control is selected by setting the corresponding proportional band(s) to on-off.

*Also refer to: Continuous Control, Current Proportioning Control; On-Off Differential; PID; Process Variable; Primary Proportional Band; Secondary Proportional Band; Relay; Setpoint; SSR Driver; Time Proportioning Control and Triac.*

### 21.84 On-Off Differential

A switching differential, centred about the setpoint, when using On-off control. Relay 'chatter' can be eliminated by proper adjustment of this parameter, but too large a value may increase process variable oscillation to unacceptable levels. On-off differential is also known as hysteresis or deadband.

*Also refer to: Input Span; On-Off Control; PID Sets; Process Variable; Relay and Setpoint*

### 21.85 On-Off Hysteresis

- Refer to *On-Off Differential*.

### 21.86 Operation Mode

The mode used during normal operation of the instrument. It can be accessed from the main menu, and is the usual mode entered at power-up. The screens shown include a main screen with bar-graphs, trend views, information about the process, alarms plus optionally, selection of auto/manual control, control output disabling. Recorder and profiler information can be displayed if these features are fitted. Up to 50 configuration menu screens also can be shown in operation mode if set to do so with the PC software. In this mode screens are not protected by a lock code.

Refer to the Operation Mode information in the Configuration & Use section.

*Also refer to: Bar-Graphs; Configuration Mode; Custom Display Mode; Display Configuration; Lock Codes; Main Menu; PC Software; Profiler Setup Menu; Recorder Menu and Trend Display.*

### 21.87 Output Configuration

A sub-menu of configuration mode used to adjust the parameters that relate to the outputs. Available settings include linear output type & scaling, output usage and retransmit output scaling etc. Boolean logical OR / AND can be used to combine alarms and/or events to a single output.

*Also refer to: Configuration Mode; Logical Output Combinations and Linear Output.*

### 21.88 Overlap/Deadband

The Overlap/Deadband parameter defines the portion of the primary and secondary proportional bands over which both outputs are active (called overlap), or neither is active (called deadband). This is entered in display units, and is limited to -20% to +20% of the sum of the two proportional bands. E.g. if the proportional bands were 2° and 8° (totalling = 10°) the maximum overlap or deadband would be  $\pm 2^\circ$ . Positive values = Overlap, negative values = Deadband. The 5 PID sets for each control loop have their own overlap/deadband setting.

Overlap/deadband is not applicable if the primary output is set for on-off control or there is no secondary output. If the secondary output is set for on-off, this parameter has the effect of moving the on-off differential band of the secondary output to create the overlap or deadband. When overlap/deadband = OFF, the edge of the secondary output differential band coincides with the point at which the primary output is at 0% (off).

*The effect of the Overlap/Deadband parameter is shown in Figure 65.*

*Also refer to: On-Off Differential; On-Off Control; PID Sets; Primary Proportional Band and Secondary Proportional Band.*




Figure 65. Overlap/Deadband

## 21.89 PC Software

The PC software can create, download and store instrument configurations & profiles. If the recorder feature is fitted, its recordings can be downloaded and analysed via the software.

In addition, changes can be made to the instrument operation by adding extra screens, amending the contact details, alarm status labels or to the functions and labels of the LED's. The software can download a new language file, change the start-up "splash screen" or configure the "Supervisor Mode" screens. An on-screen simulation of the instrument can be setup and tested on a configurable load simulator.

Refer to the PC software and use sections of this manual for full details.

*Also refer to: LEDs and Supervisor Mode.*

## 21.90 PD Control

Proportional and Derivative (PD) control combines proportional control with derivative action. It is similar to PID control, but without Integral action.

*Also refer to: Derivative; Integral; PID Control; Proportional Control and Tuning.*

## 21.91 PI Control

Proportional and Integral Control (PI) combines proportional control with integral action. It is similar to PID Control, but without derivative action. It is often used for modulating valves, dampers or motor speed control, where derivative action can sometimes cause instability or wear of mechanical components like valves, due to excessive movement.

*Also refer to: Derivative; Integral; Modulating Valve; PID Control; Proportional Control; Tuning and Valve Motor Control.*

## 21.92 PID Control

Proportional Integral and Derivative control maintains accurate and stable levels in a process (e.g. when controlling temperature or humidity etc). Proportional control avoids the oscillation characteristic of on-off control by continuously adjusting the correcting variable output(s) to keep the process variable stable. Integral action eliminates control deviation errors, and Derivative action counters rapid process movements.

*Also refer to: Control Action; Control Deviation; Control Enable; Control Type; Controller; Correcting Variable; Derivative Action; Gain Scheduling; Integral Action; Manual Mode; On-Off Control; PD Control; PI Control; PID Sets; Primary Proportional Band; Process Variable; Secondary Proportional Band; Setpoint and Tuning.*

## 21.93 PID Gain Sets

The instrument contains PID 5 sets for each control loop, allowing the instrument to be pre-set for differing conditions. Each set has individual values for the proportional bands; overlap/deadband; on-off differential and integral & derivative times.

These values are entered in the control configuration sub menu or via the automatic tuning.

The PID sets might be configured for different applications, or to allow for differing process or load conditions that might occur in a single application. In these cases one set at a time would be selected as the “Active PID” set for that loop.

The PID sets are also used by the automatic gain scheduling feature.

*Also refer to: Derivative Action; Gain Scheduling; Integral Action; On-Off Control; PID; Primary Proportional Band; Secondary Proportional Band and Tuning.*

## 21.94 PLC

This stands for Programmable Logic Controller. A microprocessor based device used in machine control. It is particularly suited to sequential control applications, and uses “Ladder Logic” programming techniques. Some PLC’s are capable of basic PID control, but tend to be expensive and often give inferior levels of control.

*Also refer to: PID.*

## 21.95 Pre-Tune

The Pre-Tune facility artificially disturbs the process variable normal start-up pattern, so that an approximation of the PID values can be made prior to the setpoint being reached. During pre-tune, the controller outputs full primary power until the process value reaches the “tuning point”. With Standard Pre-Tune this is halfway to the setpoint, but an alternative method allows the user to specify the process value to tune at. Pre-tune can be selected from the automatic tuning menu and will automatically disengage once complete.

If self-tune is enabled, it will be suspended while pre-tune runs.

A pre-tune can be configured to run at every power up using the Auto Pre-Tune function.

Refer to the Automatic Tuning section of this manual for full details.

*Also refer to: Auto Pre-Tune; PID; Process Variable; Self-Tune; and Tuning.*

## 21.96 Power Output Limits

Used to limit the correcting variable. Normally the control algorithm can set these outputs to any value between 0% and 100%. If this is undesirable in a particular application, individual settings can limit the primary power upper and lower levels and the secondary power upper and lower levels for each control loop. The upper limit values must be higher than the lower limits. These parameters are not applicable if that output is set for on-off control.

**Use with caution:** The instrument will not be able to control the process if the limits do not allow the outputs to be set to the correct values needed to maintain setpoint.

*Also refer to: Correcting Variable; On-Off Control; PID and Setpoint.*

## 21.97 Primary Proportional Band

The portion of the input span over which the primary output power level is proportional to the process variable value. Applicable if the control type is single or dual. For dual control a secondary proportional band is used for the second output. The control action can be direct or reverse acting, switching the direction of change in power relative to the change in PV.

*Also refer to: Control Action; Control Type; Overlap/Deadband; PID; Process Variable; Secondary Proportional Band; and Tuning.*

## 21.98 Process High Alarm

An alarm configured to as Process High will activate once the process has been above the high alarm value for longer than the alarm minimum duration time. Once activated, the level must drop below the alarm trigger point by more than the alarm hysteresis value before it will deactivate.

High alarm activation is not affected by setpoint changes or the level of control deviation.

*Also refer to: Alarm Operation; Alarm Types; Alarm Duration Minimum; Alarm Hysteresis; Control Deviation; Process Variable and Setpoint.*

## 21.99 Process Inputs

The main inputs used to monitor the process value(s) being controlled.

The input are “Universal”, supporting all common thermocouples, PT100 & NI120 RTDs, potentiometers and DC linear mV, voltage or mA signals. Linear inputs are compatible with any parameter that can be converted to a suitable electronic signal. They can be scaled into engineering units to match the process. The 2<sup>nd</sup> input can also act as an auxiliary input.

*Also refer to: Auxiliary Inputs; Engineering Units; Input Span; PV Offset; Process Variable; Scaled Input Lower Limit and Scaled Input Upper Limit.*

## 21.100 Process Low Alarm n Value

An alarm configured to as Process Low will activate once the process has been below the low alarm value for longer than the alarm minimum duration time. Once activated, the level must rise above the alarm trigger point by more than the alarm hysteresis value before it will deactivate.

Low alarm activation is not affected by setpoint changes or the level of control deviation.

*Also refer to: Alarm Operation; Alarm Types; Alarm Duration Minimum; Alarm Hysteresis; Control Deviation; Process Variable and Setpoint.*

## 21.101 Process Variable (PV)

Process Variables are the parameter to be controlled. Each control loop monitors its PV via one of the process inputs. PVs can be any type that can be measured by these circuits. Common types are thermocouple or RTD temperature probes, or pressure, level, flow etc from transducers that convert these parameters into DC linear input signals (e.g. 4 to 20mA). Linear signals can be scaled into engineering units using the input upper & lower limits.

*Also refer to: Engineering Units; Input Span; Linear Input; Process Input; RTD; Scaled Input Lower Limit; Scaled Input Upper Limit and Thermocouple.*

## 21.102 Process Variable Offset

- Refer to *Calibration*.

### **21.103 Profile Control Menu**

If the profiler option is fitted, a profile control menu is available from the main menu. It allows the user to select or run a profile, and then control that profile (run, hold, abort, skip to next segment etc.).

Refer to the Profiler Control Menu information in the Configuration & Use section.

*Also refer to: Main Menu; Profile Setup Menu; Profiler and Profiler Mode.*

### **21.104 Profile Events**

Events are outputs that can be made active during profile segments. Any of the five events tracks can be configured to be active or inactive for the duration of each segment, from the profile setup menu. For end segments, events selected to be stay active until the unit is powered down or a new profile runs. It is possible to logically link event and alarms to outputs with a boolean OR or AND selection.

*Also refer to: Alarm Types; Logical Combinations; Profile Segments; Profile Setup Menu; Profiler and Profiler Mode.*

### **21.105 Profile Header**

The profile header contains information about how the profile starts and stops, the power loss recovery action, if the profile should repeat multiple times when run as well as whether the profile runs as a single or two loop profile.

Refer to the Profile Components information in the Profiler Option section of this manual.

*Also refer to: Profile Segments, Profile Setup Menu, Profiler and Profiler Mode.*

### **21.106 Profile Segments**

Segments can be ramps, dwells, steps or special segments such as holds, loop-backs, ends or joins. A maximum of 255 segments are possible, shared amongst up to 64 profiles.

Refer to the Profile Components information in the Profiler Option section of this manual.

*Also refer to: Profile Events, Profile Setup Menu, Profiler and Profiler Mode.*

### **21.107 Profile Setup Menu**

If the Profiler option is fitted, a profile setup menu is available from the main menu. It allows the user to create or edit the profile header and profile segments. Profiles can also be deleted from this menu. This menu is protected by a lock code.

Refer to the Profiler Setup Menu information in the Configuration & Use section.

*Also refer to: Lock Codes; Profile Control Menu; Profile Header; Profile Segments; Profiler and Profiler Mode.*

### **21.108 Profiler**

A profiler controls the value of the actual setpoint over time; increasing, decreasing or holding its value as required. This is used in applications where the rate of rise or fall of the process variable must be closely controlled, or where a value must be maintained for a period before moving to the next value. If the Profiler is fitted, up to 64 profiles can be created with 255 segments shared amongst them. These profiles can control the setpoints for loop 1 only or both loops. Each segment can activate/deactivate the five events.

Refer to the Profiler Option section.

*Also refer to: Actual Setpoint; Controller Mode; Profile Events; Profile Control Menu; Profile Header; Profile Segments; Profile Setup Menu and Profiler Mode.*

### **21.109 Profiler Mode**

This mode is entered when a profile is selected or run. The instrument will remain in profiler mode when the profile finishes or is aborted, unless the segment end type/profile abort action is set to "Use Controller Setpoint".

*Also refer to: Controller Mode; Profile Control Menu; Profile Segments; Profile Setup Menu; Profiler and Setpoint.*

### 21.110 Proportional Control

Proportional control gradually changes the correcting variable applied from 0 to 100% of the available power as the process moves through the “Proportional Band”. If the control type is dual, both primary & secondary outputs available, equating to -100 to +100%. When the proportional bands are correctly tuned, the process is maintained at a steady value, avoiding the oscillation characteristic of on-off control. Proportional control is commonly used in conjunction with integral and derivative action to give PI, PD or PID control.

*Also refer to: Control Type; Correcting Variable; Derivative Action; Integral Action; PD; PI; PID; Primary Proportional Band; Process Variable; Secondary Proportional Band; and Tuning.*

### 21.111 Rate

- Refer to *Derivative Action*.

### 21.112 Rate of Change Alarm

An alarm based on the rate of change in the measured process variable. If the PV changes at a rate greater than the alarm level, the alarm will activate. The rate of change must be above the alarm threshold for longer than the alarm minimum duration time before the alarm will change state (from on to off, or off to on). **Caution: If the duration is less than this time, the alarm will not activate no matter how fast the rate of rise.**

*Also refer to: Alarm Hysteresis; Alarm Minimum Duration; Alarm Operation; Alarm Types and Process Variable.*

### 21.113 Ratio Control

Ratio control is where part of the process is controlled in proportion to another part. For example, it could mix two materials at a desired ratio by adjusting the flow of input 1 in relation to the flow measured by input 2. The flow of input 2 may be controlled separately, but not by the ratio loop. If two process inputs are fitted, this instrument can be configured for stoichiometric combustion control, where the fuel-air ratio is controlled for a burner.

Refer to the Ratio Control section of this manual for full details.

*Also refer to: Controller; PID and Process Variable.*

### 21.114 Recorder Configuration

If the data recorder is fitted, a recorder configuration sub-menu is added to configuration mode. This is used to adjust the recorder parameters (recording mode, sample interval, recording triggers and values to record).

*Also refer to: Configuration Mode; and Data Recorder*

### 21.115 Recorder Option

- Refer to *Data Recorder*.

### 21.116 Recorder Menu

If the data recorder is fitted, a recorder menu is added to the main menu. This is used to control the recording manual recording trigger, delete recordings or to show the recorder status. This menu is protected by a lock code.

Refer to the Recorder Menu information in the Configuration & Use section.

*Also refer to: Lock Codes; Main Menu and Data Recorder*

### 21.117 Relay

An electromechanical switch operated by a solenoid coil. Relays are used for alarms or, on-off/time proportioning control outputs. The limited current capacity and switching cycles of the internal relays means that they are often connected to larger external slave relays/contactors which are capable of switching much larger currents and are easily replaced once worn out. A suitably rated RC snubber should be used to suppress noise generated as they switch (refer to the noise suppression information in the Electrical Installation section).

*Also refer to: Latching Relay; SSR Driver; Time Proportioning Control and Triac*

### 21.118 Remote Setpoint (RSP)

The alternate setpoint type can be configured as a “remote” setpoint, where an analog VDC or mADC signal applied to the 2<sup>nd</sup> input or auxiliary input A sets the controller setpoint value. The signal can be scaled to give the desired setpoint values at the inputs’ minimum & maximum values, but the setpoint is always constrained by the setpoint limits. This method can also be used for cascade or multi-zone slaves.

*Also refer to: Alternate Setpoint; Auxiliary Input; Auxiliary Input Lower Limit; Auxiliary Input Type; Auxiliary Input Upper Limit; Cascade Control; Linear Input; Local Setpoints; Master & Slave; mADC; Setpoint and Setpoint Select; and VDC.*

### 21.119 Retransmit Output

A linear VDC or mADC output signal proportional to the process variable or setpoint, for use by slave controllers in multi-zone applications or external devices, such as a chart recorder or PLCs. The output can be scaled to transmit any portion of the input or setpoint span.

*Also refer to: Input Span; Linear Output; mADC; Master & Slave; PLC; Process Variable; Retransmit Output Scale Maximum; Retransmit Scale Minimum; Setpoint and VDC.*

### 21.120 Retransmit Output Scale Maximum

Scales a linear output if it has been selected to retransmit a process or setpoint value. Retransmit scale maximum defines the point at which the output will be at its maximum value. E.g. for a 0 to 5V output, it is the PV or SP value corresponding to 5V. If this parameter is set to less than the retransmit output scale minimum, the relationship between the process/setpoint value and the retransmission output is reversed so that higher PV/SP values give a lower output.

*Also refer to: Process Variable; Retransmit Output; Retransmit Output Scale Minimum; Scaled Input Upper Limit and Setpoint.*

### 21.121 Retransmit Output Scale Minimum

Scales a linear output if it has been selected to retransmit a process or setpoint value. Retransmit scale minimum defines the point at which the output will be at its minimum value. E.g. for a 0 to 5V output, it is the PV or SP value corresponding to 0V. If this parameter is set to a value greater than that for retransmit output scale maximum, the relationship between the process/setpoint value and the retransmission output is reversed so that higher PV/SP values give a lower output level.

*Also refer to: Process Variable; Retransmit Output; Retransmit Output Scale Maximum; Scaled Input Lower Limit and Setpoint.*

### 21.122 Reset To Defaults

This Configuration sub-menu selection returns all of the instruments settings back to their factory defaults. It should be used with great care, as the action cannot be undone.

*Also refer to: Configuration Menu.*

### 21.123 Reverse Acting Control

Reverse control action is required for applications where the primary control output increases the process variable, such as in a heating application. With reverse action, primary proportional outputs decrease the correcting variable as the process variable increases within the proportional band, and primary On-Off outputs turn off when the process exceeds the setpoint. The control action of a secondary output is always the opposite of the primary.

*Also refer to: Control Action; Control Type; Correcting Variable; Direct Acting Control; On-Off Control and Proportional Control.*

### 21.124 RS485

RS485 (also known as EIA-485) is two-wire, half-duplex, multi-drop serial communications connection. RS485 only defines the physical layer electrical specification, not the protocol that is transmitted across it. It uses differential signals (the voltage difference between the wires) to convey data. One polarity indicates a logic 1, the reverse polarity indicates logic 0. The applied voltages can be between +12 V and -7 volts, but the difference of potential must be > 0.2 volts for valid operation. RS485 can span distances up to 1200 metres

using inexpensive twisted pair wires. Data speeds can be as high as 35 Mbit/s over 10 m and 100 kbit/s at 1200 m. This instrument supports 4800, 9600, 19200, 38400, 57600 or 115200 bps.

It is recommended that the wires be connected as series of point-to-point (multi-dropped) nodes (not in a star or ring format), with 120 $\Omega$  termination resistors connected across the wires at the two ends of the network. Without termination resistors, electrical noise sensitivity is increased and signal reflections can cause data corruption. The master device should provide powered resistors to bias the wires to known voltages when they are not being driven. Without biasing the data lines float, so noise can be interpreted as data.

Converters from RS232 or USB to RS485 allow computers to communicate over RS485. Repeaters can be used to extend the distance and/or number of nodes on a network.

*Also refer to: Modbus RTU and Serial Communications*

### **21.125 RTD**

Resistance Temperature Detector. A temperature sensor that changes resistance with a change in the measured temperature. This instrument supports PT100 (platinum, 100 $\Omega$  at 0°C) and NI120 (nickel, 120 $\Omega$  at 0°C) sensors. These have positive temperature coefficients (PTC) which means their resistance increases with higher temperatures. The temperature measured by the sensor can be displayed as °C; °F or K.

*Also refer to: Input Range; Process Input and Thermocouple.*

### **21.126 Scaled Input Upper Limit**

For linear inputs, this parameter is used to scale the displayed process variable. It defines the displayed value when the process variable input is at its maximum value (e.g. if 4 to 20mA represents 0 to 14pH, this parameter should be set to 14). The value can be set from -1999 to 9999 and can be set to a value less than (but not within 100 LSDs of) the Scaled Input Lower Limit, in which case the sense of the input is reversed.

For thermocouple and RTD inputs, it is used to reduce the effective span of the input. All span related functions work from the trimmed input span. It can be adjusted within the limits of the range, but not less than 100 LSD's above the Scaled Input Lower Limit.

*Also refer to: Engineering Units; Input Range; Input Span; LSD; Process Variable and Scaled Input Lower Limit.*

### **21.127 Scaled Input Lower Limit**

For linear inputs, this parameter is used to scale the displayed process variable. It defines the displayed value when the process variable input is at its minimum value (e.g. if 4 to 20mA represents 0 to 14pH, this parameter should be set to 0). The value can be set from -1999 to 9999 and can be set to a value higher than (but not within 100 LSDs of) the Scaled Input Upper Limit, in which case the sense of the input is reversed.

For thermocouple and RTD inputs, it is used to reduce the effective range of the input. All span related functions work from the trimmed input span. It can be adjusted within the limits of the range, but not less than 100 LSD's below the Scaled Input Upper Limit.

*Also refer to: Engineering Units; Input Range; Input Span; LSD; Process Variable and Scaled Input Upper Limit.*

### **21.128 Secondary Proportional Band**

If the control type is set to dual, this is the portion of the input span over which the secondary output power level is proportional to the process variable value. The control action for the secondary output is always the opposite of the primary output.

*Also refer to: Control Action; Control Type; On-Off Control; Input Span; Overlap/Deadband; PID; Primary Proportional Band and Tuning.*

### 21.129 Self-Tune

Self-Tune continuously optimises tuning while a controller is operating. It monitors control deviation errors and uses them to calculate new PID values. If the controller is new or the application has changed, the initial values may be far from ideal, in which case pre-tune can be used to first establish new initial values. Self-tune will then fine-tune these values. Self-tune is suspended while pre-tune is running.

Refer to the Automatic Tuning section of this manual for full details.

*Also refer to: Control Deviation; Modulating Valves. On-Off Control; Pre-Tune; PI; PID; Setpoint and Tuning.*

### 21.130 Sensor Break Pre-Set Power

If a thermocouple or RTD is disconnected or breaks, the instrument detects the condition within 2 seconds, and sets the control loops output(s) to a value defined by the sensor break pre-set power parameter in the control configuration sub-menu. Process, band and deviation alarms behave as though the PV has gone high. Non-zero based linear inputs (e.g. 2 to 10V or 4 to 20mA, but not 0 to 20mA) also detect sensor break conditions and set the same pre-set power value, but alarms behave as though the PV has gone low.

*Also refer to: Input Range; Linear Input; RTD and Thermocouple.*

### 21.131 Serial Communications Configuration

A sub-menu of configuration mode used to adjust the serial communications parameters (addressing, data rate, parity, master/slave settings and write enabling).

*Also refer to: Configuration Mode and Serial Communications*

### 21.132 Serial Communications Option

An optional feature that allows other devices such as a PC, PLC or master controller, to read and change instruments parameters via an RS485 or Ethernet network.

Full details can be found in the Serial Communications sections of this manual.

*Also refer to: Ethernet; Master & Slave; Modbus RTU; Modbus TCP; PLC; RS485 and Serial Communications Configuration.*

### 21.133 Set Valve Closed Position

When valve position indication is used in valve motor drive control mode, this parameter defines the input value that is measured by the 2<sup>nd</sup> input when the valve is fully closed. The valve must be driven to its “Closed” end stop before setting this parameter.

It must not be used to limit valve movement; separate Valve Close and Open Limit parameters are available for this purpose.

*Also refer to Auxiliary Input; Set Valve Opened Position; Valve Close Limit; Valve Open Limit; Valve Motor Control and Valve Position Indication.*

### 21.134 Set Valve Opened Position

When valve position indication is used in valve motor drive control mode, this parameter defines the input value that is measured by the 2<sup>nd</sup> input, when the valve is fully opened. The valve must be driven to its “Open” end stop before setting this parameter.

It must not be used to limit valve movement; separate Valve Close and Open Limit parameters are available for this purpose.

*Also refer to Auxiliary Input; Set Valve Closed Position; Valve Close Limit; Valve Open Limit; Valve Motor Control and Valve Position Indication.*

### 21.135 Setpoint

The target value at which the instrument attempts to maintain the process, by adjusting its control output power (the correcting variable). There are two setpoints for each control loop. A main local setpoint and an alternate setpoint that can be another local setpoint or a remote setpoint input from an auxiliary input. One setpoint at a time is chosen to be active using the setpoint selection, or if the profiler is fitted it can set the actual setpoint value over time. Setpoint values are always limited by the setpoint limits.

*Also refer to: Alternate Setpoint; Auxiliary Input; Correcting Variable; Local Setpoints; Process Variable; Profiler; Remote Setpoint; Scaled Input Lower Limit; Setpoint Lower Limit; Setpoint Upper Limit and Setpoint Select*

### 21.136 Setpoint Upper Limit

The maximum value allowed for setpoints, adjustable within the scaled input limits. The value should be set below any level that might cause problems in the process. If the value is moved below the current value of a setpoint, that setpoint will automatically adjust to keep it within bounds.

*Also refer to: Input Span; Scaled Input Upper Limit; Setpoint and Setpoint Lower Limit.*

### 21.137 Setpoint Lower Limit

The minimum value allowed for setpoints, adjustable within the scaled input limits. The value should be set above any level that might cause problems in the process. If the value is moved above the current value of a setpoint, that setpoint will automatically adjust to keep it within bounds.

*Also refer to: Input Span; Scaled Input Lower Limit; Setpoint and Setpoint Upper Limit.*

### 21.138 Setpoint Ramp Rate

Setpoint ramping is used to protect the process from sudden changes in the setpoint, which would result in a rapid change in the process variable. A rate is set at which the actual setpoint value ramps towards its target value, when the setpoint value is adjusted or the active setpoint is changed. The feature can be turned off by setting the ramp rate to "OFF".

To further protect the process, the initial value of the setpoint is made equal to the current process variable value at power-up, when switching back to automatic from manual control, from control disabled to enabled or after a sensor break is repaired. The actual setpoint will rise/fall from this value at the ramp rate set, until it reaches the target setpoint value.

*Also refer to: Active Setpoint; Actual Setpoint; Manual Mode; Process Variable; Setpoint and Setpoint Selection.*

### 21.139 Setpoint Selection

The setpoint select parameter in the control sub-menu defines whether the active setpoint will be the main or alternate setpoint. The choice of setpoint can also be made via a digital input or an operation mode if the selection screen has been enabled.

*Also refer to: Active Setpoint; Display Configuration; Alternate Setpoint; Digital Input; and Setpoint.*

### 21.140 Setup Wizard

A sub-set of the configuration menu parameters chosen to allow easy setup for basic applications. Users with more complex applications should select the parameters they need directly from the configuration menus. The wizard runs automatically at the first ever power-up and exits to operation mode when completed. The wizard can be run manually from the main menu (requires an unlock code). An option to reset all parameters to default is offered when manually running the wizard.

Refer to the Setup Wizard information in the Configuration & Use section.

*Also refer to: Lock Codes; Configuration Menu; Main Menu; Operation Mode and Reset to Defaults.*

### 21.141 Solid State Relay (SSR)

An external device manufactured using two silicone controlled rectifiers in reverse parallel. SSRs can replace mechanical relays in most AC power applications. Some special SSRs can switch DC, but most cannot. As a solid-state device, an SSR does not suffer from contact degradation when switching electrical current. Much faster switching cycle times are also possible, leading to superior control. The triac option on this instrument

provides is a small 1amp AC internal SSR. The SSR driver options on this instrument provide >10VDC time-proportioned pulses at the rate defined by the cycle time. When applied to the signal input of an external SSR, it causes it to pulse current from the line supply to the load.  
The external SSR can be any current capacity available.

*Also refer to: Cycle Time; Time Proportioning Control; Relay; and Triac.*

### **21.142 Solenoid Valve**

An electromechanical device, use to control the flow of gases or liquids. Unlike a modulating valve, a solenoid valve has just two states, open or closed. Usually a spring holds the valve closed until a current passed through the solenoid coil forces it open. Standard control mode is required with a time-proportioned or on-off output for this type of valve.

Solenoid valves are often used with high/low flame burners. A bypass supplies some fuel at all times, but not enough to heat the process more than a nominal amount (low flame). A controller output opens the valve when the process requires additional heat (high flame).

*Also refer to: Modulating Valves; On-Off Control and Time Proportioning Control.*

### **21.143 Supervisor Mode**

Supervisor Mode allows access to a lock-code protected sub-set of the main configuration parameters. Up to 50 configuration menu parameters can be chosen for inclusion in using the PC configuration software.

Refer to the Supervisor Mode information in the Configuration & Use section.

*Also refer to: Configuration Menu; Lock Codes and PC Software.*

### **21.144 Thermocouple**

A temperature sensor made from two different metals. The thermoelectric effect generates a small signal (a few microvolts per °C) relative to the difference between the “cold” junction (at the measuring instrument) and the “hot” junction. This does mean that the wires and connectors used must match the metals used in their construction. Other issues are their nonlinearity and limited accuracy.

However, basic thermocouples are cheap to make and can measure a wide range of temperatures. While those made from more exotic materials can even withstand the very high temperatures found in furnaces.

The color codes for the common types are shown in the Thermocouple Wire Identification Chart in the Electrical Installation Section of this manual.

*Also refer to: Input Range; Process Input and RTD.*

### **21.145 Three Point Stepping Control**

Motorised modulating valves normally require a special “Three Point Stepping” control algorithm. This which provides an output to move the valve further open, or further closed whenever there is a control deviation error. When this error is zero, no further output is required to maintain control unless load conditions change. This type of control is use when the instrument is in Valve Motor Drive (VMD) control mode.

*Also refer to: Control Deviation; Modulating Valve and Valve Motor Control*

### **21.146 Time Proportioning Control**

Time proportioning control is accomplished by cycling the output on and off during the prescribed cycle time, whenever the process variable is within the proportional band(s). The PID control algorithm determines the ratio of time (on vs. off) to achieve the level of the correcting variable required to remove the control deviation error. E.g. for a 32 second cycle time, 25% power would result in the output turning on for 8 seconds, then off to 24 seconds. This type of output might be used with electrical contactors, solid state relays or solenoid valves. Time proportioning control can be implemented with relay, triac or SSR driver outputs.

*Also refer to: Control Deviation; Correcting Variable; Continuous Control, Current\_Proportioning\_Control; Cycle Time; PID; Primary Proportional Band; Relay; Secondary Proportional Band; Solenoid Valve; SSR and Triac.*

### 21.147 Trend Displays

Trend views are a standard feature on all models. They graphically represent recent process conditions for the control loops, showing the most recent 120 out of 240 stored data points. This data can be the process variable; process variable & setpoint (shown as a dotted line) or the minimum and maximum value of the process variable measured since the last sample. The scaling adjusts automatically to the visible data. Any active alarms are indicated above the graph. The user can scroll the right hand cursor line back to examine all 240 data points. Their sample interval and data to display is set in display configuration.

Unlike the optional data recorder, trend views do not retain the stored data if the power is turned off.

*Also refer to: Alarm Types; Display Configuration; Operation Mode; and Process Variable; Setpoint.*

### 21.148 Tuning

PID Controllers must be tuned to the process in order for them to attain the optimum level of control. Adjustment is made to the tuning terms either manually, or via the automatic tuning facilities. Tuning is not required if the controller is configured for on-off Control.

*Also refer to: Auto Pre-Tune; Controller; Derivative Action; Integral Action; On-Off control; PID; Pre-Tune; Primary Proportional Band; Self-Tune; Secondary Proportional Band and Tuning Menu.*

### 21.149 Tuning Menu

The tuning menu can be accessed from the main menu. This menu is lock-code protected. It gives access to the pre-tune, auto pre-tune and self-tune facilities. These assist with PID tuning, by setting up Proportional bands, Integral and Derivative time values.

Pre-tune can be used to set PID parameters initially. Self-tune may then be used to optimise the tuning if required. Pre-tune can be set to run automatically after every power-up by enabling Auto Pre-Tune.

Refer to the Automatic Tuning information in the Configuration & Use section.

*Also refer to: Auto Pre-Tune; Derivative Action; Integral Action; Lock Codes; Main Menu; On-Off control; PID; Pre-Tune; Primary Proportional Band; Self-Tune and Secondary Proportional Band.*

### 21.150 Triac

A small internal solid state relay, which can be used in place of a mechanical relay for low power AC switching (0.1 to 1 amp AC). Like a relay, the output is time proportioned. However, as solid-state devices, triacs do not suffer from contact degradation so much faster switching cycle times are possible, offering improved control and reliability. A snubber should be fitted across inductive loads to ensure reliable switch off the triac.

*Also refer to: Cycle Time; Relay; SSR and Time Proportioning Control.*

### 21.151 USB Menu

A lock-code protected USB menu is offered from the main menu for the USB option. This allows the user to read or write files to a USB memory stick. The current configuration of the instrument can be copied to the stick, or the instrument **can be reconfigured from a file created using the PC software or copied from another instrument. Profiles can also** be copied from the instrument to a USB stick or you can upload pre-stored files created earlier from the PC software or copied from another instrument.

Data recordings can be copied to the stick for later analysis on a PC.

Refer to the USB Menu information in the Configuration & Use section.

*Also refer to: Data Recorder; Lock Codes; Main Menu; PC Software and Profiler*

### **21.152 Valve Motor Drive Control (VMD)**

This control mode is used when directly controlling the motor of a modulating valve or damper. It uses a 3-point stepping Valve Motor Drive control algorithm to open or close the valve. VMD mode is not suitable if the modulating valve has its own positioning circuit (use standard control with a continuous current proportioned linear output) or solenoid valves (use standard control with a time proportioned output).

*Also refer to: Continuous Control, Current\_Proportioning\_Control; Linear Output; Modulating Valve; Solenoid Valve; Three Point Stepping Control and Time Proportioning Control.*

### **21.153 Valve Position or Flow Indication**

The valve motor drive control mode does not require any kind of position feedback in order to correctly control the process. However, where potentiometer feedback or (mA or VDC) flow signals are available, they can be connected to the 2nd input to indicate valve position or flow level. The display is a percentage (0 to 100%) shown as a bar-graph in the main operator mode screen.

Even if position feedback is provided, it is not used by the VMD control algorithm when positioning the valve, thus avoiding problems associated with faulty feedback signals.

*Also refer to Auxiliary Input; Bar-graph; Display Strategy; Open Loop VMD; PID; Set Valve Closed Position; Set Valve Open Position; Setpoint; and Valve Motor Control.*

### **21.154 Valve Open & Closed Limits**

When valve position indication is used in VMD control mode, the valve limit parameters can be used to “clamp” the maximum and minimum valve positions. The controller will not attempt to drive the valve past these points.

The position indication input must correctly scaled using “set valve open” and “set valve closed” before using the valve limits.

*Also refer to Set Valve Closed Position; Set Valve Open Position; Valve Motor Control and Valve Position Indication.*

# 22PC Software

The primary function of the software is to create, download and store instrument configurations and profiles. If the data recorder feature is fitted, its recordings can be downloaded and analysed via the software.

There are several extra features that are only possible via the software. Changes can be made to the operation of the instrument by adding extra screens into operation mode, enabling and configuring a “Supervisor Mode”, as well as changing the contact details, alarm status labels or the functions and labels of the front LED’s. You can download a new language file or customise the controller by changing the start-up “splash screen”.

An on-screen simulation of the instrument can be setup and tested on a configurable load simulation prior to downloading the settings to an instrument.

An additional software tool is available to set the IP address required for the Modbus TCP communications option - refer to the Network Configuration section on page 239.

## 22.1 Using the PC Software

The menus and button bar are used to select the main parameter screen or one of the other modes or functions. Hover the mouse over the parameter description or value to view a fuller description. Consult the comprehensive help (available from the Help Menu) for information about the general software functions.




Figure 66. Main Parameter Screen

The main parameter screen is used to change the configuration and other instrument settings. This screen also allows access to the Supervisor and Enhanced Operation Mode configuration screens from the Mode drop-down list. Refer to the relevant sections of this manual for full information on the various instrument modes and parameters.

The Button bar, Device and View menus are used to access the other software functions.




Figure 67. Button Bar & View Menu

## 22.2 Instrument Simulation

The software has a fully functional and interactive instrument simulation that includes a configurable simulated process, allowing the instrument settings to be tested before use.

Inputs are simulated in the top panel. A value (in display units) entered in INP1 & INP2 will override the values from the simulated processes or for a linear inputs, a mA or VDC value preceded by # (e.g. #12.0) can be used to verify the scaling. Enter F to simulate a sensor break. Tick boxes simulate the digital inputs

Active analog and digital outputs are indicated in the lower panel.

The simulated instrument can also be accessed and configured by pressing its “buttons” with your mouse, or by using the 4 arrow keys on your keyboards.

Figure 68. Honeywell DCP250 Instrument Simulation

## 22.3 Configuring the Connection

The software communicates with the instrument using Modbus via the RJ11 configuration socket located on the underside of the case, or via the Ethernet or RS485 options if fitted. *Refer to the wiring section for connection details.*

The configuration socket is intended for initial configuration before installing the instrument in the application. An RS232 to TTL lead (*available from your supplier*) is required to connect this socket to your PCs RS232 serial port or USB to RS232 adaptor.

A front mounted USB port is available on some models; this can also be used to configure the instrument or transfer profile files, via a USB memory stick.



**CAUTION:** The configuration lead/socket is not isolated from the process input or SSR Driver outputs. It is not intended for use in live applications.

A communications settings screen is shown whenever the user attempts to connect to the instrument from the software. If the settings are not in-line with the information below, the software may not be able to communicate with the instrument.

### 22.3.1 Connection from PC to Bottom Configuration Socket

When using the built-in configuration socket, set the communications parameters as shown here and in the following table.

- **Device connector** = Configuration Socket
- **PC connector** = the PC Serial Com port number you are connected to
- **Start and Stop bits** = 1
- **Data bits** = 8.
- **Parity, Bit Rate & Address** = must match settings in the table below



**Note:** When uploading or downloading via the bottom mounted configuration port, the required software communication settings depend on the module fitted in slot A. See the table below.

Settings

|                  |       |
|------------------|-------|
| Device connector | Bus   |
| PC connector     | COM1  |
| Start bits       | 1     |
| Data bits        | 8     |
| Stop bits        | 1     |
| Parity           | none  |
| Bit rate         | 19200 |
| Address          | 1     |

| Slot A Module   | Bit Rate                                                  | Parity | Address |
|-----------------|-----------------------------------------------------------|--------|---------|
| Slot A Empty    | 19200                                                     | None   | 1       |
| Digital Input   | 19200                                                     | None   | 1       |
| Ethernet Comms  | 9600                                                      | None   | 1       |
| Auxiliary Input | 4800                                                      | None   | 1       |
| RS485 Comms     | Must match the Communication Configuration menu settings. |        |         |

### 22.3.2 Connection from PC to Rear RS485 Communications Option

When using the optional RS485 communications, set the parameters as shown here.

- **Device connector** = Bus
- **PC connector** = the PC Serial Com port number you are connected to
- **Start and Stop bits** = 1
- **Data bits** = 8
- **Parity, Bit Rate & Address** = must match the settings in the instruments own Communication Configuration menu.

### 22.3.3 Connection from PC/Network to Ethernet Port

When using the optional Ethernet communications, set the parameters as shown here.

Device connector = Bus

PC connector = Ethernet (bus coupler)

IP Address = Instrument IP address\*

Port Address = 502.

|                  |                        |
|------------------|------------------------|
| Device connector | Bus                    |
| PC connector     | Ethernet (bus coupler) |
| IP address       | 192.128.1.12           |
| Port address     | 502                    |



**Note:** \*An IP address must be set before connecting via Ethernet. Use the default address of 0.0.0.0 if your network uses DHCP, BootP or AutoIP or ask your network administrator for a valid address.

Most networks will assign the IP address automatically, but you can use the Lantronix XPort® DeviceInstaller™ tool if you need to assign or change the IP address manually.

For the latest version, go to: [www.lantronix.com/device-networking/utilities-tools/device-installer.html](http://www.lantronix.com/device-networking/utilities-tools/device-installer.html)

### 22.3.4 Changing the IP Address

Connect the instrument to your network by plugging an Ethernet cable into the top mounted RJ45 socket. Run the DeviceInstaller™ tool from a PC on the same network. The tool should automatically find this and any other controllers on the network. If not use the search button. The existing IP and Hardware (MAC) addresses are shown for the instruments found.



Click the Assign IP button and enter the correct hardware address from the list (if necessary, confirm the number by comparing the hardware address with the number printed on Ethernet adaptor label).

At the next screen, choose whether to obtain the IP address automatically or to enter a specific address. For automatic addresses, select the protocols supported on your network (DHCP, BootP or AutoIP). For a specific address, enter the address, sub-net mask and default gateway information. Your network administrator will be able to provide this information. Press the assign button to confirm.


It is recommended to keep all other Ethernet device settings at the default values. If you do change the internal interface transfer speed or parity, matching settings must be made to the instruments Modbus data rate and parity settings in the communications configuration menu.



**Note:** You can enter any valid IP address, perhaps for use in another location, but if the number used does not match your existing network settings, further communication with the instrument will cease.


### 22.3.5 USB Memory Stick Folders & Files

If a USB flash drive is used to transfer files between instruments and/or the software, the files must be stored in specific **DEVICE**, **CONFIG** and **PROFILE** folders. When saving files from the software to the USB stick, always ensure they are saved to the correct folder. Local file storage on your PC can be in any location. The USB option also limits the file name to 8 characters plus the 3 digit .bct or .pfl extension. Longer file names will be truncated.



**CAUTION:** When saving a file, the data will be overwritten if the file name already exists.

## 22.4 Instrument Configuration



When creating a new configuration with the software, the basic instrument type and the options fitted to it must be defined in the Device Selection screen. You can select these from the drop down lists or by typing the full model number in the Order number field.

**Note:** It is important that the options selected match those fitted to your unit.



Alternatively the complete instrument type and existing configuration can be uploaded to the PC from your instrument, via the configuration socket or serial communications. A previously saved configuration file can be opened from the file open menu or button.

### 22.4.1 Main Parameter Adjustment


The main parameter screen contains the configuration settings broken down into functional groups similar to the instruments' menus. The parameters can be changed in the yellow Value column. Type in new values or select from the list offered. Invalid values will be highlighted in red (possible values are shown to the left). Parameters are "greyed out" if they are inaccessible due to hardware not being fitted or if they are disabled by other settings.

Once the required changes are made, the configuration can then be downloaded to the instrument or saved to hard disk or a USB stick, with a .bct file extension. The file contains the device information and configuration parameter settings, including any supervisor and enhanced operation mode screens or changes to the LED functions. Transfer of comms settings and clock date/time are via optional tick boxes on the download settings screen. Profiles, splash screens language files and data recordings are not saved in the .bct file. They are uploaded/saved separately.

## 22.4.2 Extending Functionality via Software

### 22.4.2.1 LED Functions & Labels

The allocated functions and descriptive labels for the 4 LED indicators can be changed with the PC software, replacing the default PRI; SEC; TUNE; ALARM functions. These parameters can be found in the LED settings section of the software's Display Configuration functional group.

|            |                                                                                   |                                        |
|------------|-----------------------------------------------------------------------------------|----------------------------------------|
| LED 1 to 4 |  | LED LABELS ( <i>max 5 characters</i> ) |
|------------|-----------------------------------------------------------------------------------|----------------------------------------|

Possible functions for each of the LEDs are: Loop 1 or 2 primary/secondary/valve control output indication (output ON = LED ON), or driving them from a logical OR combination of the alarm/profile event/digital inputs/auto-tune status/manual mode. This logical combination can be inverted to create a logical NOR function for the LEDs.

The user can create new 5 characters LED labels for the main and alternate language.

### 22.4.2.2 Alarm Status Screen Labels

The titles “Alarm *n*” used in the alarm status screen can be replaced with the software. Two separate sets of 8 characters labels can be entered for each of the seven alarms. One label set is used when the main display language has been selected, the other is used when the alternate language is in use.

### 22.4.2.3 Configuring the Supervisor Mode

The purpose of the supervisor mode is to allow selected operators access to a “lock-code” protected sub-set of the configuration parameters, without giving them the higher level configuration menu unlock code. Up to 50 configuration parameters can be selected for inclusion in the supervisor mode screen sequence. If the parameter is normally displayed on screen with another parameter, both parameters will appear.

It is not possible to configure supervisor mode screens without using the software.

To define these screens, first select Supervisor Mode from the mode drop-down list, then select the functional group containing the parameter to be added. Highlight the parameter name and click the Add Entry button. The Move Entry Up and Down buttons are used to change the order which the parameters will appear in the instruments' Supervisor Mode. Unwanted entries can be highlighted and deleted with the Remove Entry button.

### 22.4.2.4 Configuring Custom Display Screens for the Extended Operator Mode

Users can access a sub-set of the configuration parameters at the end of the normal operation mode if this additional screen sequence is defined from the software. Up to 50 parameters from configuration menus can be selected for inclusion in the screen sequence. If the parameter is normally displayed on screen with another parameter, both parameters will appear.

It is not possible to configure custom display screens without using the software. To define these screens, first select Extended Operator Mode from the mode drop-down list, then select the functional group containing the parameter to be added.

Highlight the parameter name and click the Add Entry button. The Move Entry Up and Down buttons are used to change the order which the parameters will appear at the end of the normal operator screens.

Unwanted entries can be highlighted and deleted with the Remove Entry button.



**Note:** Any parameters copied into the custom display screens are not password protected. They can be freely viewed and adjusted by anyone with access to the instrument keypad.





**Figure 69. Supervisor/Enhanced Operation Mode Configuration**

#### 22.4.2.5 Changing the Start-up Splash Screen

The graphic shown during the instrument start-up sequence can be changed by selecting the Download Splash Screen option from the Device menu. Choose your new graphic file (most common graphic file types are supported).

The chosen image will be converted to monochrome and be rescaled to 160 pixels wide by 80 pixels high. For best results, the image should be simple and have an aspect ratio of 2:1. Complex graphics with multiple colors or greyscales will not reproduce well. A preview of the results is shown. Click the Download button to store it to the instrument.



#### 22.4.2.6 Changing the Alternate Display Language

The alternate language can be changed by selecting the Download Language File option from the Device menu. Choose the correct file (language files have a .bin extension) and click the Open button to store it to the instrument.

Ask your supplier for a copy of the latest language file.

## 22.5 Profile Creation and Editing

Select the Profile Editor from the button bar or view menu. An existing profile file can be opened from the file open menu or button, or uploaded from an instrument connected to the PC via the configuration socket or serial communications module. The new profile can be download to the instrument or saved to disk with a .pfl file extension.



**CAUTION:** Take care to preserve any profile joins when editing or uploading profile files to an existing configuration. Joins are based on the profile numbers. Ensure profiles is uploaded to the correct location.





**Figure 70. Profile Editor – Header**



If the option to upload a profile is chosen, a list of profiles in the connected instrument is shown. The user can select the required profile from the list.

A directory of existing profiles in the instrument can also be requested. This allows one or all of the profiles to be deleted.


When downloading a profile to the instrument via the configuration socket or over serial communications, a list of existing profiles and empty profile slots is displayed. The user can select where to place the profile (a warning is shown if the profile will overwrite an existing profile).

The number of available free segments is also shown.

A drop-down menu switches between the Profile Header and Segment Data. Refer to the *Profiler Setup Menu* and *Profiler Option* sections for full details of the header and segment data.

Header data includes a 16-character profile name, options for starting the profile after a delay or at a specific day and time, the starting setpoint, the action to take after a power/sensor failure or profile abort, the number of times the profile will run and if one or both control loops will be controlled.

The segments are shown in Segment Data mode. The last segment type is either End, Join or Repeat Sequence, and cannot be deleted. The user can change any segments' type and values, or insert additional segments before the selected one. A dynamically scaled graphic shows the setpoint(s) for each segment of the profile, with the current selected segment highlighted in red. The five profile events are shown below the graph.



A hard copy of the profile, including the graph and events can be printed from the File | Print menu.

## 22.6 Data Recorder Trend Upload & Analysis

### 22.6.1.1 Uploading Data

Recordings can be transferred to a memory stick using the optional USB Port, or they can also be uploaded directly to your PC or network with the software, via the configuration port or RS485/Ethernet communications if fitted. To upload from a connected instrument, go to the Device | Upload recorder Data menu in the software. Select a folder location and enter a file name when prompted, then click Save. Enter the communications parameters for your connection, and click OK to save the data in Comma Separated (.csv) format.

### 22.6.1.2 Analysing Data


The data can be opened and analysed with the PC software, or with any spreadsheet. It can also be imported into other software that can interpret a .csv file.

To analyse a recording file in the PC software, go to the File | Open Trend menu. Locate and open the .csv file. The recording opens with the analog traces (process, power or setpoint values) in the main window at the top, and digital traces (alarm or events statuses) below.



**Note:** Analysis with the PC software is limited to 8 analog channels, so only the first 8 will be displayed. The number of recorded alarms & events is not limited.

The settings button allows trend data channels to be made visible/invisible, or change their color and scaling. Click & drag your mouse over an area of interest to zoom in (use the un-zoom button to cancel) or move the cursor line to that area to see the instantaneous analog values and the alarm & event statuses.



### 22.6.1.3 Project Documentation

The Project information (file name, instrument model code and version, modules / options fitted) and other user entered information such as the project name and version, operator details, creation and modification dates and a text description of the project can be entered into the file.

The 'Projectinfo - Device1' dialog box contains the following information:

- Project name: New Product Treatment Test
- Operator: John Smith - Project Leader
- Version number: 3.0
- Creation date: 6-AUG-2013 10:14:28
- Change date: 6-AUG-2013 13:32:40
- Description: Instrument configuration for test of new product following hardware re-design - refer to ECD005695


The printed document shows the following sections:

- Device1**
  - Input Configuration - Input 1 - Setup
  - Input Configuration - Input 1 - Calibration
  - Input Configuration - Input 2 - Setup
  - Input Configuration - Input 2 - Calibration
  - Input Configuration - Input 3 - Setup
  - Input Configuration - Input 3 - Calibration
  - Input Configuration - Input 4 - Setup
  - Input Configuration - Input 4 - Calibration
  - Input Configuration - Input 5 - Setup
  - Input Configuration - Input 5 - Calibration
  - Input Configuration - Input 6 - Setup
  - Input Configuration - Input 6 - Calibration
  - Input Configuration - Input 7 - Setup
  - Input Configuration - Input 7 - Calibration
  - Input Configuration - Input 8 - Setup
  - Input Configuration - Input 8 - Calibration
  - Input Configuration - Input 9 - Setup
  - Input Configuration - Input 9 - Calibration
  - Input Configuration - Input 10 - Setup
  - Input Configuration - Input 10 - Calibration
  - Input Configuration - Input 11 - Setup
  - Input Configuration - Input 11 - Calibration
  - Input Configuration - Input 12 - Setup
  - Input Configuration - Input 12 - Calibration
  - Input Configuration - Input 13 - Setup
  - Input Configuration - Input 13 - Calibration
  - Input Configuration - Input 14 - Setup
  - Input Configuration - Input 14 - Calibration
  - Input Configuration - Input 15 - Setup
  - Input Configuration - Input 15 - Calibration
  - Input Configuration - Input 16 - Setup
  - Input Configuration - Input 16 - Calibration
  - Input Configuration - Input 17 - Setup
  - Input Configuration - Input 17 - Calibration
  - Input Configuration - Input 18 - Setup
  - Input Configuration - Input 18 - Calibration
  - Input Configuration - Input 19 - Setup
  - Input Configuration - Input 19 - Calibration
  - Input Configuration - Input 20 - Setup
  - Input Configuration - Input 20 - Calibration
  - Input Configuration - Input 21 - Setup
  - Input Configuration - Input 21 - Calibration
  - Input Configuration - Input 22 - Setup
  - Input Configuration - Input 22 - Calibration
  - Input Configuration - Input 23 - Setup
  - Input Configuration - Input 23 - Calibration
  - Input Configuration - Input 24 - Setup
  - Input Configuration - Input 24 - Calibration
  - Input Configuration - Input 25 - Setup
  - Input Configuration - Input 25 - Calibration
  - Input Configuration - Input 26 - Setup
  - Input Configuration - Input 26 - Calibration
  - Input Configuration - Input 27 - Setup
  - Input Configuration - Input 27 - Calibration
  - Input Configuration - Input 28 - Setup
  - Input Configuration - Input 28 - Calibration
  - Input Configuration - Input 29 - Setup
  - Input Configuration - Input 29 - Calibration
  - Input Configuration - Input 30 - Setup
  - Input Configuration - Input 30 - Calibration
  - Input Configuration - Input 31 - Setup
  - Input Configuration - Input 31 - Calibration
  - Input Configuration - Input 32 - Setup
  - Input Configuration - Input 32 - Calibration
  - Input Configuration - Input 33 - Setup
  - Input Configuration - Input 33 - Calibration
  - Input Configuration - Input 34 - Setup
  - Input Configuration - Input 34 - Calibration
  - Input Configuration - Input 35 - Setup
  - Input Configuration - Input 35 - Calibration
  - Input Configuration - Input 36 - Setup
  - Input Configuration - Input 36 - Calibration
  - Input Configuration - Input 37 - Setup
  - Input Configuration - Input 37 - Calibration
  - Input Configuration - Input 38 - Setup
  - Input Configuration - Input 38 - Calibration
  - Input Configuration - Input 39 - Setup
  - Input Configuration - Input 39 - Calibration
  - Input Configuration - Input 40 - Setup
  - Input Configuration - Input 40 - Calibration
  - Input Configuration - Input 41 - Setup
  - Input Configuration - Input 41 - Calibration
  - Input Configuration - Input 42 - Setup
  - Input Configuration - Input 42 - Calibration
  - Input Configuration - Input 43 - Setup
  - Input Configuration - Input 43 - Calibration
  - Input Configuration - Input 44 - Setup
  - Input Configuration - Input 44 - Calibration
  - Input Configuration - Input 45 - Setup
  - Input Configuration - Input 45 - Calibration
  - Input Configuration - Input 46 - Setup
  - Input Configuration - Input 46 - Calibration
  - Input Configuration - Input 47 - Setup
  - Input Configuration - Input 47 - Calibration
  - Input Configuration - Input 48 - Setup
  - Input Configuration - Input 48 - Calibration
  - Input Configuration - Input 49 - Setup
  - Input Configuration - Input 49 - Calibration
  - Input Configuration - Input 50 - Setup
  - Input Configuration - Input 50 - Calibration
  - Input Configuration - Input 51 - Setup
  - Input Configuration - Input 51 - Calibration
  - Input Configuration - Input 52 - Setup
  - Input Configuration - Input 52 - Calibration
  - Input Configuration - Input 53 - Setup
  - Input Configuration - Input 53 - Calibration
  - Input Configuration - Input 54 - Setup
  - Input Configuration - Input 54 - Calibration
  - Input Configuration - Input 55 - Setup
  - Input Configuration - Input 55 - Calibration
  - Input Configuration - Input 56 - Setup
  - Input Configuration - Input 56 - Calibration
  - Input Configuration - Input 57 - Setup
  - Input Configuration - Input 57 - Calibration
  - Input Configuration - Input 58 - Setup
  - Input Configuration - Input 58 - Calibration
  - Input Configuration - Input 59 - Setup
  - Input Configuration - Input 59 - Calibration
  - Input Configuration - Input 60 - Setup
  - Input Configuration - Input 60 - Calibration
  - Input Configuration - Input 61 - Setup
  - Input Configuration - Input 61 - Calibration
  - Input Configuration - Input 62 - Setup
  - Input Configuration - Input 62 - Calibration
  - Input Configuration - Input 63 - Setup
  - Input Configuration - Input 63 - Calibration
  - Input Configuration - Input 64 - Setup
  - Input Configuration - Input 64 - Calibration
  - Input Configuration - Input 65 - Setup
  - Input Configuration - Input 65 - Calibration
  - Input Configuration - Input 66 - Setup
  - Input Configuration - Input 66 - Calibration
  - Input Configuration - Input 67 - Setup
  - Input Configuration - Input 67 - Calibration
  - Input Configuration - Input 68 - Setup
  - Input Configuration - Input 68 - Calibration
  - Input Configuration - Input 69 - Setup
  - Input Configuration - Input 69 - Calibration
  - Input Configuration - Input 70 - Setup
  - Input Configuration - Input 70 - Calibration
  - Input Configuration - Input 71 - Setup
  - Input Configuration - Input 71 - Calibration
  - Input Configuration - Input 72 - Setup
  - Input Configuration - Input 72 - Calibration
  - Input Configuration - Input 73 - Setup
  - Input Configuration - Input 73 - Calibration
  - Input Configuration - Input 74 - Setup
  - Input Configuration - Input 74 - Calibration
  - Input Configuration - Input 75 - Setup
  - Input Configuration - Input 75 - Calibration
  - Input Configuration - Input 76 - Setup
  - Input Configuration - Input 76 - Calibration
  - Input Configuration - Input 77 - Setup
  - Input Configuration - Input 77 - Calibration
  - Input Configuration - Input 78 - Setup
  - Input Configuration - Input 78 - Calibration
  - Input Configuration - Input 79 - Setup
  - Input Configuration - Input 79 - Calibration
  - Input Configuration - Input 80 - Setup
  - Input Configuration - Input 80 - Calibration
  - Input Configuration - Input 81 - Setup
  - Input Configuration - Input 81 - Calibration
  - Input Configuration - Input 82 - Setup
  - Input Configuration - Input 82 - Calibration
  - Input Configuration - Input 83 - Setup
  - Input Configuration - Input 83 - Calibration
  - Input Configuration - Input 84 - Setup
  - Input Configuration - Input 84 - Calibration
  - Input Configuration - Input 85 - Setup
  - Input Configuration - Input 85 - Calibration
  - Input Configuration - Input 86 - Setup
  - Input Configuration - Input 86 - Calibration
  - Input Configuration - Input 87 - Setup
  - Input Configuration - Input 87 - Calibration
  - Input Configuration - Input 88 - Setup
  - Input Configuration - Input 88 - Calibration
  - Input Configuration - Input 89 - Setup
  - Input Configuration - Input 89 - Calibration
  - Input Configuration - Input 90 - Setup
  - Input Configuration - Input 90 - Calibration
  - Input Configuration - Input 91 - Setup
  - Input Configuration - Input 91 - Calibration
  - Input Configuration - Input 92 - Setup
  - Input Configuration - Input 92 - Calibration
  - Input Configuration - Input 93 - Setup
  - Input Configuration - Input 93 - Calibration
  - Input Configuration - Input 94 - Setup
  - Input Configuration - Input 94 - Calibration
  - Input Configuration - Input 95 - Setup
  - Input Configuration - Input 95 - Calibration
  - Input Configuration - Input 96 - Setup
  - Input Configuration - Input 96 - Calibration
  - Input Configuration - Input 97 - Setup
  - Input Configuration - Input 97 - Calibration
  - Input Configuration - Input 98 - Setup
  - Input Configuration - Input 98 - Calibration
  - Input Configuration - Input 99 - Setup
  - Input Configuration - Input 99 - Calibration
  - Input Configuration - Input 100 - Setup
  - Input Configuration - Input 100 - Calibration

A hard copy of the instrument configuration can be printed from the File | Print menu.

This includes the project information, configuration parameters and their values, the Modbus parameter addresses, supervisor mode screens and the terminal wiring for your hardware/configuration.

Profile information can also be printed. The profile header and segment data is listed along with a graphical representation of the profile.



## 23 Specifications

### 23.1.1.1 Reference Test Conditions

|                     |                              |
|---------------------|------------------------------|
| Ambient Temperature | 20°C ±2°C.                   |
| Relative Humidity   | 60 to 70%.                   |
| Supply Voltage      | 100 to 240V AC 50Hz ±1%.     |
| Source Resistance   | <10Ω for thermocouple input. |
| RTD Lead Resistance | <0.1Ω/lead balanced (Pt100). |

## 23.2 Universal Process Inputs

### 23.2.1 General Input 1 and 2 Specifications

|                    |                                                                       |                              |
|--------------------|-----------------------------------------------------------------------|------------------------------|
| Input Sample Rate  | 100mS (Ten samples per second)                                        |                              |
| Input Filter Time  | 0.0 (OFF), 0.1 to 100.0 seconds in 0.1 second increments.             |                              |
| Input Resolution   | 16 bits. Always four times better than the display resolution.        |                              |
| Supply Voltage     | Negligible effect on readings within the specified supply tolerances. |                              |
| Humidity Influence | Negligible effect on readings if non-condensing.                      |                              |
| Temp. Stability    | Error <0.01% of span per °C change in ambient temperature.            |                              |
| Input Impedance    | V DC                                                                  | 47KΩ.                        |
|                    | mA DC                                                                 | 5Ω.                          |
|                    | Other ranges                                                          | Greater than 10MΩ resistive. |
| Isolation          | Reinforced safety isolation from outputs and other inputs.            |                              |
| User Calibration   | Single or two point. +ve values are added -ve subtracted from PV.     |                              |
| PV Display         | Displays process variable up to 5% over and 5% under span.            |                              |

### 23.2.2 Thermocouple Input

#### 23.2.2.1 Thermocouple Types & Ranges

| Sensor Type | Range in °C    | Range in °F    | Sensor Type        | Range in °C   | Range in °F   |
|-------------|----------------|----------------|--------------------|---------------|---------------|
| B           | +100 to 1824°C | +211 to 3315°F | L                  | 0 to 762°C    | 32 to 1402°F  |
| C           | 0 to 2320°C    | 32 to 4208°F   | N                  | 0 to 1399°C   | 32 to 2551°F  |
| D           | 0 to 2315°C    | 32 to 4199°F   | PtRh20%<br>PtRh40% | 0 to 1850°C   | 32 to 3362°F  |
| E           | -240 to 1000°C | -400 to 1832°F | R                  | 0 to 1759°C   | 32 to 3198°F  |
| J (default) | -200 to 1200°C | -328 to 2192°F | S                  | 0 to 1762°C   | 32 to 3204°F  |
| K           | -240 to 1373°C | -400 to 2503°F | T                  | -240 to 400°C | -400 to 752°F |



**Note:** Defaults to °F for USA units. Defaults to °C for non-USA units.

The Scaled Input Upper Limit and Scaled Input Lower Limit parameters, can be used to restrict range. An optional decimal place can be displayed.

#### 23.2.2.2 Thermocouple Performance

|                      |                                                                                                                                                                                                                                                                     |
|----------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Calibration          | Complies with BS4937, NBS125 and IEC584.                                                                                                                                                                                                                            |
| Measurement Accuracy | ±0.1% of full selected input range ±1LSD (Least significant display digit).<br><b>NOTE:</b> Reduced performance for B Thermocouple from +100 to 600°C.<br><b>NOTE:</b> PtRh 20% vs PtRh 40% Thermocouple accuracy is 0.25% and has reduced performance below 800°C. |

|                                    |                                                                                                                                                                           |
|------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Linearization Accuracy</b>      | Linearization better than $\pm 0.2^{\circ}\text{C}$ ( $\pm 0.05$ typical) for J, K, L, N and T thermocouples; than better than $\pm 0.5^{\circ}\text{C}$ for other types. |
| <b>Cold Junction</b>               | If enabled, CJC error is better than $\pm 1^{\circ}\text{C}$ under operating conditions.                                                                                  |
| <b>Sensor Resistance Influence</b> | Thermocouple 100 $\Omega$ : <0.1% of span error.<br>Thermocouple 1000 $\Omega$ : <0.5% of span error.                                                                     |
| <b>Sensor Break Protection</b>     | Break detected within two seconds. Process Control outputs go to the pre-set power value. High and Sensor Break Alarms operate.                                           |

### 23.2.3 Resistance Temperature Detector (RTD) Input

#### 23.2.3.1 RTD Types & Ranges

| Sensor Type  | Range in $^{\circ}\text{C}$    | Range in $^{\circ}\text{F}$     |
|--------------|--------------------------------|---------------------------------|
| 3-Wire PT100 | -199 to 800 $^{\circ}\text{C}$ | -328 to 1472 $^{\circ}\text{F}$ |

| Sensor Type | Range in $^{\circ}\text{C}$   | Range in $^{\circ}\text{F}$    |
|-------------|-------------------------------|--------------------------------|
| NI120       | -80 to 240 $^{\circ}\text{C}$ | -112 to 464 $^{\circ}\text{F}$ |



**Note:** The Scaled Input Upper Limit and Scaled Input Lower Limit parameters, can be used to restrict range. An optional decimal place can be displayed.

#### 23.2.3.2 RTD Performance

|                                    |                                                                                                                                                                                      |
|------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Measurement Accuracy</b>        | $\pm 0.1\%$ of full selected input range $\pm 1\text{LSD}$ (Least significant display digit).                                                                                        |
| <b>Linearization Accuracy</b>      | Better than $\pm 0.2^{\circ}\text{C}$ any point ( $\pm 0.05^{\circ}\text{C}$ typical).<br>PT100 Input complies with BS1904 and DIN43760 ( $0.00385\Omega/\Omega/^{\circ}\text{C}$ ). |
| <b>Sensor Resistance Influence</b> | Pt100 50 $\Omega$ /lead balanced.<br>Automatic Lead Compensation: <0.5% of span error.                                                                                               |
| <b>RTD Sensor Current</b>          | 150 $\mu\text{A}$ $\pm 10\%$ .                                                                                                                                                       |
| <b>Sensor Break Protection</b>     | Break detected within two seconds. Process Control outputs go to the pre-set power value. High and Sensor Break Alarms operate.                                                      |

### 23.2.4 DC Linear Input

#### 23.2.4.1 DC Linear Types & Ranges

| Input Type    | Ranges           |            |
|---------------|------------------|------------|
| mA DC         | 0 to 20mA        | 4 to 20mA  |
| mV DC         | 0 to 50mV        | 10 to 50mV |
| Potentiometer | $\geq 100\Omega$ |            |

| Input Type | Ranges   |          |
|------------|----------|----------|
| V DC       | 0 to 5V  | 1 to 5V  |
|            | 0 to 10V | 2 to 10V |

#### 23.2.4.2 DC Linear Performance

|                                           |                                                                                                                                                 |
|-------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Display Scaling</b>                    | Scalable from -2000 to 100000 for any DC Linear input type.                                                                                     |
| <b>Minimum Span</b>                       | 100 display units.                                                                                                                              |
| <b>Decimal Point Display</b>              | Decimal point selectable from 0 to 3 places.<br><b>Note:</b> Rounds to 2 places above 99.999; 1 place above 999.99 and no decimal above 9999.9. |
| <b>DC Input Multi-Point Linearization</b> | Up to 15 scaling values can be defined anywhere between 0.1 and 100% of input.                                                                  |
| <b>Measurement Accuracy</b>               | $\pm 0.1\%$ of span $\pm 1\text{LSD}$ (Least significant display digit).                                                                        |

|                                |                                                                                                                                                                                                      |
|--------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Maximum Overload</b>        | 1A (mA input terminals), 30V (voltage input terminals) at 25°C ambient.                                                                                                                              |
| <b>Sensor Break Protection</b> | <b>Applicable for 4 to 20mA, 1 to 5V and 2 to 10V ranges only.</b><br>Break detected within two seconds. Process Control outputs go to the pre-set power value. Low and Sensor Break Alarms operate. |

### 23.2.5 Input Functions

| Function                | Input 1             | Input 2                   |
|-------------------------|---------------------|---------------------------|
| Process Control         | Loop 1              | Loop 2                    |
| Cascade Control         | Master Loop         | Slave Loop                |
| Ratio Control           | Controlled Variable | Un-controlled Variable    |
| Remote Setpoint (RSP)   | -                   | RSP for loop 1            |
| Valve Position Feedback | -                   | Valve Position for loop 1 |



**Note:** RSP Linear inputs only, scalable between -9999 to 10000, but actual setpoint value is kept within the setpoint limit settings.

## 23.3 Auxiliary Input

### 23.3.1.1 Auxiliary Input A Types & Ranges

| Input Type   | Ranges    |           |
|--------------|-----------|-----------|
| <b>mA DC</b> | 0 to 20mA | 4 to 20mA |
| <b>V DC</b>  | 0 to 5V   | 1 to 5V   |
|              | 2 to 10V  | 0 to 10V  |

### 23.3.1.2 Auxiliary Input Performance

|                               |                                                                                                                                                                                                                                                                    |                                     |
|-------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|
| <b>Input Sampling rate</b>    | 4 samples per second.                                                                                                                                                                                                                                              |                                     |
| <b>Input Resolution</b>       | 16 bit ADC.                                                                                                                                                                                                                                                        |                                     |
| <b>Input Function</b>         | Scalable as a Remote Setpoint (RSP) between $\pm 0.001$ & $\pm 10000$<br>Scaled input value used for setpoint ( <i>but constrained by setpoint limits</i> ).                                                                                                       |                                     |
| <b>Measurement Accuracy</b>   | $\pm 0.25\%$ of input span $\pm 1\text{LSD}$ (Least significant display digit).                                                                                                                                                                                    |                                     |
| <b>Input Resistance</b>       | V DC                                                                                                                                                                                                                                                               | 47K $\Omega$                        |
|                               | mA DC                                                                                                                                                                                                                                                              | 10 $\Omega$                         |
|                               | Other ranges                                                                                                                                                                                                                                                       | Greater than 10M $\Omega$ resistive |
| <b>Input protection</b>       | <b>Voltage input:</b> will withstand up to 5x input voltage overload without damage or degradation of performance in either polarity.<br><b>Current input:</b> will withstand 5x input current overload in reverse direction and up to 1A in the normal direction. |                                     |
| <b>Isolation</b>              | Reinforced safety isolation from outputs and inputs                                                                                                                                                                                                                |                                     |
| <b>Sensor Break Detection</b> | <b>Applicable for 4 to 20mA, 1 to 5V and 2 to 10V ranges only.</b><br>Control goes to the pre-set power value if Auxiliary Input is providing the active setpoint source.                                                                                          |                                     |

## 23.4 Digital Inputs

### 23.4.1.1 Digital Input Functions

| Function                                                                                                                                                                                                                                                                                                                                                                                                                                            | Logic High* | Logic Low*   |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------|--------------|
|  Loop 1 Control Select                                                                                                                                                                                                                                                                                                                                             | Enabled     | Disabled     |
|  Loop 2 Control Select                                                                                                                                                                                                                                                                                                                                             | Enabled     | Disabled     |
|  Loop 1 Auto/Manual Select                                                                                                                                                                                                                                                                                                                                         | Automatic   | Manual       |
|  Loop 2 Auto/Manual Select                                                                                                                                                                                                                                                                                                                                         | Automatic   | Manual       |
|  Loop 1 Setpoint Select                                                                                                                                                                                                                                                                                                                                            | Main SP     | Alternate SP |
|  Loop 2 Setpoint Select                                                                                                                                                                                                                                                                                                                                            | Main SP     | Alternate SP |
|  Loop 1 Pre-Tune Select                                                                                                                                                                                                                                                                                                                                            | Stop        | Run          |
|  Loop 2 Pre-Tune Select                                                                                                                                                                                                                                                                                                                                            | Stop        | Run          |
|  Loop 1 Self-Tune Select                                                                                                                                                                                                                                                                                                                                           | Stop        | Run          |
|  Loop 2 Self-Tune Select                                                                                                                                                                                                                                                                                                                                           | Stop        | Run          |
|  Profile Run/Hold                                                                                                                                                                                                                                                                                                                                                  | Hold        | Run          |
|  Profile Hold Segment Release                                                                                                                                                                                                                                                                                                                                      | No Action   | Release      |
|  Profile Abort                                                                                                                                                                                                                                                                                                                                                     | No Action   | Abort        |
|  Data Recorder Trigger                                                                                                                                                                                                                                                                                                                                             | Not Active  | Active       |
|  Output <i>n</i> Forcing Open/Close                                                                                                                                                                                                                                                                                                                                | Off/Open    | On/Closed    |
|  Clear All Latched Outputs                                                                                                                                                                                                                                                                                                                                         | No Action   | Reset        |
|  Output <i>n</i> Clear Latch                                                                                                                                                                                                                                                                                                                                       | No Action   | Reset        |
|  Key <i>n</i> Mimic (for     ) | No Action   | Key Pressed  |
|  Inputs C1-C7 can be used as Binary or BCD Profile Selection                                                                                                                                                                                                                                                                                                       | Binary 0    | Binary 1     |



**Note:** , \*but the High/Low function can be switched using the Inputs to Invert selection screen.

### 23.4.1.2 Digital Input Performance

|                           |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |
|---------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Number Available          | 0 to 9. One from Module Slot A, 8 from Multi-Digital Input C                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |
| Type                      | Voltage-free or TTL-compatible voltage signals.<br>Held in High state via pull-up resistors.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |
| Logic States              | <b>Logic High</b> = Open contacts ( $>5000\Omega$ ) or 2 to 24VDC signal.<br><b>Logic Low</b> = Closed contacts ( $<50\Omega$ ) or -0.6 to +0.8VDC signal.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |
| *Inverted Logic           | <i>Inputs can be inverted. This swaps the actions listed above (e.g. Profile Aborts on Logic High if selected input is inverted).</i>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |
| Digital Input Sensitivity | Inputs set for: Control disable; Auto/Manual; Setpoint Select; Pre-Tune; Self-Tune; Profile Run/Hold and Profile Hold Segment Release are all <b>Edge Sensitive</b> , where a High-Low or Low-High transition changes the function status. Pre-Tune is always off at power on (except if using the auto pre-tune feature), but others functions retain their power off status at power on.<br>Inputs set for: Profile Abort; Data Recorder Trigger; Output Forcing; Clearing Latched Outputs; Key Mimic and Profile Selection are all <b>Level Sensitive</b> , where a high or low input sets the function status.<br><i>Digital inputs generally work in parallel with equivalent menus, where either can change the function status.</i> |
| Response Time             | Response within $<0.25$ second of signal state change.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
| Isolation                 | Reinforced safety isolation from inputs and outputs.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       |

## 23.5 Output Specifications

### 23.5.1.1 Output Module Types

|                   |                                                                                                                  |
|-------------------|------------------------------------------------------------------------------------------------------------------|
| Plug-in Slot 1    | Single SPDT Relay, Single SSR Driver, Triac or DC linear.                                                        |
| Plug-in Slot 2    | Single SPDT Relay, Dual SPST Relay, Single SSR Driver, Dual SSR Driver, Triac or 24VDC Transmitter Power Supply. |
| Plug-in Slot 3    | Single SPDT Relay, Dual SPST Relay, Single SSR Driver, Dual SSR Driver, Triac or 24VDC Transmitter Power Supply. |
| Base Option 4 & 5 | Slot 4 SPDT Relay ( <i>std.</i> ). Slot 5 SPDT Relay ( <i>optional.</i> )                                        |
| Base Option 6 & 7 | Slots 6 & 7 DC Linear ( <i>optional.</i> )                                                                       |

### 23.5.1.2 Single Relay Output 1-3 Performance

|                |                                                                                      |
|----------------|--------------------------------------------------------------------------------------|
| Positions      | Optional in Plug-in Modules 1, 2 & 3.                                                |
| Contact Type   | Single pole double throw (SPDT).                                                     |
| Contact Rating | 2A resistive at 120/240V AC                                                          |
| Lifetime       | >500,000 operations at full rated AC voltage/current. De-rate if switching DC loads. |
| Isolation      | Reinforced safety isolation from inputs and other outputs.                           |



**CAUTION:** Plastic pegs prevent fitting of older non-reinforced single relay modules – Remove the peg to fit dual relays (all dual relay modules have reinforced isolation).

### 23.5.1.3 Dual Relay Output 2-3 Performance

|                |                                                                                      |
|----------------|--------------------------------------------------------------------------------------|
| Positions      | Optional in Plug-in Modules 2 & 3.                                                   |
| Contact Type   | 2 x Single pole single throw (SPST) relays with <b><u>shared common</u></b> .        |
| Contact Rating | 2A resistive at 120/240V AC.                                                         |
| Lifetime       | >200,000 operations at full rated AC voltage/current. De-rate if switching DC loads. |
| Isolation      | Reinforced safety isolation from inputs and other outputs.                           |

### 23.5.1.4 Base Relay 4-5 Output Performance

|                |                                                                                                      |
|----------------|------------------------------------------------------------------------------------------------------|
| Positions      | Base outputs 4 & 5.                                                                                  |
| Contact Type   | 1 x Single pole single throw (SPST).                                                                 |
| Contact Rating | 2A resistive at 120/240V AC.                                                                         |
| Lifetime       | >200,000 operations and which contacts at full rated voltage/current. De-rate if switching DC loads. |
| Isolation      | Reinforced safety isolation from inputs and other outputs.                                           |

### 23.5.1.5 Single SSR Driver Output 1-3 Output Performance

|                  |                                                                                                      |
|------------------|------------------------------------------------------------------------------------------------------|
| Positions        | Optional in Plug-in Modules 1, 2 & 3.                                                                |
| Drive Capability | 1 x Logic / SSR Driver output at >10VDC into 500Ω minimum.                                           |
| Isolation        | Isolated from all inputs/outputs <u>except</u> other SSR driver outputs and the configuration socket |

### 23.5.1.6 Dual SSR Driver Output 2-3 Performance

|                         |                                                                                                                                |
|-------------------------|--------------------------------------------------------------------------------------------------------------------------------|
| <b>Positions</b>        | Optional in Plug-in Modules 2 & 3.                                                                                             |
| <b>Drive Capability</b> | 2 x Logic / SSR Driver outputs* at >10VDC into 500Ω minimum.<br>*Dual SSR Driver modules have <b>shared positive</b> terminal. |
| <b>Isolation</b>        | Isolated from all inputs/outputs <u>except</u> other SSR driver outputs and the configuration socket                           |

### 23.5.1.7 Triac Output 1-3 Performance

|                                                |                                                                                           |
|------------------------------------------------|-------------------------------------------------------------------------------------------|
| <b>Positions</b>                               | Optional in Plug-in Modules 1, 2 & 3.                                                     |
| <b>Operating Voltage</b>                       | 20 to 280Vrms @47 to 63Hz.                                                                |
| <b>Current Rating</b>                          | 0.01 to 1A (full cycle rms on-state @ 25°C); de-rates linearly above 40°C to 0.5A @ 80°C. |
| <b>Non-repetitive Surge Current</b>            | 25A peak maximum, for <16.6ms.                                                            |
| <b>OFF-State dv/dt</b>                         | 500V/μs Minimum at Rated Voltage.                                                         |
| <b>OFF-State leakage</b>                       | 1mA rms Maximum at Rated Voltage.                                                         |
| <b>ON-State Voltage Drop</b>                   | 1.5V peak Maximum at Rated Current.                                                       |
| <b>Repetitive Peak OFF-state Voltage, Vdrm</b> | 600V minimum.                                                                             |
| <b>Isolation</b>                               | Reinforced safety isolation from inputs and other outputs.                                |

### 23.5.1.8 Single DC Linear Output Types & Ranges

| Output Type | Ranges    |           |
|-------------|-----------|-----------|
| mA DC       | 0 to 20mA | 4 to 20mA |

| Output Type | Ranges   |                 |
|-------------|----------|-----------------|
| V DC        | 0 to 5V  | 0 to 10V        |
|             | 2 to 10V | 0 to 10V TxPSU* |

### 23.5.1.9 DC Linear Output 1, 6-7 Performance

|                                             |                                                                                                                              |
|---------------------------------------------|------------------------------------------------------------------------------------------------------------------------------|
| <b>Positions</b>                            | Optional in Plug-in Module 1, and Base Options 6 & 7.                                                                        |
| <b>Resolution</b>                           | Eight bits in 250mS<br>(10 bits in 1 second typical, >10 bits in >1 second typical).                                         |
| <b>Update Rate</b>                          | Every control algorithm execution (10 times per second).                                                                     |
| <b>Load Impedance</b>                       | 0 to 20mA & 4 to 20mA: 500Ω maximum.<br>0 to 5V, 0 to 10V & 2 to 10V: 500Ω minimum. Short circuit protected.                 |
| <b>Accuracy</b>                             | ±0.25% of range at 250Ω (mA) or 2kΩ (V). Degrades linearly to ±0.5% for increasing burden (to specification limits).         |
| <b>Over/Under Drive</b>                     | For 4 to 20mA and 2 to 10V a 2% over/underdrive is applied (3.68 to 20.32mA and 1.84 to 10.16V) when used as control output  |
| <b>Isolation</b>                            | Reinforced safety isolation from inputs and other outputs.                                                                   |
| <b>0 to 10VDC Transmitter Power Supply*</b> | Can be used to provide an adjustable 0.0 to 10.0V (regulated), up to 20mA output to excite external circuits & transmitters. |

### 23.5.1.10 24V Transmitter Power Supply 2-3 Performance

|                                                                                    |                                                                                                                                 |
|------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------|
| <b>Positions</b>                                                                   | Optional in Plug-in Modules 2 & 3.                                                                                              |
| <b>Power Rating</b>                                                                | 1 x 24V nominal (unregulated) excitation for external circuits & transmitters. Rated at 19 to 28VDC at 20mA. Load 910Ω minimum. |
| <b>Isolation</b>                                                                   | Reinforced safety isolation from inputs and other outputs.                                                                      |
| <i>*see Linear output (above) for adjustable 0 to 10V Transmitter Power Supply</i> |                                                                                                                                 |



**CAUTION:** Only one Transmit PSU is supported by the instrument. Do not fit in both positions simultaneously.

## 23.6 Communications

### 23.6.1.1 Supported Communication Methods

|                         |                                                                                                         |
|-------------------------|---------------------------------------------------------------------------------------------------------|
| Plug-in Slot A          | RS485 or Ethernet                                                                                       |
| PC Configuration Socket | TTL socket fitted as standard beneath the case.<br>Requires the optional PC Configuration Lead for use. |
| USB Port                | Optional front mounted USB socket. Use with memory sticks only.                                         |

### 23.6.1.2 PC Configuration Socket

|            |                                                                      |
|------------|----------------------------------------------------------------------|
| Functions  | PC software for configuration, data extraction and profile creation. |
| Type       | Proprietary TTL level serial communications.                         |
| Connection | RS232 via PC Configurator Cable to RJ11 socket under case            |
| Isolation  | Not isolated from SSR driver outputs. For bench configuration only.  |



**CAUTION:** The configuration lead/socket is not isolated from SSR Driver outputs. It is not intended for use in live applications.

### 23.6.1.3 RS485

|                     |                                                                                                                                                                                                           |
|---------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Functions           | Setpoint broadcast master or general communications slave to any suitable Modbus RTU master device (inc. extraction of recordings, transfer of configuration & profile files to or from the PC software). |
| Type                | RS485 Asynchronous serial communications module.                                                                                                                                                          |
| Connection          | Locates in Option Slot A.<br>Connection via rear terminals 16-18 ( <i>refer to wiring diagram</i> ).                                                                                                      |
| Protocol            | Modbus RTU slave or Modbus RTU setpoint broadcast master.                                                                                                                                                 |
| Slave Address Range | 1 to 255 or setpoint master broadcast mode                                                                                                                                                                |
| Bit rate            | 4800, 9600, 19200, 38400, 57600 or 115200 bps.                                                                                                                                                            |
| Bits per character  | 10 or 11 (1 start and 1 stop bit, 8 data bits plus 1 optional parity bit).                                                                                                                                |
| Parity              | None, even or odd (selectable).                                                                                                                                                                           |
| Isolation           | 240V reinforced safety isolation from all inputs and outputs.                                                                                                                                             |

### 23.6.1.4 Ethernet

|                       |                                                                                                                                    |
|-----------------------|------------------------------------------------------------------------------------------------------------------------------------|
| Functions             | General communications (inc. extraction of data recordings, transfer of configuration & profile files to or from the PC software). |
| Type                  | Ethernet communications module.                                                                                                    |
| Connection            | Locates in plug-in Slot A. Connection via RJ45 socket in case top.                                                                 |
| Protocol              | Modbus TCP <b>Slave</b> only.                                                                                                      |
| Supported Speed       | 10BaseT or 100BaseT (automatically detected)                                                                                       |
| IP Address Allocation | Via DHCP or manual configuration via PC Tool.                                                                                      |
| Isolation             | 240V reinforced safety isolation from all inputs and outputs.                                                                      |

### 23.6.1.5 USB Socket

|                            |                                                                                                                                       |
|----------------------------|---------------------------------------------------------------------------------------------------------------------------------------|
| <b>Functions</b>           | Extraction of data recordings, transfer of configuration & profiles files to or from the PC software or direct to another controller. |
| <b>Targeted Peripheral</b> | USB Memory Stick with FAT32 formatted file system                                                                                     |
| <b>Supply Current</b>      | Up to 250mA.                                                                                                                          |
| <b>Connection</b>          | Locates in slot C. Provides an optional front mounted connector.                                                                      |
| <b>Protocol</b>            | USB 1.1 or 2.0 compatible. Mass Storage Class.                                                                                        |
| <b>Isolation</b>           | Reinforced safety isolation from all inputs and outputs                                                                               |

## 23.7 Control Loop(s)

|                            |                                                                                                                                                                                                                                                                                                                                        |
|----------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Control types</b>       | <b>1 or 2 control loops</b> , each with either standard PID (single or dual control) or Valve Motor Drive (3-point stepping PID control).<br><b>2 internally linked cascade loops</b> , with standard PID (single or dual control) or Valve Motor Drive (3-point stepping PID control).<br><b>1 Ratio loop</b> for combustion control. |
| <b>VMD Feedback</b>        | Second input can provide valve position feedback or flow indication. Feedback not required or used for control algorithm.                                                                                                                                                                                                              |
| <b>Tuning Types</b>        | Pre-Tune, Auto Pre-Tune, Self-Tune and Manual Tuning with up to 5 PID sets stored internally for each control loop.                                                                                                                                                                                                                    |
| <b>Gain Scheduling</b>     | Automatically switches the 5 PID sets at user definable break-points relating to the process variable or setpoint value.                                                                                                                                                                                                               |
| <b>Proportional Bands</b>  | Primary & Secondary (e.g. Heat & Cool) 1 to 9999 display units, or On-Off control.                                                                                                                                                                                                                                                     |
| <b>Automatic Reset</b>     | Integral Time Constant, 1s to 99min 59s and OFF                                                                                                                                                                                                                                                                                        |
| <b>Rate</b>                | Derivative Time Constant, 1s to 99 min 59s and OFF                                                                                                                                                                                                                                                                                     |
| <b>Manual Reset</b>        | Bias added each control algorithm execution.<br>Adjustable 0 to 100% of output power (single primary control) or -100% to +100% of output power (dual primary & secondary control).                                                                                                                                                    |
| <b>Deadband/Overlap</b>    | Overlap (+ve values) or Deadband (-ve values) between primary & secondary proportional bands for Dual Control. Adjustable In display units - limited to 20% of the combined proportional bands width.                                                                                                                                  |
| <b>ON/OFF Differential</b> | ON/OFF switching differential 1 to 300 display units.                                                                                                                                                                                                                                                                                  |
| <b>Auto/Manual Control</b> | Selectable with “bumpless” transfer when switching between Automatic and Manual control.                                                                                                                                                                                                                                               |
| <b>Control Cycle Times</b> | Selectable from 0.5 to 512 seconds in 0.1s steps.                                                                                                                                                                                                                                                                                      |
| <b>Setpoint Maximum</b>    | Limited by Scaled Input Upper Limit and Setpoint Minimum.                                                                                                                                                                                                                                                                              |
| <b>Setpoint Minimum</b>    | Limited by Scaled Input Lower Limit and Setpoint Maximum.                                                                                                                                                                                                                                                                              |
| <b>Setpoint Ramp</b>       | Ramp rate selectable 1 to 9999 LSD's (Least significant display digits) <u>per hour</u> and OFF (infinite).                                                                                                                                                                                                                            |

## 23.8 Alarms

|                                               |                                                                                                                                                                                                                                                                                                                 |
|-----------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Number of Alarms</b>                       | Seven alarms are configurable for any supported type.                                                                                                                                                                                                                                                           |
| <b>Alarm Types</b>                            | <b>Process High; Process Low; PV-SP Deviation; Band; Control Loop; Rate Of Signal Change per minute</b> – all with optional minimum duration and start-up inhibit.<br><b>Input Signal Break; % Recorder Memory Used, Control Power High, Control Power Low.</b>                                                 |
| <b>Duration &amp; Start-up Inhibit</b>        | Process High; Low; Deviation; Band; Loop; Rate Of Change alarms have an optional start-up inhibit function and adjustable minimum duration time from Off to 9999 seconds before activation.<br><b>CAUTION:</b> If the duration is less than this time, the alarm will not activate no matter what the value is. |
| <b>Alarm Hysteresis</b>                       | Adjustable deadband from 1 LSD (Least significant display digit) to full span (in display units) for Process, Band or Deviation Alarms.                                                                                                                                                                         |
| <b>Combination Alarm &amp; Events Outputs</b> | Logically <b>AND</b> or <b>OR</b> any alarm or profile event (inc Profile running or ended) to switch an output. The output can be set to switch on when the condition is <b>true</b> , or when the condition is <b>not true</b> .                                                                              |

## 23.9 Profiler Option

|                                          |                                                                                                                                                                                                          |
|------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Profile Limits</b>                    | Number of profiles = 64 maximum.<br>Total number of segments = 255 maximum (shared by all programs).                                                                                                     |
| <b>Segment Types</b>                     | Ramp Up/Down over time, Ramp Rate Up/Down*, Step, Dwell, Hold, Loop, Join A Profile, End or Repeat Sequence Then End.<br><i>*Ramp Rate is not available when profile controls two loops</i>              |
| <b>Time-base</b>                         | All times are specified in hh:mm:ss (Hours, Minutes & Seconds).                                                                                                                                          |
| <b>Segment Time</b>                      | Maximum segment time 99:59:59 hh:mm:ss. Use loop-back for longer segments (e.g. 24:00:00 x 100 loops = 100 days).                                                                                        |
| <b>Ramp Rate</b>                         | Ramp Up or Down at 0.001 to 9999.9 display units per hour.                                                                                                                                               |
| <b>Hold Segment Release</b>              | Release from menu key-press, At Time Of Day or via a Digital Input.                                                                                                                                      |
| <b>Profile Starting Point</b>            | The first segment setpoint(s) begin from either the setpoint, or current measured input value, of the controlled loop(s)                                                                                 |
| <b>Delayed Start</b>                     | After 0 to 99:59 (hh:mm) time delay, or at specified day(s) & time.                                                                                                                                      |
| <b>Profile End Action</b>                | Selectable from: Keep Last Profile Setpoint, Use Controller Setpoint or Control Outputs Off.                                                                                                             |
| <b>Profile Abort Action</b>              | Selectable from: Keep Last Profile Setpoint, Use Controller Setpoint or Control Outputs Off.                                                                                                             |
| <b>Power/signal Loss Recovery Action</b> | Selectable from: Continue Profile, Restart Profile, Keep Last Profile Setpoint, Use Controller Setpoint or Control Outputs Off.                                                                          |
| <b>Auto-Hold</b>                         | Off or Hold if input >Band above and/or below SP for each segment.                                                                                                                                       |
| <b>Profile Control</b>                   | Run, Manual Hold/Release, Abort or jump to next segment.                                                                                                                                                 |
| <b>Profile Timing Accuracy</b>           | 0.02% Basic Profile Timing Accuracy.<br>±<0.5 second per Loop, End or Join segment.                                                                                                                      |
| <b>Profile Cycling</b>                   | 1 to 9999 or Infinite repeats per profile.                                                                                                                                                               |
| <b>Sequence Repeats</b>                  | 1 to 9999 or Infinite repeats of joined profile sequences.                                                                                                                                               |
| <b>Loop Back Segments</b>                | 1 to 9999 loops back to specified segment.                                                                                                                                                               |
| <b>Segment Events</b>                    | Events turn on for the duration of the segment. If events are set on for End segments, the event states persist until another profile starts, the user exits profiler mode, or the unit is powered down. |

## 23.10 Data Recorder Option

|                    |                                                                                                                                                                                          |
|--------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Recording Memory   | 1Mb non-volatile flash memory ( <i>data retained when power is off</i> ).                                                                                                                |
| Recording Interval | 1; 2; 5; 10; 15; 30 seconds or 1; 2; 5; 10; 15; 30 minutes.                                                                                                                              |
| Recording Capacity | Dependant on sample rate and number of values recorded.<br>Example: 2 values can be recorded for 21 days at 30 second intervals. More values or faster sample rates reduce the duration. |
| RTC Battery Type   | VARTA CR 1616 3V Lithium. Clock runs for >1 year without power.                                                                                                                          |
| RTC accuracy       | Real Time Clock error <1second per day.                                                                                                                                                  |

## 23.11 Display

|                    |                                                                                 |
|--------------------|---------------------------------------------------------------------------------|
| Display Type       | 160 x 80 pixel, monochrome graphic LCD with a dual color (red/green) backlight. |
| Display Area       | 66.54mm (W) x 37.42mm (H).                                                      |
| Display Characters | 0 to 9, a to z, A to Z, plus @ ( ) ß ö - and _                                  |

## 23.12 Operating Conditions

|                                               |                                                                                                                                              |
|-----------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------|
| Location                                      | Intended for indoor use only.                                                                                                                |
| Ambient Temperatures                          | 0°C to 55°C (operating) and -20°C to 80°C (storage).                                                                                         |
| Relative Humidity                             | 20% to 90% non-condensing.                                                                                                                   |
| Altitude                                      | Up to 2000m above sea level.                                                                                                                 |
| Supply Voltage & Power (Mains versions)       | Mains Supply: 100 to 240V ±10% AC 50/60Hz. Consumption 20VA<br>Fuse rating: 1amp type-T / Slow-blow                                          |
| Supply Voltage & Power (Low voltage versions) | AC Supply: 20 to 48V AC 50/60Hz. Consumption 5VA<br>DC Supply: 22 to 65V DC. Consumption 12W.<br>Fuse rating: 350milliamp type-T / Slow-blow |
| Front Panel Sealing                           | To IP66 (IP65 front USB connector). <i>IP20 behind the panel.</i><br>( <i>IP ratings are not tested for or approved by UL</i> )              |

## 23.13 Conformance Norms

|                  |                                                                                                     |
|------------------|-----------------------------------------------------------------------------------------------------|
| EMI              | Complies with EN61326-1:2013. CE.                                                                   |
| Safety Standards | Complies with UL61010-1 edition 3, CE, UL and cUL.<br>Pollution Degree 2, Installation Category II. |

## 23.14 Dimensions

|                      |                                                                                               |
|----------------------|-----------------------------------------------------------------------------------------------|
| Front Bezel Size     | 1/4 DIN (96 x 96mm).                                                                          |
| Mounting             | Plug-in with panel mounting fixing strap.                                                     |
| Panel & Cut-out Size | Panel must be rigid with Max thickness 6.0mm (0.25inch).<br>Cut-out 92mm x 92mm +0.5, -0.0mm. |
| Depth Behind Panel   | 117mm                                                                                         |
| Ventilation          | 20mm gap required above, below and behind.                                                    |
| Weight               | 0.65kg maximum.                                                                               |
| Terminals            | Screw type (combination head).                                                                |

# 24Model Selection Guide

## Instructions

- Select the desired Key Number. The arrow to the right marks the selection available.
- Make one selection each from Table I thru IX, using the column below the proper arrow.
- A dot (●) denotes unrestricted availability. A letter denotes restricted availability.

| Key Number | I     | II    | III   | IV    | V     | VI    | VII   | VIII  | IX    | X     | XI    |
|------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| _____      | _____ | _____ | _____ | _____ | _____ | _____ | _____ | _____ | _____ | _____ | _____ |

## KEY NUMBER Description

|                                              |        |
|----------------------------------------------|--------|
| Controller Programmer                        | DCP251 |
| Controller Programmer with USB Port          | DCP252 |
| Controller Programmer w/Recording            | DCP253 |
| Controller Programmer w/Recording & USB Port | DCP254 |

## Availability

|   |   |   |   |
|---|---|---|---|
| ↓ |   |   |   |
|   | ↓ |   |   |
|   |   | ↓ |   |
|   |   |   | ↓ |

## TABLE I - Power Supply

|                    |   |
|--------------------|---|
| 100 - 240 Vac      | 0 |
| 24 - 48 Vac or Vdc | 2 |

|   |   |   |   |
|---|---|---|---|
| ● | ● | ● | ● |
| ● | ● | ● | ● |

## TABLE II - Control Loops

|                              |   |
|------------------------------|---|
| One Control Loop             | 1 |
| One Control Loop + Aux Input | A |
| Two Control Loops            | 2 |

|   |   |   |   |
|---|---|---|---|
| ● | ● | ● | ● |
| ● | ● | ● | ● |
| ● | ● | ● | ● |

## TABLE III - Base Option 1

|                                 |   |
|---------------------------------|---|
| Relay Output                    | 1 |
| Relay Output + Linear DC Output | M |

|   |   |   |   |
|---|---|---|---|
| ● | ● | ● | ● |
| ● | ● | ● | ● |

## TABLE IV - Base Option 2

|                                 |   |
|---------------------------------|---|
| None                            | 0 |
| Relay Output + Linear DC Output | M |

|   |   |   |   |
|---|---|---|---|
| ● | ● | ● | ● |
| ● | ● | ● | ● |

## TABLE V - Output Slot 1


|                  |   |
|------------------|---|
| None             | 0 |
| Relay            | 1 |
| DC Drive for SSR | 2 |
| Linear DC Output | L |
| Triac Output     | 8 |

|   |   |   |   |
|---|---|---|---|
| ● | ● | ● | ● |
| ● | ● | ● | ● |
| ● | ● | ● | ● |
| ● | ● | ● | ● |
| ● | ● | ● | ● |

## TABLE VI - Output Slot 2

|                        |   |
|------------------------|---|
| None                   | 0 |
| Relay                  | 1 |
| DC Drive for SSR       | 2 |
| Triac Output           | 8 |
| Dual Relay Output      | 9 |
| Dual SSR Driver Output | Y |
| 24Vdc Xmtr Power       | T |

|   |   |   |   |
|---|---|---|---|
| ● | ● | ● | ● |
| ● | ● | ● | ● |
| ● | ● | ● | ● |
| ● | ● | ● | ● |
| ● | ● | ● | ● |
| ● | ● | ● | ● |
| ● | ● | ● | ● |



## Selection

|   |   |   |   |
|---|---|---|---|
| ● | ● | ● | ● |
| ● | ● | ● | ● |
| ● | ● | ● | ● |
| ● | ● | ● | ● |
| ● | ● | ● | ● |

|   |   |   |   |
|---|---|---|---|
| ● | ● | ● | ● |
| ● | ● | ● | ● |

|   |   |   |   |
|---|---|---|---|
| ● | ● | ● | ● |
| ● | ● | ● | ● |
| ● | ● | ● | ● |
| ● | ● | ● | ● |
| ● | ● | ● | ● |

|   |   |   |   |
|---|---|---|---|
| ● | ● | ● | ● |
| ● | ● | ● | ● |
| ● | ● | ● | ● |

## Reference

## Sales and Service

For application assistance, current specifications, pricing, or name of the nearest Authorized Distributor, contact one of the offices below.

### ASIA PACIFIC

Honeywell Process Solutions,  
(TAC) [hfs-tac-support@honeywell.com](mailto:hfs-tac-support@honeywell.com)

#### Australia

Honeywell Limited  
Phone: +(61) 7-3846 1255  
FAX: +(61) 7-3840 6481  
Toll Free 1300-36-39-36  
Toll Free Fax:  
1300-36-04-70

#### China – PRC - Shanghai

Honeywell China Inc.  
Phone: (86-21) 5257-4568  
Fax: (86-21) 6237-2826

#### Singapore

Honeywell Pte Ltd.  
Phone: +(65) 6580 3278  
Fax: +(65) 6445-3033

#### South Korea

Honeywell Korea Co Ltd  
Phone: +(822) 799 6114  
Fax: +(822) 792 9015

### EMEA

Honeywell Process Solutions,  
Phone: + 80012026455 or  
+44 (0)1344 656000

Email: (Sales)

[FP-Sales-Apps@Honeywell.com](mailto:FP-Sales-Apps@Honeywell.com)

or

(TAC)

[hfs-tac-support@honeywell.com](mailto:hfs-tac-support@honeywell.com)

### AMERICAS

Honeywell Process Solutions,  
Phone: (TAC) 1-800-423-9883 or  
215/641-3610  
(Sales) 1-800-343-0228

Email: (Sales)

[FP-Sales-Apps@Honeywell.com](mailto:FP-Sales-Apps@Honeywell.com)

or

(TAC)

[hfs-tac-support@honeywell.com](mailto:hfs-tac-support@honeywell.com)

*Specifications are subject to change without notice.*